



<b>SOUTH COAST AIR QUALITY MANAGEMENT</b>	Pages 2	Page 1
<i>ENGINEERING AND COMPLIANCE DIVISION</i> <i>Refinery &amp; Waste Management Permitting</i>	A/N 401675	Date 10/11/12
<b>TESORO LOGISTICS – WILMINGTON SALES TERMINAL</b> <b>RULE 462 CMS PLAN MODIFICATION</b>	Processed by TGL	Reviewed by

- EVALUATION FOR RULE 463 -  
STORAGE TANK INSPECTION & MAINTENANCE  
PLAN

**COMPANY NAME AND LOCATION ADDRESS**

BP West Coast Products, LLC  
Carson Crude Terminal  
24696 S. Wilmington Avenue  
Carson, CA 90745

Facility ID# 132124

**MAILING ADDRESS:** 1300 Pier "B" Street  
Long Beach, CA 90813

**CONTACT PERSON:** Mr. Stephen D. Comley  
**TELEPHONE NO.:** (562) 499-2241

**A/N 401675:** Rule 463 Inspection & Maintenance Plan

**BACKGROUND**

This application was submitted on 5/21/2002 and has been evaluated for compliance with the requirements of Rule 463 (e)(1)(A) and 463 (e)(3)(A). The plan is recommended for approval. This is a Title V facility which is a petroleum product storage and distribution bulk terminal.

**EVALUATION OF INSPECTION AND MAINTENANCE PLAN**

**A. INVENTORY OF TANKS:**

This plan contains inventory of all tanks subject to Rule 463. The tank information listed on Page 2-2 of the submitted plan satisfies the requirements of Rule 463(e)(1)(A.).

**B. PROPOSED SELF-INSPECTION:**

The company will perform inspections of the subject tanks according to the schedule listed on Pages 2-5 and 2-6 of the submitted plan.



<b>SOUTH COAST AIR QUALITY MANAGEMENT</b>	Pages <b>2</b>	Page <b>2</b>
<b>ENGINEERING AND COMPLIANCE DIVISION</b> <b><i>Refinery &amp; Waste Management Permitting</i></b>	A/N <b>401675</b>	Date <b>10/11/12</b>
<b>TESORO LOGISTICS – WILMINGTON SALES TERMINAL</b> <b>RULE 462 CMS PLAN MODIFICATION</b>	Processed by <b>TGL</b>	Reviewed by

---

**C. CERTIFIED TANK INSPECTORS:**

BP indicated that certified inspectors will be used for the inspection program. See Page 2-8 and email from Steve Comley.

**RECOMMENDATION:**

Propose the Rule 463 Inspection and Maintenance Plan in Section I as a minor permit revision under Regulation XXX to EPA for 45-day review (no TV revision folder will be needed).