



FACILITY PERMIT TO OPERATE

**U S A WASTE OF CAL(EL SOBRANTE LANDFILL)
10910 DAWSON CANYON RD
CORONA, CA 92883**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER


By 
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance



Table of Content	
Facility ID:	113674
Revision #:	6
Date:	January 03, 2014

**FACILITY PERMIT TO OPERATE
U S A WASTE OF CAL(EL SOBRANTE LANDFILL)**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	2	01/03/2014
B	RECLAIM Annual Emission Allocation	1	03/30/2012
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	6	01/03/2014
E	Administrative Conditions	1	03/30/2012
F	RECLAIM Monitoring and Source Testing Requirements	1	03/30/2012
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	1	03/30/2012
H	Permit To Construct and Temporary Permit to Operate	3	03/30/2012
I	Compliance Plans & Schedules	2	01/01/2014
J	Air Toxics	1	03/30/2012
K	Title V Administration	1	03/30/2012
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	1	03/30/2012
B	Rule Emission Limits	1	03/30/2012



**FACILITY PERMIT TO OPERATE
U S A WASTE OF CAL(EL SOBRANTE LANDFILL)**

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: U S A WASTE OF CAL(EL SOBRANTE LANDFILL)

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 10910 DAWSON CANYON RD
CORONA, CA 92883

MAILING ADDRESS: 10910 DAWSON CANYON RD
CORONA, CA 92883

RESPONSIBLE OFFICIAL: MIKE WILLIAMS

TITLE: SENIOR DISTRICT MANAGER

TELEPHONE NUMBER: (951) 277-1740

CONTACT PERSON: CODY COWGILL

TITLE: SITE ENGINEER

TELEPHONE NUMBER: (951) 277-5106

TITLE V PERMIT ISSUED: March 30, 2012

TITLE V PERMIT EXPIRATION DATE: March 29, 2017

TITLE V	RECLAIM
----------------	----------------

YES	NOx:	NO
	SOx:	NO
	CYCLE:	0
	ZONE:	INLAND



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178





**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

**Facility Description and Equipment Specific Conditions
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements. Also included are the rule origin and authority of each emission limit and permit condition.



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

PERMITTED EQUIPMENT LIST

The following is a list of all permits to operate at this facility:

Application No.	Permit No.	Equipment description	Page No.
430422	F86553	ICE (>500 HP) LANDFILL GAS	6
430424	F86554	ICE (>500 HP) LANDFILL GAS	10
430729	F86555	ICE (>500 HP) LANDFILL GAS	14
537512	G29217	FLARE, ENCLOSED LANDFILL GAS	18
537513	G29218	LANDFILL GAS COLLECTION (>50 WELLS)	23
537514	G29219	LANDFILL CONDENSATE/LEACHATE/COLLECTION	28

NOTE: ANY APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]
2. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT. ON OR AFTER JUNE 1, 2004, THE OPERATOR SHALL NOT PURCHASE DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT.
[RULE 431.2]
3. THE OPERATOR SHALL NOT USE LANDFILL GAS CONTAINING SULFUR COMPOUNDS IN EXCESS OF 150 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED DAILY.
[RULE 431.1]
4. THE OWNER/OPERATOR OF A MSW LANDFILL SHALL COMPLY WITH THE FOLLOWING:
 - A. INSTALL AND OPERATE A WIND SPEED AND DIRECTION MONITORING SYSTEM WITH A CONTINUOUS RECORDER. FOR WIND SPEED, USE A 3 CUP ASSEMBLY WITH A RANGE OF 0 TO 50 MILES AN HOUR, WITH A THRESHOLD OF 0.75 MILE PER HOUR OR LESS. FOR WIND DIRECTION, USE A VANE WITH A RANGE OF 0 TO 540 DEGREES AZIMUTH, WITH A THRESHOLD OF PLUS-MINUS 2 DEGREES. AN APPROVED ALTERNATIVE MAY BE USED IN LIEU OF THE ABOVE.
 - B. MONITOR AND COLLECT MONTHLY, OR AS PER THE APPROVED 1150.1 ALTERNATIVE, SAMPLES FOR ANALYSIS OF TOC AND TAC FROM THE SUBSURFACE REFUSE BOUNDARY SAMPLING PROBES.
 - C. OPERATE THE GAS COLLECTION AND CONTROL SYSTEM TO PREVENT THE CONCENTRATION OF TOC MEASURED AS METHANE FROM EXCEEDING 5% BY VOLUME IN THE SUBSURFACE REFUSE BOUNDARY SAMPLING PROBES.
 - D. COLLECT MONTHLY, OR AS PER THE APPROVED 1150.1 ALTERNATIVE, INTEGRATED SAMPLES FOR ANALYSIS OF TOC AND TAC FROM THE LANDFILL SURFACE.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

- E. OPERATE THE GAS COLLECTION AND CONTROL SYSTEM TO PREVENT THE CONCENTRATION OF TOC MEASURED AS METHANE FROM EXCEEDING 25 PPMV AS DETERMINED BY INTEGRATED SAMPLES TAKEN ON NUMBERED 50,000 SQUARE FOOT LANDFILL GRIDS OR AS PER THE APPROVED 1150.1 ALTERNATIVE
 - F. MONITOR QUARTERLY, OR AS PER THE APPROVED 1150.1 ALTERNATIVE, THE LANDFILL SURFACE FOR TOC.
 - G. OPERATE THE GAS COLLECTION AND CONTROL SYSTEM TO PREVENT THE CONCENTRATION OF TOC MEASURED AS METHANE FROM EXCEEDING 500 PPMV ABOVE BACKGROUND AS DETERMINED BY INSTANTANEOUS MONITORING AT ANY LOCATION ON THE LANDFILL, EXCEPT AT THE OUTLET OF ANY CONTROL DEVICE.
 - H. OPERATE THE GAS COLLECTION AND CONTROL SYSTEM SO THAT THERE ARE NO LEAKS THAT EXCEED 500 PPMV TOC MEASURED AS METHANE AT ANY COMPONENT UNDER POSITIVE PRESSURE.
 - I. COLLECT MONTHLY, OR AS PER THE APPROVED 1150.1 ALTERNATIVE, LANDFILL GAS SAMPLES FOR ANALYSIS OF TOC AND TAC FROM THE MAIN GAS COLLECTION HEADER LINE ENTERING THE GAS TREATMENT AND/OR GAS CONTROL SYSTEM.
 - J. COLLECT MONTHLY, OR AS PER THE APPROVED 1150.1 ALTERNATIVE, AMBIENT AIR SAMPLES FOR ANALYSIS OF TOC AND TAC FROM THE LANDFILL PROPERTY BOUNDARY.
 - K. OPERATE THE GAS COLLECTION AND CONTROL SYSTEM AT ALL TIMES FOR LANDFILLS WITH ACTIVE COLLECTION SYSTEMS.
 - L. OPERATE ALL WELLHEADS SO THE GAUGE PRESSURE IS UNDER A CONSTANT VACUUM, EXCEPT DURING WELL HEAD RAISING AND/OR REPAIR AND TEMPORARY SHUTDOWN DUE TO A CATASTROPHIC EVENT.
[RULE 1150.1]
5. THE OWNER/OPERATOR OF A MSW LANDFILL SHALL COMPLY WITH THE FOLLOWING:
- A. OPERATE THE COLLECTION SYSTEM SUCH THAT THE GAS IS COLLECTED FROM EACH AREA, CELL OR GROUP OF CELLS OF THE LANDFILL IN WHICH THE INITIAL SOLID WASTE HAS BEEN IN PLACE FOR A PERIOD OF:
 - 1. 5 YEARS OR MORE IF ACTIVE; OR
 - 2. 2 YEARS OR MORE IF CLOSED OR AT FINAL GRADE.
 - B. OPERATE THE COLLECTION SYSTEM WITH NEGATIVE PRESSURE AT EACH WELL-HEAD EXCEPT UNDER THE FOLLOWING CONDITIONS:
 - 1. DURING A FIRE OR INCREASED WELL TEMPERATURE- THE OWNER/OPERATOR SHALL RECORD THE INSTANCES WHEN POSITIVE PRESSURE OCCURS IN EFFORTS TO PREVENT A FIRE. THIS REPORT SHALL BE SUBMITTED WITH THE ANNUAL REPORTS AS PROVIDED IN 40 CFR 60.757(f)(1).
 - 2. WHENEVER A GEOMEMBRANE OR SYNTHETIC COVER IS IN PLACE- THE OWNER/OPERATOR SHALL DEVELOP ACCEPTABLE PRESSURE LIMITS IN THE DESIGN PLAN.
 - 3. WHEN A WELL IS DECOMMISSIONED-A WELL MAY EXPERIENCE A STATIC



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

POSITIVE PRESSURE AFTER SHUT DOWN TO ACCOMMODATE FOR DECLINING FLOWS.

- C. OPERATE EACH INTERIOR WELLHEAD IN THE COLLECTION SYSTEM WITH A LANDFILL GAS TEMPERATURE LESS THAN 55 DEGREES C AND WITH EITHER A NITROGEN LEVEL LESS THAN 20% OR AN OXYGEN LEVEL LESS THAN 5% AS DETERMINED BY METHODS DESCRIBED IN 40 CFR 60.753(c).
 - D. OPERATE THE COLLECTION SYSTEM SO THAT THE METHANE CONCENTRATION IS LESS THAN 500 PPM ABOVE BACKGROUND AT THE SURFACE OF THE LANDFILL AS DETERMINED IN ACCORDANCE WITH MONITORING PROCEDURES SPECIFIED IN 40 CFR 60.753 AND 40 CFR 60.754.
 - E. OPERATE THE COLLECTION SYSTEM SUCH THAT ALL COLLECTED GASES ARE VENTED TO A CONTROL SYSTEM DESIGNED AND OPERATED IN COMPLIANCE WITH 40 CFR 60.752(b)(2)(iii).
 - F. OPERATE THE COLLECTION AND CONTROL SYSTEM IN COMPLIANCE WITH TEST METHODS AND PROCEDURES OF 40 CFR 60.754.
 - G. OPERATE THE COLLECTION AND CONTROL SYSTEM IN COMPLIANCE WITH COMPLIANCE PROVISIONS OF 40 CFR 60.755.
 - H. OPERATE THE COLLECTION AND CONTROL SYSTEM IN COMPLIANCE WITH MONITORING PROCEDURES OF 40 CFR 60.756.
 - I. OPERATE THE COLLECTION AND CONTROL SYSTEM IN COMPLIANCE WITH REPORTING REQUIREMENTS OF 40 CFR 60.757.
 - J. OPERATE THE COLLECTION AND CONTROL SYSTEM IN COMPLIANCE WITH RECORD KEEPING REQUIREMENTS OF 40 CFR 60.758.
- [GASEOUS EMISSION: 40CFR60 SUBPART WWW]



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

PERMIT TO OPERATE

Permit No. F86553
A/N 430422

Equipment Description:

LANDFILL GAS CONTROL SYSTEM CONSISTING OF:

1. FUEL CONDITIONING SYSTEM (NO. 1), WITH CENTRIFUGAL FILTER, 10 MICRON COALESCING FILTER, 40 HP BLOWER, FIRST STAGE HEAT EXCHANGER, SECOND STAGE HEAT EXCHANGER, TWO WATER KNOCKOUT TOWERS, 0.3 MICRON COALESCING FILTER
2. INTERNAL COMBUSTION ENGINE (NO. 1), DEUTZ CORPORATION, MODEL TBG 620 VI6K, LANDFILL GAS FIRED, 16 CYLINDERS, LEAN BURN, TURBOCHARGED, AFTERCOOLED, 1877 BHP, WITH 1358 KW GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE LANDFILL GAS SUPPLY LINE TO EACH ENGINE TO MEASURE AND RECORD THE QUANTITY OF LANDFILL GAS (IN SCFM) BEING BURNED.
[RULE 1303(b)(2)-OFFSET]
5. A SAMPLING PORT SHALL BE INSTALLED AT THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A LANDFILL GAS SAMPLE.
[RULE 217, RULE 431.1, RULE 1150.1]
6. TWO SAMPLING PORTS SHALL BE INSTALLED AND MAINTAINED IN THE ENGINE EXHAUST 8-10 DUCT DIAMETERS DOWNSTREAM AND TWO DUCT DIAMETERS UPSTREAM OF ANY FLOW DISTURBANCE, AT 90 DEGREES APART, AND SHALL CONSIST OF TWO 2-1/2 INCH WELDED NIPPLES WITH CAPS. AN EQUIVALENT METHOD FOR EMISSIONS SAMPLING MAY BE USED UPON APPROVAL OF THE SCAQMD. ADEQUATE AND SAFE ACCESS TO THE TEST PORTS SHALL BE PROVIDED.
[RULE 217]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

7. THE TOTAL HEATING VALUE OF LANDFILL GAS BURNED IN THIS ENGINE SHALL NOT EXCEED 17.4 MILLION BTU'S PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST WEEKLY BTU CONTENT READING.
[RULE 1303(b)(2)-OFFSET]
8. WEEKLY READINGS OF THE BTU CONTENT OF THE LANDFILL GAS AT THE INLET TO THE ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 1303(b)(2)-OFFSET]
9. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY.
[RULE 1303(b)(2)-OFFSET]
10. OPERATION OF THIS EQUIPMENT SHALL NOT RESULT IN THE RELEASE OF RAW LANDFILL GAS INTO THE ATMOSPHERE. ANY BREAKDOWN OR MALFUNCTION WHICH RESULTS IN EMISSIONS OF RAW LANDFILL GAS SHALL BE REPORTED TO THE SCAQMD MANAGER OF TOXICS AND WASTE MANAGEMENT TEAM WITHIN ONE HOUR OF OCCURRENCE AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.
[RULE 402, RULE 430, RULE 1150.1]
11. THIS ENGINE SHALL NOT BE OPERATED IN SUCH A MANNER AS TO INTERFERE WITH THE ABILITY OF THE LANDFILL OPERATOR/OWNER TO COMPLY WITH SCAQMD RULE 1150.1 OR ANY OTHER DISTRICT, STATE OR FEDERAL RULE LIMITING LANDFILL GAS MIGRATION OR SURFACE EMISSIONS.
[RULE 1150.1]
12. THE APPLICANT SHALL CONDUCT ANNUAL SOURCE TESTS IN ACCORDANCE WITH SCAQMD APPROVED TEST PROCEDURES AND FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER ANNIVERSARY OF INITIAL PERFORMANCE TEST. WRITTEN NOTICE OF SOURCE TESTS SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED TO THE SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO THE START OF TESTS. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, A TEST OF THE INLET FUEL GAS TO THE ENGINE AND THE ENGINE EXHAUST FOR:
 - A. METHANE.
 - B. TOTAL NON-METHANE ORGANICS.
 - C. OXIDES OF NITROGEN (EXHAUST ONLY).
 - D. CARBON MONOXIDE (EXHAUST ONLY).
 - E. TOTAL PARTICULATES (EXHAUST ONLY).
 - F. HYDROGEN SULFIDE (INLET ONLY).
 - G. C 1 THROUGH C3 SULFUR COMPOUNDS (SPECIATED, INLET ONLY).
 - H. CARBON DIOXIDE.
 - I. ALDEHYDES (EXHAUST ONLY).
 - J. RULE 1150.1 TABLE 1 COMPOUNDS.
 - K. OXYGEN.
 - L. NITROGEN.
 - M. MOISTURE CONTENT.
 - N. TEMPERATURE.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

- O. FLOWRATE.
- P. NMOC DESTRUCTION EFFICIENCY.
- Q. BTU CONTENT (INLET ONLY).
[RULE 1110.2, RULE 150.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET, RULE 1401, 40CFR63 SUBPART AAAA]

13. EMISSIONS RESULTING FROM THE ENGINE EXHAUST SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS/HOUR
NOX, AS NO2	2.5
SOX, AS SO2	0.72
CO	9.9
PM10	0.21
NMHC	1.65

[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

14. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 0.6 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]
15. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 2.4 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]
16. REACTIVE ORGANIC GAS EMISSIONS SHALL NOT EXCEED 0.4 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]
17. A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS) SHALL BE INSTALLED AND OPERATED TO MEASURE THE ENGINE EXHAUST STACK CONCENTRATION FOR NOX AND O2, ON A DRY BASIS. IN ADDITION, THE SYSTEM SHALL CONVERT THE ACTUAL NOX CONCENTRATION TO A CORRECTED NOX CONCENTRATION AT 15% O2 AND CONTINUOUSLY RECORD THE STACK NOX CONCENTRATION, STACK O2 CONCENTRATION AND CORRECTED NOX CONCENTRATION AT 15% O2. THIS MONITORING SYSTEM SHALL COMPLY WITH THE REQUIREMENTS OF SCAQMD RULE 218. PRIOR TO INSTALLATION, THIS MONITORING SYSTEM SHALL BE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
[RULE 218, RULE 1110.2]
18. THE OPERATOR SHALL OPERATE AND MAINTAIN THIS EQUIPMENT ACCORDING TO THE FOLLOWING REQUIREMENTS:

THE EXHAUST OXYGEN SHALL BE MAINTAINED IN THE RANGE OF 4.38% TO 9.18% WHENEVER THE ENGINE IS IN OPERATION, EXCEPT DURING PERIODS OF STARTUP AND SHUTDOWN.

CONTINUOUS EXHAUST OXYGEN MONITORING AND RECORDING SYSTEM SHALL BE PURSUANT TO THE OPERATION AND MAINTENANCE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.7. SUCH A SYSTEM SHALL BE INSPECTED, MAINTAINED, AND CALIBRATED ON A QUARTERLY BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS USING AN APPLICABLE SCAQMD OR EPA APPROVED METHOD.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

FOR THE PURPOSE OF THIS CONDITION, A DEVIATION SHALL BE DEFINED AS WHEN AN OXYGEN PERCENTAGE OF LESS THAN 4.38% OR GREATER THAN 9.18% OF THE EXHAUST FROM THE ENGINE, AVERAGED OVER ONE HOUR, OCCURS DURING NORMAL OPERATION EXCEPT DURING STARTUPS OR SHUT DOWNS, NOT TO EXCEED 30 MINUTES. THE OPERATOR SHALL REVIEW THE RECORDS OF OXYGEN PERCENTAGE ON A DAILY BASIS TO DETERMINE IF A DEVIATION OCCURS OR SHALL INSTALL AN ALARM SYSTEM TO ALERT THE OPERATOR WHEN A DEVIATION OCCURS.

FOR EACH SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K, WHENEVER A DEVIATION OCCURS FROM THE OXYGEN RANGE, THE OPERATOR SHALL TAKE IMMEDIATE CORRECTIVE ACTION, AND KEEP RECORDS OF THE DURATION AND CAUSE (INCLUDING UNKNOWN CAUSE, IF APPLICABLE) OF THE DEVIATION AND THE CORRECTIVE ACTION TAKEN.

ALL DEVIATIONS SHALL BE REPORTED TO THE AQMD ON A SEMI-ANNUAL BASIS PURSUANT TO THE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.9 AND CONDITION NOS. 22 AND 23 IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL SUBMIT AN APPLICATION WITH A QUALITY IMPROVEMENT PLAN (QIP) IN ACCORDANCE WITH 40 CFR PART 64.8 TO THE SCAQMD IF AN ACCUMULATION OF DEVIATIONS EXCEEDS 5 PERCENT DURATION OF THIS EQUIPMENTS TOTAL OPERATING TIME FOR ANY SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K OF THIS PERMIT. THE REQUIRED QIP SHALL BE SUBMITTED TO THE SCAQMD WITHIN 90 CALENDAR DAYS AFTER THE DUE DATE FOR THE SEMI-ANNUAL MONITORING REPORT.

THE OPERATOR SHALL KEEP ADEQUATE RECORDS IN A FORMAT THAT IS ACCEPTABLE TO THE SCAQMD TO DEMONSTRATE COMPLIANCE WITH ALL APPLICABLE REQUIREMENTS SPECIFIED IN THIS CONDITION AND 40 CFR PART 64.9 FOR A MINIMUM OF FIVE YEARS.
[RULE 3004(a)(4)-PERIODIC MONITORING, 40 CFR PART 64]

19. THIS EQUIPMENT SHALL NOT BURN NATURAL GAS OR OTHER AUXILIARY FUEL.
[RULE 1303(b)(2)-OFFSET]

Emissions and Requirements:

20. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- NMOC: 20 PPMV OR 98 WEIGHT PERCENT REDUCTION, RULE 1150.1, 40 CFR 60 SUBPART WWW, 40 CFR 63 SUBPART AAAA
CO: 2000 PPMV @15% OXYGEN, 15 MINUTE AVERAGE, RULE 1110.2
NOX: 36 PPMV @15% OXYGEN, 15 MINUTE AVERAGE, @25% EFFICIENCY, RULE 1110.2
ROG: 40 PPMV, AS CARBON @15% OXYGEN, RULE 1110.2
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
HAP: 40 CFR 63 ZZZZ



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

PERMIT TO OPERATE

**Permit No. F86554
A/N 430424**

Equipment Description:

LANDFILL GAS CONTROL SYSTEM CONSISTING OF:

1. FUEL CONDITIONING SYSTEM (NO.2), WITH CENTRIFUGAL FILTER, 10 MICRON COALESCING FILTER, 40 HP BLOWER, FIRST STAGE HEAT EXCHANGER, SECOND STAGE HEAT EXCHANGER, TWO WATER KNOCKOUT TOWERS, 0.3 MICRON COALESCING FILTER.
2. INTERNAL COMBUSTION ENGINE (NO.2), DEUTZ CORPORATION, MODEL TBG 620 VI6K, LANDFILL GAS FIRED, 16 CYLINDERS, LEAN BURN, TURBOCHARGED, AFTERCOOLED, 1877 BHP, WITH 1358 KW GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE LANDFILL GAS SUPPLY LINE TO EACH ENGINE TO MEASURE AND RECORD THE QUANTITY OF LANDFILL GAS (IN SCFM) BEING BURNED.
[RULE 1303(b)(2)-OFFSET]
5. A SAMPLING PORT SHALL BE INSTALLED AT THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A LANDFILL GAS SAMPLE.
[RULE 217, RULE 431.1, RULE 1150.1]
6. TWO SAMPLING PORTS SHALL BE INSTALLED AND MAINTAINED IN THE ENGINE EXHAUST 8-10 DUCT DIAMETERS DOWNSTREAM AND TWO DUCT DIAMETERS UPSTREAM OF ANY FLOW DISTURBANCE, AT 90 DEGREES APART. AND SHALL CONSIST OF TWO 2-1/2 INCH WELDED NIPPLES WITH CAPS. AN EQUIVALENT METHOD FOR EMISSIONS SAMPLING MAY BE USED UPON APPROVAL OF THE SCAQMD. ADEQUATE AND SAFE ACCESS TO THE TEST PORTS SHALL BE PROVIDED.
[RULE 217]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

7. THE TOTAL HEATING VALUE OF LANDFILL GAS BURNED IN THIS ENGINE SHALL NOT EXCEED 17.4 MILLION BTU'S PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST WEEKLY BTU CONTENT READING.
[RULE 1303(b)(2)-OFFSET]
8. WEEKLY READINGS OF THE BTU CONTENT OF THE LANDFILL GAS AT THE INLET TO THE ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 1303(b)(2)-OFFSET]
9. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY.
[RULE 1303(b)(2)-OFFSET]
10. OPERATION OF THIS EQUIPMENT SHALL NOT RESULT IN THE RELEASE OF RAW LANDFILL GAS INTO THE ATMOSPHERE. ANY BREAKDOWN OR MALFUNCTION WHICH RESULTS IN EMISSIONS OF RAW LANDFILL GAS SHALL BE REPORTED TO THE SCAQMD MANAGER OF TOXICS AND WASTE MANAGEMENT TEAM WITHIN ONE HOUR OF OCCURRENCE AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.
[RULE 402, RULE 430, RULE 1150.1]
11. THIS ENGINE SHALL NOT BE OPERATED IN SUCH A MANNER AS TO INTERFERE WITH THE ABILITY OF THE LANDFILL OPERATOR/OWNER TO COMPLY WITH SCAQMD RULE 1150.1 OR ANY OTHER DISTRICT, STATE OR FEDERAL RULE LIMITING LANDFILL GAS MIGRATION OR SURFACE EMISSIONS.
[RULE 1150.1]
12. THE APPLICANT SHALL CONDUCT ANNUAL SOURCE TESTS IN ACCORDANCE WITH SCAQMD APPROVED TEST PROCEDURES AND FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER ANNIVERSARY OF INITIAL PERFORMANCE TEST. WRITTEN NOTICE OF SOURCE TESTS SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED TO THE SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO THE START OF TESTS. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, A TEST OF THE INLET FUEL GAS TO THE ENGINE AND THE ENGINE EXHAUST FOR:
 - A. METHANE.
 - B. TOTAL NON-METHANE ORGANICS.
 - C. OXIDES OF NITROGEN (EXHAUST ONLY).
 - D. CARBON MONOXIDE (EXHAUST ONLY).
 - E. TOTAL PARTICULATES (EXHAUST ONLY).
 - F. HYDROGEN SULFIDE (INLET ONLY).
 - G. C 1 THROUGH C3 SULFUR COMPOUNDS (SPECIATED, INLET ONLY).
 - H. CARBON DIOXIDE.
 - I. ALDEHYDES (EXHAUST ONLY).
 - J. RULE 1150.1 TABLE 1 COMPOUNDS.
 - K. OXYGEN.
 - L. NITROGEN.
 - M. MOISTURE CONTENT.
 - N. TEMPERATURE.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

O. FLOWRATE.
P. NMOC DESTRUCTION EFFICIENCY.
Q. BTU CONTENT (INLET ONLY).
[RULE 1110.2, RULE 150.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET, RULE 1401. 40CFR63 SUBPART AAAA]

13. EMISSIONS RESULTING FROM THE ENGINE EXHAUST SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS/HOUR
NOX, AS NO2	2.5
SOX, AS SO2	0.72
CO	9.9
PM10	0.21
NMHC	1.65

[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

14. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 0.6 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]

15. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 2.4 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]

16. REACTIVE ORGANIC GAS EMISSIONS SHALL NOT EXCEED 0.4 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]

17. A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS) SHALL BE INSTALLED AND OPERATED TO MEASURE THE ENGINE EXHAUST STACK CONCENTRATION FOR NOX AND O2, ON A DRY BASIS. IN ADDITION, THE SYSTEM SHALL CONVERT THE ACTUAL NOX CONCENTRATION TO A CORRECTED NOX CONCENTRATION AT 15% O2 AND CONTINUOUSLY RECORD THE STACK NOX CONCENTRATION, STACK O2 CONCENTRATION AND CORRECTED NOX CONCENTRATION AT 15% O2. THIS MONITORING SYSTEM SHALL COMPLY WITH THE REQUIREMENTS OF SCAQMD RULE 218. PRIOR TO INSTALLATION, THIS MONITORING SYSTEM SHALL BE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
[RULE 218, RULE 1110.2]

18. THE OPERATOR SHALL OPERATE AND MAINTAIN THIS EQUIPMENT ACCORDING TO THE FOLLOWING REQUIREMENTS:

THE EXHAUST OXYGEN SHALL BE MAINTAINED IN THE RANGE OF 4.38% TO 9.18% WHENEVER THE ENGINE IS IN OPERATION, EXCEPT DURING PERIODS OF STARTUP AND SHUTDOWN.

CONTINUOUS EXHAUST OXYGEN MONITORING AND RECORDING SYSTEM SHALL BE PURSUANT TO THE OPERATION AND MAINTENANCE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.7. SUCH A SYSTEM SHALL BE INSPECTED, MAINTAINED, AND CALIBRATED ON A QUARTERLY BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS USING AN APPLICABLE SCAQMD OR EPA APPROVED METHOD.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

FOR THE PURPOSE OF THIS CONDITION, A DEVIATION SHALL BE DEFINED AS WHEN AN OXYGEN PERCENTAGE OF LESS THAN 4.38% OR GREATER THAN 9.18% OF THE EXHAUST FROM THE ENGINE, AVERAGED OVER ONE HOUR, OCCURS DURING NORMAL OPERATION EXCEPT DURING STARTUPS OR SHUT DOWNS, NOT TO EXCEED 30 MINUTES. THE OPERATOR SHALL REVIEW THE RECORDS OF OXYGEN PERCENTAGE ON A DAILY BASIS TO DETERMINE IF A DEVIATION OCCURS OR SHALL INSTALL AN ALARM SYSTEM TO ALERT THE OPERATOR WHEN A DEVIATION OCCURS.

FOR EACH SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K, WHENEVER A DEVIATION OCCURS FROM THE OXYGEN RANGE, THE OPERATOR SHALL TAKE IMMEDIATE CORRECTIVE ACTION, AND KEEP RECORDS OF THE DURATION AND CAUSE (INCLUDING UNKNOWN CAUSE, IF APPLICABLE) OF THE DEVIATION AND THE CORRECTIVE ACTION TAKEN.

ALL DEVIATIONS SHALL BE REPORTED TO THE SCAQMD ON A SEMI-ANNUAL BASIS PURSUANT TO THE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.9 AND CONDITION NOS. 22 AND 23 IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL SUBMIT AN APPLICATION WITH A QUALITY IMPROVEMENT PLAN (QIP) IN ACCORDANCE WITH 40 CFR PART 64.8 TO THE SCAQMD IF AN ACCUMULATION OF DEVIATIONS EXCEEDS 5 PERCENT DURATION OF THIS EQUIPMENTS TOTAL OPERATING TIME FOR ANY SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K OF THIS PERMIT. THE REQUIRED QIP SHALL BE SUBMITTED TO THE SCAQMD WITHIN 90 CALENDAR DAYS AFTER THE DUE DATE FOR THE SEMI-ANNUAL MONITORING REPORT.

THE OPERATOR SHALL KEEP ADEQUATE RECORDS IN A FORMAT THAT IS ACCEPTABLE TO THE SCAQMD TO DEMONSTRATE COMPLIANCE WITH ALL APPLICABLE REQUIREMENTS SPECIFIED IN THIS CONDITION AND 40 CFR PART 64.9 FOR A MINIMUM OF FIVE YEARS.
[RULE 3004(a)(4)-PERIODIC MONITORING, 40 CFR PART 64]

19. THIS EQUIPMENT SHALL NOT BURN NATURAL GAS OR OTHER AUXILIARY FUEL.
[RULE 1303(b)(2)-OFFSET]

Emissions and Requirements:

20. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NMOC: 20 PPMV OR 98 WEIGHT PERCENT REDUCTION, RULE 1150.1, 40 CFR 60 SUBPART WWW, 40 CFR 63 SUBPART AAAA
CO: 2000 PPMV @15% OXYGEN, 15 MINUTE AVERAGE, RULE 1110.2
NOX: 36 PPMV @15% OXYGEN, 15 MINUTE AVERAGE, @ 25% EFFICIENCY, RULE 1110.2
ROG: 40 PPMV, AS CARBON @15% OXYGEN, RULE 1110.2
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
HAP: 40 CFR 63 ZZZZ



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

PERMIT TO OPERATE

**Permit No. F86555
A/N 430726**

Equipment Description:

LANDFILL GAS CONTROL SYSTEM CONSISTING OF:

1. FUEL CONDITIONING SYSTEM (NO.3), WITH CENTRIFUGAL FILTER, 10 MICRON COALESCING FILTER, 40 HP BLOWER, FIRST STAGE HEAT EXCHANGER, SECOND STAGE HEAT EXCHANGER, TWO WATER KNOCKOUT TOWERS, 0.3 MICRON COALESCING FILTER
2. INTERNAL COMBUSTION ENGINE (NO. 3), DEUTZ CORPORATION, MODEL TBG 620 V16K, LANDFILL GAS FIRED, 16 CYLINDERS, LEAN BURN, TURBOCHARGED, AFTERCOOLED, 1877 BHP, WITH 1358 KW GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE LANDFILL GAS SUPPLY LINE TO EACH ENGINE TO MEASURE AND RECORD THE QUANTITY OF LANDFILL GAS (IN SCFM) BEING BURNED.
[RULE 1303(b)(2)-OFFSET]
5. A SAMPLING PORT SHALL BE INSTALLED AT THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A LANDFILL GAS SAMPLE.
[RULE 217, RULE 431.1, RULE 1150.1]
6. TWO SAMPLING PORTS SHALL BE INSTALLED AND MAINTAINED IN THE ENGINE EXHAUST 8-10 DUCT DIAMETERS DOWNSTREAM AND TWO DUCT DIAMETERS UPSTREAM OF ANY FLOW DISTURBANCE, AT 90 DEGREES APART, AND SHALL CONSIST OF TWO 2-1/2 INCH WELDED NIPPLES WITH CAPS. AN EQUIVALENT METHOD FOR EMISSIONS SAMPLING MAY BE USED UPON APPROVAL OF THE SCAQMD. ADEQUATE AND SAFE ACCESS TO THE TEST PORTS SHALL BE PROVIDED.
[RULE 217]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

7. THE TOTAL HEATING VALUE OF LANDFILL GAS BURNED IN THIS ENGINE SHALL NOT EXCEED 17.4 MILLION BTU'S PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST WEEKLY BTU CONTENT READING.
[RULE 1303(b)(2)-OFFSET]
8. WEEKLY READINGS OF THE BTU CONTENT OF THE LANDFILL GAS AT THE INLET TO THE ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 1303(b)(2)-OFFSET]
9. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY.
[RULE 1303(b)(2)-OFFSET]
10. OPERATION OF THIS EQUIPMENT SHALL NOT RESULT IN THE RELEASE OF RAW LANDFILL GAS INTO THE ATMOSPHERE. ANY BREAKDOWN OR MALFUNCTION WHICH RESULTS IN EMISSIONS OF RAW LANDFILL GAS SHALL BE REPORTED TO THE SCAQMD MANAGER OF TOXICS AND WASTE MANAGEMENT TEAM WITHIN ONE HOUR OF OCCURRENCE AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.
[RULE 402, RULE 430, RULE 1150.1]
11. THIS ENGINE SHALL NOT BE OPERATED IN SUCH A MANNER AS TO INTERFERE WITH THE ABILITY OF THE LANDFILL OPERATOR/OWNER TO COMPLY WITH SCAQMD RULE 1150.1 OR ANY OTHER DISTRICT, STATE OR FEDERAL RULE LIMITING LANDFILL GAS MIGRATION OR SURFACE EMISSIONS.
[RULE 1150.1]
12. THE APPLICANT SHALL CONDUCT ANNUAL SOURCE TESTS IN ACCORDANCE WITH SCAQMD APPROVED TEST PROCEDURES AND FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER ANNIVERSARY OF INITIAL PERFORMANCE TEST. WRITTEN NOTICE OF SOURCE TESTS SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED TO THE SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO THE START OF TESTS. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, A TEST OF THE INLET FUEL GAS TO THE ENGINE AND THE ENGINE EXHAUST FOR:
 - A. METHANE.
 - B. TOTAL NON-METHANE ORGANICS.
 - C. OXIDES OF NITROGEN (EXHAUST ONLY).
 - D. CARBON MONOXIDE (EXHAUST ONLY).
 - E. TOTAL PARTICULATES (EXHAUST ONLY).
 - F. HYDROGEN SULFIDE (INLET ONLY).
 - G. C 1 THROUGH C3 SULFUR COMPOUNDS (SPECIATED, INLET ONLY).
 - H. CARBON DIOXIDE.
 - I. ALDEHYDES (EXHAUST ONLY).
 - J. RULE 1150.1 TABLE 1 COMPOUNDS.
 - K. OXYGEN.
 - L. NITROGEN.
 - M. MOISTURE CONTENT.
 - N. TEMPERATURE.



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

- O. FLOWRATE.
- P. NMOC DESTRUCTION EFFICIENCY.
- Q. BTU CONTENT (INLET ONLY).
[RULE 1110.2, RULE 150.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET, RULE 1401, 40CFR63 SUBPART AAAA]

13. EMISSIONS RESULTING FROM THE ENGINE EXHAUST SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS/HOUR
NOX, AS NO2	2.5
SOX, AS SO2	0.72
CO	9.9
PM10	0.21
NMHC	1.65

[RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

14. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 0.6 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]

15. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 2.4 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]

16. REACTIVE ORGANIC GAS EMISSIONS SHALL NOT EXCEED 0.4 GRAMS PER BRAKE HORSEPOWER HOUR.
[RULE 1303(a)(1)-BACT]

17. A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS) SHALL BE INSTALLED AND OPERATED TO MEASURE THE ENGINE EXHAUST STACK CONCENTRATION FOR NOX AND O2, ON A DRY BASIS. IN ADDITION, THE SYSTEM SHALL CONVERT THE ACTUAL NOX CONCENTRATION TO A CORRECTED NOX CONCENTRATION AT 15% O2 AND CONTINUOUSLY RECORD THE STACK NOX CONCENTRATION, STACK O2 CONCENTRATION AND CORRECTED NOX CONCENTRATION AT 15% O2. THIS MONITORING SYSTEM SHALL COMPLY WITH THE REQUIREMENTS OF SCAQMD RULE 218. PRIOR TO INSTALLATION, THIS MONITORING SYSTEM SHALL BE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
[RULE 218, RULE 1110.2]

18. THE OPERATOR SHALL OPERATE AND MAINTAIN THIS EQUIPMENT ACCORDING TO THE FOLLOWING REQUIREMENTS:

THE EXHAUST OXYGEN SHALL BE MAINTAINED IN THE RANGE OF 4.38% TO 9.18% WHENEVER THE ENGINE IS IN OPERATION, EXCEPT DURING PERIODS OF STARTUP AND SHUTDOWN.

CONTINUOUS EXHAUST OXYGEN MONITORING AND RECORDING SYSTEM SHALL BE PURSUANT TO THE OPERATION AND MAINTENANCE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.7. SUCH A SYSTEM SHALL BE INSPECTED, MAINTAINED, AND CALIBRATED ON A QUARTERLY BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS USING AN APPLICABLE SCAQMD OR EPA APPROVED METHOD.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

FOR THE PURPOSE OF THIS CONDITION, A DEVIATION SHALL BE DEFINED AS WHEN AN OXYGEN PERCENTAGE OF LESS THAN 4.38% OR GREATER THAN 9.18% OF THE EXHAUST FROM THE ENGINE, AVERAGED OVER ONE HOUR, OCCURS DURING NORMAL OPERATION EXCEPT DURING STARTUPS OR SHUT DOWNS, NOT TO EXCEED 30 MINUTES. THE OPERATOR SHALL REVIEW THE RECORDS OF OXYGEN PERCENTAGE ON A DAILY BASIS TO DETERMINE IF A DEVIATION OCCURS OR SHALL INSTALL AN ALARM SYSTEM TO ALERT THE OPERATOR WHEN A DEVIATION OCCURS.

FOR EACH SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K, WHENEVER A DEVIATION OCCURS FROM THE OXYGEN RANGE, THE OPERATOR SHALL TAKE IMMEDIATE CORRECTIVE ACTION, AND KEEP RECORDS OF THE DURATION AND CAUSE (INCLUDING UNKNOWN CAUSE, IF APPLICABLE) OF THE DEVIATION AND THE CORRECTIVE ACTION TAKEN.

ALL DEVIATIONS SHALL BE REPORTED TO THE SCAQMD ON A SEMI-ANNUAL BASIS PURSUANT TO THE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.9 AND CONDITION NOS. 22 AND 23 IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL SUBMIT AN APPLICATION WITH A QUALITY IMPROVEMENT PLAN (QIP) IN ACCORDANCE WITH 40 CFR PART 64.8 TO THE SCAQMD IF AN ACCUMULATION OF DEVIATIONS EXCEEDS 5 PERCENT DURATION OF THIS EQUIPMENTS TOTAL OPERATING TIME FOR ANY SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K OF THIS PERMIT. THE REQUIRED QIP SHALL BE SUBMITTED TO THE SCAQMD WITHIN 90 CALENDAR DAYS AFTER THE DUE DATE FOR THE SEMI-ANNUAL MONITORING REPORT.

THE OPERATOR SHALL KEEP ADEQUATE RECORDS IN A FORMAT THAT IS ACCEPTABLE TO THE SCAQMD TO DEMONSTRATE COMPLIANCE WITH ALL APPLICABLE REQUIREMENTS SPECIFIED IN THIS CONDITION AND 40 CFR PART 64.9 FOR A MINIMUM OF FIVE YEARS.
[RULE 3004(a)(4)-PERIODIC MONITORING, 40 CFR PART 64]

19. THIS EQUIPMENT SHALL NOT BURN NATURAL GAS OR OTHER AUXILIARY FUEL.
[RULE 1303(b)(2)-OFFSET]

Emissions and Requirements:

20. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NMOC: 20 PPMV OR 98 WEIGHT PERCENT REDUCTION, RULE 1150.1, 40 CFR 60 SUBPART WWW, 40 CFR 63 SUBPART AAAA
CO: 2000 PPMV @15% OXYGEN, 15 MINUTE AVERAGE, RULE 1110.2
NOX: 36 PPMV @15% OXYGEN, 15 MINUTE AVERAGE, @25% EFFICIENCY, RULE 1110.2
ROG: 40 PPMV, AS CARBON @15% OXYGEN, RULE 1110.2
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
HAP: 40 CFR 63 ZZZZ



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

PERMIT TO OPERATE

**Permit No. G29217
A/N 537512**

Equipment Description:

LANDFILL GAS FLARING SYSTEM CONSISTING OF:

1. KNOCKOUT VESSEL/GAS FILTER, ENDUSTRA, 2'-6" DIA. BY 6'-1" HIGH, 5,500 CFM CAPACITY.
2. SHUTOFF VALVES.
3. BLOWER, HOUSTON SERVICE INDUSTRIES, 200 HP, 5,500 SCFM CAPACITY, COMMON TO THE FLARING SYSTEM AND LANDFILL GAS FIRED INTERNAL COMBUSTION ENGINES.
4. TWO (2) BLOWERS, HOUSTON SERVICE INDUSTRIES, MODEL 14104, EACH 200 HP, 5,500 SCFM VARIABLE FREQUENCY DRIVE.
5. FLARE (NO. 3), JOHN ZINK, MODEL ZULE, 13' DIA. BY 60' HIGH, AUTOMATIC AIR DAMPER, PROPANE PILOT, 100 HP COMBUSTION AIR BLOWER, FOUR SOURCE TEST PORTS.
6. TWO PROPANE TANKS, 8.5 GALLONS EACH.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED AND MAINTAINED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. FOUR (4) SAMPLING PORTS SHALL BE PROVIDED IN THE FLARE STACK AT LEAST FIVE (5) FEET UPSTREAM OF THE FLARE OUTLET. EACH SAMPLING PORT SHALL CONSIST OF A FOUR INCH COUPLING. ALL PORTS SHALL BE PROPERLY CENTERED. AN EQUIVALENT METHOD OF EMISSION SAMPLING MAY BE USED UPON APPROVAL OF THE EXECUTIVE OFFICER, ADEQUATE AND SAFE ACCESS TO ALL TEST PORTS SHALL BE PROVIDED.
[RULE 217]
5. A SAMPLING PORT SHALL BE MAINTAINED AT THE INLET GAS LINE TO THE FLARE(S) TO ALLOW THE COLLECTION OF LANDFILL GAS SAMPLES.
[RULE 217, RULE 431.1, RULE 150.1]



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178

Section D Page: 19
Facility ID: 113674
Revision #: 6
Date: January 3, 2014

FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRRANTE LANDFILL)

6. THE FLARE SHALL BE EQUIPPED WITH A TEMPERATURE INDICATOR AND RECORDER WHICH MEASURES AND RECORDS THE GAS TEMPERATURE IN THE FLARE STACK. THE TEMPERATURE INDICATOR AND RECORDER SHALL OPERATE WHENEVER THE FLARE IS IN OPERATION. THE TEMPERATURE SHALL BE MEASURED AT A LOCATION ABOVE THE FLAME ZONE AT LEAST 0.6 SECONDS DOWNSTREAM OF THE BURNER AND NOT LESS THAN FIVE (5) FEET FROM THE TOP OF THE STACK.
[RULE 1303(a)(1)-BACT]

7. WHENEVER THE FLARE IS IN OPERATION, A TEMPERATURE OF NOT LESS THAN 1400 DEGREES FAHRENHEIT, IS MINUTE AVERAGE, AS MEASURED BY THE TEMPERATURE INDICATOR AND RECORDER, SHALL BE MAINTAINED EXCEPT DURING PERIODS OF STARTUP AND SHUTDOWN. STARTUP IS DEFINED AS THE PERIOD FROM FLARE IGNITION TO THE TIME WHEN 1400 DEGREES FAHRENHEIT IS ACHIEVED, NOT TO EXCEED 30 MINUTES. SHUTDOWN IS THE PERIOD BEGINNING WHEN THE GAS VALVE BEGINS TO CLOSE AND ENDING WHEN THE GAS VALVE COMPLETELY SHUTS OFF, NOT TO EXCEED 30 MINUTES.
[RULE 1303(a)(1)-BACT]

8. THE OPERATOR SHALL OPERATE AND MAINTAIN THIS EQUIPMENT ACCORDING TO THE FOLLOWING REQUIREMENTS:

THE EXHAUST TEMPERATURE, FOR THE FLARE, SHALL BE MAINTAINED AT A MINIMUM 1400 DEGREES FAHRENHEIT WHENEVER THE EQUIPMENT IT SERVES IS IN OPERATION.
CONTINUOUS EXHAUST TEMPERATURE MONITORING AND RECORDING SYSTEM SHALL BE PURSUANT TO THE OPERATION AND MAINTENANCE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.7. SUCH A SYSTEM SHALL HAVE AN ACCURACY OF WITHIN +/-1% OF THE TEMPERATURE BEING MONITORED AND SHALL BE INSPECTED, MAINTAINED, AND CALIBRATED ON AN ANNUAL BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS USING AN APPLICABLE SCAQMD OR EPA APPROVED METHOD.

FOR THE PURPOSE OF THIS CONDITION, A DEVIATION SHALL BE DEFINED AS WHEN A TEMPERATURE OF LESS THAN 1400 DEGREES FAHRENHEIT OCCURS DURING NORMAL OPERATION EXCEPT DURING STARTUPS AND SHUTDOWNS NOT TO EXCEED 30 MINUTES. AVERAGE SHALL BE COMPUTED FROM SUCH DATA POINTS. THE OPERATOR SHALL REVIEW THE RECORDS OF TEMPERATURE ON A DAILY BASIS TO DETERMINE IF A DEVIATION OCCURS OR SHALL INSTALL AN ALARM SYSTEM TO ALERT THE OPERATOR WHEN A DEVIATION OCCURS.

FOR EACH SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K, WHENEVER A DEVIATION OCCURS FROM 1400 DEGREES FAHRENHEIT, THE OPERATOR SHALL TAKE IMMEDIATE CORRECTIVE ACTION, AND KEEP RECORDS OF THE DURATION AND CAUSE (INCLUDING UNKNOWN CAUSE, IF APPLICABLE) OF THE DEVIATION AND THE CORRECTIVE ACTION TAKEN.

ALL DEVIATIONS SHALL BE REPORTED TO THE SCAQMD ON A SEMI-ANNUAL BASIS PURSUANT TO THE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.9 AND CONDITION NOS. 22 AND 23 IN SECTION K OF THIS PERMIT.



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178

Section ID: Page: 20
Facility ID: 113674
Revision #: 6
Date: January 3, 2014

FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRRANTE LANDFILL)

THE OPERATOR SHALL SUBMIT AN APPLICATION WITH A QUALITY IMPROVEMENT PLAN (QIP) IN ACCORDANCE WITH 40 CFR PART 64.8 TO THE SCAQMD IF AN ACCUMULATION OF DEVIATIONS EXCEEDS 5 PERCENT DURATION OF THIS EQUIPMENT'S TOTAL OPERATING TIME FOR ANY SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K OF THIS PERMIT. THE REQUIRED QIP SHALL BE SUBMITTED TO THE SCAQMD WITHIN 90 CALENDAR DAYS AFTER THE DUE DATE FOR THE SEMI-ANNUAL MONITORING REPORT. THE OPERATOR SHALL KEEP ADEQUATE RECORDS IN A FORMAT THAT IS ACCEPTABLE TO THE SCAQMD TO DEMONSTRATE COMPLIANCE WITH ALL APPLICABLE REQUIREMENTS SPECIFIED IN THIS CONDITION AND 40 CFR PART 64.9 FOR A MINIMUM OF FIVE YEARS. [40 CFR 64]

9. THE FLARE SHALL BE EQUIPPED WITH AN AUTOMATIC SHUT DOWN SYSTEM WITH A FAILURE ALARM, WHICH HAS BEEN APPROVED BY SCAQMD, TO AUTOMATICALLY ISOLATE THE FLARE FROM THE LANDFILL GAS SUPPLY LINE, SHUT OFF THE BLOWERS AND IMMEDIATELY NOTIFY A RESPONSIBLE PARTY OF THE SHUT DOWN. [RULE 1303(a)(1)-BACT]

10. THE AUTOMATIC SHUT DOWN SAFETY SYSTEM SHALL BE TESTED AT LEAST ANNUALLY FOR PROPER OPERATION AND THE RESULTS RECORDED. [RULE 1303(a)(1)-BACT]

11. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE LANDFILL GAS SUPPLY LINE TO THE FLARE TO MEASURE AND RECORD THE QUANTITY OF LANDFILL GAS IN STANDARD CUBIC FEET PER MINUTE (SCFM) BEING BURNED IN THE FLARE. [RULE 1303(b)(2)-OFFSET]

12. THE VOLUME OF LANDFILL GAS BURNED IN FLARE NO. 3 SHALL NOT EXCEED 6325 SCFM. [RULE 1303(b)(2)-OFFSET]

13. THE HEAT INPUT THROUGH FLARE NO. 3 SHALL NOT EXCEED 167.15 MILLION BTU(S) PER HOUR. [RULE 1303(b)(2)-OFFSET]

14. WEEKLY READINGS OF THE METHANE CONTENT OF THE GAS AT THE INLET TO THE FLARE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY SCAQMD. ALL RESULTS SHALL BE RECORDED. [RULE 1303(b)(2)-OFFSET]

15. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY. [RULE 1303(b)(2)-OFFSET]

16. THE FLARE SHALL BE EQUIPPED WITH A SUFFICIENT NUMBER OF VIEW PORTS TO ALLOW VISUAL INSPECTION OF THE FLAME HEIGHT WITHIN THE FLARE AT ALL TIMES. THE VIEW PORTS SHALL BE LOCATED AT THE ELEVATION OF THE TEMPERATURE SENSOR LOCATIONS. SAFE AND ADEQUATE ACCESS SHALL BE PROVIDED FOR ALL VIEW PORTS UPON REQUEST BY SCAQMD PERSONNEL. [RULE 217, RULE 1303(a)(1)-BACT]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

17. THE FLARE SHALL BE OPERATED SO THAT THE FLAME IN THE FLARE REMAINS BELOW THE HEIGHT OF THE FLARE'S OPERATING THERMOCOUPLE AT ALL TIMES.
[RULE 1303(a)(1)-BACT]
18. THE MAXIMUM FLARE SKIN TEMPERATURE AT ANY LOCATION SHALL NOT EXCEED 250 DEGREES FAHRENHEIT.
[RULE 217]
19. THE OPERATION OF THIS EQUIPMENT SHALL NOT RESULT IN THE RELEASE OF RAW LANDFILL GAS INTO THE ATMOSPHERE. ANY BREAKDOWNS OR MALFUNCTION WHICH RESULTS IN EMISSIONS OF RAW LANDFILL GAS SHALL BE REPORTED TO THE SCAQMD WITHIN ONE HOUR AFTER OCCURRENCE, AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.
[RULE 402, RULE 430, RULE 1150.1]
20. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT ANNUAL PERFORMANCE TESTS IN ACCORDANCE WITH SCAQMD APPROVED TEST PROCEDURES AND FURNISH THE SCAQMD WITH WRITTEN RESULTS OF SUCH PERFORMANCE TESTS IN ACCORDANCE WITH SCAQMD RULE 1150.1 REQUIREMENTS. WRITTEN NOTICE OF THE PERFORMANCE TESTS SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED TO THE SCAQMD FOR APPROVAL AT LEAST 60 DAYS PRIOR TO THE TESTING.

THE TESTS SHALL BE CONDUCTED AT THE MAXIMUM FLOW RATES ALLOWED BY THIS PERMIT, OR THE MAXIMUM FLOW RATES ACHIEVABLE, AND SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, A TEST OF THE INLET GAS TO THE FLARE AND THE FLARE EXHAUST FOR:

- A. METHANE.
- B. TOTAL NON-METHANE ORGANICS.
- C. OXIDES OF NITROGEN (EXHAUST ONLY).
- D. CARBON MONOXIDE (EXHAUST ONLY).
- E. TOTAL PARTICULATES (EXHAUST ONLY).
- F. HYDROGEN SULFIDE (INLET ONLY).
- G. C1 THROUGH C3 SULFUR COMPOUNDS (SPECIATED, INLET ONLY).
- H. CARBON DIOXIDE.
- I. RULE 1150.1 TABLE 1 COMPOUNDS.
- J. OXYGEN.
- K. NITROGEN.
- L. MOISTURE CONTENT.
- M. TEMPERATURE.
- N. FLOWRATE.
- O. NMOC DESTRUCTION EFFICIENCY.

[RULE 1150.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET, RULE 1401, 40 CFR 60 SUBPART WWW, 40 CFR 63 SUBPART AAAA]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

Emissions and Requirements:

21. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 0.06 LBS/MMBTU, RULE 1303(a)(1)-BACT
CO: 10.03 LBS/HR, RULE 1303(b)(2)-OFFSETS
CO: 7322 LBS/MONTH, RULE 1313
NOX: 0.025 LBS/MMBTU, RULE 1303(a)(1)-BACT
NOX: 4.18 LBS/HR, AS NO2, RULE 1303(b)(2)-OFFSETS
NOX: 3051 LBS/MONTH, RULE 1313
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: 0.1 GR/SCF, RULE 409
PM10: 3.41 LBS/HR, RULE 1303(b)(2)-OFFSETS
PM10: 2489 LBS/MONTH, RULE 1313
NMOC: 20 PPMV OR 98 WEIGHT PERCENT REDUCTION, RULE 1150.1, 40 CFR 60 SUBPART WWW, 40 CFR SUBPART AAAA
TNMOC: 6.57 LBS/HR, AS CH4, RULE 1303(b)(2)-OFFSETS
TNMOC: 4796 LBS/MONTH, RULE 1313
SOX: 6.41 LBS/HR, AS SO2, RULE 1303(b)(2)-OFFSETS
SOX: 4679LBS/MONTH, RULE 1313



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

PERMIT TO CONSTRUCT/OPERATE

**Permit No. G29218
A/N 537513**

Equipment Description:

ALTERATION OF:

LANDFILL GAS COLLECTION SYSTEM CONSISTING OF:

1. PHASE I-II LANDFILL GAS COLLECTION SYSTEM:
 - A. TWENTY-FOUR (24) VERTICAL WELLS, 4" AND 6" DIA. AT VARYING DEPTHS RANGING FROM 20 FEET TO 170 FEET.
2. PHASE III-V LANDFILL GAS COLLECTION SYSTEM:
 - A. SIX (6) HORIZONTAL COLLECTOR LINES, HDPE PIPING, VARYING DIAMETERS RANGING FROM 6" 12" DIA. WITH VARYING LENGTHS FROM 880 FEET TO 1,220 FEET.
 - B. FORTY-SIX (46) VERTICAL WELLS, 4" AND 6" DIA. AT VARYING DEPTHS RANGING FROM 13 FEET TO 200 FEET.
3. PHASE VI-X LANDFILL GAS COLLECTION SYSTEM:
 - A. FOUR (4) HORIZONTAL COLLECTOR LINES, HDPE PIPING, 6" DIA. WITH VARYING LENGTHS FROM 225 TO 1,900 FEET.
 - B. FORTY-THREE (43) VERTICAL WELLS, 4" AND 6" DIA. AT VARYING DEPTHS RANGING FROM 25 FEET TO 200 FEET.
4. GAS TRANSMISSION HEADER AND LATERAL PIPING SYSTEM SERVING THE VERTICAL AND HORIZONTAL WELLS TO DIRECT THE LANDFILL GAS TO THE PROCESSING/CONTROL SYSTEM.

BY ADDITION OF:

1. TWO HUNDRED (200) ADDITIONAL VERTICAL WELLS AS NEEDED.
2. FIFTY (50) ADDITIONAL HORIZONTAL COLLECTORS AS NEEDED.

AND/OR REMOVAL OF:

1. SEVENTY-FIVE (75) VERTICAL WELLS AS NEEDED.
2. TWENTY-FIVE (25) HORIZONTAL COLLECTORS AS NEEDED.



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

Conditions:

1. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED AND MAINTAINED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. WELL DRILLING, DRIVING AND/OR TRENCHING SHALL NOT BE CONDUCTED BETWEEN THE HOURS OF 6 P.M. AND 7 A.M. OR ON SATURDAYS, SUNDAYS OR LEGAL HOLIDAYS, UNLESS OTHERWISE APPROVED BY THE SCAQMD.
[RULE 402, RULE 1150]
5. WELL DRILLING, DRIVING, AND/OR TRENCHING SHALL NOT BE CONDUCTED ON DAYS WHEN THE SCAQMD FORECASTS FIRST, SECOND OR THIRD STAGE EPISODES FOR AREA NO. 22, OR WHEN THE SCAQMD REQUIRES COMPANIES IN AREA NO. 22 TO IMPLEMENT THEIR FIRST, SECOND OR THIRD STAGE EPISODE PLANS. EPISODE FORECASTS FOR THE FOLLOWING DAY CAN BE OBTAINED BY CALLING (800) CUT-SMOG.
[RULE 1150]
6. WELL DRILLING, DRIVING AND/OR TRENCHING SHALL NOT BE CONDUCTED WHEN THE WIND SPEED IS GREATER THAN 15 M.P.H. AVERAGE (OVER 15 MINUTES) OR THE WIND SPEED INSTANTANEOUSLY EXCEEDS 25 M.P.H.
[RULE 402, RULE 403, RULE 1150]
7. DURING WELL DRILLING, A LANDFILL GAS CONTROL BOX SHALL BE USED TO PREVENT THE EMISSIONS OF LANDFILL GAS INTO THE ATMOSPHERE, AND THIS CONTROL BOX SHALL BE VENTED TO AN APPROVED EMISSIONS CONTROL SYSTEM.
[RULE 1150, RULE 1303(a)(1)-BACT]
8. EACH WELL SHALL BE COMPLETED AND CAPPED THE SAME DAY ITS CONSTRUCTION COMMENCES UNLESS THE WELL HOLE IS COMPLETELY SEALED AND THE WELL CASING IS CONNECTED TO THE GAS COLLECTION HEADER TO PREVENT ANY LANDFILL GAS FROM ESCAPING INTO THE ATMOSPHERE.
[RULE 402, RULE 1150.1]
9. THE CONSTRUCTION OF ANY PIPING OR WELL TRENCH WHICH EXPOSES LANDFILL TRASH TO THE ATMOSPHERE SHALL BE STAGED SUCH THAT NO MORE THAN ONE HUNDRED (100) LINEAR FEET OF TRENCH IS EXPOSED AT ANY TIME PRIOR TO BACKFILLING.
[RULE 402, RULE 1150]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

10. WELL HOLES, TRENCHES, AND EXPOSED LANDFILL TRASH SHALL BE COMPLETELY COVERED TO PREVENT ANY EMISSIONS OF LANDFILL GAS TO THE ATMOSPHERE WHENEVER WORK IS NOT ACTIVELY IN PROGRESS. THE COVER SHALL INCLUDE, BUT MAY NOT BE LIMITED TO A MINIMUM OF 6 INCHES OF CLEAN DIRT, APPROVED FOAM, OR HEAVY-DUTY PLASTIC SHEETING. FOAM BY ITSELF SHALL NOT BE USED AS A NIGHT COVER IF IT IS RAINING OR RAIN IS PREDICTED BY THE NATIONAL WEATHER SERVICE PRIOR TO THE NEXT SCHEDULED WORKING DAY.
[RULE 402, RULE 1150]
11. FOR PURPOSES OF THIS PERMIT, CONSTRUCTION SPOILS ARE LANDFILL TRASH, MATERIAL THAT IS MIXED WITH LANDFILL TRASH, MATERIAL THAT HAS BEEN IN CONTACT WITH LANDFILL TRASH, OR ODOROUS MATERIAL THAT IS REMOVED FROM WELL HOLES OR TRENCHES.
[RULE 1150]
12. CONSTRUCTION SPOILS AND ALL WORKING AREAS BEING ACTIVELY USED FOR TRUCK AND CONSTRUCTION EQUIPMENT TRAFFICKING SHALL BE MAINTAINED IN A MOIST CONDITION TO MINIMIZE DUST AND EMISSIONS.
[RULE 401, RULE 403, RULE 1150]
13. ALL CONSTRUCTION SPOILS SHALL BE TRANSPORTED TO THE ACTIVE WORKING FACE OF THE LANDFILL WITHIN ONE HOUR OF GENERATION OR AS DEEMED NECESSARY BY THE DISTRICT PERSONNEL.
[RULE 402, RULE 1150]
14. DURING TRANSPORT OF THE CONSTRUCTION SPOILS, NO MATERIAL SHALL EXTEND ABOVE THE SIDES OR REAR OF THE VEHICLE HAULING THE MATERIAL.
[RULE 1150]
15. THE EXTERIOR OF THE VEHICLE (INCLUDING THE TIRES) HAULING THE CONSTRUCTION SPOILS SHALL BE CLEANED OFF PRIOR TO LEAVING THE WORKING SITE.
[RULE 1150]
16. IF A DISTINCT ODOR LEVEL (LEVEL III OR GREATER) RESULTING FROM THE CONSTRUCTION IS DETECTED AT OR BEYOND THE PROPERTY LINE, ALL WORK SHALL CEASE UNTIL THE ODOR SOURCES ARE DETERMINED AND ELIMINATED. ODOR LEVELS SHALL BE DETERMINED BY SCAQMD PERSONNEL OR ON-SITE SAFETY COORDINATOR IN THE ABSENCE OF SCAQMD PERSONNEL.
[RULE 402, RULE 1150]
17. DURING CONSTRUCTION, IF A CONSIDERABLE NUMBER OF COMPLAINTS ARE RECEIVED, ALL WORK SHALL CEASE AND APPROVED MITIGATION MEASURES SHALL BE IMPLEMENTED IMMEDIATELY. WORK SHALL NOT RESUME UNTIL THE EMISSIONS CAUSING THE COMPLAINTS ARE MITIGATED AND THE APPROVAL TO RESUME WORK IS RECEIVED FROM THE SCAQMD.
[RULE 402, RULE 1150]
18. MITIGATION MEASURES, OTHER THAN THOSE INDICATED IN THESE CONDITIONS, WHICH ARE DEEMED APPROPRIATE BY SCAQMD PERSONNEL AS NECESSARY TO PROTECT THE COMFORT, REPOSE, HEALTH OR SAFETY OF THE PUBLIC SHALL BE IMPLEMENTED UPON REQUEST.
[RULE 402, RULE 1150]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

19. ANY BREAKDOWN OR MALFUNCTION OF THE SYSTEM RESULTING IN THE EMISSION OF RAW LANDFILL GAS SHALL BE REPORTED TO THE SCAQMD WITHIN ONE HOUR AFTER OCCURRENCE AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.
[RULE 430]
20. EACH HORIZONTAL GAS COLLECTION WELL SHALL BE CONNECTED TO AN OPERATING LANDFILL GAS HEADER OR THE ENDS OF THE WELL SHALL BE SEALED WITH BLIND FLANGES OR OTHER TYPES OF SEALS APPROVED BY THE SCAQMD AS SOON AS THE WELL IS INSTALLED.
[RULE 1150.1]
21. EACH VERTICAL AND HORIZONTAL WELL HEAD SHALL BE EQUIPPED WITH A SHUT-OFF VALVE AND A SAMPLING PORT.
[RULE 1150, RULE 1150.1]
22. UNTIL CONNECTED TO AN OPERATING LANDFILL GAS COLLECTION SYSTEM, EACH COMPLETED WELL SHALL BE CAPPED AND ITS GAS CONTROL VALVE CLOSED TO AVOID VENTING LANDFILL GAS TO THE ATMOSPHERE.
[RULE 402, RULE 1150, RULE 1150.1]
23. EACH WELL SHALL BE SECURELY SEALED TO PREVENT ANY EMISSIONS OF LANDFILL GAS FROM AROUND THE WELL CASING.
[RULE 402, RULE 1150, RULE 1150.1]
24. ALL OPENINGS OF THIS SYSTEM SHALL BE PROPERLY COVERED AND SEALED TO PREVENT ANY VAPORS FROM ENTERING INTO THE ATMOSPHERE.
[RULE 402, RULE 1150, RULE 1150.1]
25. ALL GASES COLLECTED BY THIS SYSTEM SHALL BE VENTED TO A COMBUSTION OR PROCESSING FACILITY WHICH IS IN FULL USE, CAN ADEQUATELY PROCESS THE VOLUME OF GAS COLLECTED, AND HAS BEEN ISSUED A VALID PERMIT TO CONSTRUCT OR OPERATE BY THE SCAQMD.
[RULE 1150.1, RULE 1303(a)(1)-BACT]
26. THE OPERATION OF THIS EQUIPMENT SHALL NOT RESULT IN THE RELEASE OF ANY RAW LANDFILL GAS OR CONDENSATE INTO THE ATMOSPHERE.
[RULE 402, RULE 1150.1]
27. THE SCAQMD SHALL BE NOTIFIED IN WRITING AT LEAST ONE (1) WEEK IN ADVANCE WHEN AN ADDITIONAL WELL OR SET OF WELLS AND THEIR ASSOCIATED PIPING WILL BE INSTALLED. THE PROPOSED WELL LOCATIONS AND CONNECTING PIPING SHALL BE IDENTIFIED ON A DRAWING WHICH SHOWS THE ENTIRE GAS COLLECTION SYSTEM AND SHALL BE DESCRIBED IN WRITING. ESTIMATED GAS COLLECTION VOLUME, WELL DEPTHS, PIPE LENGTHS, DIAMETERS AND LAYOUTS SHALL BE SUPPLIED TO THE SCAQMD IN THIS ADVANCE NOTIFICATION.
[RULE 1150.1]
28. THE PERMITTEE SHALL SUBMIT ANNUAL AS-BUILT DRAWINGS IN DUPLICATE TO THE SCAQMD. AS-BUILT DRAWINGS SHALL DEPICT ALL WELLS CONSTRUCTED TO DATE.
[RULE 1150.1]



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

29. THIS PERMIT TO CONSTRUCT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER. AT LEAST 30 DAYS PRIOR TO THE EXPIRATION DATE OF THE PERMIT TO CONSTRUCT, THE OPERATOR SHALL MAKE A WRITTEN REQUEST FOR AND OBTAIN AN EXTENSION OF TIME TO CONSTRUCT THIS EQUIPMENT ON AN ANNUAL BASIS UNTIL SUCH TIME CONSTRUCTION IS COMPLETED.
[RULE 205]

Emissions and Requirements:

30. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- GASEOUS EMISSIONS: RULE 1150.1
GASEOUS EMISSIONS: 40 CFR 60 SUBPART WWW
GASEOUS EMISSIONS: 40 CFR 63 SUBPART AAAA



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178

Section D Page: 28
Facility ID: 113674
Revision #: 6
Date: January 3, 2014

FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRRANTE LANDFILL)

PERMIT TO CONSTRUCT/OPERATE

Permit No. G29219
A/N 537514

Equipment Description:

ALTERATION OF:

LANDFILL GAS CONDENSATE, LEACHATE, GROUNDWATER AND SUBDRAIN WATER COLLECTION,
STORAGE AND TREATMENT SYSTEM CONSISTING OF:

1. CONDENSATE COLLECTION SYSTEM.

A. FOUR (4) CONDENSATE SUMPS.

B. CONDENSATE TANK (CHS-19), UNDERGROUND, EPOXY LINED CARBON STEEL, 300
GALLON CAPACITY, 2'-6" DIA. BY 8' HIGH, LOCATED WITHIN OPEN FIBERGLASS TANK AT
THE FLARE STATION, COLLECTING CONDENSATE FROM PARTICULATE
FILTER/MOISTURE KNOCKOUT AND OTHER SOURCES, VENTED TO GAS HEADER.

C. CONDENSATE COLLECTION TANK (T-101), UNDERGROUND, DOUBLE WALLED,
FIBERGLASS REINFORCED PLASTIC, 1000 GALLON CAPACITY, 4' OUTSIDE DIA. BY 11'
LONG, VENTED TO GAS HEADER.

2. LCRS COLLECTION SYSTEM.

A. FIVE (5) SUMPS.

B. LEACHATE LINES SERVING THE LCRS SYSTEM.

3. GROUNDWATER/SUBDRAIN WATER COLLECTION SYSTEM.

A. GROUNDWATER EXTRACTION WELLS.

B. SUBDRAIN LINES SERVING GROUNDWATER SYSTEM.

4. LIQUIDS STORAGE SYSTEM.

A. TANK (T-104A), LEACHATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12'-0" DIA. BY 17'-2"
HIGH, VENTED TO GAS HEADER.

B. TANK (T-104B), LEACHATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12'-0" DIA. BY
17'-2" HIGH, VENTED TO GAS HEADER.

C. TANK (T-104C), LEACHATE, ABOVEGROUND, 5,000 GALLON CAPACITY, 10'-0" DIA. BY 8'-
10" HIGH, VENTED TO GAS HEADER.



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

D. TANK (T-104C), ABOVEGROUND, CROSS LINKED POLYETHYLENE, 13,000 GALLON CAPACITY, 12'-0" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER, TO BE INSTALLED WHEN NEEDED TO REPLACE T-104C (5000 GALLON).

5. ASSOCIATED PUMPS, DRAIN LINES AND PIPING.

6. UP TO FOUR TEMPORARY TANKS, BAKER TYPE.

BY ADDITION OF:

1. ONE (1) CONDENSATE SUMP. [1. CONDENSATE COLLECTION SYSTEM ITEM A.]

2. FIVE (5) OPTIONAL CONDENSATE SUMPS. [1. CONDENSATE COLLECTION SYSTEM ITEM B.]

3. FIVE (5) OPTIONAL SUMPS. [2. LCRS COLLECTION SYSTEM ITEM B.]

4. SUBDRAIN LIQUIDS COLLECTION TANK (T-101), UNDERGROUND, DOUBLE WALLED, FIBERGLASS REINFORCED PLASTIC, 1000 GALLON CAPACITY, 4' OUTSIDE DIA. BY 11' LONG, VENTED TO GAS HEADER. [3. GROUNDWATER/SUBDRAIN WATER COLLECTION SYSTEM ITEM C.]

6. TANK (T-104A), LEACHATE AND CONDENSATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER. [4. LIQUIDS STORAGE SYSTEM ITEM A.]

7. TANK (T-104B), LEACHATE AND CONDENSATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12'-0" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER. [4. LIQUIDS STORAGE SYSTEM ITEM B.]

8. TANK (T-104C), LEACHATE AND CONDENSATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12'-0" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER. [4. LIQUIDS STORAGE SYSTEM ITEM C.]

9. UP TO FOUR TEMPORARY TANKS.

BY REMOVAL OF:

1. CONDENSATE COLLECTION TANK (T-101), UNDERGROUND, DOUBLE WALLED, FIBERGLASS REINFORCED PLASTIC, 1000 GALLON CAPACITY, 4' OUTSIDE DIA. BY 11' LONG, VENTED TO GAS HEADER.

2. TANK (T-104A), LEACHATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER.

3. TANK (T-104B), LEACHATE, ABOVEGROUND, 13,000 GALLON CAPACITY, 12'-0" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER.

4. TANK (T-104C), LEACHATE, ABOVEGROUND, 5,000 GALLON CAPACITY, 10'-0" DIA. BY 8'-10" HIGH, VENTED TO GAS HEADER.

5. TANK (T-104C), ABOVEGROUND, CROSS LINKED POLYETHYLENE, 13,000 GALLON CAPACITY, 12'-0" DIA. BY 17'-2" HIGH, VENTED TO GAS HEADER, TO BE INSTALLED WHEN NEEDED TO REPLACE T-104C (5000 GALLON).



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

6. UP TO FOUR TEMPORARY TANKS, BAKER TYPE.

Conditions:

1. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. CONSTRUCTION SHALL NOT BE CONDUCTED BETWEEN THE HOURS OF 6 P.M. AND 7 A.M. OR ON SATURDAYS, SUNDAYS OR LEGAL HOLIDAYS, UNLESS OTHERWISE APPROVED BY THE SCAQMD.
[RULE 402, RULE 1150]
5. CONSTRUCTION SHALL NOT BE CONDUCTED ON DAYS WHEN THE SCAQMD FORECASTS FIRST, SECOND OR THIRD STAGE EPISODES FOR AREA NO. 22, OR WHEN THE SCAQMD REQUIRES COMPANIES IN AREA NO. 22 TO IMPLEMENT THEIR FIRST, SECOND OR THIRD STAGE EPISODE PLANS. EPISODE FORECASTS FOR THE FOLLOWING DAY CAN BE OBTAINED BY CALLING (800) CUT-SMOG.
[RULE 1150]
6. CONSTRUCTION SHALL NOT BE CONDUCTED WHEN THE WIND SPEED IS GREATER THAN 15 M.P.H. AVERAGE (OVER 15 MINUTES) OR THE WIND SPEED INSTANTANEOUSLY EXCEEDS 25 M.P.H.
[RULE 402, RULE 403, RULE 1150]
7. THE CONSTRUCTION OF ANY PIPING OR TRENCH WHICH EXPOSES LANDFILL TRASH TO THE ATMOSPHERE SHALL BE STAGED SUCH THAT NO MORE THAN ONE HUNDRED (100) LINEAR FEET OF TRENCH IS EXPOSED AT ANY TIME PRIOR TO BACKFILLING.
[RULE 402, RULE 1150]
8. TRENCHES AND EXPOSED LANDFILL TRASH SHALL BE COMPLETELY COVERED TO PREVENT ANY EMISSIONS OF LANDFILL GAS TO THE ATMOSPHERE WHENEVER WORK IS NOT ACTIVELY IN PROGRESS. THE COVER SHALL INCLUDE, BUT MAY NOT BE LIMITED TO A MINIMUM OF 6 INCHES OF CLEAN DIRT, APPROVED FOAM, OR HEAVY-DUTY PLASTIC SHEETING. FOAM BY ITSELF SHALL NOT BE USED AS A NIGHT COVER IF IT IS RAINING OR RAIN IS PREDICTED BY THE NATIONAL WEATHER SERVICE PRIOR TO THE NEXT SCHEDULED WORKING DAY.
[RULE 402, RULE 1150]



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

9. FOR PURPOSES OF THIS PERMIT, CONSTRUCTION SPOILS ARE LANDFILL TRASH, MATERIAL THAT IS MIXED WITH LANDFILL TRASH, MATERIAL THAT HAS BEEN IN CONTACT WITH LANDFILL TRASH, OR ODOROUS MATERIAL THAT IS REMOVED FROM WELL HOLES OR TRENCHES.
[RULE 1150]
10. CONSTRUCTION SPOILS AND ALL WORKING AREAS BEING ACTIVELY USED FOR TRUCK AND CONSTRUCTION EQUIPMENT TRAFFICKING SHALL BE MAINTAINED IN A MOIST CONDITION TO MINIMIZE DUST AND EMISSIONS.
[RULE 401, RULE 403, RULE 1150]
11. ALL CONSTRUCTION SPOILS SHALL BE TRANSPORTED TO THE ACTIVE WORKING FACE OF THE LANDFILL WITHIN ONE HOUR OF GENERATION OR AS DEEMED NECESSARY BY THE DISTRICT PERSONNEL.
[RULE 402, RULE 1150]
12. DURING TRANSPORT OF THE CONSTRUCTION SPOILS, NO MATERIAL SHALL EXTEND ABOVE THE SIDES OR REAR OF THE VEHICLE HAULING THE MATERIAL.
[RULE 1150]
13. THE EXTERIOR OF THE VEHICLE (INCLUDING THE TIRES) HAULING THE CONSTRUCTION SPOILS SHALL BE CLEANED OFF PRIOR TO LEAVING THE WORKING SITE.
[RULE 1150]
14. IF A DISTINCT ODOR LEVEL (LEVEL III OR GREATER) RESULTING FROM THE CONSTRUCTION IS DETECTED AT OR BEYOND THE PROPERTY LINE, ALL WORK SHALL CEASE UNTIL THE ODOR SOURCES ARE DETERMINED AND ELIMINATED. ODOR LEVELS SHALL BE DETERMINED BY SCAQMD PERSONNEL OR ON-SITE SAFETY COORDINATOR IN THE ABSENCE OF SCAQMD PERSONNEL.
[RULE 402, RULE 1150]
15. DURING CONSTRUCTION, IF A CONSIDERABLE NUMBER OF COMPLAINTS ARE RECEIVED, ALL WORK SHALL CEASE AND APPROVED MITIGATION MEASURES SHALL BE IMPLEMENTED IMMEDIATELY. WORK SHALL NOT RESUME UNTIL THE EMISSIONS CAUSING THE COMPLAINTS ARE MITIGATED AND THE APPROVAL TO RESUME WORK IS RECEIVED FROM THE SCAQMD.
[RULE 402, RULE 1150]
16. MITIGATION MEASURES, OTHER THAN THOSE INDICATED IN THESE CONDITIONS, WHICH ARE DEEMED APPROPRIATE BY SCAQMD PERSONNEL AS NECESSARY TO PROTECT THE COMFORT, REPOSE, HEALTH OR SAFETY OF THE PUBLIC SHALL BE IMPLEMENTED UPON REQUEST.
[RULE 402, RULE 1150]
17. THE SCAQMD SHALL BE NOTIFIED IN WRITING AT LEAST ONE (1) WEEK IN ADVANCE WHEN ADDITIONAL LINES OR PIPING WILL BE INSTALLED. THE PROPOSED LOCATIONS SHALL BE IDENTIFIED ON A DRAWING WHICH SHOWS THE ENTIRE SYSTEM AND SHALL BE DESCRIBED IN WRITING. ESTIMATED PIPE LENGTHS, DIAMETERS AND LAYOUTS SHALL BE SUPPLIED TO THE SCAQMD IN THIS ADVANCE NOTIFICATION.
[RULE 1150.1]



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

18. THE PERMITTEE SHALL SUBMIT ANNUAL AS-BUILT DRAWINGS IN DUPLICATE TO THE SCAQMD. AS-BUILT DRAWINGS SHALL DEPICT ALL EQUIPMENT CONSTRUCTED TO DATE.
[RULE 1150.1]
19. ALL CONDENSATE, LEACHATE, AND CONTAMINATED GROUNDWATER/SUBDRAIN WATER COLLECTED SHALL BE PROPERLY DISPOSED OR TREATED.
[RULE 402]
20. ALL PERMANENT TANKS SHALL BE VENTED TO THE LANDFILL GAS COLLECTION SYSTEM.
[RULE 402, RULE 1303(a)(1)-BACT]
21. ALL CONNECTIONS, VALVES AND OPENINGS SHALL BE PROPERLY SEALED OR CLOSED SO AS TO PREVENT RAW LANDFILL GAS AND/OR ORGANIC VAPORS FROM ENTERING INTO THE ATMOSPHERE.
[RULE 402, RULE 1303(a)(1)-BACT]
22. THIS PERMIT TO CONSTRUCT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER. AT LEAST 30 DAYS PRIOR TO THE EXPIRATION DATE OF THE PERMIT TO CONSTRUCT, THE OPERATOR SHALL MAKE A WRITTEN REQUEST FOR AND OBTAIN AN EXTENSION OF TIME TO CONSTRUCT THIS EQUIPMENT ON AN ANNUAL BASIS UNTIL SUCH TIME CONSTRUCTION IS COMPLETED.
[RULE 205]



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOB RANTE LANDFILL)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Conditions:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.
[RULE 1113]

Emissions and Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

Emissions and Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE USA WASTE OF CAL (EL SOBRANTE LANDFILL)

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, OPEN TOP-VAPOR DEGREASERS, HEATED, < 1.0 FT2.

Conditions:

1. THE OPERATOR SHALL PERFORM A MONTHLY INSPECTION OF THE COVER TO ASSURE COMPLIANCE WITH RULE 1122 (c)(2)(A).
2. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH RULE 1122 (e)(6) REQUIREMENTS BY MEASURING THE TEMPERATURE AT THE CENTER OF THE AIR BLANKET ONCE A MONTH IF THE FREEBOARD REFRIGERATION DEVICE IS USED, OR MEASURING THE TEMPERATURE AT THE CENTER OF THE SUPERHEATED SOLVENT VAPOR ZONE ONCE A MONTH IF SUPERHEATED VAPOR SYSTEM IS USED. IN ADDITION TO THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS FACILITY PERMIT, THE OPERATOR SHALL KEEP RECORDS OF THE CORRECTIVE ACTIONS TAKEN WHEN THE MONITORING DEMONSTRATE NON COMPLIANCE.

Emissions and Requirements:

3. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
VOC: RULE 1122



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178





FACILITY PERMIT TO OPERATE U S A WASTE OF CAL(EL SOBRANTE LANDFILL)

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules specified below. The operator shall comply with all conditions specified in the approval of these plans .

Documents pertaining to the plan applications listed below are available for public review at AQMD Headquarters. Any changes to plan applications will require permit modification in accordance with Title V permit revision procedures.

List of approved plans:

Application	Rule
343069	1150.1
351821	431.1
486028	1110.2
532329	3003

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.



South Coast
AQMD

South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178





**FACILITY PERMIT TO OPERATE
USA WASTE OF CAL (EL SOBRANTE LANDFILL)**

APPLICATION NUMBER 486028

**RULE 1110.2(f)(1)(D) INSPECTION AND MONITORING (I & M) PLAN FOR THE
FACILITY LOCATED AT 10910 DAWSON CANYON ROAD, CORONA, CA 92883.**

Please refer to the application you submitted for the evaluation of your Inspection and Monitoring (I & M) plan under District Rule 1110.2(f)(1)(D), for the facility described above.

The Rule 1110.2 Inspection & Monitoring plan you submitted has been APPROVED.

A copy of your approved plan, together with any addendum, statements or declarations you provided during the evaluation of your plan, is attached. In accordance with Rule 1110.2(f)(1)(D)(ix), any changes in equipment, control equipment, operating conditions or emission limits will require that you submit an application to the District for the revision of your I & M plan.



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178





**WASTE MANAGEMENT
EL SOBRANTE LANDFILL**

10910 Dawson Canyon Road
Corona, CA 92883
(951) 277-1740
(951) 277-1861 Fax

November 8, 2013

Charlie Tupac
South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, CA 91765

RE: El Sobrante Landfill (Facility ID #113674) - Response to Comments Regarding El Sobrante's Inspection and Monitoring Plan

Dear Mr. Tupac,

USA Waste of California, Inc., owner/operator of the El Sobrante Landfill, is submitting a response to your email dated September 25, 2013 regarding El Sobrante's Inspection and Monitoring (I&M) Plan.

This response consists of the following:

- Attachment 1 : Responses to AQMD Comments
- Attachment 2 : Second Quarter 2013 Portable Analyzer Monitoring Results
- Attachment 3 : Third Quarter 2013 Portable Analyzer Monitoring Results
- Attachment 4 : Table of Malfunctions and Codes from the Total Electronic Management (TEM) unit.

If you have any questions regarding these reports, please contact Cody Cowgill at (951) 277-5106.

Sincerely,

Cody Cowgill

Digitally signed by Cody Cowgill
DN: cn=Cody Cowgill, ou=Waste Management,
ou_email=ccowgill@wm.com, c=US
Date: 2013.11.08 17:03:55 -08'00'

Cody Cowgill
Site Engineer

Attachment 1

Attachment 1 – Responses to AQMD Comments

	Questions from AQMD	WM Responses
1	Name of contractor (was Run Energy), list of current contractors/staff with R1110.2 Portable Analyzer (PA) training certification.	<p>Power Management Inc. (PMI), a Division of American Environmental Group, are contracted to operate the El Sobrante Landfill. A list of current PMI staff at El Sobrante with PA training certification include:</p> <ul style="list-style-type: none"> -Don Hart -Tom Beaty -Rob Klock -James Smith -Bob Edwards
2	PA calibration schedule and procedure.	<p>PMI uses the ECOM Advanced Data Acquisition System (DAS) to record all PA calibration results. The ECOM is calibrated in the field according to the following calibration gas levels: Carbon Monoxide (CO) (799 ppm), Nitrous Oxide (NO) (102 ppm), and Nitrogen Dioxide (NO2) (98 ppm). The ECOM is calibrated every 10 days or after it is used on 10 engines, whichever comes first. The ECOM is also calibrated and a linearity test is conducted by the local ECOM representative bi-annually. Calibration test results are maintained onsite.</p>
3	PA readings recordkeeping format and manner of storage of records	<p>PMI uses the ECOM Advanced DAS to record all PA readings. The results are electronically saved to the facility field computer. The records are also saved in hard copy format and placed in the Quarterly CO Monitoring binder located in the control room at the facility.</p>
4	PA monitoring schedule, copy of two most recent recording events, method for alerting contractor/staff that monitoring is due.	<p>The PA monitoring is conducted quarterly to measure CO emissions per AQMD Rule 1110.2. PA monitoring results for Quarter 2 and Quarter 3, 2013 are provided in Attachments 2 and 3, respectively.</p> <p>Waste Management utilizes two contractors, CB&I and PMI to coordinate the scheduling of the required monitoring events. PMI has dedicated personnel who perform the PA testing. CB&I coordinates directly with these personnel as well as plant operators to ensure the testing has occurred within the required timeframe.</p>

Attachment 1 – Responses to AQMD Comments

	Questions from AQMD	WM Responses
5	Daily schedule and procedure for monitoring and verifying set points for various loads	<p>The cylinder set points are established at the normal load and the minimum, midpoint, and maximum loads that actually occur during normal operations as described in the current I&M Plan. The average cylinder temperature set points are evaluated and verified for compliance with applicable emission limits during the annual engine source test and quarterly CO emission checks by measuring emissions at low, mid, and high loads.</p> <p>The average engine cylinder temperature is monitored daily and recorded in a daily log to ensure that the cylinder temperature falls within the acceptable range. The daily log is maintained onsite by the plant operator.</p> <p>Oxygen is continuously monitored by the Total Electronic Management (TEM) unit and is maintained in the range of 4.38% to 9.18%. By ensuring that Oxygen is maintained within this permitted range, daily CO emissions are assumed to be below the CO emission limit. The engine's exhaust oxygen value is good indicator of CO emission compliance.</p>
6	List of malfunctions and associated codes, procedure for alerting staff, procedure for correcting out of range parameters, procedure for follow-up emission check.	<p>A list of malfunctions and associated codes has been included in the Attachment 4. Plant operators are notified if parameters are close to becoming out of permit range by an auto-dialer that sends a page with a malfunction code to each operator's cell phone. Plant operators will make adjustments to the system in an attempt to correct out of range parameters.</p> <p>A follow-up emission check will be performed with the PA if the TEM system indicates that the emissions are out of permit range. The PA emission results will assist in verifying the accuracy of the TEM system.</p>
7	CO concentrations corresponding to permit condition limits for CO (9.9 lbs/hr, 2.4 grams/bhp-hr) used to demonstrate compliance at emission checks.	<p>PMI corrects the CO emission reading from the PA to 15% oxygen using the formula below:</p> $\text{CO (ppm) corrected to 15\% O}_2 = (20.9 - 15) / (20.9 - \text{Engine O}_2 \%) * \text{CO (ppm)}$ <p>PMI varies that the CO emissions are in compliance with the permit limit of 2000 ppmv corrected to 15% oxygen and 250 ppmv corrected to 15% oxygen, as required by Rule 1110.2.</p>

Attachment 2

Second Quarter 2013 Portable Analyzer Monitoring Results for Engine 1, 2, and 3

=====

PRE-POST TEST CALIBRATION INFORMATION

DATE OF TEST 5/3/2013 Quarter: 2
 TIME OF TEST 9:28:54

AREA Corona Ca FACILITY WMRE El Sobrante

AIR PERMIT # 186553 PERMIT EQUIP # 1
 PERMIT DATE 3/30/2012

EQUIPMENT El Sobrante E1 UNIT# 1
 MODEL TBG620V16 SERIAL NUMBER: 2202932

ANALYZER MAKE: ECOM ANALYZER MODEL: J2K(N)
 ANALYZER S/N. 2975

PRE TEST PERFORMED: 5/3/2013 8:26:17
 POST TEST PERFORMED: 5/3/2013 9:48:09

SAMPLE FLOW RATE: 3.5 l/min
 RESPONSE TIME: 2:00 RAMP-UP TIME: 4:00
 RAMP-UP TIME OK: YES

MAX O2 ZERO ERROR: 0.3 % O2
 MAX CO NO NO2 ZERO ERROR: 3.0 % SPAN
 MAX ZERO DRIFT: 5.0 % SPAN
 MAX O2 CAL ERROR: 0.5 % O2
 MAX CO NO NO2 CAL ERROR: 5.0 % SPAN
 MAX SPAN DRIFT: 5.0 % SPAN

PRE TEST CALIBRATION DATA

	MAX ZERO	ZERO OK	RESP	CAL ERROR	CAL OK
NO	0	3.1 YES		101	1.00% YES
NO2	0	2.9 YES		98	0.00% YES
CO	0	24 YES		799	0.00% YES
O2	0	0.3 YES		21	0.1 % O2 YES

POST TEST CALIBRATION DATA

	MAX ZERO	ZERO OK	ZERO DRIFT	ZERO DRIFT OK	RESP	CAL ERROR	CAL OK	SPAN DRIFT	SPAN DRIFT OK	CAL GAS VALUE	CAL GAS EXP DATE
NO	0	3.1 YES	0.00%	YES		101	1.00% YES	0.00%	YES	102	9/8/2012
NO2	0	2.9 YES	0.00%	YES		98	0.00% YES	0.00%	YES	98	9/1/2012
CO	0	24 YES	0.00%	YES		799	0.00% YES	0.00%	YES	799	9/8/2012
O2	0	0.3 YES	0.00%	YES		21	0.1 % O2 YES	0.00%	YES	20.9	

PRE/POST TEST CALIBRATION CORRECTIONS

$$\text{Corrected Value} = \frac{(C_{mea} - C_z) * C_{cal}}{(C_m - C_z)}$$

where

- C_{mea} is the average measured value.
- C_z is the average of the pre and post test calibration zero readings.
- C_m is the average of the pre and post test calibration span readings.
- C_{cal} is the calibration gas concentration

NO Corrected = 10
 NO C_{mea} = 9.902
 NO C_z = 0
 NO C_m = 101
 NO C_{cal} = 102
 NO2 Corrected = 39.279
 NO2 C_{mea} = 39.279
 NO2 C_z = 0
 NO2 C_m = 98
 NO2 C_{cal} = 98
 CO Corrected = 532.3
 CO C_{mea} = 532.3
 CO C_z = 0
 CO C_m = 799
 CO C_{cal} = 799
 O2 Corrected = 7.799
 O2 C_{mea} = 7.836
 O2 C_z = 0
 O2 C_m = 21
 O2 C_{cal} = 20.9

Technician:

Donald Hart

DATE

=====

EMISSION TEST RECORDED DATA

DATE OF TEST: 5/3/2013 Quarter: 2
 TIME OF TEST: 9:28:54

AREA: Corona Ca FACILITY: WMRE El Sobrante

AIR PERMIT #: f86553 PERMIT EQUIP #: 1
 PERMIT DATE: 3/30/2012

EQUIPMENT: El Sobrante E1 UNIT#: 1
 MODEL: TBG620V16 SERIAL NUMBER: 2202932

Operator Comments

 El Sobrante Unit 1 2nd Qtr CO Monitoring

Starting Cell Temperat 878.0F
 Ending Cell Temperatt 878.0F
 Average Cell Tempera 878.0F

This test was conducti Test Run As-Found

The following is uncorrected and unadjusted data as received from the analyzer.
 The NOx and CO(mass) and NOx(mass) values reported here are calculated from this uncorrected and unadjusted data.

Test 1 Data:

Sample TinO2	CO	NO	NO2	NOx	CO2	Tgas	Tamb	COmass	NOxmass	Signal Status	
09:29:27	7.8	535	9	39	48	7.4	879	113.7	240.954	21.618 OK	First Sample of Test D
09:29:42	7.8	535	9	39	48	7.4	879	113.9	240.954	21.618 OK	
09:29:57	7.8	535	9	39	48	7.4	879	114	240.954	21.618 OK	
09:30:12	7.8	534	10	39	49	7.4	879	114.2	240.504	22.069 OK	
09:30:27	7.9	534	10	39	49	7.3	879	114.4	242.354	22.238 OK	
09:30:42	7.8	534	10	39	49	7.4	879	114.4	240.504	22.069 OK	
09:30:57	7.8	534	9	39	48	7.4	878	114	240.504	21.618 OK	
09:31:12	7.8	534	9	39	48	7.4	879	113.9	240.504	21.618 OK	
09:31:27	7.8	533	9	39	48	7.4	878	113.9	240.053	21.618 OK	
09:31:42	7.8	533	10	39	49	7.4	878	114	240.053	22.069 OK	
09:31:57	7.8	533	9	39	48	7.4	878	114.4	240.053	21.618 OK	
09:32:12	7.9	533	9	39	48	7.3	878	114.6	241.9	21.785 OK	
09:32:27	7.9	533	9	39	48	7.3	878	114.8	241.9	21.785 OK	
09:32:42	7.8	534	9	38	47	7.4	878	114.9	240.504	21.168 OK	
09:32:57	7.8	534	9	40	49	7.4	878	115.3	240.504	22.069 OK	
09:33:12	7.8	534	10	40	50	7.4	878	115.5	240.504	22.519 OK	
09:33:27	7.8	534	10	40	50	7.4	878	115.7	240.504	22.519 OK	
09:33:42	7.8	534	10	40	50	7.4	878	115.8	240.504	22.519 OK	
09:33:57	7.8	534	10	40	50	7.4	879	116.2	240.504	22.519 OK	
09:34:12	7.9	534	10	39	49	7.3	879	116.2	242.354	22.238 OK	
09:34:27	7.9	533	10	39	49	7.3	879	116.4	241.9	22.238 OK	
09:34:42	7.9	534	10	39	49	7.3	879	116.6	242.354	22.238 OK	
09:34:57	7.9	534	9	39	48	7.3	879	116.7	242.354	21.785 OK	
09:35:12	7.9	534	9	39	48	7.3	879	116.9	242.354	21.785 OK	
09:35:27	7.9	534	9	39	48	7.3	878	117.1	242.354	21.785 OK	
09:35:42	7.9	535	10	39	49	7.3	878	117.1	242.808	22.238 OK	
09:35:57	7.9	534	10	39	49	7.3	878	117.3	242.354	22.238 OK	
09:36:12	7.9	534	10	39	49	7.3	879	117.5	242.354	22.238 OK	
09:36:27	7.9	534	10	39	49	7.3	879	117.6	242.354	22.238 OK	
09:36:42	7.8	533	10	39	49	7.4	879	117.6	240.053	22.069 OK	
09:36:57	7.8	533	10	39	49	7.4	879	117.6	240.053	22.069 OK	
09:37:12	7.8	533	10	38	48	7.4	879	117.5	240.053	21.618 OK	
09:37:27	7.9	534	10	38	48	7.3	878	117.5	242.354	21.785 OK	
09:37:42	7.8	534	10	38	48	7.4	878	117.5	240.504	21.618 OK	
09:37:57	7.8	533	10	39	49	7.4	878	117.5	240.053	22.069 OK	
09:38:12	7.8	533	11	40	51	7.4	878	117.3	240.053	22.969 OK	
09:38:27	7.8	532	11	40	51	7.4	878	116.9	239.603	22.969 OK	
09:38:42	7.8	532	11	40	51	7.4	878	116.7	239.603	22.969 OK	
09:38:57	7.8	531	11	39	50	7.4	878	116.7	239.153	22.519 OK	

09:39:12	7.8	531	11	39	50	7.4	878	116.6	239.153	22.519	OK
09:39:27	7.9	532	10	39	49	7.3	878	116.2	241.446	22.238	OK
09:39:42	7.9	531	10	39	49	7.3	878	116	240.992	22.238	OK
09:39:57	7.9	532	10	39	49	7.3	878	116	241.446	22.238	OK
09:40:12	7.9	531	10	39	49	7.3	878	115.8	240.992	22.238	OK
09:40:27	7.8	530	10	39	49	7.4	879	115.8	238.702	22.069	OK
09:40:42	7.8	530	10	39	49	7.4	879	115.8	238.702	22.069	OK
09:40:57	7.8	530	11	39	50	7.4	879	115.8	238.702	22.519	OK
09:41:12	7.8	530	10	39	49	7.4	879	115.7	238.702	22.069	OK
09:41:27	7.8	530	10	39	49	7.4	879	115.3	238.702	22.069	OK
09:41:42	7.8	530	10	40	50	7.4	878	114.8	238.702	22.519	OK
09:41:57	7.8	530	10	40	50	7.4	878	114.4	238.702	22.519	OK
09:42:12	7.8	529	10	40	50	7.4	878	114.2	238.252	22.519	OK
09:42:27	7.8	530	10	40	50	7.4	877	114.2	238.702	22.519	OK
09:42:42	7.8	529	10	40	50	7.4	877	114	238.252	22.519	OK
09:42:57	7.8	529	10	41	51	7.4	877	113.9	238.252	22.969	OK
09:43:12	7.8	529	10	40	50	7.4	878	113.9	238.252	22.519	OK
09:43:27	7.9	528	10	40	50	7.3	878	114	239.631	22.692	OK
09:43:42	7.8	528	11	40	51	7.4	878	114.2	237.802	22.969	OK
09:43:57	7.9	529	10	40	50	7.3	878	114.4	240.085	22.692	OK
09:44:12	7.9	530	10	40	50	7.3	878	114.6	240.538	22.692	OK
09:44:27	7.9	530	11	40	51	7.3	878	114.8	240.538	23.146	OK

Last Sample of Test Data

Average CO Value = 532.295

Average NO Value = 9.902

Average NO2 Value = 39.279

Average NOx Value = 49.180

Average O2 Value = 7.836

End Of Test 1 Data.

Overall Average CO Value = 532.295

Overall Average NO Value = 9.902

Overall Average NO2 Value = 39.279

Overall Average NOx Value = 49.180

Overall Average O2 Value = 7.836

Technician:

Donald Hart

DATE

=====

EMISSION REPORT CALCULATIONS

DATE OF TEST: 5/3/2013
TIME OF TEST: 9:28:54

Quarter: 2

AREA: Corona Ca

FACILITY: WMRE El Sobrante

AIR PERMIT #: f86553
PERMIT DATE: 3/30/2012

PERMIT EQUIP #: 1

EQUIPMENT: El Sobrante E1
MODEL: TBG620V16

UNIT#: 1
SERIAL NUMBER: 2202932

Mass emission calculations are as follows:

$$E[\text{lb/hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * \text{HP}[\text{HP}] * 0.0000001[\text{MMBTU/BT}]$$
$$E[\text{g/hp-hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * 453.5924[\text{g/lb}] * 0.0000001[\text{N}]$$

where:

Fd = 10100.000 dscf/MMBTU (40 CFR CHAPTER I PART 60 Appendix A-7 Table 19-2)

Average Measured O2d% = 7.836 % (Corrected value used if Post-Calibration performed)

Fc(CO) = 7.268e-8 lb/dscf

Fc(NOx) = 1.194e-7 lb/dscf

Average Measured CO Cd = 532.295 ppm (Corrected value used if Post-Calibration performed)

Average Measured NOx Cd = 49.180 ppm (Corrected value used if Post-Calibration performed)

Specific Fuel Consumption = 11000.000 BTU/hp-hr (default value)

HP = 1000.000 HP (HP at time of test)

Conversion factors were calculated at 68 F and 14.696 PSI.

Assumptions:

Ambient O2 concentration 20.9%.

=====

GENERAL EMISSIONS TEST FORM

DATE OF TEST: 5/3/2013
TIME OF TEST: 9:28:54

Quarter: 2

AREA: Corona Ca

FACILITY: WMRE El Sobrante

AIR PERMIT #: f86553
PERMIT DATE: 3/30/2012

PERMIT EQUIP #: 1

EQUIPMENT: El Sobrante E1
MODEL: TBG620V16
SERVICE:

UNIT#: 1
SERIAL NUMBER: 2202932

SITE RATED HP: 1
INTAKE PRESS: 20 psi
RPM: 1800
Fuel: Landfill Gas
FUEL FLOW: 1000.000 lb/hr

HP DURING TEST: 1
INTAKE TEMP: 120 F
IGNITION TIMING: 26
SPECIFIC GRAVITY: 0.99

AIR/FUEL CONTROLLER

MAKE: TEMS

MODEL: TEMS

CATALYTIC CONVERTER

MAKE: n/a

MODEL: n/a

STACK HEIGHT: 34 FT IN
STACK FLOW: n/a

SENSOR TEMP: 878.0 F
STACK TEMP: 840 F

PERMITTED LIMITS:

CO: 250.00 g/bhp-hr CO emissions are below permitted limits.
NOx: 36.00 g/bhp-hr NOx emissions are below permitted limits.

CALCULATED EMISSIONS FROM TEST:

CO: 0.000 g/bhp-hr 0.000 lb/hr
NOx: 0.000 g/bhp-hr 0.000 lb/hr

Post Test Calibration adjustments have been applied.

Technician: Donald Hart

Engine Emission Test Recording

Test Date: 05/03/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E1*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202932*
 Engine Hours: *59874*
 Engine Parameters: *1200KW*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *00/00/00*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *00/00/00*

TEST RECORDING

Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
09:29:27	7.8	535	9	39	First Sample of Test Data
09:29:42	7.8	535	9	39	
09:29:57	7.8	535	9	39	
09:30:12	7.8	534	10	39	
09:30:27	7.9	534	10	39	
09:30:42	7.8	534	10	39	
09:30:57	7.8	534	9	39	
09:31:12	7.8	534	9	39	
09:31:27	7.8	533	9	39	
09:31:42	7.8	533	10	39	
09:31:57	7.8	533	9	39	
09:32:12	7.9	533	9	39	
09:32:27	7.9	533	9	39	
09:32:42	7.8	534	9	38	
09:32:57	7.8	534	9	40	
09:33:12	7.8	534	10	40	
09:33:27	7.8	534	10	40	
09:33:42	7.8	534	10	40	
09:33:57	7.8	534	10	40	
09:34:12	7.9	534	10	39	
09:34:27	7.9	533	10	39	
09:34:42	7.9	534	10	39	
09:34:57	7.9	534	9	39	
09:35:12	7.9	534	9	39	
09:35:27	7.9	534	9	39	
09:35:42	7.9	535	10	39	
09:35:57	7.9	534	10	39	
09:36:12	7.9	534	10	39	
09:36:27	7.9	534	10	39	
09:36:42	7.8	533	10	39	
09:36:57	7.8	533	10	39	
09:37:12	7.8	533	10	38	
09:37:27	7.9	534	10	38	
09:37:42	7.8	534	10	38	
09:37:57	7.8	533	10	39	
09:38:12	7.8	533	11	40	
09:38:27	7.8	532	11	40	
09:38:42	7.8	532	11	40	
09:38:57	7.8	531	11	39	
09:39:12	7.8	531	11	39	
09:39:27	7.9	532	10	39	
09:39:42	7.9	531	10	39	
09:39:57	7.9	532	10	39	
09:40:12	7.9	531	10	39	
09:40:27	7.8	530	10	39	
09:40:42	7.8	530	10	39	
09:40:57	7.8	530	11	39	
09:41:12	7.8	530	10	39	
09:41:27	7.8	530	10	39	
09:41:42	7.8	530	10	40	
09:41:57	7.8	530	10	40	
09:42:12	7.8	529	10	40	

Test Date: 05/03/13

Engine Emission Test Recording



Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
09:42:27	7.8	530	10	40	
09:42:42	7.8	529	10	40	
09:42:57	7.8	529	10	41	
09:43:12	7.8	529	10	40	
09:43:27	7.9	528	10	40	
09:43:42	7.8	528	11	40	
09:43:57	7.9	529	10	40	
09:44:12	7.9	530	10	40	
09:44:27	7.9	530	11	40	Last Sample of Test Data

Test Phase Average Values	7.8361	532.295	9.902	39.279
---------------------------	--------	---------	-------	--------

=====

PRE-POST TEST CALIBRATION INFORMATION

DATE OF TEST: 5/3/2013 Quarter: 2
 TIME OF TEST: 9 28 54

AREA: Corona Ca FACILITY: WMRE El Sobrante

AIR PERMIT #: F86554 PERMIT EQUIP #: 2
 PERMIT DATE: 30-Mar-12

EQUIPMENT: El Sobrante E2 UNIT#: 1
 MODEL: TBGG20V16 SERIAL NUMBER: 2202870

ANALYZER MAKE: ECOM ANALYZER MODEL: J2K(N)
 ANALYZER S/N: 2975

PRE TEST PERFORMED: 5/3/2013 8:26:17
 POST TEST PERFORMED: 5/3/2013 9:48:09

SAMPLE FLOW RATE: 3.5 l/min
 RESPONSE TIME: 2:00 RAMP-UP TIME: 4:00
 RAMP-UP TIME OK: YES

MAX O2 ZERO ERROR: 0.3 % O2
 MAX CO NO NO2 ZERO ERROR: 3.0 % SPAN
 MAX ZERO DRIFT: 5.0 % SPAN
 MAX O2 CAL ERROR: 0.5 % O2
 MAX CO NO NO2 CAL ERROR: 5.0 % SPAN
 MAX SPAN DRIFT: 5.0 % SPAN

PRE TEST CALIBRATION DATA

	MAX ZERO	ZERO OK	RESP	CAL ERROR	CAL OK
NO	0	3.1 YES		101 1.00%	YES
NO2	0	2.9 YES		98 0.00%	YES
CO	0	24 YES		799 0.00%	YES
O2	0	0.3 YES		21 0.1 % O2	YES

POST TEST CALIBRATION DATA

	MAX ZERO	ZERO OK	ZERO DRIFT	ZERO DRIFT OK	RESP	CAL ERROR	CAL OK	SPAN DRIFT	SPAN DRIFT OK	CAL GAS VALUE	CAL GAS EXP DATE
NO	0	3.1 YES	0.00%	YES		101 1.00%	YES	0.00%	YES	102	9/8/2012
NO2	0	2.9 YES	0.00%	YES		98 0.00%	YES	0.00%	YES	98	9/1/2012
CO	0	24 YES	0.00%	YES		799 0.00%	YES	0.00%	YES	799	9/8/2012
O2	0	0.3 YES	0.00%	YES		21 0.1 % O2	YES	0.00%	YES	20.9	

PRE/POST TEST CALIBRATION CORRECTIONS

$$\text{Corrected Value} = ((C_{\text{mea}} - C_z) * C_{\text{cal}}) / (C_m - C_z)$$

where

C_{mea} is the average measured value.
 C_z is the average of the pre and post test calibration zero readings.
 C_m is the average of the pre and post test calibration span readings.
 C_{cal} is the calibration gas concentration.

NO Corrected = 7.632
 NO C_{mea} = 7.557
 NO C_z = 0
 NO C_m = 101
 NO C_{cal} = 102
 NO2 Corrected = 37.246
 NO2 C_{mea} = 37.246
 NO2 C_z = 0
 NO2 C_m = 98
 NO2 C_{cal} = 98
 CO Corrected = 496.44
 CO C_{mea} = 496.44
 CO C_z = 0
 CO C_m = 799
 CO C_{cal} = 799
 O2 Corrected = 7.456
 O2 C_{mea} = 7.492
 O2 C_z = 0
 O2 C_m = 21
 O2 C_{cal} = 20.9

Technician:

Donald Hart

DATE

=====

GENERAL EMISSIONS TEST FORM

DATE OF TEST: 5/3/2013 Quarter: 2
TIME OF TEST: 8:54:08

AREA: Corona Ca FACILITY: WMRE El Sobrante

AIR PERMIT #: F86554 PERMIT EQUIP #: 2
PERMIT DATE: 30-Mar-12

EQUIPMENT: El Sobrante E2 UNIT#: 1
MODEL: TBG620V16 SERIAL NUMBER: 2202870
SERVICE:

SITE RATED HP: 1 HP DURING TEST: 1
INTAKE PRESS: n/a INTAKE TEMP: 120 F
RPM: 1800 IGINITION TIMING: 26
Fuel: Landfill Gas SPECIFIC GRAVITY: 0.99
FUEL FLOW: 1000.000 lb/hr

AIR/FUEL CONTROLLER
MAKE: TEMS MODEL: TEMS

CATALYTIC CONVERTER
MAKE: n/a MODEL: n/a

STACK HEIGHT: 34 FT IN SENSOR TEMP: 879.0 F
STACK FLOW: n/a STACK TEMP: 840 F

PERMITTED LIMITS:
CO: 250.00 g/bhp-hr CO emissions are below permitted limits.
NOx: 36.00 g/bhp-hr NOx emissions are below permitted limits.

CALCULATED EMISSIONS FROM TEST:
CO: 0.000 g/bhp-hr 0.000 lb/hr
NOx: 0.000 g/bhp-hr 0.000 lb/hr
Post Test Calibration adjustments have been applied.

Technician: Donald Hart

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E2*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202870*
 Engine Hours: *55452*
 Engine Parameters: *1200kW*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *00/00/00*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *00/00/00*

TEST RECORDING

Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
08:54:52	7.8	526	7	39	First Sample of Test Data
08:55:07	7.8	526	7	39	
08:55:22	0.0	0	0	0	
08:55:37	0.0	0	0	0	
08:55:52	7.8	525	7	39	
08:56:07	7.8	524	8	39	
08:56:22	7.8	524	8	40	
08:56:37	7.8	524	8	40	
08:56:52	7.8	524	8	40	
08:57:07	7.8	524	8	40	
08:57:22	7.9	524	7	39	
08:57:37	7.9	524	7	39	
08:57:52	7.8	524	7	39	
08:58:07	7.8	524	7	39	
08:58:22	7.8	524	8	39	
08:58:37	7.8	523	8	39	
08:58:52	7.9	523	7	39	
08:59:07	7.9	523	8	39	
08:59:22	7.9	523	8	39	
08:59:37	7.9	523	8	39	
08:59:52	7.9	523	7	39	
09:00:07	7.9	522	8	39	
09:00:22	7.9	522	8	39	
09:00:37	7.9	522	8	39	
09:00:52	7.8	522	8	40	
09:01:07	7.9	522	8	40	
09:01:22	7.9	522	8	40	
09:01:37	7.9	522	8	39	
09:01:52	7.9	522	8	39	
09:02:07	7.9	522	8	39	
09:02:22	7.9	523	8	39	
09:02:37	7.9	523	8	39	
09:02:52	7.9	522	8	39	
09:03:07	7.9	521	8	39	
09:03:22	7.9	521	8	39	
09:03:37	7.9	521	8	39	
09:03:52	7.9	521	8	39	
09:04:07	7.9	521	8	39	
09:04:22	7.9	521	8	39	
09:04:37	7.9	521	8	39	
09:04:52	7.9	521	8	39	
09:05:07	7.9	521	8	39	
09:05:22	7.9	521	8	40	
09:05:37	7.9	520	8	40	
09:05:52	7.9	520	8	40	
09:06:07	7.9	520	8	40	
09:06:22	0.0	0	0	0	
09:06:37	7.9	520	8	40	
09:06:52	7.9	519	9	40	
09:07:07	7.9	519	9	39	
09:07:22	7.9	519	9	39	
09:07:37	7.9	519	9	39	

Test Date: 05/03/13

Engine Emission Test Recording



Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
09:07:52	7.9	519	8	39	
09:08:07	7.9	521	8	38	
09:08:22	8.0	523	8	38	
09:08:37	7.9	525	8	38	
09:08:52	7.9	525	8	38	
09:09:07	7.9	523	8	39	
09:09:22	7.9	521	8	39	
09:09:37	7.9	520	9	39	
09:09:52	7.9	519	9	40	Last Sample of Test Data

Test Phase Average Values	7.4918	496.443	7.557	37.246
---------------------------	--------	---------	-------	--------

Engine Emission Test Report

Test Date: 05/03/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E2*
 Model: *TBG620V16*
 Service:

Unit Number: 1
 Serial Number: 2202870
 Engine Hours: 55452
 Engine Parameters: 1200kW

PERMIT INFORMATION

Permit Number: *F86554*
 Permit Equipment #: 2
 Permit CO Limit: 250

Permit Date: *30Aug07*
 Permit Units: *ppm @ 15% O2*
 Permit NOx Limit: 36

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *00/00/00*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *00/00/00*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
 Max O2 Cal Error: *0.5*
 Max Zero Drift: 5

Max CO, NO, NO2 Zero Error: 3
 Max CO, NO, NO2 Cal Error: 5
 Max Span Drift: 5

PRE-TEST CALIBRATION / POST-TEST VERIFICATION RESULTS

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)
Pre-Test Zero	0.0	0	0	0
Post-Test Zero	0.0	0	0	0
Mean Zero, Ccz	0.0000	0.000	0.000	0.000
Pre-Test Span	21.0	799	101	98
Post-Test Span	21.0	799	101	98
Span Drift (%)	0.0	0.0	0.0	0.0
Mean Span, Ccm	21.0000	799.000	101.000	98.000
Calibration Gas, Ccal	20.9	799 9/8/12	102 9/8/12	98 9/1/12

Drift = ((PostTest R - PreTest R)/PreTest R) * 100

(Cal gas expiration dates included)

Pre-Test / Post-Test Procedure Results: PASSED

EMISSION TEST RESULTS

Test Run As-Found 05/03/13 08:54:08

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	NOx (ppm)
Average Measured, Cmeas	7.4918	496.443	7.557	37.246	
Cal Adjusted, Cadj	7.4561	496.443	7.632	37.246	44.878
Cadj @ 15% O2		217.869			19.695
Permit Limit (@ 15% O2)		250			36

NOx = NO + NO2
 Cadj = (Cmeas - Ccz) * (Ccal / (Ccm - Ccz))

Cadj @ 15% O2 = Cadj * ((5.9) / (20.9 - O2))

Cell Temp. Start: 882.0F End: 879.0F Ambient Temp: 115.1F

Test Result: Measured emission levels are at or below permit limits.. (See attached notes.)

CERTIFICATION: Based on the information and belief formed after reasonable inquiry, I certify that the statements and information contained in this report are true, accurate, and representative of the emissions from this source.

Donald Hart, Power Management Inc

Title

Date

Test Date: 05/03/13

Engine Emission Test Report



PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E2*
Model: *TBG620V16*
Service:

Unit Number: *1*
Serial Number: *2202870*
Engine Hours: *55452*
Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86554*
Permit Equipment #: *2*
Permit CO Limit: *250*

Permit Date: *30Aug07*
Permit Units: *ppm @ 15% O2*
Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
Last Stability Test: *00/00/00*

Serial No. / EC: *02975 / OCVNX*
Last Linearity Test: *00/00/00*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
Max O2 Cal Error: *0.5*
Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
Max CO, NO, NO2 Cal Error: *5*
Max Span Drift: *5*

NOTES

El Sobrante Unit 2 2nd Qtr CO Monitoring

PRE-POST TEST CALIBRATION INFORMATION

DATE OF TEST: 5/3/2013 Quarter: 2
 TIME OF TEST: 9:28:54
 AREA: Corona Ca FACILITY: WMRE El Sobrante
 AIR PERMIT #: FB6555 PERMIT EQUIP #: 3
 PERMIT DATE: 30-Mar-12
 EQUIPMENT: El Sobrante E3 UNIT#: 1
 MODEL: TBG620V16 SERIAL NUMBER: 2202931
 ANALYZER MAKE: ECOM ANALYZER MODEL: J2K(N)
 ANALYZER S/N: 2975
 PRE TEST PERFORMED: 5/3/2013 8:26:17
 POST TEST PERFORMED: 5/3/2013 9:48:09
 SAMPLE FLOW RATE: 3.5 l/min RAMP-UP TIME: 4:00
 RESPONSE TIME: 2:00 RAMP-UP TIME OK: YES

MAX O2 ZERO ERROR: 0.3 % O2
 MAX CO NO NO2 ZERO ERROR: 3.0 % SPAN
 MAX ZERO DRIFT: 5.0 % SPAN
 MAX O2 CAL ERROR: 0.5 % O2
 MAX CO NO NO2 CAL ERROR: 5.0 % SPAN
 MAX SPAN DRIFT: 5.0 % SPAN

PRE TEST CALIBRATION DATA

	MAX ZERO	ZERO OK	RESP	CAL ERROR	CAL OK
NO	0	3.1 YES	101	1.00% YES	
NO2	0	2.9 YES	98	0.00% YES	
CO	0	24 YES	799	0.00% YES	
O2	0	0.3 YES	21	0.1 % O2 YES	

POST TEST CALIBRATION DATA

	MAX ZERO	ZERO OK	ZERO DRIFT	ZERO DRIFT OK	RESP	CAL ERROR	CAL OK	SPAN DRIFT	SPAN DRIFT OK	CAL GAS VALUE	CAL GAS EXP DATE
NO	0	3.1 YES	0.00% YES		101	1.00% YES		0.00% YES		102	9/8/2012
NO2	0	2.9 YES	0.00% YES		98	0.00% YES		0.00% YES		98	9/1/2012
CO	0	24 YES	0.00% YES		799	0.00% YES		0.00% YES		799	9/8/2012
O2	0	0.3 YES	0.00% YES		21	0.1 % O2 YES		0.00% YES		20.9	

PRE/POST TEST CALIBRATION CORRECTIONS

Corrected Value = $\frac{(C_{mea} - C_z) * C_{cal}}{(C_m - C_z)}$
 where

C_{mea} is the average measured value.
 C_z is the average of the pre and post test calibration zero readings.
 C_m is the average of the pre and post test calibration span readings.
 C_{cal} is the calibration gas concentration.

NO Corrected = 9.139
 NO C_{mea} = 9.049
 NO C_z = 0
 NO C_m = 101
 NO C_{cal} = 102
 NO2 Corrected = 38.639
 NO2 C_{mea} = 38.639
 NO2 C_z = 0
 NO2 C_m = 98
 NO2 C_{cal} = 98
 CO Corrected = 540.36
 CO C_{mea} = 540.36
 CO C_z = 0
 CO C_m = 799
 CO C_{cal} = 799
 O2 Corrected = 7.763
 O2 C_{mea} = 7.8
 O2 C_z = 0
 O2 C_m = 21
 O2 C_{cal} = 20.9

Technician:

Donald Hart

DATE

=====

GENERAL EMISSIONS TEST FORM

DATE OF TEST: 5/3/2013
TIME OF TEST: 8:26:29

Quarter: 2

AREA: Corona Ca

FACILITY: WMRE El Sobrante

AIR PERMIT #: F86555
PERMIT DATE: 30-Mar-13

PERMIT EQUIP #: 3

EQUIPMENT: El Sobrante E3
MODEL: TBG620V16
SERVICE:

UNIT#: 1
SERIAL NUMBER: 2202931

SITE RATED HP: 1
INTAKE PRESS: n/a
RPM: 1800
Fuel: Landfill Gas
FUEL FLOW: 1000.000 lb/hr

HP DURING TEST: 1
INTAKE TEMP: 120 F
IGNITION TIMING: 26
SPECIFIC GRAVITY: 0.99

AIR/FUEL CONTROLLER

MAKE: TEMS

MODEL: TEMS

CATALYTIC CONVERTER

MAKE: n/a

MODEL: n/a

STACK HEIGHT: 34 FT IN
STACK FLOW: n/a

SENSOR TEMP: 876.0 F
STACK TEMP: 840 F

PERMITTED LIMITS:

CO: 250.00 g/bhp-hr CO emissions are below permitted limits.
NOx: 36.00 g/bhp-hr NOx emissions are below permitted limits.

CALCULATED EMISSIONS FROM TEST:

CO: 0.000 g/bhp-hr 0.000 lb/hr
NOx: 0.000 g/bhp-hr 0.000 lb/hr

Post Test Calibration adjustments have been applied.

Technician: Donald Hart

Engine Emission Test Recording

Test Date: 05/03/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E3*
 Model: *TBG620V16*
 Service:

Unit Number: 1
 Serial Number: 2202931
 Engine Hours: 54641
 Engine Parameters: 1200kW

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: 00/00/00

Serial No. / EC: 02975 / OCVNX
 Last Linearity Test: 00/00/00

TEST RECORDING

Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
08:28:03	7.8	543	10	38	First Sample of Test Data
08:28:18	7.8	544	10	38	
08:28:33	7.8	544	10	38	
08:28:48	7.8	544	9	38	
08:29:03	7.8	544	9	38	
08:29:18	7.8	544	9	38	
08:29:33	7.8	543	9	38	
08:29:48	7.8	544	9	38	
08:30:03	7.8	544	9	37	
08:30:18	7.8	543	9	37	
08:30:33	7.8	543	9	37	
08:30:48	7.8	543	9	38	
08:31:03	7.8	542	9	38	
08:31:18	7.8	542	9	38	
08:31:33	7.8	542	9	38	
08:31:48	7.8	541	9	38	
08:32:03	7.8	542	9	39	
08:32:18	7.8	542	9	39	
08:32:33	7.8	542	9	39	
08:32:48	7.8	541	9	39	
08:33:03	7.8	542	9	39	
08:33:18	7.8	542	9	39	
08:33:33	7.8	541	9	39	
08:33:48	7.8	541	9	39	
08:34:03	7.8	541	9	39	
08:34:18	7.8	541	9	39	
08:34:33	7.8	541	9	39	
08:34:48	7.8	541	9	39	
08:35:03	7.8	541	9	39	
08:35:18	7.8	541	9	39	
08:35:33	7.8	541	9	39	
08:35:48	7.8	541	9	39	
08:36:03	7.8	540	9	38	
08:36:18	7.8	540	9	38	
08:36:33	7.8	540	9	38	
08:36:48	7.8	540	9	39	
08:37:03	7.8	540	9	39	
08:37:18	7.8	540	9	39	
08:37:33	7.8	539	9	39	
08:37:48	7.8	539	9	39	
08:38:03	7.8	539	9	39	
08:38:18	7.8	539	9	39	
08:38:33	7.8	539	9	39	
08:38:48	7.8	539	9	39	
08:39:03	7.8	538	9	39	
08:39:18	7.8	538	9	39	
08:39:33	7.8	538	9	39	
08:39:48	7.8	538	9	39	
08:40:03	7.8	538	9	39	
08:40:18	7.8	538	9	39	
08:40:33	7.8	538	9	39	
08:40:48	7.8	537	9	39	

Test Date: 05/03/13

Engine Emission Test Recording



Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
08:41:03	7.8	537	9	39	
08:41:18	7.8	537	9	39	
08:41:33	7.8	537	9	39	
08:41:48	7.8	536	9	39	
08:42:03	7.8	537	9	39	
08:42:18	7.8	537	9	39	
08:42:33	7.8	538	9	39	
08:42:48	7.8	538	9	39	
08:43:03	7.8	537	9	39	Last Sample of Test Data

Test Phase Average Values	7.8000	540.361	9.049	38.639
---------------------------	--------	---------	-------	--------

Engine Emission Test Report

Test Date: 05/03/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E3*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202931*
 Engine Hours: *54641*
 Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86555*
 Permit Equipment #: *3*
 Permit CO Limit: *250*

Permit Date: *30Aug07*
 Permit Units: *ppm @ 15% O2*
 Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *00/00/00*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *00/00/00*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
 Max O2 Cal Error: *0.5*
 Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
 Max CO, NO, NO2 Cal Error: *5*
 Max Span Drift: *5*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION RESULTS

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	
Pre-Test Zero	0.0	0	0	0	
Post-Test Zero	0.0	0	0	0	
Mean Zero, Ccz	0.0000	0.000	0.000	0.000	
Pre-Test Span	21.0	799	101	98	
Post-Test Span	21.0	799	101	98	
Span Drift (%)	0.0	0.0	0.0	0.0	Drift = ((PostTest R - PreTest R)/PreTest R) * 100
Mean Span, Ccm	21.0000	799.000	101.000	98.000	
Calibration Gas, Ccal	20.9	799 <i>9/8/12</i>	102 <i>9/8/12</i>	98 <i>9/1/12</i>	(Cal gas expiration dates included)

Pre-Test / Post-Test Procedure Results: PASSED

EMISSION TEST RESULTS

Test Run As-Found 05/03/13 08:26:29

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	NOx (ppm)
Average Measured, Cmeas	7.8000	540.361	9.049	38.639	
Cal Adjusted, Cadj	7.7629	540.361	9.139	38.639	47.778
Cadj @ 15% O2		242.681			21.458
Permit Limit (@ 15% O2)		250			36

NOx = NO + NO2
 Cadj = (Cmeas - Ccz) * (Ccal / (Ccm - Ccz))
 Cadj @ 15% O2 = Cadj * ((5.9) / (20.9 - O2))

Cell Temp. Start: 877.0F End: 876.0F Ambient Temp: 115.1F

Test Result: Measured emission levels are at or below permit limits.. (See attached notes.)

CERTIFICATION: Based on the information and belief formed after reasonable inquiry, I certify that the statements and information contained in this report are true, accurate, and representative of the emissions from this source.

Donald Hart, Power Management Inc

Title

Date

Test Date: 05/03/13

Engine Emission Test Report

ecom[™]

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E3*

Model: *TBG620V16*

Service:

Unit Number: *1*

Serial Number: *2202931*

Engine Hours: *54641*

Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86555*

Permit Equipment #: *3*

Permit CO Limit: *250*

Permit Date: *30Aug07*

Permit Units: *ppm @ 15% O2*

Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*

Last Stability Test: *00/00/00*

Serial No. / EC: *02975 / OCVNX*

Last Linearity Test: *00/00/00*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*

Max O2 Cal Error: *0.5*

Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*

Max CO, NO, NO2 Cal Error: *5*

Max Span Drift: *5*

NOTES

El Sobrante Unit 3 2nd Qtr CO Monitoring

Attachment 3

Third Quarter 2013 Portable Analyzer Monitoring Results for Engine 1, 2, and 3

=====

EMISSION REPORT CALCULATIONS

DATE OF TEST:	9/12/2013	Quarter:	3
TIME OF TEST:	11:26:01		
AREA:	Corona Ca	FACILITY:	WMRE El Sobrante
AIR PERMIT #:	f86553	PERMIT EQUIP #:	1
PERMIT DATE:	3/30/2012		
EQUIPMENT:	El Sobrante E1	UNIT#:	1
MODEL:	TBG620V16	SERIAL NUMBER:	2202932

Mass emission calculations are as follows:

$$E[\text{lb/hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * \text{HP}[\text{HP}] * 0.0000001[\text{MMBTU/BTU}]$$

$$E[\text{g/hp-hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * 453.5924[\text{g/lb}] * 0.0000001[\text{MMBTU/BTU}]$$

where:

Fd = 10100.000 dscf/MMBTU (40 CFR CHAPTER I PART 60 Appendix A-7 Table 19-2)
 Average Measured O2d% = 7.562 % (Corrected value used if Post-Calibration performed)
 Fc(CO) = 7.268e-8 lb/dscf
 Fc(NOx) = 1.194e-7 lb/dscf
 Average Measured CO Cd = 547.918 ppm (Corrected value used if Post-Calibration performed)
 Average Measured NOx Cd = 47.869 ppm (Corrected value used if Post-Calibration performed)
 Specific Fuel Consumption = 11000.000 BTU/hp-hr (default value)
 HP = 1000.000 HP (HP at time of test)

Conversion factors were calculated at 68 F and 14.696 PSI.

Assumptions:

Ambient O2 concentration 20.9%.

Engine Emission Test Report

Test Date: 09/12/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E1*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202932*
 Engine Hours: *62922*
 Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *f86553*
 Permit Equipment #: *1*
 Permit CO Limit: *250*

Permit Date: *8/30/07*
 Permit Units: *ppm @ 15% O2*
 Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *08/05/13*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
 Max O2 Cal Error: *0.5*
 Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
 Max CO, NO, NO2 Cal Error: *5*
 Max Span Drift: *5*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION RESULTS

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)
Pre-Test Zero	0.0	0	0	0
Post-Test Zero	0.0	0	0	0
Mean Zero, Ccz	0.0000	0.000	0.000	0.000
Pre-Test Span	21.0	799	101	98
Post-Test Span	21.0	799	101	98
Span Drift (%)	0.0	0.0	0.0	0.0
Mean Span, Ccm	21.0000	799.000	101.000	98.000
Calibration Gas, Ccal	20.9	799 9/8/13	102 9/8/13	98 9/1/13

Drift = ((PostTest R - PreTest R) / PreTest R) * 100

(Cal gas expiration dates included)

Pre-Test / Post-Test Procedure Results: PASSED

EMISSION TEST RESULTS

Test Run As-Found 09/12/13 11:26:01

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	NOx (ppm)
Average Measured, Cmeas	7.5623	547.918	5.311	42.557	
Cal Adjusted, Cadj	7.5263	547.918	5.364	42.557	47.921
Cadj @ 15% O2		241.722			21.141
Permit Limit (@ 15% O2)		250			36

NOx = NO + NO2
 Cadj = (Cmeas - Ccz) * (Ccal / (Ccm - Ccz))
 Cadj @ 15% O2 = Cadj * ((5.9) / (20.9 - O2))

Cell Temp. Start: 887.0F End: 887.0F Ambient Temp: 0.0F

Test Result: Measured emission levels are at or below permit limits.. (See attached notes.)

CERTIFICATION: Based on the information and belief formed after reasonable inquiry, I certify that the statements and information contained in this report are true, accurate, and representative of the emissions from this source.

Donald Hart, Power Management Inc

Title

Date

Test Date: 09/12/13

Engine Emission Test Report

ecom[®]

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *EI Sobrante E1*

Model: *TBG620V16*

Service:

Unit Number: *1*

Serial Number: *2202932*

Engine Hours: *62922*

Engine Parameters: *1200KW*

PERMIT INFORMATION

Permit Number: *f86553*

Permit Equipment #: *1*

Permit CO Limit: *250*

Permit Date: *8/30/07*

Permit Units: *ppm @ 15% O2*

Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*

Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*

Last Linearity Test: *08/05/13*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*

Max O2 Cal Error: *0.5*

Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*

Max CO, NO, NO2 Cal Error: *5*

Max Span Drift: *5*

NOTES

EI Sobrante Unit 1 3rd Qtr CO monitoring

=====

EMISSION REPORT CALCULATIONS

DATE OF TEST: 9/12/2013 Quarter: 3
TIME OF TEST: 10:49:43

AREA: Corona Ca FACILITY: WMRE El Sobrante

AIR PERMIT #: F86554 PERMIT EQUIP #: 2
PERMIT DATE: 30-Mar-12

EQUIPMENT: El Sobrante E2 UNIT#: 1
MODEL: TBG620V16 SERIAL NUMBER: 2202870

Mass emission calculations are as follows:

$$E[\text{lb/hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * \text{HP}[\text{HP}] * 0.0000001[\text{MMBTU/BTU}]$$
$$E[\text{g/hp-hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * 453.5924[\text{g/lb}] * 0.0000001[\text{MMBTU/BTU}]$$

where:

Fd = 10100.000 dscf/MMBTU (40 CFR CHAPTER I PART 60 Appendix A-7 Table 19-2)
Average Measured O2d% = 7.030 % (Corrected value used if Post-Calibration performed)
Fc(CO) = 7.268e-8 lb/dscf
Fc(NOx) = 1.194e-7 lb/dscf
Average Measured CO Cd = 560.066 ppm (Corrected value used if Post-Calibration performed)
Average Measured NOx Cd = 56.443 ppm (Corrected value used if Post-Calibration performed)
Specific Fuel Consumption = 11000.000 BTU/hp-hr (default value)
HP = 1000.000 HP (HP at time of test)

Conversion factors were calculated at 68 F and 14.696 PSI.

Assumptions:

Ambient O2 concentration 20.9%.

Engine Emission Test Recording

Test Date: 09/12/13

PHYSICAL LOCATION

Operational Area: Corona

EQUIPMENT INFORMATION

Equipment Name: El Sobrante E2
 Model: TBG620V16
 Service:

ANALYZER INFORMATION

Model: ECOM J2K(N)
 Last Stability Test: 08/05/13

Serial No. / EC: 02975 / OCVNX
 Last Linearity Test: 08/05/13

TEST RECORDING

Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
10:50:55	7.0	563	9	46	First Sample of Test Data
10:51:10	7.1	564	9	46	
10:51:25	7.1	563	9	46	
10:51:40	7.1	561	9	46	
10:51:55	7.0	561	9	45	
10:52:10	7.0	561	9	45	
10:52:25	7.1	561	9	46	
10:52:40	7.1	563	9	46	
10:52:55	7.1	563	9	47	
10:53:10	7.1	564	8	47	
10:53:25	7.1	563	8	47	
10:53:40	7.1	563	8	47	
10:53:55	7.1	563	9	47	
10:54:10	7.0	564	9	48	
10:54:25	7.0	565	9	48	
10:54:40	7.0	564	9	48	
10:54:55	7.0	564	9	48	
10:55:10	7.0	564	9	48	
10:55:25	7.0	564	9	47	
10:55:40	7.0	563	9	47	
10:55:55	7.0	563	9	47	
10:56:10	7.0	562	9	47	
10:56:25	7.1	562	9	47	
10:56:40	7.1	562	8	47	
10:56:55	7.0	561	8	47	
10:57:10	7.0	561	8	47	
10:57:25	7.0	561	9	48	
10:57:40	7.0	561	10	48	
10:57:55	7.0	561	9	48	
10:58:10	7.0	559	9	48	
10:58:25	7.0	560	9	48	
10:58:40	7.0	560	10	48	
10:58:55	7.0	560	10	48	
10:59:10	7.0	560	9	47	
10:59:25	7.0	559	9	47	
10:59:40	7.0	560	10	48	
10:59:55	7.0	561	9	48	
11:00:10	7.1	560	9	48	
11:00:25	7.1	560	10	48	
11:00:40	7.1	559	10	47	
11:00:55	7.1	558	9	47	
11:01:10	7.0	557	9	47	
11:01:25	7.0	558	10	47	
11:01:40	7.0	558	10	47	
11:01:55	7.0	558	9	47	
11:02:10	7.0	557	10	48	
11:02:25	7.0	558	9	48	
11:02:40	7.0	558	9	48	
11:02:55	7.0	557	9	48	
11:03:10	7.0	557	9	48	
11:03:25	7.0	557	9	48	
11:03:40	7.0	557	9	48	

Engine Emission Test Recording

Test Date: 09/12/13

Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
11:03:55	7.0	557	9	48	
11:04:10	7.0	556	10	48	
11:04:25	7.0	557	9	48	
11:04:40	7.1	556	9	48	
11:04:55	7.1	555	9	48	
11:05:10	7.0	555	10	48	
11:05:25	7.0	556	10	48	
11:05:40	7.0	555	9	48	
11:05:55	7.0	554	9	48	Last Sample of Test Data

Test Phase Average Values	7.0295	560.066	9.098	47.344
---------------------------	--------	---------	-------	--------

Test Date: 09/12/13

Engine Emission Test Report



PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E2*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202870*
 Engine Hours: *58456*
 Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86554*
 Permit Equipment #: *2*
 Permit CO Limit: *250*

Permit Date: *30Aug07*
 Permit Units: *ppm @ 15% O2*
 Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *08/05/13*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
 Max O2 Cal Error: *0.5*
 Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
 Max CO, NO, NO2 Cal Error: *5*
 Max Span Drift: *5*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION RESULTS

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)
Pre-Test Zero	0.0	0	0	0
Post-Test Zero	0.0	0	0	0
Mean Zero, Ccz	0.0000	0.000	0.000	0.000
Pre-Test Span	21.0	799	101	98
Post-Test Span	21.0	799	101	98
Span Drift (%)	0.0	0.0	0.0	0.0
Mean Span, Ccm	21.0000	799.000	101.000	98.000
Calibration Gas, Ccal	20.9	799 9/8/13	102 9/8/13	98 9/1/13

Drift = ((PostTest R - PreTest R)/PreTest R) * 100

(Cal gas expiration dates included)

Pre-Test / Post-Test Procedure Results: **PASSED**

EMISSION TEST RESULTS

Test Run As-Found 09/12/13 10:49:43

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	NOx (ppm)
Average Measured, Cmeas	7.0295	560.066	9.098	47.344	
Cal Adjusted, Cadj	6.9960	560.066	9.188	47.344	56.532
Cadj @ 15% O2		237.657			23.989
Permit Limit (@ 15% O2)		250			36

NOx = NO + NO2
 Cadj = (Cmeas - Ccz) * (Ccal / (Ccm - Ccz))
 Cadj @ 15% O2 = Cadj * ((5.9) / (20.9 - O2))

Cell Temp. Start: 887.0F End: 887.0F Ambient Temp: 0.0F

Test Result: Measured emission levels are at or below permit limits.. (See attached notes.)

CERTIFICATION: Based on the information and belief formed after reasonable inquiry, I certify that the statements and information contained in this report are true, accurate, and representative of the emissions from this source.

Donald Hart, Power Management Inc

Title

Date

Engine Emission Test Report

Test Date: 09/12/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E2*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202870*
 Engine Hours: *58456*
 Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86554*
 Permit Equipment #: *2*
 Permit CO Limit: *250*

Permit Date: *30Aug07*
 Permit Units: *ppm @ 15% O2*
 Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *08/05/13*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
 Max O2 Cal Error: *0.5*
 Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
 Max CO, NO, NO2 Cal Error: *5*
 Max Span Drift: *5*

NOTES

El Sobrante 3rd Qtr CO monitoring

=====

EMISSION REPORT CALCULATIONS

DATE OF TEST: 9/12/2013 Quarter: 3

TIME OF TEST: 12:11:00

AREA: Corona Ca FACILITY: WMRE El Sobrante

AIR PERMIT #: F86555 PERMIT EQUIP #: 3

PERMIT DATE: 30-Mar-12

EQUIPMENT: El Sobrante E3 UNIT#: 1

MODEL: TBG620V16 SERIAL NUMBER: 2202931

Mass emission calculations are as follows:

$$E[\text{lb/hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * \text{HP}[\text{HP}] * 0.0000001[\text{MMBTU/BTU}]$$
$$E[\text{g/hp-hr}] = Fd[\text{dscf/MMBTU}] * (20.9/(20.9 - O2d\%)) * Fc[\text{lb/scf}] * Cd[\text{ppm}] * \text{Specific Fuel Consumption}[\text{BTU/hp-hr}] * 453.5924[\text{g/lb}] * 0.0000001[\text{MMBTU/BTU}]$$

where:

- Fd = 10100.000 dscf/MMBTU (40 CFR CHAPTER I PART 60 Appendix A-7 Table 19-2)
- Average Measured O2d% = 7.615 % (Corrected value used if Post-Calibration performed)
- Fc(CO) = 7.268e-8 lb/dscf
- Fc(NOx) = 1.194e-7 lb/dscf
- Average Measured CO Cd = 536.459 ppm (Corrected value used if Post-Calibration performed)
- Average Measured NOx Cd = 43.131 ppm (Corrected value used if Post-Calibration performed)
- Specific Fuel Consumption = 11000.000 BTU/hp-hr (default value)
- HP = 1000.000 HP (HP at time of test)

Conversion factors were calculated at 68 F and 14.696 PSI.

Assumptions:

Ambient O2 concentration 20.9%.

Test Date: 09/12/13

Engine Emission Test Recording

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E3*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202931*
 Engine Hours: *57656*
 Engine Parameters: *1200kW*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *08/05/13*

TEST RECORDING

Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
12:12:33	7.6	536	4	39	First Sample of Test Data
12:12:48	7.6	536	4	39	
12:13:03	7.6	537	4	39	
12:13:18	7.7	537	4	39	
12:13:33	7.7	537	4	39	
12:13:48	7.6	537	4	39	
12:14:03	7.7	538	4	39	
12:14:18	7.7	538	4	39	
12:14:33	7.7	537	4	39	
12:14:48	7.6	537	4	39	
12:15:03	7.7	537	4	39	
12:15:18	7.7	537	4	39	
12:15:33	7.6	537	4	39	
12:15:48	7.6	537	4	39	
12:16:03	7.6	537	4	39	
12:16:18	7.6	536	4	39	
12:16:33	7.6	536	4	39	
12:16:48	7.6	538	4	39	
12:17:03	7.6	538	4	39	
12:17:18	7.6	538	4	39	
12:17:33	7.6	538	4	39	
12:17:48	7.6	539	4	39	
12:18:03	7.6	538	4	39	
12:18:18	7.7	537	4	39	
12:18:33	7.6	538	4	39	
12:18:48	7.6	537	4	39	
12:19:03	7.6	537	4	39	
12:19:18	7.6	537	4	39	
12:19:33	7.6	537	4	39	
12:19:48	7.6	537	4	39	
12:20:03	7.6	537	4	39	
12:20:18	7.6	537	4	39	
12:20:33	7.6	537	4	39	
12:20:48	7.7	537	4	39	
12:21:03	7.6	538	4	39	
12:21:18	7.6	537	4	38	
12:21:33	7.6	536	4	38	
12:21:48	7.6	536	4	39	
12:22:03	7.6	536	4	39	
12:22:18	7.6	536	4	39	
12:22:33	7.6	535	4	39	
12:22:48	7.6	535	4	39	
12:23:03	7.6	535	4	39	
12:23:18	7.6	535	4	40	
12:23:33	7.6	536	4	39	
12:23:48	7.6	536	4	39	
12:24:03	7.6	536	4	40	
12:24:18	7.6	536	4	40	
12:24:33	7.6	535	4	39	
12:24:48	7.6	535	4	40	
12:25:03	7.6	536	4	40	
12:25:18	7.6	535	4	40	

Test Date: 09/12/13

Engine Emission Test Recording



Sample Time	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	Notes
12:25:33	7.6	535	4	39	
12:25:48	7.6	536	4	39	
12:26:03	7.6	536	4	39	
12:26:18	7.6	536	4	39	
12:26:33	7.6	536	4	39	
12:26:48	7.6	535	4	40	
12:27:03	7.6	534	4	40	
12:27:18	7.6	534	4	40	
12:27:33	7.6	534	4	40	Last Sample of Test Data

Test Phase Average Values	7.6148	536.459	4.000	39.131
---------------------------	--------	---------	-------	--------

Engine Emission Test Report

Test Date: 09/12/13

PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E3*
 Model: *TBG620V16*
 Service:

Unit Number: *1*
 Serial Number: *2202931*
 Engine Hours: *57656*
 Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86555*
 Permit Equipment #: *3*
 Permit CO Limit: *250*

Permit Date: *30Aug07*
 Permit Units: *ppm @ 15% O2*
 Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
 Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*
 Last Linearity Test: *08/05/13*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
 Max O2 Cal Error: *0.5*
 Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
 Max CO, NO, NO2 Cal Error: *5*
 Max Span Drift: *5*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION RESULTS

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)
Pre-Test Zero	0.0	0	0	0
Post-Test Zero	0.0	0	0	0
Mean Zero, Ccz	0.0000	0.000	0.000	0.000
Pre-Test Span	21.0	799	101	98
Post-Test Span	21.0	799	101	98
Span Drift (%)	0.0	0.0	0.0	0.0
Mean Span, Ccm	21.0000	799.000	101.000	98.000
Calibration Gas, Ccal	20.9	799 <i>9/8/13</i>	102 <i>9/8/13</i>	98 <i>9/1/13</i>

Drift = ((PostTest R - PreTest R)/PreTest R) * 100

(Cal gas expiration dates included)

Pre-Test / Post-Test Procedure Results: PASSED

EMISSION TEST RESULTS

Test Run As-Found 09/12/13 12:11:00

	O2 (%)	CO (ppm)	NO (ppm)	NO2 (ppm)	NOx (ppm)
Average Measured, Cmeas	7.6148	536.459	4.000	39.131	
Cal Adjusted, Cadj	7.5785	536.459	4.040	39.131	43.171
Cadj @ 15% O2		237.594			19.120
Permit Limit (@ 15% O2)		250			36

NOx = NO + NO2
 Cadj = (Cmeas - Ccz) * (Ccal / (Ccm - Ccz))
 Cadj @ 15% O2 = Cadj * ((5.9) / (20.9 - O2))

Cell Temp. Start: 906.0F End: 906.0F Ambient Temp: 0.0F

Test Result: Measured emission levels are at or below permit limits.. (See attached notes.)

CERTIFICATION: Based on the information and belief formed after reasonable inquiry, I certify that the statements and information contained in this report are true, accurate, and representative of the emissions from this source.

Donald Hart, Power Management Inc

Title

Date

Test Date: 09/12/13

Engine Emission Test Report



PHYSICAL LOCATION

Operational Area: *Corona*

Facility Name:

EQUIPMENT INFORMATION

Equipment Name: *El Sobrante E3*
Model: *TBG620V16*
Service:

Unit Number: *1*
Serial Number: *2202931*
Engine Hours: *57656*
Engine Parameters: *1200kW*

PERMIT INFORMATION

Permit Number: *F86555*
Permit Equipment #: *3*
Permit CO Limit: *250*

Permit Date: *30Aug07*
Permit Units: *ppm @ 15% O2*
Permit NOx Limit: *36*

ANALYZER INFORMATION

Model: *ECOM J2K(N)*
Last Stability Test: *08/05/13*

Serial No. / EC: *02975 / OCVNX*
Last Linearity Test: *08/05/13*

PRE-TEST CALIBRATION / POST-TEST VERIFICATION REQUIREMENTS

Max O2 Zero Error: *0.3*
Max O2 Cal Error: *0.5*
Max Zero Drift: *5*

Max CO, NO, NO2 Zero Error: *3*
Max CO, NO, NO2 Cal Error: *5*
Max Span Drift: *5*

NOTES

El Sobrante 3rd Qtr CO Monitoring

Attachment 4

Table of Malfunctions and Codes from the TEM Unit



DEUTZ ENERGY

TEM Evolution System

11 Total List of Logic Informations

bit	no.	type	logic 0	logic 1	specification
0.0		message	manual	auto	genset operating mode "auto"
0.1		message	auto	manual	power control operating mode "manual "
0.2		message	auto	manual	mixture control operating mode "manual "
0.4	103	message	mains parallel		island operating mode island
1.4	203	message	OK	message	overtemp. air inlet
2.0	156	message	OK	failure	pre-heating failure
2.3		message	disable	enable	enable pre-heating
3.0		message	inactive	active	oil change active
3.3		message	alarm	OK	collective alarm
3.4		message	fault	OK	collective fault
4.1		message	off	running	engine running
4.3	106	message	off	on	power circuit breaker On
4.4	105	message	disabled	enabled	key switch manual op. mode
4.5		message	inactive	active	ramp down for low CH4 value
4.6		message	inactive	active	calibration of CH4 sensor
8.2	868	message		stop limit	MK ctrl. valve limit stop warm
8.3	867	message		stop limit	MK ctrl. valve limit stop cold
9.2	885	message		stop limit	GK ctrl. valve limit stop warm
9.3	886	message		stop limit	GK ctrl. valve limit stop cold
13.2		message		SP n. reached	gas mixer start pos. not reached
13.3		message		SP n. reached	gas mixer stop pos. not reached
15.6	124	message		available	gas available
16.0	124	message	OK	too low	gas pressure gas regul. section
17.0	197	message		LR active	power red. due to throttle position
17.1	207	message		LR active	power red. due to jacket water temp.
17.2	201	message		LR active	power red. due to recavertemp.
17.4	311	message		LR active	power red. due to CH4-value
18.7		message	off	on	test mode collective message
20.0		message	off	on	ignition
20.1		message	off	on	starter
20.2		message	off	on	speed governor
20.3		message	off	on	pre-lube pump
20.4		message	off	on	pre-heating
20.5		message	off	on	engine cool. circuit pump
20.7		message	off	on	intercooler circuit pump
21.3		message	off	on	refilling lube oil
21.4		message	off	on	pump off lube oil
22.6		message	closed	open	gas valve A1
22.7		message	closed	open	gas valve A2
26.0		message	off	on	reset emerg. shutdown unit
26.2		message	disable	enable	enable (request) power circuit breaker on
27.0		message		active	GK dry cooler stage 2
27.1		message		active	GK dry cooler stage 3



DEUTZ ENERGY

TEM Evolution System

total list of logic informations (continuation)

bit	no.	type	logic 0	logic 1	specification
27.2		message		active	GK dry cooler stage 4
27.3		message		active	NK dry cooler stage 2
27.4		message		active	NK dry cooler stage 3
27.5		message		active	NK dry cooler stage 4
33.0	196	alarm		too low	P196 lube oil pressure too low
33.1	196	alarm		too low	interval pre-/re-lube pressure too low
33.2	208	alarm		too high	T208 lube oil overtemperature
33.3	234	alarm		too low	L234 lube oil level too low
33.4	234	alarm		too high	L234 lube oil level too high
33.5		alarm		alarm	lube oil filter dirty
34.0	157	alarm		too high	P157 exhaust back pressure too high
34.1	200	alarm		too high	S200 speed before start too high
34.2	145	alarm		too low	P145 low pressure crank case
37.0	461	alarm		low temp.	T461 low temperature comb. chamber A1
37.1	462	alarm		low temp.	T462 low temperature comb. chamber A2
37.2	463	alarm		low temp.	T463 low temperature comb. chamber A3
37.3	464	alarm		low temp.	T464 low temperature comb. chamber A4
37.4	465	alarm		low temp.	T465 low temperature comb. chamber A5
37.5	466	alarm		low temp.	T466 low temperature comb. chamber A6
37.6	467	alarm		low temp.	T467 low temperature comb. chamber A7
37.7	468	alarm		low temp.	T468 low temperature comb. chamber A8
38.2	471	alarm		low temp.	T471 low temperature comb. chamber B1
38.3	472	alarm		low temp.	T472 low temperature comb. chamber B2
38.4	473	alarm		low temp.	T473 low temperature comb. chamber B3
38.5	474	alarm		low temp.	T474 low temperature comb. chamber B4
38.6	475	alarm		low temp.	T475 low temperature comb. chamber B5
38.7	476	alarm		low temp.	T476 low temperature comb. chamber B6
39.0	477	alarm		low temp.	T477 low temperature comb. chamber B7
39.1	478	alarm		low temp.	T478 low temperature comb. chamber B8
40.4	206	alarm		overtemp	T206 overtemp. jacket water engine outlet
43.0	198	alarm		alarm	power too long below 30%
44.0	311	alarm		too low	Q311 CH4-value too low
44.1		alarm		too long	calibration ch4 sensor (ramp down)
46.0	209	alarm		overtemp	T209 overtemperature generator winding U1
46.1	210	alarm		overtemp	T210 overtemperature generator winding V1
46.2	211	alarm		overtemp	T211 overtemperature generator winding W1
46.5	459	alarm		overtemp	T459 overtemperature generator bearing A
46.6	460	alarm		overtemp	T460 overtemperature generator bearing B
47.0		alarm		alarm	ignition system collective alarm
47.7		alarm		alarm	stepper motor board collective alarm
48.0		alarm		alarm	CAN-bus collective alarm
48.2		alarm		alarm	earth fault analog inputs
48.3		alarm		alarm	speed governor collective alarm
48.4		alarm		below 18V	supply voltage below 18 V
48.5		alarm		over 30V	supply voltage above 30 V
50.3	203	sensor a.			T203 air inlet
53.0	405	sensor a.			T405 GK dry cooler outlet
53.1	419	sensor a.			T419 NK dry. cooler outlet



DEUTZ ENERGY

TEM Evolution System

total list of logic informations (continuation)

bit	no.	type	logic 0	logic 1	specification
55.0	311	sensor a.			Q311 CH4-value
57.0		sensor a.			collective alarm digital inputs bus
57.1		sensor a.			collective alarm digital outputs bus
57.2		sensor a.			collective alarm digital outputs TEM
58.0		sensor a.			parametrizable measurement 01
58.1		sensor a.			parametrizable measurement 02
64.0	196	fault		too low	P196 lube oil pressure too low
64.1	196	fault		too low	interval pre-/post-lube pressure too low
64.2	196	fault		too low	P196 pre-lube pressure at start
64.3	208	fault		too high	T208 lube oil overtemperature
64.4	234	fault		too low	L234 lube oil level too low
64.5	234	fault		too high	L234 lube oil level too high
64.6		fault		fault	lube oil filter dirty
65.2	201	fault		too high	T201 overtemperature receiver
66.1	200	fault		too high	S200 overspeed
66.2	200	fault		too low	S200 low speed
66.3	145	fault		too high	P145 overpressure crank case
66.4		fault		fault	engine does not start
68.0	461	fault		too high	T461 overtemp. comb. chamber A1
68.1	462	fault		too high	T462 overtemp. comb. chamber A2
68.2	463	fault		too high	T463 overtemp. comb. chamber A3
68.3	464	fault		too high	T464 overtemp. comb. chamber A4
68.4	465	fault		too high	T465 overtemp. comb. chamber A5
68.5	466	fault		too high	T466 overtemp. comb. chamber A6
68.6	467	fault		too high	T467 overtemp. comb. chamber A7
68.7	468	fault		too high	T468 overtemp. comb. chamber A8
69.2	471	fault		too high	T471 overtemp. comb. chamber B1
69.3	472	fault		too high	T472 overtemp. comb. chamber B2
69.4	473	fault		too high	T473 overtemp. comb. chamber B3
69.5	474	fault		too high	T474 overtemp. comb. chamber B4
69.6	475	fault		too high	T475 overtemp. comb. chamber B5
69.7	476	fault		too high	T476 overtemp. comb. chamber B6
70.0	477	fault		too high	T477 overtemp. comb. chamber B7
70.1	478	fault		too high	T478 overtemp. comb. chamber B8
70.4	461	fault		too low	T461 low temp. comb. chamber A1
70.5	462	fault		too low	T462 low temp. comb. chamber A2
70.6	463	fault		too low	T463 low temp. comb. chamber A3
70.7	464	fault		too low	T464 low temp. comb. chamber A4
71.0	465	fault		too low	T465 low temp. comb. chamber A5
71.1	466	fault		too low	T466 low temp. comb. chamber A6
71.2	467	fault		too low	T467 low temp. comb. chamber A7
71.3	468	fault		too low	T468 low temp. comb. chamber A8
71.6	471	fault		too low	T471 low temp. comb. chamber B1
71.7	472	fault		too low	T472 low temp. comb. chamber B2
72.0	473	fault		too low	T473 low temp. comb. chamber B3
72.1	474	fault		too low	T474 low temp. comb. chamber B4
72.2	475	fault		too low	T475 low temp. comb. chamber B5
72.3	476	fault		too low	T476 low temp. comb. chamber B6



DEUTZ ENERGY

TEM Evolution System

total list of logic informations (continuation)

bit	no.	type	logic 0	logic 1	specification
72.4	477	fault		too low	T477 low temp. comb. chamber B7
72.5	478	fault		too low	T478 low temp. comb. chamber B8
73.0	46x	fault		fault	comb. chamber monitoring A (mean v.)
73.1	47x	fault		fault	comb. chamber monitoring B (mean v.)
73.2	46x	fault			
73.3	47x	fault			
75.0	207	fault		too high	T207 overtemp. jacket water engine inlet
75.1	206	fault		too high	T206 overtemp. jacket water engine outlet
79.2	126	fault		fault	dp flow monitoring engine cooling circuit
79.3	309	fault		fault	dp flow monitoring intercooler circuit
80.0	123	fault		fault	low water engine cooling circuit
80.1	308	fault		fault	low water intercooler circuit
82.0		fault		fault	mixture controller
82.6		fault		too long	calibration ch4 sensor
82.7	311	fault		too low	Q311 CH4-value too low
83.0		fault		overload	engine overload
83.1		fault		fault	power control
83.2		fault		fault	power reduction below 80% necessary
83.3	198	fault		fault	power too long below 30%
84.2	124	fault		fault	P124 gas pressure
84.4	147	fault		fault	temperature monitoring gas regul. section
86.0	209	fault		too high	T209 overtemp. generator winding U1
86.1	210	fault		too high	T210 overtemp. generator winding V1
86.2	211	fault		too high	T211 overtemp. generator winding W1
86.3	459	fault		too high	T459 overtemp. generator bearing A
86.4	460	fault		too high	T460 overtemp. generator bearing B
87.0		fault		fault	synchronization failure
87.1	198	fault		rev. power	reverse power
87.6	121	fault		fault	collective fault generator protection
89.2		fault		fault	circuit breaker TEM
90.0		fault		fault	reset while engine was running
90.1		fault		fault	internal quick stop
90.2	117	fault		fault	external quick stop without heat removal
90.3	116	fault		fault	external quick stop with heat removal
90.7		fault		fault	security chain open
92.0		fault		fault	ignition system collective fault
93.0		fault		fault	speed governor collective fault
93.1		fault		fault	stepper motor board collective fault
93.2		fault		fault	CAN-Bus collective fault
94.0		fault		fault	control parameters
97.0	196	sensor f.			P196 lube oil pressure before filter
97.2	208	sensor f.			T208 lube oil
97.4	234	sensor f.			L234 lube oil level
98.0	201	sensor f.			T201 receiver
98.4	145	sensor f.			P145 crank case pressure
99.2	200	sensor f.			S200 speed governor actual speed
100.0	203	sensor f.			T203 air inlet
101.0	461	sensor f.			T461 comb. chamber A1



July 29, 2008

Mr. Charlie Tupac
Engineering and Compliance Division
South Coast AQMD
21865 E. Copley Drive
Diamond Bar, CA 19765

**WASTE MANAGEMENT
EL SOBRANTE LANDFILL**

P.O. Box 77908
Corona, CA 92677
(951) 277-1740
(951) 277-1861 Fax

Subject: USA Waste of California (El Sobrante), Facility ID 113674

- Rule 1110.2 Inspection and Monitoring Plan Submission;
- Application for Change of Conditions in Permits to Operate for the Engines; and
- Application for Administrative Revision to Title V Permit

Dear Mr. Tupac:

USA Waste of California (El Sobrante) is submitting this application package consisting of the following:

- Rule 1110.2 Inspection & Monitoring Plan, Forms 400-A, 400-CEQA;
- Application for Change of Conditions in Permits to Operate (PTO) F86553, F86554, F86555, Forms 400-A, 400-CEQA;
- Application for Administrative Revision to Title V Permit, Forms 400-A, 400-CEQA, 500-A2, 500-C1;
- Check for the plan and applications fees.

Rule 1110.2 Inspection and Monitoring Plan

El Sobrante is submitting the Inspection and Monitoring Plan (I&M Plan) per the requirements of Rule 1110.2, as amended on February 1, 2008. The I&M Plan is applicable to the three Landfill Gas (LFG) fired Internal Combustion (IC) engines operating in the facility.

From everyday collection to environmental protection, Think Green® Think Waste Management.

Change of Conditions: PTO Nos. F86553, F86554, F86555

Per Rule 1110.2, as amended on February 1, 2008, the IC engines at El Sobrante are subject to a new concentration limit for NOx emissions (different from the present limit in PTO). The present concentration limit for NOx emissions is 36 PPMV. The new concentration limit is 36 x ECF PPMV. El Sobrante is submitting applications for a change of the NOx emission concentration limit and to add a new condition in all three engine PTOs as follows:

1. Change of NOx emission concentration limit

Present Condition No. 19 (Emissions and Requirements)

NOx: 36 PPMV @ 15% OXYGEN, 15 MINUTE AVERAGE, AT 25% EFF

Desired Change NOx: 36 x ECF PPMV @ 15% OXYGEN

The ECF will be determined by conducting a performance test for the engines following ASME PTC 17 -1973, per Rule 1110.2 (d)(1)(C)(i) and (ii). After performing the test, El Sobrante will submit the test results to the District so that the ECF-corrected NOx concentration becomes the new concentration limit for NOx emissions.

2. Add a new permit condition

The concentration limits for emissions from the engine exhaust shall not apply during an engine start-up. The start-up period shall not exceed 30 minutes.

The above two changes are applicable to the PTO of all three engines, i.e. PTO Nos. F86553, F86554, F86555.

Administrative Revision to Title V Permit

The El Sobrante engines operate with a Total Electronic Management System (TEM) air-fuel mixture control. El Sobrante is submitting this application to add the TEM system to the engine description in all engine PTOs, i.e. PTO Nos. F86553, F86554, F86555. Please refer to Section 2.2 of the attached I&M Plan for a description of the air-fuel mixture control.

I certify under penalty of law that based on information and belief, formed after reasonable inquiry, the statements and information in this application package are true,

accurate, and complete. I also certify under penalty of law that I am the authorized representative for this facility as defined in SCAQMD Regulation XXX.

If you have any questions regarding this test report, please contact our consultant, Mr. Andrew Washington of Shaw Environmental, at (661) 775-9635.

Sincerely,

A handwritten signature in black ink, appearing to read "Damon De Frates". The signature is written in a cursive style with a long horizontal stroke extending to the left.

Damon De Frates
Senior District Manager

Encl:

1. I&M Plan
2. SCAQMD Forms
3. Check for \$ 7,365.51

USA WASTE OF CALIFORNIA
Inspection and Monitoring Plan – Rule 1110.2
Landfill Gas Fired Internal Combustion Engines 1 to 3
Permit Nos. F86553, F86554, F86555
Facility ID 113674

July 2008

Prepared for:



WASTE MANAGEMENT, INC.

El Sobrante Landfill
10910 Dawson Canyon Road,
Corona, CA 92883

Prepared by:



Shaw Shaw Environmental, Inc.

3347 Michelson Drive, Suite 200
Irvine, California 92612

Table of Contents

1.0	Introduction	1-1
1.1	Purpose	1-1
2.0	Engine Operating Parameters	2-1
2.1	Operating Parameters	2-1
2.2	Air-Fuel Mixture Control	2-1
2.2.1	Control Set Points	2-1
2.2.2	Malfunctions	2-2
3.0	Carbon Monoxide Emission Checks	3-1
3.1	Portable Analyzer	3-1
4.0	Monitoring and Inspection	4-1
5.0	Maintenance	5-2
5.1	Preventive Maintenance	5-2
6.0	Notification	6-3
7.0	Recordkeeping	7-4
8.0	Revisions to I&M Plan	8-5

1.0 Introduction

USA Waste of California (El Sobrante) operates three internal combustion (IC) engines. Each engine is an 1877 BHP Deutz Model TBG620V16K landfill gas (LFG) fired lean burn engine with 16 cylinders, turbocharged, and aftercooled. Each engine drives a 1358 KW electrical generator and is equipped with Rule 218 approved continuous emissions monitoring system (CEMS) for Oxides of Nitrogen (NOx) and Oxygen (O₂).

1.1 Purpose

El Sobrante is submitting this document to serve as the inspection and monitoring (I&M) plan for the engines as required by South Coast Air Quality Management District (SCAQMD) Rule 1110.2, amended February 1, 2008. The engines will be inspected and maintained per this I&M plan.

2.0 Engine Operating Parameters

The IC engines have spark ignition and burn LFG generated in the landfill to generate electricity. Each engine drives a 1358 KW generator.

2.1 Operating Parameters

The engine operating parameters include: i) engine cylinder or combustion temperature; ii) water jack temperature; iii) crankcase pressure; and iv) engine operating load.

2.2 Air-Fuel Mixture Control

Each Deutz engine is equipped with a Total Electronic Management (TEM) system that provides complete engine control. The TEM controls functions such as engine start/stop, output control, gas-air (or fuel-air) mixture control with short correction time, integrated digital speed control, component system monitoring including the cooling and lube oil systems. The TEM also transmits measured values, operation, alarm and fault messages via a serial interface to the master control system.

The TEM, through a fuel-air mixer, controls the gas-air mixture going into the combustion chamber based on the average combustion cylinder temperature. The objective of the TEM is to maintain the average temperature of the 16 cylinders at the established set point. The set point of the average cylinder temperature is established such that the performance of the engine is optimum at any given operating load. The fuel-air mixer works by allowing more or less gas into the inlet manifold to make sure the average cylinder temperature is at the established set point.

At any given load, as long as the engine operates with the average cylinder temperature in the range corresponding to the set point, the engine's performance is optimized. The emissions will also be within the permissible limits. However, there maybe deviations in the emissions in certain situations such as drop in the fuel quality, water in the fuel line, etc.

2.2.1 Control Set Points

At El Sobrante, the cylinder set points are established at the normal load and the minimum, midpoint, and maximum loads that actually occur during normal operations. Following are the cylinder temperature set points for the various operating loads at El Sobrante:

Table 2.1 Operating Load and Temperature Set Points

Engine Operating Condition	Operating Load	Average Cylinder Temperature Set Point
Minimum Load	40 %	Between 260 °C and 295 °C

Engine Operating Condition	Operating Load	Average Cylinder Temperature Set Point
Midpoint Load	60 %	Between 280 °C and 320 °C
Normal Load	70 %	Between 285 °C and 320 °C
Maximum Load	80 %	Between 297 °C and 330 °C

The set points will be checked for compliance with the applicable emission limits during the annual engine source test and CO emission checks using a portable analyzer (discussed later). The set points will be reestablished as necessary.

2.2.2 Malfunctions

The TEM system monitors the cylinder temperature and compares it with the average cylinder temperature set point. If the temperature of any cylinder drops 70 °C below the average cylinder temperature set point for a period exceeding 15 minutes, the TEM sends out a Low Cylinder Temperature alarm. If the cylinder temperature remains low for 30 minutes, the engine shuts down. The engine also shut down if temperature in any cylinder temperature reaches 600 °C.

A fuel-air mixer malfunction is a deviation of the combustion control and will result in a fault.

2.2.3 Emission Limits

Compliance with the applicable emission limits for the engines are demonstrated during the annual compliance engine source test, conducted by a District-approved contractor. Additionally, compliance with the applicable CO emission limit will be demonstrated during the CO emission checks performed with a CO portable analyzer. NOx emissions are monitored continuously through the CEMS.

3.0 Carbon Monoxide Emission Checks

The engine is equipped with Rule 218 approved CEMS for NO_x and O₂. Per the requirements of Rule 1110.2, a portable CO analyzer will be used to check the engine exhaust for CO emissions at least quarterly, or every 2000 engine operating hours, whichever occurs later. No engine maintenance or tuning will be scheduled within 72 hours prior to the emission check.

3.1 Portable Analyzer

A portable CO analyzer will be used to conduct CO emission checks. The analyzer will be calibrated, maintained and operated in accordance with the manufacturer's specifications and recommendations and per the requirements of SCAQMD published protocol for the periodic monitoring of CO from stationary engines subject to Rule 1110.2, or subsequent protocol approved by EPA and the Executive Officer.

The CO emission checks will be performed by a person who has completed the District-approved training program for the portable analyzer and has received certification from the District.

4.0 Monitoring and Inspection

The engine load and fuel input rate is measured continuously and recorded. The data is compiled in the form of a daily heat input report, which is reviewed the following day for compliance determination. Following are the acceptable ranges of the engine operating parameters:

- Water Jacket Outlet Temperature – Alarm is generated at a temperature of 96 °C while the engine shuts down at a temperature of 98 °C.
- Crankcase Pressure – The engine shuts down at a pressure of 20 mbar.
- Cylinder or Combustion Temperature – Alarm is generated if the temperature is 70 °C below the set point for more than 15 minutes and the engine shuts down if the temperature continues to remain low for 30 minutes. The engine also shuts down if the temperature of any cylinder reaches 600 °C.

- Engine Operating Load

The TEM system records the operating hours of the engine. The site engine operator takes daily notes of operating hours, load settings, mixer readings, throttle position, oil hours, engine water temperature, and air inlet temperature and oil pressure. The operating hours since the last CO emission check can be obtained by subtracting the operating hours on the day of emission check from the current operating hours.

A fuel-air mixer malfunction is a deviation of the combustion control and will generate a fault alarm.

5.0 Maintenance

The engines at El Sobrante are operated and maintained by Run Energy, a contractor hired by El Sobrante. Run Energy has a 24-hour on-call operator who responds to any engine malfunction alarm and other call. The operator diagnoses the cause of the alarm and repairs the malfunction, if any, in accordance with Run Energy procedures.

Any breakdown resulting in a violation of Rule 1110.2 or a permit condition, any excess emissions, or any incident resulting in the parameters going out-of-range will be addressed in the manner specified in Rule 1110.2 (February 1, 2008).

5.1 Preventive Maintenance

Run Energy's maintenance plan is based on engine hours of operation.

The preventive maintenance program consists of four progressive levels of service G1, G2, G3 and G4. Each level consists of measurements, adjustments, calibration check, and visual inspection of the engine and generator. The corrective and preventive maintenance plan is as follows:

- G1, G2, G3, and G4 levels of service every 1000 \pm 100 hours of operation;
- Engine oil changes, spark plug cleaning, and air filter cleaning are performed once every 168 to 225 hours of operation;
- Fuel mixer cleaning is performed once every 2000-4000 hours of operation;
- Top end de-coat is performed once every 4000-8000 hours of operation;
- Top end overhaul is performed once every 8000-12000 hours of operation;
- Bottom end overhaul is performed once every 12000-16000 hours of operation

All maintenance and overhaul is performed in according with Run Energy procedures.

6.0 Notification

Run Energy has a 24-hour on-call support operator who responds to the malfunction alarms and other calls. The operator diagnoses the cause of the problem and performs the necessary repairs. If the problem is beyond the operator's knowledge or expertise, the operator calls the supervisor for further action.

Run Energy coordinates with Waste Management and Shaw Environmental, Inc to facilitate the notification procedure to the SCAQMD. All notifications are made per the requirements of SCAQMD Rules 1110.2, 430, and 218.

7.0 Recordkeeping

The following documents are retained on site:

- The daily heat input reports for all engines
- The daily readings taken by the engine site operator. The TEM electronically stores the engine operating hours and other information.
- The engine source test reports, CEMS units Relative Accuracy Test Audit (RATA) and calibration gas audit (CGA) reports
- All engine operating parameters, engine start-ups, shutdowns, and malfunctions, and emission monitoring data

All other data collected and recorded as described in this plan and required by Rule 1110.2 will be maintained on-site for five years and made available to SCAQMD upon request.

8.0 Revisions to I&M Plan

El Sobrante will follow all the procedures outlined in this plan. If any changes are planned to the operating procedures, the I&M plan will be updated and submitted to the SCAQMD for approval. Following the approval of the revised/updated plan, the planned changes will be made effective.