

## FACILITY PERMIT TO OPERATE CONOCOPHILLIPS CO. LA TERMINAL

### PERMIT TO OPERATE

Permit No. ....  
A/N 455327

#### Equipment Description:

STORAGE TANK, CARBOB, ETHANOL, DIESEL, 85'-0" DIA. X 48'-0" H., PONTOON TYPE, INTERNAL FLOATING ROOF, 40,000 BARREL CAPACITY, WELDED SHELL, WITH A MECHANICAL SHOE PRIMARY SEAL AND A RIM MOUNTED WIPER TYPE SECONDARY SEAL.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS TANK SHALL NOT BE USED FOR STORING ORGANIC LIQUID HAVING A REID VAPOR PRESSURE OF GREATER THAN 12 PSIA.  
[RULE 1303(b)(2)-OFFSETS]
4. THE THROUGHPUT OF ORGANIC LIQUID TO THIS TANK SHALL NOT EXCEED 1,183,333 BARRELS IN ANY ONE CALENDAR MONTH.  
[RULE 1303(b)(2)-OFFSETS]
5. THE OPERATOR SHALL MONITOR THE HYDROCARBON CONCENTRATION OF THE VAPOR SPACE USING AN EXPLOSIMETER OR EQUIVALENT DEVICE EVERY SIX MONTHS.  
[RULE 463]
6. THE HYDROCARBON CONCENTRATION IN THE VAPOR SPACE ABOVE THE INTERNAL FLOATING ROOF SHALL NOT EXCEED 30% OF THE VAPOR LOWER EXPLOSIVE UNIT.  
[RULE 463, RULE 1178]
7. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):  
  
TYPE OF LIQUID STORED  
THROUGHPUT  
TURNOVERS  
RANGES OF TRUE VAPOR PRESSURE OF SUCH LIQUIDS  
[RULE 463]

## FACILITY PERMIT TO OPERATE CONOCOPHILLIPS CO. LA TERMINAL

8. THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT, TO SHOW COMPLIANCE WITH ALL CONDITIONS. SUCH RECORDS SHALL BE MAINTAINED AND KEPT ON FILE AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS AUTHORIZED REPRESENTATIVE UPON REQUEST.  
[RULE 463, 40CFR 60 SUBPART Kb]

**Periodic Monitoring:** NONE

**Emissions and Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 463
  - VOC: RULE 1149
  - VOC: RULE 1178
  - VOC: 40 CFR 60, SUBPART Kb

## FACILITY PERMIT TO OPERATE CONOCOPHILLIPS CO. LA TERMINAL

### PERMIT TO OPERATE

**Permit No.**  
**A/N 502579**

#### **Equipment Description:**

VAULT TANK, RECOVERED GASOLINE AND WATER, UL-2085, FIXED ROOF, 2800 GALLON CAPACITY, 6'-11" W. X 11'-10" L. X 4'-7" H.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS TANK SHALL NOT BE USED FOR STORING ORGANIC LIQUID HAVING A REID VAPOR PRESSURE OF GREATER THAN 6 PSIA.  
[RULE 1303(b)(2)-OFFSETS]
4. THIS TANK SHALL BE EQUIPPED WITH A PRESSURE-VACUUM VALVE WHICH IS SET TO WITHIN 10 PER CENT OF THE MAXIMUM ALLOWABLE WORKING PRESSURE OF THE CONTAINER.  
[RULE 463(d)(1)]
5. A FLOWMETER OR LEVEL INDICATOR SHALL BE INSTALLED TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6.  
[RULE 1303(a)-BACT, RULE 1303(b)(2)-OFFSETS]
6. THE THROUGHPUT OF ORGANIC LIQUID TO THIS TANK SHALL NOT EXCEED 89 GALLONS PER DAY.  
[RULE 1303(a)-BACT, RULE 1303(b)(2)-OFFSETS]
7. THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT, TO SHOW COMPLIANCE WITH ALL CONDITIONS. SUCH RECORDS SHALL BE MAINTAINED AND KEPT ON FILE AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS AUTHORIZED REPRESENTATIVE UPON REQUEST.  
[RULE 463, 40CFR 60 SUBPART Kb]

## FACILITY PERMIT TO OPERATE CONOCOPHILLIPS CO. LA TERMINAL

**Periodic Monitoring:** NONE

**Emissions and Requirements:**

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 463  
VOC: RULE 1149