



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 12, 2013
Via Electronic Submittal

Mr. Gerardo Rios
U.S. EPA, Region IX
Mail Stop A-5-2
75 Hawthorne Street
San Francisco, CA 94105

Re: Proposed De Minimis Revision to Title V Permit for the City of LA, Sanitation Bureau, Hyperion Treatment Plant (Facility ID # 800214)

Dear Mr. Rios:

Enclosed for your 45-day review is the proposed revision to the Title V Permit for City of LA, Sanitation Bureau, Hyperion Treatment Plant, located at 12000 Vista del Mar, Playa del Rey, CA 90293. The revisions are considered to be a "De Minimis permit revision" and a 45-day EPA review is required. We are enclosing the pertinent portions of proposed Section D and Section H, including the revised permit as shown below, and the engineering evaluations.

SECTION D: PERMITS TO OPERATE

Appl. Nos.	Description of Revision
516867	Modification of Digester Gas Desulfurization System (A/N 266268) by replacing two of the existing compressors with 4 new compressors and addition of one Gas Holder.
522847	Operation of existing 28.8-mmbtu/hr standby boiler with a prior rental permit.
531841	Modification of Spray Booth (P/O No. F19609) by converting the existing Water Wash Type to Dry Filtration Type Spray Booth.


SECTION H: PERMITS TO CONSTRUCT

Appl. Nos.	Description
522846	Construction of a 62-mmbtu/hr boiler, replacing 62 mmbtu/hr boiler (A/N 388675).

The initial Title V permit for this facility was issued on January 12, 2009. These proposed revisions are filed under applications 522845 and 531838.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Mr. Abdi Majidifar at (909) 396-2449 or by email at amajidifar@aqmd.gov.

Very truly yours,



Andrew Lee, P.E.
Senior Engineering Manager
Waste Management/Terminals - Permitting

AL: CDT: AM

Enclosures

cc: Steve Fan, Plant Manager, w/o evaluation
A/Ns 522845 & 531838