

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, copies of all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit number	Equipment description
374616	F34756	I C E (50-500 HP) EM FIRE FGHT-DIESEL
374623	F37712	BOILER (5-20 MMBTU/HR) NAT GAS ONLY
374635	F34764	SOLVENT RECLAIM STILL (1 STAGE)
386189	F39934	I C E (>500 HP) EM ELEC GEN DIESEL
386190	F39935	I C E (>500 HP) EM ELEC GEN DIESEL
386191	F39939	I C E (>500 HP) EM ELEC GEN DIESEL
427663	F69143	PRINTING PRESS LITHOGRAPHIC AIR DRY
427664	F69145	PRINTING PRESS LITHOGRAPHIC AIR DRY
427665	F69148	PRINTING PRESS LITHOGRAPHIC AIR DRY
427666	F69149	PRINTING PRESS LITHOGRAPHIC AIR DRY
427667	F69150	PRINTING PRESS LITHOGRAPHIC AIR DRY
465960	F88725	GROUNDWATER TREATMENT SYSTEM
477157		I C E (>500 HP) EM ELEC GEN DIESEL
477158		I C E (>500 HP) EM ELEC GEN DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]
2. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 431.2]
3. AFTER JUNE 1, 2004, THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
[RULE 431.2]
4. THE TOTAL QUANTITY OF VOLATILE ORGANIC COMPOUND (VOC) EMISSIONS DISCHARGED TO THE ATMOSPHERE FROM THIS FACILITY SHALL NOT EXCEED 420 POUNDS IN ANY ONE DAY.
[RULE 1302(b)(2)-OFFSET]
5. IN ADDITION TO THE REQUIREMENTS OF RULE 109, THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS FACILITY TO VERIFY COMPLIANCE WITH ALL CONDITIONS STATED IN THIS PERMIT. SUCH RECORDS SHALL BE MAINTAINED IN A MANNER ACCEPTABLE TO THE DISTRICT, RETAINED AT THE FACILITY FOR AT LEAST FIVE YEARS, AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 109, 1303(b)(2)-OFFSET]
6. MATERIAL SAFETY DATA SHEETS FOR ALL INKS, COATINGS AND SOLVENTS USED AT THIS FACILITY AND SUBJECT TO DISTRICT RULES SHALL BE KEPT CURRENT AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 109, 1303(b)(2)-OFFSET]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F34756
A/N 374616**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, MODEL NO. NHS61F, SERIAL NO. 529755, 6 CYLINDERS, 4 CYCLES, SUPER-CHARGED, 290 BHP, WITH 1 EXHAUST, DRIVING EMERGENCY FIRE FIGHTING EQUIPMENT.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THE ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS SHALL BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303(a)(1)-BACT]

Periodic Monitoring:

4. THIS EQUIPMENT SHALL BE OPERATED LESS THAN 200 HOURS IN ANY ONE YEAR. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1110.2, 1304(a)(4), 3004 (a)(4)]
5. A LOG LISTING THE ENGINE OPERATING TIME, IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1110.2, 1304(a)(4), 3004(a)(4)]

Emissions and Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No. F37712
A/N 374623

Equipment Description:

BOILER, SELLERS, FIRETUBE TYPE, MODEL 120 HPLN490, 5,020,800 BTU PER HOUR, NATURAL GAS FIRED, WITH A SELLERS LN490 LOW-NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT]
4. EMISSIONS FROM THIS BOILER SHALL NOT EXCEED MORE THAN 30 PPM OF OXIDES OF NITROGEN (NO_x) CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1146]
5. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS IN ORDER TO VERIFY COMPLIANCE WITH CONDITION NOS. 3 AND 4. THESE RECORDS SHALL BE RETAINED ON FILE FOR FIVE YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

Periodic Monitoring:

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO_x EMISSION LIMIT(S) BY CONDUCTING A TEST AT LEAST ONCE EVERY FIVE YEARS USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD OR , IF NOT AVAILABLE, A NON-AQMD APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH THE NO_x CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) BY CONDUCTING A TEST AT LEAST ONCE EVERY FIVE YEARS USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD OR , IF NOT AVAILABLE, A NON-AQMD APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH THE CO CONCENTRATION LIMIT(S). THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- NOX: 30 PPM, RULE 1146
CO: 400 PPM, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1gr/scf, RULE 409

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F34764
A/N 374635**

Equipment Description:

INK RECLAMATION SYTEM, STI, WITH A VACUUM DISTILLATION UNIT, 3'-5" DIA. X 6'-0" H., 230 GALLONS CAPACITY, A CONDENSER, A CARBON FILTER, A MIXER, 1,500 GALLONS CAPACITY, AND A CENTRIFUGE, 14 ½ H.P. TOTAL.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

Emissions And Requirements:

3. THIS EQUIPEMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 109

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F39934
A/N 386189**

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 3, DIESEL, DETROIT DIESEL ALLISON, MODEL NO. 9163-7305, 1515 B.H.P., TURBOCHARGED, DRIVING A 1700 KW EMERGENCY ELECTRIC GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN ELAPSED OPERATING TIME METER SHALL BE INSTALLED ON THIS ENGINE, SO AS TO INDICATE, IN CUMULATIVE HOURS, THE AMOUNT OF TIME THE ENGINE HAS OPERATED.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 200 HOURS PER CALENDAR YEAR.
[RULE 1110.2, 1303(a)(1)-BACT, 1304(a)(4)-MODELING AND OFFSET EXEMPTION]
5. THE TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED, AT A MINIMUM, ONCE EVERY THREE YEARS. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS SHALL BE PERFORMED BY A QUALIFIED MECHANIC ACCORDING TO THE ENGINE MANUFACTURER'S RECOMMENDED PROCEDURES.
[RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS OF THE OPERATION OF THIS ENGINE TO VERIFY COMPLIANCE WITH CONDITION NOS. 4, 5, AND 6. THESE RECORDS SHALL BE RETAINED ON FILE FOR A PERIOD OF AT LEAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

Emissions and Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F39935
A/N 386190**

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 4, DIESEL, DETROIT DIESEL ALLISON, MODEL NO. 9163-7305, 1515 B.H.P., TURBOCHARGED, DRIVING A 1700 KW EMERGENCY ELECTRIC GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN ELAPSED OPERATING TIME METER SHALL BE INSTALLED ON THIS ENGINE, SO AS TO INDICATE, IN CUMULATIVE HOURS, THE AMOUNT OF TIME THE ENGINE HAS OPERATED.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 200 HOURS PER CALENDAR YEAR.
[RULE 1110.2, 1303(a)(1)-BACT, 1304(a)(4)-MODELING AND OFFSET EXEMPTION]
5. THE TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED, AT A MINIMUM, ONCE EVERY THREE YEARS. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS SHALL BE PERFORMED BY A QUALIFIED MECHANIC ACCORDING TO THE ENGINE MANUFACTURER'S RECOMMENDED PROCEDURES.
[RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS OF THE OPERATION OF THIS ENGINE TO VERIFY COMPLIANCE WITH CONDITION NOS. 4, 5, AND 6. THESE RECORDS SHALL BE RETAINED ON FILE FOR A PERIOD OF AT LEAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

Emissions and Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F39939
A/N 386191**

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 5, DIESEL, DETROIT DIESEL ALLISON, MODEL NO. 16V- 149TI, S/N KA-94562, 16 CYLINDER, 1540 B.H.P., TWO CYCLE, TURBOCHARGED, INTERCOOLED, DRIVING AN 1100 KW EMERGENCY ELECTRIC GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN ELAPSED OPERATING TIME METER SHALL BE INSTALLED ON THIS ENGINE, SO AS TO INDICATE, IN CUMULATIVE HOURS, THE AMOUNT OF TIME THE ENGINE HAS OPERATED.
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL BE OPERATED LESS THAN 200 HOURS PER CALENDAR YEAR.
[RULE 1110.2, 1303(a)(1)-BACT, 1304(a)(4)-MODELING AND OFFSET EXEMPTION]
5. THE TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1303(a)(1)-BACT]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED, AT A MINIMUM, ONCE EVERY THREE YEARS. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS SHALL BE PERFORMED BY A QUALIFIED MECHANIC ACCORDING TO THE ENGINE MANUFACTURER'S RECOMMENDED PROCEDURES.
[RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS OF THE OPERATION OF THIS ENGINE TO VERIFY COMPLIANCE WITH CONDITION NOS. 4, 5, AND 6. THESE RECORDS SHALL BE RETAINED ON FILE FOR A PERIOD OF AT LEAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

Emissions and Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No.F69145
A/N 427663

Equipment Description:

LITHOGRAPHIC NEWSPAPER PRINTING SYSTEM "L" GOSS, COLORLINER, AIR DRY, TWELVE UNIT PLUS FOLDER CONSISTING OF:

1. SEVEN GOSS COLORLINER MONO UNITS, BLACK ONLY
2. ONE MANROLAND COLORMAN FOUR-HIGH FOUR-COLOR UNIT
3. FOUR GOSS COLORLINER FOUR-HIGH FOUR-COLOR TOWER UNITS
4. ONE GOSS FOLDER

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE VOLATILE ORGANIC COMPOUND (VOC) CONTENT OF THE FOUNTAIN SOLUTION USED IN THIS EQUIPMENT SHALL NOT EXCEED 0.17 POUNDS OF VOC PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
[RULE 1303(a)(1)-BACT]
4. THE COMPOSITE VAPOR PRESSURE OF THE VOC IN THE BLANKET AND ROLLER WASHES USED ON THIS EQUIPMENT SHALL NOT EXCEED 10 mm Hg AT 20 DEGREES CELSIUS.
[RULE 1303(a)(1)-BACT]
5. IN ADDITION TO THE RECORD KEEPING REQUIREMENTS OF RULE 109, THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS EQUIPMENT TO VERIFY THE FOLLOWING:
 - A. DENSITY OF EACH INK IN POUNDS PER GALLON.
 - B. THE PERCENTAGE BY WEIGHT OF LITHOGRAPHIC OILS IN EACH INK.
 - C. THE INK ABSORPTION FACTOR AS SPECIFIED BY CURRENT DISTRICT GUIDELINES.

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

- D. THE VOC CONTENT OF FOUNTAIN SOLUTIONS, WASH MATERIALS, AND ANY OTHER VOC-CONTAINING MATERIALS IN POUNDS PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
- E. THE DAILY VOC EMISSIONS IN POUNDS.
- F. OTHER DATA AS REQUIRED TO VERIFY COMPLIANCE WITH THE CONDITIONS SPECIFIED IN THIS PERMIT.
[RULE 109, 1303(a)(1)-BACT, 1303(b)(2)-OFFSET]

Emissions and Requirements:

- 6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 109
VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F69147
A/N 427664**

Equipment Description:

LITHOGRAPHIC NEWSPAPER PRINTING SYSTEM "K" GOSS, METROLINER, AIR DRY, TWELVE UNIT PLUS FOLDER CONSISTING OF:

1. FIVE GOSS METROLINER MONO UNITS, BLACK ONLY
2. THREE GOSS METROLINER MONO UNITS WITH HALF DECKS
3. TWO GOSS HEADLINER OFFSET (HO) FOUR-COLOR UNITS
4. TWO GOSS COLORLINER FOUR-HIGH FOUR-COLOR TOWER UNITS
5. ONE GOSS FOLDER

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE VOLATILE ORGANIC COMPOUND (VOC) CONTENT OF THE FOUNTAIN SOLUTION USED IN THIS EQUIPMENT SHALL NOT EXCEED 0.17 POUNDS OF VOC PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
[RULE 1303(a)(1)-BACT]
4. THE COMPOSITE VAPOR PRESSURE OF THE VOC IN THE BLANKET AND ROLLER WASHES USED ON THIS EQUIPMENT SHALL NOT EXCEED 10 mm Hg AT 20 DEGREES CELSIUS.
[RULE 1303(a)(1)-BACT]
5. THE TOTAL QUANTITY OF VOC EMISSIONS FROM THIS EQUIPMENT SHALL NOT EXCEED 175 POUNDS IN ANY ONE DAY.
[RULE 1303(b)(2)-OFFSET]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

6. IN ADDITION TO THE RECORD KEEPING REQUIREMENTS OF RULE 109, THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS EQUIPMENT TO VERIFY THE FOLLOWING:
- A. DENSITY OF EACH INK IN POUNDS PER GALLON.
 - B. THE PERCENTAGE BY WEIGHT OF LITHOGRAPHIC OILS IN EACH INK.
 - C. THE INK ABSORPTION FACTOR AS SPECIFIED BY CURRENT DISTRICT GUIDELINES.
 - D. THE VOC CONTENT OF FOUNTAIN SOLUTIONS, WASH MATERIALS, AND ANY OTHER VOC-CONTAINING MATERIALS IN POUNDS PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
 - E. THE DAILY VOC EMISSIONS IN POUNDS.
 - F. OTHER DATA AS REQUIRED TO VERIFY COMPLIANCE WITH THE CONDITIONS SPECIFIED IN THIS PERMIT.
[RULE 109, 1303(a)(1)-BACT, 1303(b)(2)-OFFSET]

Emissions and Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 109
 - VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No. F69148
A/N 427665

Equipment Description:

LITHOGRAPHIC NEWSPAPER PRINTING SYSTEM "H" GOSS, COLORLINER, AIR DRY, TWELVE UNIT PLUS FOLDER CONSISTING OF:

1. SEVEN GOSS COLORLINER MONO UNITS, BLACK ONLY
2. ONE MANROLAND COLORMAN FOUR-HIGH FOUR-COLOR UNIT
3. FOUR GOSS COLORLINER FOUR-HIGH FOUR-COLOR TOWER UNITS
4. ONE GOSS FOLDER

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE VOLATILE ORGANIC COMPOUND (VOC) CONTENT OF THE FOUNTAIN SOLUTION USED IN THIS EQUIPMENT SHALL NOT EXCEED 0.17 POUNDS OF VOC PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
[RULE 1303(a)(1)-BACT]
4. THE COMPOSITE VAPOR PRESSURE OF THE VOC IN THE BLANKET AND ROLLER WASHES USED ON THIS EQUIPMENT SHALL NOT EXCEED 10 mm Hg AT 20 DEGREES CELSIUS.
[RULE 1303(a)(1)-BACT]
5. IN ADDITION TO THE RECORD KEEPING REQUIREMENTS OF RULE 109, THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS EQUIPMENT TO VERIFY THE FOLLOWING:
 - A. DENSITY OF EACH INK IN POUNDS PER GALLON.
 - B. THE PERCENTAGE BY WEIGHT OF LITHOGRAPHIC OILS IN EACH INK.
 - C. THE INK ABSORPTION FACTOR AS SPECIFIED BY CURRENT DISTRICT GUIDELINES.

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

- D. THE VOC CONTENT OF FOUNTAIN SOLUTIONS, WASH MATERIALS, AND ANY OTHER VOC-CONTAINING MATERIALS IN POUNDS PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
 - E. THE DAILY VOC EMISSIONS IN POUNDS.
 - F. OTHER DATA AS REQUIRED TO VERIFY COMPLIANCE WITH THE CONDITIONS SPECIFIED IN THIS PERMIT.
[RULE 109, 1303(a)(1)-BACT, 1303(b)(2)-OFFSET]
6. MATERIALS USED IN THIS EQUIPMENT SHALL NOT CONTAIN ANY CARCINOGENIC AIR CONTAMINANTS IDENTIFIED IN RULE 1401, TABLE 1, WITH AN EFFECTIVE DATE OF AUGUST 18, 2000 OR EARLIER.
[RULE 1401]

Emissions and Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 109
 - VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No. F69149
A/N 427666

Equipment Description:

LITHOGRAPHIC NEWSPAPER PRINTING SYSTEM "M" GOSS, COLORLINER, AIR DRY, TWELVE UNIT PLUS FOLDER CONSISTING OF:

1. SEVEN GOSS COLORLINER MONO UNITS, BLACK ONLY
2. ONE MANROLAND COLORMAN FOUR-HIGH FOUR-COLOR UNIT
3. FOUR GOSS COLORLINER FOUR-HIGH FOUR-COLOR TOWER UNITS
4. ONE GOSS FOLDER

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE VOLATILE ORGANIC COMPOUND (VOC) CONTENT OF THE FOUNTAIN SOLUTION USED IN THIS EQUIPMENT SHALL NOT EXCEED 0.17 POUNDS OF VOC PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
[RULE 1303(a)(1)-BACT]
4. THE COMPOSITE VAPOR PRESSURE OF THE VOC IN THE BLANKET AND ROLLER WASHES USED ON THIS EQUIPMENT SHALL NOT EXCEED 10 mm Hg AT 20 DEGREES CELSIUS.
[RULE 1303(a)(1)-BACT]
5. IN ADDITION TO THE RECORD KEEPING REQUIREMENTS OF RULE 109, THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS EQUIPMENT TO VERIFY THE FOLLOWING:
 - A. DENSITY OF EACH INK IN POUNDS PER GALLON.
 - B. THE PERCENTAGE BY WEIGHT OF LITHOGRAPHIC OILS IN EACH INK.
 - C. THE INK ABSORPTION FACTOR AS SPECIFIED BY CURRENT DISTRICT GUIDELINES.

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

- D. THE VOC CONTENT OF FOUNTAIN SOLUTIONS, WASH MATERIALS, AND ANY OTHER VOC-CONTAINING MATERIALS IN POUNDS PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
- E. THE DAILY VOC EMISSIONS IN POUNDS.
- F. OTHER DATA AS REQUIRED TO VERIFY COMPLIANCE WITH THE CONDITIONS SPECIFIED IN THIS PERMIT.
[RULE 109, 1303(a)(1)-BACT, 1303(b)(2)-OFFSET]

Emissions and Requirements:

- 6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
 - VOC: RULE 109
 - VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

**Permit No. F69150
A/N 427667**

Equipment Description:

LITHOGRAPHIC NEWSPAPER PRINTING SYSTEM "J" GOSS, COLORLINER, AIR DRY, TWELVE UNIT PLUS FOLDER CONSISTING OF:

1. SEVEN GOSS COLORLINER MONO UNITS, BLACK ONLY
2. ONE MANROLAND COLORMAN FOUR-HIGH FOUR-COLOR UNIT
3. FOUR GOSS COLORLINER FOUR-HIGH FOUR-COLOR TOWER UNITS
4. ONE GOSS FOLDER

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE VOLATILE ORGANIC COMPOUND (VOC) CONTENT OF THE FOUNTAIN SOLUTION USED IN THIS EQUIPMENT SHALL NOT EXCEED 0.17 POUNDS OF VOC PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
[RULE 1303(a)(1)-BACT]
4. THE COMPOSITE VAPOR PRESSURE OF THE VOC IN THE BLANKET AND ROLLER WASHES USED ON THIS EQUIPMENT SHALL NOT EXCEED 10 mm Hg AT 20 DEGREES CELSIUS.
[RULE 1303(a)(1)-BACT]
5. IN ADDITION TO THE RECORD KEEPING REQUIREMENTS OF RULE 109, THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS EQUIPMENT TO VERIFY THE FOLLOWING:
 - A. DENSITY OF EACH INK IN POUNDS PER GALLON.
 - B. THE PERCENTAGE BY WEIGHT OF LITHOGRAPHIC OILS IN EACH INK.
 - C. THE INK ABSORPTION FACTOR AS SPECIFIED BY CURRENT DISTRICT GUIDELINES.

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

- D. THE VOC CONTENT OF FOUNTAIN SOLUTIONS, WASH MATERIALS, AND ANY OTHER VOC-CONTAINING MATERIALS IN POUNDS PER GALLON AS APPLIED, INCLUDING WATER AND EXEMPT COMPOUNDS.
 - E. THE DAILY VOC EMISSIONS IN POUNDS.
 - F. OTHER DATA AS REQUIRED TO VERIFY COMPLIANCE WITH THE CONDITIONS SPECIFIED IN THIS PERMIT.
[RULE 109, 1303(a)(1)-BACT, 1303(b)(2)-OFFSET]
6. MATERIALS USED IN THIS EQUIPMENT SHALL NOT CONTAIN ANY CARCINOGENIC AIR CONTAMINANTS IDENTIFIED IN RULE 1401, TABLE 1, WITH AN EFFECTIVE DATE OF AUGUST 18, 2000 OR EARLIER.
[RULE 1401]

Emissions and Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 109
 - VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No. F88725
A/N 465960

GROUNDWATER TREATMENT SYSTEM CONSISTING OF:

1. GROUNDWATER RECOVERY WELLS.
2. PRODUCT STORAGE TANK, FIXED ROOF TYPE, 3'-0" W. X 4'-0" L. X 3'-0" H., 200 GALLON CAPACITY.
3. LIQUID PHASE CARBON ADSORPTION SYSTEM, US FILTER/WESTATES, MODEL NO. PV-50, WITH TWO 4'-0" DIA. X 8'-0" H. CARBON CANISTERS (IN SERIES), EACH CONTAINING 1500 POUNDS ACTIVATED CARBON.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN IDENTIFICATION TAG OR NAMEPLATE SHALL BE ATTACHED TO THE EQUIPMENT, AND THE TAG OR NAMEPLATE SHALL IDENTIFY THE EQUIPMENT MANUFACTURER, THE MODEL NUMBER, AND THE SERIAL NUMBER. THE TAG OR NAMEPLATE SHALL BE ISSUED BY THE MANUFACTURER, AND IT SHALL BE ATTACHED TO THE EQUIPMENT IN A PERMANENT AND CONSPICUOUS POSITION.
[RULE 204]
4. UPON COMPLETION, ANY EXTRACTION WELLS AND DUCTS SHALL BE CAPPED TO PREVENT VAPORS FROM VENTING TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT]
5. THIS EQUIPMENT SHALL ONLY BE USED TO EXTRACT AND TREAT GROUNDWATER CONTAMINATED WITH GASOLINE.
[RULE 1303(a)(1)-BACT]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No.
A/N 477157

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 1, DIESEL, DETROIT DIESEL ALLISON, MODEL NO. 16V-149TIB, S/N 3250-B-90, 16 CYLINDER, 2340 B.H.P., TWO CYCLE, TURBOCHARGED, AFTERCOOLED, DRIVING A 1600 KW EMERGENCY ELECTRIC GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303(a)(1)-BACT]
4. THE OPERATOR SHALL NOT PURCHASE OR USE DIESEL FUEL WITH A SULFUR CONTENT THAT EXCEEDS 15 PPM BY WEIGHT.
[RULE 431.2]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 1 HOUR IN ANY ONE DAY FOR TESTING.
[RULE 1303(a)(1)-BACT]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE CALENDAR YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS PER CALENDAR YEAR FOR MAINTENANCE AND TESTING AS REQUIRED IN RULE 1470(c)(3).
[RULE 1470]
7. OPERATION BEYOND THE ALLOTTED TIME FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

8. THIS ENGINE SHALL NOT BE USED AS PART OF AN INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ELECTRIC LOAD ON THE GRID WHEN REQUESTED BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1303(a)(1)-BACT]

9. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. BY JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL TOTAL AND RECORD THE TOTAL HOURS OF OPERATION (INCLUDING HOURS FOR BOTH MANUAL OPERATION AND AUTOMATIC OPERATION) FOR THE PREVIOUS CALENDAR YEAR.
[RULE 1303(a)(1)-BACT]

10. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]

Emissions and Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

PERMIT TO OPERATE

Permit No.
A/N 477158

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 2, DIESEL, DETROIT DIESEL ALLISON, MODEL NO. 16V-149TIB, S/N 3249-B-90, 16 CYLINDER, 2340 B.H.P., TWO CYCLE, TURBOCHARGED, AFTERCOOLED, DRIVING A 1600 KW EMERGENCY ELECTRIC GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1303(a)(1)-BACT]
4. THE OPERATOR SHALL NOT PURCHASE OR USE DIESEL FUEL WITH A SULFUR CONTENT THAT EXCEEDS 15 PPM BY WEIGHT.
[RULE 431.2]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 1 HOUR IN ANY ONE DAY FOR TESTING.
[RULE 1303(a)(1)-BACT]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE CALENDAR YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS PER CALENDAR YEAR FOR MAINTENANCE AND TESTING AS REQUIRED IN RULE 1470(c)(3).
[RULE 1470]
7. OPERATION BEYOND THE ALLOTTED TIME FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

8. THIS ENGINE SHALL NOT BE USED AS PART OF AN INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ELECTRIC LOAD ON THE GRID WHEN REQUESTED BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1303(a)(1)-BACT]

9. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. BY JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL TOTAL AND RECORD THE TOTAL HOURS OF OPERATION (INCLUDING HOURS FOR BOTH MANUAL OPERATION AND AUTOMATIC OPERATION) FOR THE PREVIOUS CALENDAR YEAR.
[RULE 1303(a)(1)-BACT]

10. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]

Emissions and Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

**FACILITY PERMIT TO OPERATE
LOS ANGELES TIMES COMMUNICATIONS LLC**

PERMIT TO CONSTRUCT

NONE

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.
FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.
[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CR⁺⁶: RULE 1404

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EQUIPMENT, CLEANING EQUIPMENT, SMALL UNHEATED, NON-CONVEYORIZED

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1122

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EQUIPMENT, FIRE EXTINGUISHING EQUIPMENT

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1418

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:	RULE 1415
REFRIGERANT:	40CFR 82 SUBART F

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, PRINTING EQUIPMENT, LOW USE OR EMISSIONS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 109

VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES TIMES COMMUNICATIONS LLC

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 400,000 BTU/HR BUT < 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407