

FACILITY PERMIT TO OPERATE EQUILON ENTERPRISES, LLC, SHELL OIL PRODUCTS

PERMIT TO CONSTRUCT/OPERATE

Permit no. TBD
A/N 509123

Equipment Description:

ALTERATION TO STORAGE TANK NO. 13, 54'-6" DIA. X 48' -1" H., 20,000 BBL. CAPACITY, WELDED SHELL, PONTOON EXTERNAL FLOATING ROOF WITH A SHOE TYPE PRIMARY SEAL AND A SECONDARY SEAL BY:

THE INSTALLATION OF A GEODESIC DOME

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD 01OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THIS TANK SHALL NOT BE USED FOR STORING ORGANIC LIQUID HAVING A VAPOR PRESSURE OF 569 MM HG (11 PSIA) OR GREATER UNDER ACTUAL STORAGE CONDITIONS.
[RULE 463]
- 4) THIS TANK SHALL NOT BE USED FOR STORING PURE ORGANIC COMPOUNDS.
[RULE 204]
- 5) UPON COMPLETION OF THE INSTALLATION OF THE GEODESIC DOME, THROUGHPUT OF MATERIALS IN THIS TANK SHALL NOT EXCEED 250,000 BARRELS IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2) OFFSETS]
- 6) THE OPERATOR SHALL IN ADDITION TO THOSE RECORDS REQUIRED BY RULE 463, KEEP RECORDS OF MATERIALS STORED, VAPOR PRESSURE, AND THROUGHPUT. SUCH RECORDS SHALL BE MAINTAINED FOR A FIVE YEAR PERIOD AND BE MADE AVAILABLE FOR INSPECTION BY DISTRICT PERSONNEL UPON REQUEST.
[RULE 463; RULE 1303(b)(2) OFFSETS]
- 7) THIS PERMIT TO CONSTRUCT SHALL EXPIRE ONE YEAR FROM THE DATE OF ISSUANCE UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.
[RULE 205]

FACILITY PERMIT TO OPERATE EQUILON ENTERPRISES, LLC, SHELL OIL PRODUCTS

Periodic Monitoring: None

Emissions and Requirements:

8) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 463
VOC: RULE 1149

**FACILITY PERMIT TO OPERATE
EQUILON ENTERPRISES, LLC, SHELL OIL PRODUCTS**

PERMIT TO CONSTRUCT/OPERATE

**Permit no. TBD
A/N 515267**

Equipment Description:

ALTERATION TO STORAGE TANK NO. 14, 54' -6" DIA. X 48'-1" H., 20,000 BBL. CAPACITY, WELDED SHELL, PONTOON EXTERNAL FLOATING ROOF WITH A SHOE TYPE PRIMARY SEAL AND A SECONDARY SEAL BY:

THE INSTALLATION OF A GEODESIC DOME

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THIS TANK SHALL NOT BE USED FOR STORING ORGANIC LIQUID HAVING A VAPOR PRESSURE OF 569 MM HG (11 PSIA) OR GREATER UNDER ACTUAL STORAGE CONDITIONS.
[RULE 463]
- 4) THIS TANK SHALL NOT BE USED FOR STORING PURE ORGANIC COMPOUNDS.
[RULE 204]
- 5) UPON COMPLETION OF THE INSTALLATION OF THE GEODESIC DOME, THROUGHPUT OF MATERIALS IN THIS TANK SHALL NOT EXCEED 250,000 BARRELS IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2) OFFSETS]
- 6) THE OPERATOR SHALL IN ADDITION TO THOSE RECORDS REQUIRED BY RULE 463, KEEP RECORDS OF MATERIALS STORED, VAPOR PRESSURE, AND THROUGHPUT. SUCH RECORDS SHALL BE MAINTAINED FOR A FIVE YEAR PERIOD AND BE MADE AVAILABLE FOR INSPECTION BY DISTRICT PERSONNEL UPON REQUEST.
[RULE 463; RULE 1303(b)(2) OFFSETS]
- 7) THIS PERMIT TO CONSTRUCT SHALL EXPIRE ONE YEAR FROM THE DATE OF ISSUANCE UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.
[RULE 205]

Periodic Monitoring: None

FACILITY PERMIT TO OPERATE EQUILON ENTERPRISES, LLC, SHELL OIL PRODUCTS

Emissions and Requirements:

- 8) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 463
VOC: RULE 1149

DRAFT