


LINDA LINGLE  
GOVERNOR OF HAWAII



CHIYOME L. FUKINO, M.D.  
DIRECTOR OF HEALTH

STATE OF HAWAII  
DEPARTMENT OF HEALTH  
P.O. Box 3378  
HONOLULU, HAWAII 96801-3378

In reply, please refer to:  
File:

July 21, 2010

Mr. Charles K.H. Young  
Plant Manager  
Mauna Loa Macadamia Nut Corporation,  
a subsidiary of The Hershey Company  
16-701 Macadamia Road  
Keaau, Hawaii 96749-8020

10-531E CAB  
File No. 0317

Dear Mr. Young:

**Subject: Covered Source Permit (CSP) No. 0317-02-C  
Permit Application for Modification No. 0317-05  
Mauna Loa Macadamia Nut Corporation  
Biomass/Oil Fired Boilers and Diesel Engine Generators  
Located at: 16-701 Macadamia Road, Keaau, Hawaii**

Please find enclosed the subject covered source permit that was recently approved by the Department of Health subsequent to the 30-day public comment period and the 45-day review period by the U.S. Environmental Protection Agency. For your information, the Department added the following reporting table to the **Monitoring Report Form: Diesel Engine Generators**:

2. Report the maximum % aromatic content or minimum cetane index for the fuel fired by the diesel engine generators for the reporting period.

FUEL OIL NO. 2 CONSUMPTION			
Diesel Engine Generator Unit	Capacity (kW)	Maximum % Aromatic Content	Minimum Cetane Index
Caterpillar unit no. 4101	300		
Caterpillar unit no. 4102	300		

If there are any questions regarding this matter, please contact Mr. Mike Madsen of my staff at (808) 586-4200.

Sincerely,

WILFRED K. NAGAMINE  
Manager, Clean Air Branch

MM:smk  
Enclosure

c: EPA Region 9  
Ed Yamamoto, EHS - Hilo  
CAB Monitoring Section