



SOUTH COAST AIR QUALITY MANAGEMENT	Pages 2	Page 1
<i>ENGINEERING AND COMPLIANCE DIVISION</i> <i>Waste Management & Bulk Terminal Permitting</i>	A/N 531880	Date 03/09/12
EXXONMOBIL ATWOOD TERMINAL RULE 462 CMS PLAN MODIFICATION	Processed by Ed O'Neal	Checked by EDT

EVALUATION FOR RULE 462 CONTINUOUS
MONITORING SYSTEM (CMS) PLAN

COMPANY NAME AND ADDRESS

ExxonMobil Oil Corporation
1477 N. Jefferson Street
Anaheim, CA 92807

Facility ID# 800091

BACKGROUND

This is a Title V facility which is a truck loading terminal and storage tank facility which stores refinery products. The Title V Revision application is 531885, and will be processed as a "minor permit revision" pursuant to Regulation XXX.

Exxon Mobil Vernon Terminal submitted an application to modify their Rule 1162 Plan.

This is a Class "A" Facility under District Rule 462. As such, the facility is required to equip its vapor recovery/control system with a Continuous Monitoring System (CMS) that is approved by the District. A Rule 462 CMS Plan has been approved for the Atwood Terminal under A/N 424144. The CMS is required, under 462(f)(2) to be in compliance with Code of Federal Regulations Title 40 Part 63 Subpart R Section 63.427 and Code of Federal Regulations Title 40 Part 60 Appendix B, as applicable. ExxonMobil proposes to modify the Plan by installation of a "card" type DX1000 series recorder to replace the "floppy" type DX100 series recorder.

There have been no NOV's or NC's issued for this facility within the last 2 years.

DISCUSSION

The new recorder is functionally identical to the one being replaced, but records data on a "card". The plan description will be updated to reflect this change, but plan conditions will not change.

EMISSIONS CALCULATION

Not applicable.



SOUTH COAST AIR QUALITY MANAGEMENT	Pages 2	Page 2
<i>ENGINEERING AND COMPLIANCE DIVISION</i> <i>Waste Management & Bulk Terminal Permitting</i>	A/N 531880	Date 03/09/12
EXXONMOBIL ATWOOD TERMINAL RULE 462 CMS PLAN MODIFICATION	Processed by Ed O'Neal	Checked by

RECOMMENDATIONS

Issue the Rule 462 continuous monitoring system (CMS) plan with a modified permit description and the conditions on current plan.