

FACILITY PERMIT TO OPERATE SFPP, L.P.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 3: SUMPS AND OIL/WATER SEPARATION					
System 1: SUMPS					
SUMP, SPILL TANK, UNDERGROUND, 10000 GALS; DIAMTER: 9 FT 5 IN; HEIGHT: 20 FT 5 IN, LOCATED AT RACK 4 A/N 334958 561284	D55				C1.13, K67.5 K67.XX
PUMP, SUBMERSIBLE, 2 HP A/N 561284	D__				

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 3: SUMPS AND OIL/WATER SEPARATION					
System 2: OIL/WATER SEPARATOR					
OIL WATER SEPARATOR, FIXED ROOF, ENQUIP, IN-GROUND TANK, MODEL M-10-32, DOUBLE WALL, LENGTH: 23 FT; DIAMETER: 8 FT A/N 497136-558802	D53				E448.2, E448.6, H23.9 C1.X K67.XX
PUMP, RECOVERED OIL, 5 HP MOTOR A/N 497136 558802	D54				H23.1
FILTER, WATER, F-101A & F101B, 2 TOTAL A/N 558802	D__				
TANK, SURGE, T-101A, WATER, 10000 GAL; DIAMTER: 11 FT 11 IN; HEIGHT: 14 FT 6 IN A/N 558802	D__				

- * (1) (1A) (1B) Denotes RECLAIM emission factor
 (3) Denotes RECLAIM concentration limit
 (5) (5A) (5B) Denotes command and control emission limit
 (7) Denotes NSR applicability limit
 (9) See App B for Emission Limits
- (2) (2A) (2B) Denotes RECLAIM emission rate
 (4) Denotes BACT emission limit
 (6) Denotes air toxic control rule limit
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (10) See section J for NESHAP/MACT requirements
- ** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE SFPP, L.P.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

TANK, SURGE, T-101B, WATER, 10000 GAL; DIAMETER: 11 FT 11 IN; HEIGHT: 14 FT 6 IN A/N 558802	D __				
PUMP, WATER FEED, P101, 10 HP A/N 558802	D __				
VESSEL, LPC-101A, ACTIVATED LIQUID PHASE CARBON; DIAMETER: 4FT; HEIGHT: 8 FT 9 IN A/N 558802	D __?				
VESSEL, LPC-101B, ACTIVATED LIQUID PHASE CARBON; DIAMETER: 4FT; HEIGHT: 8 FT 9 IN A/N 558802	D __				
VESSEL, LPC-101C, ACTIVATED LIQUID PHASE CARBON; DIAMETER: 4FT; HEIGHT: 8 FT 9 IN A/N 558802	D __				

- * (1) (1A) (1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5) (5A) (5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2) (2A) (2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See section J for NESHAP/MACT requirements
- ** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE SFPP, L.C.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.13 The operator shall limit the throughput to no more than 25,000 gallon(s) per year

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition: D55]

C1.X The operator shall limit the throughput to no more than 177,000 gallon(s) per month.

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition: D53]

~~E448.2 The operator shall comply with the following requirements:~~

~~—— The operator shall install a turbidity meter or hydrocarbon sensor in the water discharge line. The turbidity meter or hydrocarbon sensor shall be operated and monitored to prevent hydrocarbons from being discharged to the water evaporation tank.~~

~~—— [RULE 1303(a)(1)-BACT, 5-10-1996]~~

~~—— [Devices subject to this condition: D53]~~

E448.6 The operator shall comply with the following requirements:

All openings from this equipment to the atmosphere shall be sealed and totally enclosing the liquid contents

[RULE 464, 12-7-1990]

[Devices subject to this condition: D53, D317]

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

**FACILITY PERMIT TO OPERATE
SFPP, L.C.**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

<u>Contaminant</u>	<u>Rule</u>	<u>Rule/Subpart</u>
VOC	District Rule	466
VOC	District Rule	466.1

[RULE 466, 10-7-1983, RULE 466.1, 5-2-1980, RULE 466.1, 3-16-1984]

[Devices subject to this condition: D2, D4, D5, D6, D7, D47, D54, D56, D60, D61, D287, D288, D289, D290, D291, D292, D296, D297, D298, D299, D300, D305]

H23.9 This equipment is subject to the applicable requirements of the following rules or regulations:

<u>Contaminant</u>	<u>Rule</u>	<u>Rule/Subpart</u>
VOC	District Rule	464

[RULE 464, 12-7-1990]

[Devices subject to this condition: D53]

K67.XX The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Throughput

[RULE 1303(b)(2)-Offset, 5-10-1996, RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition: D53, D55]

FACILITY PERMIT TO OPERATE SFPP, L.C.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.5 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Throughput and true vapor pressure under actual storage conditions

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition: D19, D27, D36, D44, D48, D50, D51, D52, D55]