



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 1, 2011

Mr. Gerardo Rios
U.S. EPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105

SUBJECT: Transmittal of Proposed Title V Renewal Permit
LA County USC Medical Center
1200 N. STATE STREET
Los Angeles, CA 90033
Facility ID 20197

Dear Mr. Rios:

Enclosed is the above-referenced proposed renewal of a Title V permit along with the facility permit application, a Statement of Basis and public notice. With your receipt of this proposed Title V permit, we will note that the EPA 45-day review period has begun.

Questions on the proposed permit should be directed to Mr. Chris Perri, Air Quality Engineer, at (909) 396-2696 or cperri@aqmd.gov.

Sincerely,


A handwritten signature in black ink, appearing to read 'Brian L. Yeh', is written over a diagonal line.

Brian L. Yeh.
Senior Manager
Mechanical, Chemical, and Public Services Team
Engineering and Compliance

MN:BLY:AYL:JTY:CGP

Enclosures:

Facility Permit (Proposed Renewal)
Public Notice
Statement of Basis
Facility Permit Application



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

NOTICE OF PROPOSED RENEWAL TITLE V PERMIT

The South Coast Air Quality Management District (AQMD) is proposing to renew the existing Title V permit previously issued to the facility listed below:

Facility Locations and Contact People

LA COUNTY USC MEDICAL CENTER
1200 N. State Street
Los Angeles, CA 90033
Facility ID 20197

Contact Person:

Luis Fonseca
Director of Facilities Management
1200 N. State Street
Los Angeles, CA 90033

The facility operates 10 steam boilers, 26 emergency diesel generators, ethylene oxide sterilization equipment and a gasoline dispensing unit used in the operation of the hospital.

Pursuant to Title V of the federal Clean Air Act and the AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, this facility has submitted a Title V renewal application and requested the AQMD to renew their Title V permits. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to this facility.

The proposed permit is available for public review at the AQMD, 21865 Copley Dr., Diamond Bar, CA, and at the Lincoln Heights Branch Library,

2530 Workman Street, Los Angeles, CA 90031. Information regarding the facility owner's compliance history submitted to the AQMD pursuant to California Health & Safety Code Section 42336, or otherwise known to the AQMD based on credible information, is also available from the AQMD for public review. For more information or to review additional supporting documents, call the AQMD's Title V hotline at (909) 396-3013. Written comments should be submitted to Mr. Chris Perri, Air Quality Engineer, 21865 Copley Drive, Diamond Bar, CA 91765-4178. Comments must be received by October 8, 2011. The AQMD will consider all public comments and may revise the Title V permit in accordance with AQMD rules and regulations.

The public may request the AQMD to conduct a public hearing on the proposed permit by submitting a Hearing Request Form (Form 500-G) to Chris Perri at the above AQMD address. The AQMD will hold a public hearing if there is evidence that the proposed permit is not correct or is not adequate to ensure compliance with regulatory requirements, and a hearing will likely provide additional information that will affect the drafting and/or issuance of the permit. Public hearing request forms and the schedule of public hearings may be obtained from the AQMD by calling the Title V hotline at (909) 396-3013, or from the Internet at <http://www.aqmd.gov/titlev>. Requests for public hearings are due by September 23, 2011. A copy of the hearing request must also be sent by first class mail to the appropriate facility contact person listed above.

South Coast Air Quality Management District

Statement of Basis

Proposed Title V Renewal Permit

Facility Name:	LA County USC Medical Center
Facility ID:	20197
SIC Code:	8060
Equipment Location:	1200 N. State St Los Angeles, CA 90033
Application #(s):	522467
Application Submittal Date(s):	05/11/11
AQMD Contact Person:	Chris Perri, Air Quality Engineer
Phone Number:	(909) 396-2696
E-Mail Address:	cperri@aqmd.gov

1. Introduction and Scope of Permit

Title V is a national operating permit program for air pollution sources. Facilities subject to Title V must obtain a Title V permit and comply with specific Title V procedures to modify the permit. This permit replaces the facility's other existing permits. Title V does not necessarily include any new requirements for reducing emissions. It does, however, include new permitting, noticing, record keeping, and reporting requirements.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years after the date of issuance, unless such permit has been renewed. Accordingly, each facility is required to submit a Title V renewal application and request that the AQMD renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The AQMD implements Title V through Regulation XXX – Title V Permits, adopted by the AQMD Governing Board in order to comply with EPA's requirement that local air permitting authorities develop a Title V program. Regulation XXX was developed with the participation of the public and affected facilities through a series of public workshops, working group meetings, public hearings and other meetings.

The Title V major source threshold for a particular pollutant depends on the attainment status of the pollutant. NO₂, SO₂, CO, and lead are in attainment with federal standards. The status for

PM-10 is serious nonattainment. The status for ozone is currently extreme nonattainment. For the South Coast Air Basin (SOCAB) the threshold levels are as follows:

Pollutant	SOCAB Major Source Thresholds
VOC	10
NOx	10
SOx	100
CO	50
PM-10	70
Single HAP	10
Combination of HAPS	25

A Title V permit is proposed to be issued to cover the operations of the LA County/USC Medical Center, located at 1200 N. State St in Los Angeles. This facility is subject to Title V requirements because it is a major source of one of more criteria pollutants.

2. Facility Description

This is an existing hospital and medical care services facility. The facility operates 10 boilers to provide heating and cooling for the buildings, 26 emergency back up diesel generators, ethylene oxide sterilizing equipment, and a small fuel dispensing unit. All the boilers are natural gas-fired (with oil back-up). Six of the units are equipped with Low NOx burners which achieve a 9 ppm NOx level. The two largest units are scheduled to meet a 5 ppm NOx limit by 2013 in accordance with Rule 1146. The facility has an approved Rule 1146 plan (A/N 505047). The diesel generators are of various sizes. The facility has an approved Rule 1470 plan for the engines (A/N516410).

3. Construction and Permitting History

The USC Medical Center has been in Southern California for over 100 years. The facility has had permits from AQMD since the early 1970's. As the facility has grown, it's added heating and cooling capacity in the form of boilers, and emergency backup power in the form of diesel generators. The initial Title V permit was issued on 3/26/01. It was renewed on 10/26/06. Since the last permit renewal, there have been 3 permit revisions. Two minor revisions - one to add an emergency generator, and one to upgrade their gasoline dispensing nozzles to Phase II, and one administrative revision to issue final Permits to Operate for 4 boilers.

4. Regulatory Applicability Determinations

Applicable legal requirements for this facility are required to be identified in the Title V permit (for example, Section D, E, and H of the proposed Title V permit). Applicability determinations (i.e., determinations made by the District with respect to what legal requirements apply to a specific piece of equipment, process, or operation) can be found in the Engineering Evaluations.

The following summarizes the key rules that apply to the major equipment at this site:

Boilers

- 401 – Visible Emissions
- 402 – Nuisance
- 407 – Liquid and Gaseous Air Contaminants (CO and SO_x)
- 409 – Combustion Contaminants (PM)
- 431.1 – Sulfur Content of Gaseous Fuel (SO_x)
- 1146 – NO_x from Boilers

Emergency Engines

- 401 – Visible Emissions
- 402 - Nuisance
- 404 – Particulate Matter
- 431.2 – Sulfur Content of Liquid Fuels
- Rule 1470 – Air Toxic Control Measure

Fuel Dispensing

- 461 – Gasoline Dispensing

Sterilizers

- 1405 – Control of Ethylene Oxide from Sterilizers

The facility is not a major source of HAPs and therefore is not subject to any MACT standards. There are no area source MACT standards which apply to this facility. Compliance Assurance Monitoring (CAM) requirements of 40 CFR Part 64 do not apply to any of the equipment at this site.

The permit terms and conditions may be found in Section D of the Title V permit.

5. Monitoring and Operational Requirements

Applicable monitoring and operational requirements for which the facility is required to comply are identified in the Title V permit (for example, Section D, F, and J, and Appendix B). Discussion of any applicable monitoring and operational requirements can be found in the Engineering Evaluations. All periodic monitoring requirements were developed using strict adherence to the following applicable guidance documents: SCAQMD Periodic Monitoring Guidelines for Title V Facilities (November 1997), CAPCOA/CARB/EPA region IX Periodic Monitoring Recommendations for Generally Applicable Requirements in SIP (June 1999), and CAPCOA/CARB/EPA Region IX Recommended Periodic Monitoring for Generally Applicable Grain Loading Standards in the SIP: Combustion Sources (July 2001).

Under Rule 1146, a stack test for NO_x and CO on the boilers is required once every 5 years, and periodic testing with portable analyzers is required every 2000 operating hours. The gasoline dispensing facility is required to be inspected on a semi-annual basis.

Discussion of any applicable monitoring and operational requirements can be found in the Engineering Evaluations.

6. Permit Features

Permit Shield

A permit shield is an optional part of a Title V permit that gives the facility explicit protection from requirements that may be incorrectly specified in the permit. A permit shield is a provision in a permit that states that compliance with the conditions contained in the permit shall be deemed compliance with all identified regulatory requirements. To incorporate a permit shield into the Title V permit involves submission of applications for change of conditions for each equipment affected by the permit shield. Permit shields are addressed in Rule 3004 (c). This facility has not applied for a permit shield.

Streamlining Requirements

Some emission units may be subject to multiple requirements which are closely related or redundant. The conditions may be streamlined to simplify the permit conditions and compliance. Emission limits, work practice standards, and monitoring, recordkeeping, and reporting requirements may be streamlined. Compliance with a streamlined condition will be deemed compliance with the underlying requirements whether or not the emission unit is actually in compliance with the specific underlying requirement. This facility has not applied for any streamlined conditions.

7. Summary of Emissions and Health Risks

**Criteria Pollutant Emissions (tons/year)
Annual Reported Emissions for Reporting Period 2010**

Pollutant	Emissions (tons/year)
NOx	5.578
CO	11.816
VOC	6.784
PM	4.322
SOx	0.135

**Toxic Air Contaminants Emissions (TAC)
Annual Reported Emissions for Reporting Period 2010**

The Following TACs Were Reported	Emissions (lbs/yr)
1,3 Butadiene	0.702
Ammonia	1330
Benzene	2.996
Formaldehyde	10.653
Cadmium	0.004
Lead	0.026

Naphthalene	0.187
Nickel	0.012
Polynuclear aromatic hydrocarbons (PAHs)	0.158

Health Risk from Toxic Air Contaminants

The facility is subject to review by the Air Toxics Information and Assessment Act (AB2588). The final Facility Health Risk was approved in 2007 with the following risk factors:

Cancer Risk	7.5 in one million
Cancer Burden	0.031
Acute Hazard Index	0.70
Chronic Hazard Index	0.38

8. Compliance History

As noted, the facility has been in constant operation for over 100 years. The facility has been subject to both self-reporting requirements and AQMD inspections. The facility has had 0 citizen complaints filed, 0 Notices to Comply issued, and 0 Notices of Violation issued in the last two calendar years.

9. Compliance Certification

By virtue of the Title V permit application and renewal of this permit, the reporting frequency for compliance certification for the facility shall be annual.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT Title V Permit Summary

AQMD Facility ID: 20197	Company Name: LA COUNTY USC MEDICAL CENTER		
Equipment Location: 1200 N STATE ST, LOS ANGELES, CALIFORNIA 90033	SIC Code: 8060		
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected:	
Application #(s): 522467	Application Submittal Date(s): 05/10/11		
AQMD Contact Person: CHRIS PERRI	Phone #: (909) 396- 2696	E-Mail Address: cperri@aqmd.gov	
Project Description: This is an existing facility applying for a renewal to their Title V permit. The facility is a hospital providing medical care services. This facility operates 10 natural gas fired boilers, 26 emergency diesel generators, a fuel dispensing unit, and ethylene oxide sterilizing equipment.			
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal			
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance			
Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for Reporting Year: 2010	<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> The Following TACs Were Reported:		<u>Emissions (lbs/yr):</u> AMMONIA 1330 BENZENE 2.996 FORMALDEHYDE 10.653 NAPHTHALENE 0.187 PAH 0.158 1,3 BUTADIENE 0.702 CADMIUM 0.004 LEAD 0.026 NICKEL 0.012
Health Risk From Toxic Air Contaminants:	<input type="checkbox"/> Health Risk Reduction Plan in Force (AQMD Rule 1402) (date): _____ <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input checked="" type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input checked="" type="checkbox"/> Final Facility Health Risk Approved _____ 2000 Cancer Risk = <u>7.5 in a million</u> Acute Hazard Index = <u>0.70</u> Chronic Hazard Index = <u>0.38</u>		
Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2010	<input checked="" type="checkbox"/> NOx 5.578 <input checked="" type="checkbox"/> CO 11.816 <input checked="" type="checkbox"/> VOC 6.674	<input checked="" type="checkbox"/> PM 4.322 <input checked="" type="checkbox"/> SOx 0.135 <input type="checkbox"/> Other: _____	
Compliance History: <input checked="" type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years (0) <input checked="" type="checkbox"/> Notices to Comply Issued in Last Two Calendar Years (0) <input checked="" type="checkbox"/> Notices of Violation Issued in Last Two Calendar Years (0)			
Comments: None			

FACILITY PERMIT TO OPERATE

**LAC/USC MEDICAL CENTER
1200 N STATE ST
LOS ANGELES, CA 90033**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By _____
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	07/12/2011
B	RECLAIM Annual Emission Allocation	DRAFT	07/12/2011
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	07/12/2011
E	Administrative Conditions	DRAFT	07/12/2011
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	07/12/2011
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	07/12/2011
H	Permit To Construct and Temporary Permit to Operate	DRAFT	07/12/2011
I	Compliance Plans & Schedules	DRAFT	07/12/2011
J	Air Toxics	DRAFT	07/12/2011
K	Title V Administration	DRAFT	07/12/2011
 Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	07/12/2011
B	Rule Emission Limits	DRAFT	07/12/2011

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: LAC/USC MEDICAL CENTER

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 1200 N STATE ST
LOS ANGELES, CA 90033-1029

MAILING ADDRESS: 1200 N STATE ST RM 128 PLT MGT MAINT
LOS ANGELES, CA 90033

RESPONSIBLE OFFICIAL: PETE DELGADO

TITLE: CHIEF EXECUTIVE OFFICER

TELEPHONE NUMBER: (323) 226-2800

CONTACT PERSON: JOSE MENDOZA

TITLE: CHIEF ENGINEER

TELEPHONE NUMBER: (323) 226-3034

TITLE V PERMIT ISSUED: October 26, 2006

TITLE V PERMIT EXPIRATION DATE: October 25, 2011

TITLE V	RECLAIM
YES	NOx: NO SOx: NO CYCLE: 0 ZONE: COASTAL

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

NOT APPLICABLE

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit to Operate number	Equipment description
443478	N17156	FUEL STORAGE AND DISPENSING
199974	F5725	I C E (50-500 HP) EM ELEC GEN-DIESEL
224034	D93523	BOILER (>50 MMBTU/HR) COMB GAS-RESID
224035	D93522	BOILER (>50 MMBTU/HR) COMB GAS-DISTILL
224036	D93521	BOILER (>50 MMBTU/HR) COMB GAS-DISTILL
226649	D25143	I C E (50-500 HP) EM ELEC GEN-DIESEL
244309	D41378	I C E (50-500 HP) EM ELEC GEN-DIESEL
244310	D38299	I C E (50-500 HP) EM ELEC GEN-DIESEL
244312	D41380	I C E (50-500 HP) EM ELEC GEN-DIESEL
244317	D41145	I C E (50-500 HP) EM ELEC GEN-NAT GAS
244318	D41385	I C E (50-500 HP) N-EM STAT DIESEL
244319	D41386	I C E (50-500 HP) EM ELEC GEN-DIESEL
244320	D41387	I C E (50-500 HP) EM ELEC GEN-DIESEL
244321	D39314	I C E (>500 HP) EM ELEC GEN DIESEL
249479	D39159	I C E (50-500 HP) EM ELEC GEN-DIESEL
255744	D47299	I C E (50-500 HP) EM ELEC GEN-DIESEL
271884	D61857	I C E (50-500 HP) EM ELEC GEN-DIESEL
303040	D92777	ETHYLENE OXIDE STERILIZATION HOSPITAL
303041	D92778	ETHYLENE OXIDE STERILIZATION HOSPITAL
303042	D92779	ETHYLENE OXIDE STERILIZATION CTL (HOSP)
303043	D92780	ETHYLENE OXIDE STERILIZATION CTL (HOSP)
312824	D97367	I C E (>500 HP) EM ELEC GEN DIESEL
321229	F3444	I C E (>500 HP) EM ELEC GEN DIESEL
G00291	42664	SPRAY BOOTH PAINT AND SOLVENT
G03352	M22610	I C E (>500 HP) EM ELEC GEN DIESEL
G03353	M22611	I C E (>500 HP) EM ELEC GEN DIESEL
414595	F81696	BOILER (<5 MMBTU/HR) NAT GAS ONLY
414596	F81697	BOILER (<5 MMBTU/HR) NAT GAS ONLY
427583	F68148 (AT PARKING STRUCTURE 12)	I C E (50-500 HP) EM ELEC GEN-DIESEL
452794	F84815	I C E (>500 HP) EM ELEC GEN DIESEL
452795	F84814	I C E (>500 HP) EM ELEC GEN DIESEL
452796	F84813	I C E (>500 HP) EM ELEC GEN DIESEL
452797	F84812	I C E (>500 HP) EM ELEC GEN DIESEL

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

452798	F84811	I C E (>500 HP) EM ELEC GEN DIESEL
452799	F84810	I C E (>500 HP) EM ELEC GEN DIESEL
452800	F84809	I C E (>500 HP) EM ELEC GEN DIESEL
452801	F96938	BOILER (20-<50 MMBTU/HR) NAT GAS/LPG
452802	F96939	BOILER (20-<50 MMBTU/HR) NAT GAS/LPG
452803	F96940	BOILER (20-<50 MMBTU/HR) NAT GAS/LPG
452804	F97100	BOILER (20-<50 MMBTU/HR) NAT GAS/LPG
452805	F96941	BOILER (20-<50 MMBTU/HR) NAT GAS/LPG
461429	F88000	I C E (51-500 HP) EM ELEC GEN DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAS NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:

- A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGLEMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
- B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]

2. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.0015 PERCENT BY WEIGHT.
[RULE 431.2]

3. ACCIDENTAL RELEASE PREVENTION REQUIREMENTS OF SECTION 112(r)(7):

THE OPERATOR SHALL COMPLY WITH THE ACCIDENTAL RELEASE PREVENTION REQUIREMENTS PURSUANT TO 40 CFR Part 68 AND SHALL SUBMIT TO THE EXECUTIVE OFFICER, AS PART OF ANNUAL COMPLIANCE CERTIFICATION, A STATEMENT THAT CERTIFIES COMPLIANCE WITH ALL THE REQUIREMENTS OF 40 CFR Part 68, INCLUDING THE REGISTRATION AND SUBMISSION OF A RISK MANAGEMENT PLAN (RMP).

THE OPERATOR SHALL SUBMIT ANY ADDITIONAL RELEVANT INFORMATION REQUESTED BY THE EXECUTIVE OFFICER OR DESIGNATED AGENCY.
[40 CFR68-ACCIDENTAL RELEASE PREVENTION]

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

PERMIT TO OPERATE

Permit No. N17156
A/N 443478

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY CONSISTING OF:

- 1) 1- GASOLINE UNDERGROUND STORAGE TANK, 3,000- GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM OPW (VR-102-E), 1 METHANOL COMPATIBLE.
- 2) 2 - GASOLINE NOZZLES DISPENSING 2 PRODUCTS, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, BALANCE RETRACTOR (G-70-52-AM).

Conditions:

- 1. OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
- 3. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS. [RULE 461]
- 4. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461. [RULE 461]
- 5. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS. [RULE 461]
- 6. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO BACK-FILLING ANY UNDERGROUND STORAGE TANK OR PIPING, THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461BACKFILL@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTORS; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE BACK-FILLING PROCEDURE. THE BACK-FILLING PROCEDURE SHALL NOT COMMENCE UNTIL INSPECTED BY A DISTRICT REPRESENTATIVE. [RULE 461]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

7. DEPENDING ON THE SYSTEM CONFIGURATION, A PRESSURE INTEGRITY TEST OF THE DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A PRESSURE INTEGRITY TEST OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND SPILL CONTAINER DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE. EITHER TEST SHALL BE CONDUCTED AS A REVERIFICATION TEST AND THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP-201.1C OR TP-201.1D, RESPECTIVELY. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF EITHER THE PRESSURE INTEGRITY TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY OR PRESSURE INTEGRITY TEST OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND SPILL CONTAINER DRAIN VALVE.
[RULE 461]

8. A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN THIRTY DAYS (30) AFTER THE START OF OPERATION OF THE OPW PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201.1E. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES.
[RULE 461]

9. A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED AS A REVERIFICATION TEST TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201.1B. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

START AND COMPLETION DATES OF THE STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS.
[RULE 461]

10. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE SYSTEM INCLUDING NOZZLE, VAPOR HOSE, SWIVELS, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURES DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

NITROGEN FLOWRATES (CFH)	DYNAMIC BACK PRESSURE (INCHES OF WATER)
60	0.35
80	0.62

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4, METHODOLOGY 1. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE DYNAMIC BACK PRESSURE TESTS.
[RULE 461]

11. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE STATIC PRESSURE LEAK DECAY TEST.
[RULE 461]

12. IF THE CARB EXECUTIVE ORDER REQUIRES THE INSTALLATION OF A LIQUID REMOVAL DEVICE, A LIQUID REMOVAL RATE TEST SHALL BE CONDUCTED TO DEMONSTRATE THE REMOVAL OF GASOLINE FROM THE VAPOR PASSAGE OF THE COAXIAL HOSE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.6. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE LIQUID REMOVAL RATE TEST.

[RULE 461]

13. THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.

[RULE 461]

14. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461]

Periodic Monitoring:

15. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(C)(6) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT D, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.

[RULE 3004 (a)(4)]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 461

VOC: RULE 1170

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F5725
A/N 199974

Equipment Description:

INTERNAL COMBUSTION ENGINE (MEDICAL EXAMINER), DETROIT DIESEL, MODEL NO. 6161T, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, 6 CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 213 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D93523
A/N 224034

Equipment Description:

BOILER NO. 2, FOSTER WHEELER, MODEL AGM-252-B, WATER-TUBE TYPE, WITH ECONOMIZER, A TODD VARIFLAME LOW NOX BURNER, 82,000,000 BTUS PER HOUR, NATURAL GAS OR LOW NITROGEN FUEL OIL FIRED, 60 HP COMBUSTION AIR BLOWER AND A 40 HP FORCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION, EXCEPT DURING ELECTRIC POWER OUTAGES. RECORDS SHALL BE KEPT INDICATING THE DATE AND DURATION OF SUCH POWER OUTAGES AND WHICH BOILER(S) IS/ARE IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL FIRE NATURAL GAS ONLY, EXCEPT DURING PERIODS OF FORCED MAJEURE NATURAL GAS CURTAILMENTS, DURING MAINTENANCE TESTING OF THE BOILER NOT TO EXCEED 30 MINUTES PER MONTH, AND DURING COMPLIANCE TESTING.
[RULE 1146]
5. FUEL OIL SUPPLIED AT THE BURNER SHALL BE NO. 2 OR LIGHTER GRADE AS DESCRIBED BY THE LATEST ASTM SPECIFICATIONS AND SHALL CONTAIN NO MORE THAN 0.0015 PERCENT SULFUR BY WEIGHT.
[RULE 431.2, RULE 1146]
6. THE BOILER SHALL BE EQUIPPED WITH INSTRUMENTATION WHICH SHOWS THE BOILER FIRING RATE.
[RULE 1146]
7. THE BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL.
[RULE 1146]
8. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 30 PPM DRY, AT 3 PERCENT OXYGEN.
[RULE 1146]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

9. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 400 PPM DRY, AT 3 PERCENT OXYGEN.
[RULE 1146]
10. THE BOILER OPERATOR SHALL RECORD THE ANNUAL FUEL USE IN A MANNER APPROVED IN WRITING BY THE AQMD. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF FIVE YEARS AND BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1146]

Periodic Monitoring:

11. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
12. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
13. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
 - A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

14. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 5.2 . THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

15. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
CO: 400 PPMV, RULE 1146
NOX: 40 PPMV, RULE 1146, Fuel Oil
NOX: 30 PPMV, RULE 1146, Natural Gas

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

PERMIT TO OPERATE

Permit No. D93522
A/N 224035

Equipment Description:

BOILER NO. 3, FOSTER WHEELER, MODEL AGM-252-B, WATER-TUBE TYPE, WITH A TODD VARIFLAME LOW NOX BURNER, 82,000,000 BTUS PER HOUR, NATURAL GAS OR LOW NITROGEN FUEL OIL FIRED, 60 HP COMBUSTION AIR BLOWER AND A 40 HP FORCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION, EXCEPT DURING ELECTRIC POWER OUTAGES. RECORDS SHALL BE KEPT INDICATING THE DATE AND DURATION OF SUCH POWER OUTAGES AND WHICH BOILER(S) IS/ARE IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL FIRE NATURAL GAS ONLY, EXCEPT DURING PERIODS OF FORCED MAINTURE NATURAL GAS CURTAINMENTS, DURING MAINTENANCE TESTING OF THE BOILER NOT TO EXCEED 30 MINUTES PER MONTH, AND DURING COMPLIANCE TESTING.
[RULE 1146]
5. FUEL OIL SUPPLIED AT THE BURNER SHALL BE NO. 2 OR LIGHTER GRADE AS DESCRIBED BY THE LATEST ASTM SPECIFICATIONS AND SHALL CONTAIN NO MORE THAN 0.0015 PERCENT SULFUR BY WEIGHT.
[RULE 431.2, RULE 1146]
6. THE BOILER SHALL BE EQUIPPED WITH INSTRUMENTATION WHICH SHOWS THE BOILER FIRING RATE.
[RULE 1146]
7. THE BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL.
[RULE 1146]
8. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 30 PPM DRY, AT 3 PERCENT OXYGEN.
[RULE 1146]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

9. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 400 PPM DRY, AT 3 PERCENT OXYGEN.
[RULE 1146]
10. THE BOILER OPERATOR SHALL RECORD THE ANNUAL FUEL USE IN A MANNER APPROVED IN WRITING BY THE AQMD. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF FIVE YEARS AND BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1146]

Periodic Monitoring:

11. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
12. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
13. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
 - C. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - D. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- E. STACK OR EMISSION POINT IDENTIFICATION;

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

F. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;

G. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND

H. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

14. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 5.2 . THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

B. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

15. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
CO: 400 PPMV, RULE 1146
NOX: 40 PPMV, RULE 1146, Fuel Oil
NOX: 30 PPMV, RULE 1146, Natural Gas

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D93521
A/N 224036

Equipment Description:

BOILER NO. 1, FOSTER WHEELER, MODEL AGM-252-B, WATER-TUBE TYPE, WITH ECONOMIZER, WITH A TODD VARIFLAME LOW NOX BURNER, 82,000,000 BTUS PER HOUR, NATURAL GAS OR LOW NITROGEN FUEL OIL FIRED, 60 HP COMBUSTION AIR BLOWER AND A 40 HP FORCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION, EXCEPT DURING ELECTRIC POWER OUTAGES. RECORDS SHALL BE KEPT INDICATING THE DATE AND DURATION OF SUCH POWER OUTAGES AND WHICH BOILER(S) IS/ARE IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL FIRE NATURAL GAS ONLY, EXCEPT DURING PERIODS OF FORCED MAJOR NATURAL GAS CURTAILMENTS, DURING MAINTENANCE TESTING OF THE BOILER NOT TO EXCEED 30 MINUTES PER MONTH, AND DURING COMPLIANCE TESTING.
[RULE 1146]
5. FUEL OIL SUPPLIED AT THE BURNER SHALL BE NO. 2 OR LIGHTER GRADE AS DESCRIBED BY THE LATEST ASTM SPECIFICATIONS AND SHALL CONTAIN NO MORE THAN 0.0015 PERCENT SULFUR BY WEIGHT.
[RULE 431.2, RULE 1146]
6. THE BOILER SHALL BE EQUIPPED WITH INSTRUMENTATION WHICH SHOWS THE BOILER FIRING RATE.
[RULE 1146]
7. THE BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL.
[RULE 1146]
8. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 30 PPM DRY, AT 3 PERCENT OXYGEN.
[RULE 1146]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

9. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 400 PPM DRY, AT 3 PERCENT OXYGEN.
[RULE 1146]
10. THE BOILER OPERATOR SHALL RECORD THE ANNUAL FUEL USE IN A MANNER APPROVED IN WRITING BY THE AQMD. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF FIVE YEARS AND BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1146]

Periodic Monitoring:

11. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
12. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
13. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
 - A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

14. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 5.2 . THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

15. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
CO: 400 PPMV, RULE 1146
NOX: 40 PPMV, RULE 1146, Fuel Oil
NOX: 30 PPMV, RULE 1146, Natural Gas

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D25143
A/N 226649

Equipment Description:

INTERNAL COMBUSTION ENGINE, GENERAL MOTORS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 62B07RD, SERIAL NO. 6B21323, 6 CYLINDERS, TWO CYCLE, NATURALLY ASPIRATED, 291 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41378
A/N 244309

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO KT-1150-G, SERIAL NO. 31101195, 6 CYLINDERS, 4 CYCLES, TURBOCHARGED, 465 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D38299
A/N 244310

Equipment Description:

INTERNAL COMBUSTION ENGINE, VOLVO VENTA, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO. TID121KGP, SERIAL NO. 1101015799, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED, INTERCOOLED, 440 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]
9. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1304(a), RULE 1110.2]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41380
A/N 244312

Equipment Description:

INTERNAL COMBUSTION ENGINE, VALLEY DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO. 1063-7305, SERIAL NO. 6A458608, 6 CYLINDERS, 2 CYCLES, TURBOCHARGED, 315 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41145
A/N 244317

Equipment Description:

INTERNAL COMBUSTION ENGINE, WHITE, NATURAL GAS-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO. G2300X285, SERIAL NO. G2300X285, 6 CYLINDERS, 4 CYCLES, NATURALLY ASPIRATED, 88 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING STAGE II OR III ELECTRICAL EMERGENCIES DECLARED BY THE ELECTRICAL GRID OPERATOR. THIS ENGINE MAY BE USED AS PART OF AN INTERRUPTIBLE ELECTRIC SERVICE PROGRAM.
[RULE 1304(a)(1)-BACT]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]
9. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1304(a), RULE 1110.2]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41145
A/N 244317

Equipment Description:

INTERNAL COMBUSTION ENGINE, WHITE, NATURAL GAS-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO. G2300X285, SERIAL NO. G2300X285, 6 CYLINDERS, 4 CYCLES, NATURALLY ASPIRATED, 88 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a), RULE 1110.2]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY DURING EMERGENCIES RESULTING IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING STAGE II OR III ELECTRICAL EMERGENCIES DECLARED BY THE ELECTRICAL GRID OPERATOR. THIS ENGINE MAY BE USED AS PART OF AN INTERRUPTIBLE ELECTRIC SERVICE PROGRAM.
[RULE 1304(a)(1)-BACT]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41385
A/N 244318

Equipment Description:

INTERNAL COMBUSTION ENGINE, GENERAL MOTORS, DIESEL-FUELED, MODEL NO. 5043-7101, 4 CYLINDERS, 2 CYCLES, NATURALLY ASPIRATED, 93 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41386
A/N 244319

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO. 7083-7305, SERIAL NO. 8VA321658, 8 CYLINDERS, 2 CYCLES, TURBOCHARGED, 315 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]
9. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1304(a), RULE 1110.2]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D41387
A/N 244320

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR, MODEL NO. KT-1150-G, SERIAL NO. 3110128701800, 6 CYLINDERS, 4 CYCLES, TURBOCHARGED, 465 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

**Permit No. D39314
A/N 244321**

Equipment Description:

INTERNAL COMBUSTION ENGINE (INTRA-FACILITY), DETROIT DIESEL, MODEL 8083-7405, SERIAL NO. 08VF139017, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, TURBOCHARGED, AFTERCOOLED, 8 CYLINDERS, 540 B.H.P.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]
9. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1304(a), RULE 1110.2]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D39159
A/N 249479

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6BT5.9G1, TURBOCHARGED, 6 CYLINDERS, FOUR CYCLE, 134 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]

7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D47299
A/N 255744

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL 8063-7405, SERIAL NO. AD201983 SNE, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, 402 B.H.P.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]
9. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1304(a), RULE 1110.2]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D61857
A/N 271884

Equipment Description:

INTERNAL COMBUSTION ENGINE, GENERAC, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 13.3 DTA, SD 250, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, 400 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]
9. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1304(a), RULE 1110.2]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92777
A/N 303040

Equipment Description:

ETHYLENE OXIDE (ETO) GAS STERILIZER/AERATOR, AMSCO, MODEL EAGLE 3047,2'-0" W X 4'-0" L X 3'-0" H (INTERNAL DIMENSIONS), STEAM HEATED, WITH A 3 HP VACUUM PUMP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE TOTAL COMBINED MAXIMUM AMOUNT OF STERILANT GAS (10% ETO/63% HCFC- 124/27% HCFC-22 BY WEIGHT) USED IN THE TWO STERILIZERS (COVERED UNDER A/N 303040 AND A/N 303041) SHALL NOT EXCEED 11.7 POUNDS IN ANY ONE DAY OR 304 POUNDS IN ANY CALENDAR MONTH.
[RULE 1405]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT AND/OR OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. THIS EQUIPMENT SHALL BE LEAKED CHECKED PER AOMD RULE 1405 (d)(5).
[RULE 1405]
6. ALL RECORDS, SUCH AS OPERATING SCHEDULES AND NUMBER OF LOADS PROCESSED, SHALL BE MAINTAINED, KEPT ON FILE FOR A MINIMUM OF FIVE YEARS, AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92778
A/N 303041

Equipment Description:

ETHYLENE OXIDE (ETO) GAS STERILIZER/AERATOR, AMSCO, MODEL EAGLE 3047,2'-0" W X 4'-0" L X 3'-0" H (INTERNAL DIMENSIONS), STEAM HEATED, WITH A 3 HP VACUUM PUMP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE TOTAL COMBINED MAXIMUM AMOUNT OF STERILANT GAS (10% ETO/63% HCFC- 124/27% HCFC-22 BY WEIGHT) USED IN THE TWO STERILIZERS (COVERED UNDER A/N 303040 AND A/N 303041) SHALL NOT EXCEED 11.7 POUNDS IN ANY ONE DAY OR 304 POUNDS IN ANY CALENDAR MONTH.
[RULE 1405]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT AND/OR OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. THIS EQUIPMENT SHALL BE LEAKED CHECKED PER AOMD RULE 1405 (d)(5).
[RULE 1405]
6. ALL RECORDS, SUCH AS OPERATING SCHEDULES AND NUMBER OF LOADS PROCESSED, SHALL BE MAINTAINED, KEPT ON FILE FOR A MINIMUM OF FIVE YEARS, AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92779
A/N 303042

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER (EO DISPOSER), AMSCO, 2'-5" W. X 2'-5" L. X 6'-10" H. (EXTERIOR DIMENSIONS), WITH A 10 KW PREHEATER, PREFILTER, 0.5 HP VACUUM PUMP, AND A CATALYST.
2. EXHAUST SYSTEM WITH A 0.6 HP AIR BLOWER VENTING THE ETHYLENE OXIDE STERILIZER/AERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. ONLY ONE STERILIZER SHALL BE VENTED TO THE CATALYTIC OXIDIZER (ETO DISPOSER) AT ANY TIME.
[RULE 1405]
4. THE TEMPERATURE OF THE EXHAUST FROM THE CATALYST BED SHALL BE MAINTAINED AT A MINIMUM OF 350 DEGREES F AS INDICATED BY A PROPER TEMPERATURE GAUGE AND/OR RECORDER.
[RULE 1405]
5. THE OWNER OR OPERATOR OF THE EQUIPMENT SHALL CONDUCT ANNUAL SOURCE TESTS PER AQMD RULE 1405(d)(6).
[RULE 1405]
6. RECORDS SHALL BE MAINTAINED TO SHOW COMPLIANCE WITH THE ABOVE IN A FORMAT APPROVED BY THE AQMD. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92780
A/N 303043

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER (EO DISPOSER), AMSCO, 2'-5" W. X 2'-5" L. X 6'-10" H. (EXTERIOR DIMENSIONS), WITH A 10 KW PREHEATER, PREFILTER, 0.5 HP VACUUM PUMP, AND A CATALYST.
2. EXHAUST SYSTEM WITH A 0.6 HP AIR BLOWER VENTING THE ETHYLENE OXIDE STERILIZER/AERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. ONLY ONE STERILIZER SHALL BE VENTED TO THE CATALYTIC OXIDIZER (ETO DISPOSER) AT ANY TIME.
[RULE 1405]
4. THE TEMPERATURE OF THE EXHAUST FROM THE CATALYST BED SHALL BE MAINTAINED AT A MINIMUM OF 350 DEGREES F AS INDICATED BY A PROPER TEMPERATURE GAUGE AND/OR RECORDER.
[RULE 1405]
5. THE OWNER OR OPERATOR OF THE EQUIPMENT SHALL CONDUCT ANNUAL SOURCE TESTS PER AQMD RULE 1405(d)(6).
[RULE 1405]
6. RECORDS SHALL BE MAINTAINED TO SHOW COMPLIANCE WITH THE ABOVE IN A FORMAT APPROVED BY THE AQMD. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D97367
A/N 312824

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. KTA19-G3, 685 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]

7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F3444
A/N 321229

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. KTA19-G3, 685 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. 42664
A/N G00291

Equipment Description:

SPRAY BOOTH, DEVILBISS, WATER-WASH TYPE, 16' W. X 8' H. X 10' D., WITH A 7 ½ H.P. EXHAUST FAN AND A 7 ½ H.P. WATER PUMP.

Conditions:

1. THE OPERATOR SHALL NOT OPERATE THIS EQUIPMENT UNLESS THE WATER WASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION WITH THE WATER CURTAIN COMPLETELY COVERING THE EXHAUST SECTION OF THE BOOTH. THE OPERATOR SHALL ALSO PERFORM A WEEKLY INSPECTION OF THE WATER CURTAIN INTEGRITY. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE WATER WASH;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.[RULE 3004 (a)(4)]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- VOC: RULE 109
- VOC: RULE 1136, SEE APPENDIX B FOR EMISSION LIMITS
- VOC: RULE 1107, SEE APPENDIX B FOR EMISSION LIMITS
- VOC: RULE 1168, SEE APPENDIX B FOR EMISSION LIMITS
- VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS
- PM: RULE 481
- VOC: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. M22610
A/N G03352

Equipment Description:

ENGINE #2, GENERAL MOTORS, MODEL 16-645-E1, 2,000 H.P., SERIAL NO. 72-71-1052, DIESEL FIRED, DRIVING A 1250 KW CAPACITY EMERGENCY ELECTRIC GENERATOR.

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. M22611
A/N G03353

Equipment Description:

ENGINE #1, GENERAL MOTORS, MODEL 16-567-D1, 2,000 H.P., SERIAL NO. 66-J3-1027, DIESEL FIRED, DRIVING A 1250 KW CAPACITY EMERGENCY ELECTRIC GENERATOR.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F81696
A/N 414595

Equipment Description:

BOILER, B-1, PARKER, MODEL NO. 105-90, SERIAL NO. 19241, WITH A:NATURAL GAS FIRED, LOW NOx METAL FIBER BURNER, PARKER, RATED AT 3,780,000 BTU PER HOUR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NOX), CALCULATED AS NO2, AND 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O2.
[RULE 1146.1]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR AND FUEL AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146.1]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146.1]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Periodic Monitoring:

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; or (b) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (d)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146.1 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146.1, RULE 3004 (a)(4)]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; or (b) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (d)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146.1 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146.1, RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146.1
NOx: 30 PPM, RULE 1146.1
PM: 0.1 gr/sct, RULE 409
SOx: 500 PPM, RULE 407

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F81697
A/N 414596

Equipment Description:

BOILER, B-2, PARKER, MODEL NO. 105-90, SERIAL NO. 19242, WITH A:NATURAL GAS FIRED, LOW NO_x METAL FIBER BURNER, PARKER, RATED AT 3,780,000 BTU PER HOUR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY.
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1146.1]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR AND FUEL AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146.1]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146.1]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

Periodic Monitoring:

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; or (b) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (d)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146.1 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146.1, RULE 3004 (a)(4)]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; or (b) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (d)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146.1 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146.1, RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146.1
NOx: 30 PPM, RULE 1146.1
PM: 0.1 gr/sct, RULE 409
SOx: 500 PPM, RULE 407

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F68148
A/N 427583

Equipment Description:

INTERNAL COMBUSTION ENGINE (AT PARKING STRUCTURE 12), GENERAC, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3.9DTA,, SERIAL NO. 2075007, DIESEL FUELED, TURBOCHARGED AND AFTERCOOLED, 147 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84815
A/N 452794

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010956, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84814
A/N 452795

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010955, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84813
A/N 452796

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010954, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]

7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84812
A/N 452797

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010952, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84811
A/N 452798

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010385, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84810
A/N 452799

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010384, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F84809
A/N 452800

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T1637M36, SERIAL NO. 2010383, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2,936 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F88000
A/N 461429

Equipment Description:

INTERNAL COMBUSTION ENGINE, JOHN DEERE, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6068HF485T, DIESEL FUELED, SIX CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 315 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304(a), RULE 1110.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304(a), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a), RULE 1110.2, RULE 1470]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

6. THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F96938
A/N 452801

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE-TUBE TYPE, MODEL NO. CBL700X-900-150S, SERIAL NO. OL103147, WITH A NATURAL-GAS (PRIMARY FUEL) AND LPG (STAND-BY) FIRED, LOW NO_x BURNER, INDUSTRIAL COMBUSTION, RATED AT 37,800,000 BTU PER HOUR, AND EQUIPPED WITH A FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY. HOWEVER, LPG CAN BE USED DURING PERIODS OF NATURAL GAS CURTAILMENT AND DURING MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH.
[RULE 1304(a) (1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON NATURAL GAS AND EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON LPG, ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1304(a) (1)-BACT]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1304(a) (1)-BACT]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146, RULE 1304(a) (1)-BACT]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1304(a) (1)-BACT]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) BY: (A) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; AND (B) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (D)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146, RULE 3004 (a) (4)]

Emissions And Requirements:

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146, WHEN FIRED WITH LPG
NOX: 30 PPM, RULE 1146, WHEN FIRED WITH LPG
PM: 0.1 GR/SCF, RULE 409
SOX: 500 PPM, RULE 407
NOX: 9 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS
CO: 50 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F96939
A/N 452802

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE-TUBE TYPE, MODEL NO. CBL700X-900-150S, SERIAL NO. OL103146, WITH A NATURAL-GAS (PRIMARY FUEL) AND LPG (STAND-BY) FIRED, LOW NO_x BURNER, INDUSTRIAL COMBUSTION, RATED AT 37,800,000 BTU PER HOUR, AND EQUIPPED WITH A FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY. HOWEVER, LPG CAN BE USED DURING PERIODS OF NATURAL GAS CURTAILMENT AND DURING MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH.
[RULE 1304(a) (1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON NATURAL GAS AND EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON LPG, ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1304(a) (1)-BACT]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1304(a) (1)-BACT]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146, RULE 1304(a) (1)-BACT]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1304(a) (1)-BACT]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) BY: (A) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; AND (B) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (D)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146, RULE 3004 (a) (4)]

Emissions And Requirements:

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146, WHEN FIRED WITH LPG
NOX: 30 PPM, RULE 1146, WHEN FIRED WITH LPG
PM: 0.1 GR/SCF, RULE 409
SOX: 500 PPM, RULE 407
NOX: 9 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS
CO: 50 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F96940
A/N 452803

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE-TUBE TYPE, MODEL NO. CBL700X-900-150S, SERIAL NO. OL103145, WITH A NATURAL-GAS (PRIMARY FUEL) AND LPG (STAND-BY) FIRED, LOW NO_x BURNER, INDUSTRIAL COMBUSTION, RATED AT 37,800,000 BTU PER HOUR, AND EQUIPPED WITH A FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY. HOWEVER, LPG CAN BE USED DURING PERIODS OF NATURAL GAS CURTAILMENT AND DURING MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH.
[RULE 1304(a) (1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON NATURAL GAS AND EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON LPG, ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1304(a) (1)-BACT]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1304(a) (1)-BACT]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146, RULE 1304(a) (1)-BACT]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1304(a) (1)-BACT]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) BY: (A) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; AND (B) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (D)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146, RULE 3004 (a) (4)]

Emissions And Requirements:

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146, WHEN FIRED WITH LPG
NOX: 30 PPM, RULE 1146, WHEN FIRED WITH LPG
PM: 0.1 GR/SCF, RULE 409
SOX: 500 PPM, RULE 407
NOX: 9 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS
CO: 50 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F97100
A/N 452804

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE-TUBE TYPE, MODEL NO. CBL700X-900-150S, SERIAL NO. OL103144, WITH A NATURAL-GAS (PRIMARY FUEL) AND LPG (STAND-BY) FIRED, LOW NO_x BURNER, INDUSTRIAL COMBUSTION, RATED AT 37,800,000 BTU PER HOUR, AND EQUIPPED WITH AN FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY. HOWEVER, LPG CAN BE USED DURING PERIODS OF NATURAL GAS CURTAILMENT AND DURING MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH.
[RULE 1304(a) (1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON NATURAL GAS AND EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON LPG, ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1304(a) (1)-BACT]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1304(a) (1)-BACT]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146, RULE 1304(a) (1)-BACT]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1304(a) (1)-BACT]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) BY: (A) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; AND (B) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (D)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146, RULE 3004 (a) (4)]

Emissions And Requirements:

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146, WHEN FIRED WITH LPG
NOX: 30 PPM, RULE 1146, WHEN FIRED WITH LPG
PM: 0.1 GR/SCF, RULE 409
SOX: 500 PPM, RULE 407
NOX: 9 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS
CO: 50 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F96941
A/N 452805

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE-TUBE TYPE, MODEL NO. CBL700X-900-150S, SERIAL NO. OL103143, WITH A NATURAL-GAS (PRIMARY FUEL) AND LPG (STAND-BY) FIRED, LOW NO_x BURNER, INDUSTRIAL COMBUSTION, RATED AT 37,800,000 BTU PER HOUR, AND EQUIPPED WITH A FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY. HOWEVER, LPG CAN BE USED DURING PERIODS OF NATURAL GAS CURTAILMENT AND DURING MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH.
[RULE 1304(a) (1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON NATURAL GAS AND EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NO_x), CALCULATED AS NO₂, AND 50 PPM OF CARBON MONOXIDE (CO) WHEN FIRED ON LPG, ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O₂.
[RULE 1304(a) (1)-BACT]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO MAINTAIN ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.
[RULE 1146, RULE 1304(a) (1)-BACT]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UP AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST 2 YEARS AND MADE AVAILABLE UPON REQUEST OF THE DISTRICT PERSONNEL.
[RULE 1146, RULE 1304(a) (1)-BACT]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146, RULE 1304(a) (1)-BACT]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) BY: (A) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; AND (B) CONDUCTING A SOURCE TEST ANNUALLY AS PER ANY OF THE METHODS OUTLINED IN DISTRICT RULE 1146 (D)(4). THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1146, RULE 3004 (a) (4)]

Emissions And Requirements:

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146, WHEN FIRED WITH LPG
NOX: 30 PPM, RULE 1146, WHEN FIRED WITH LPG
PM: 0.1 GR/SCF, RULE 409
SOX: 500 PPM, RULE 407
NOX: 9 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS
CO: 50 PPM, RULE 1303 (A) (1), WHEN FIRED WITH NATURAL GAS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 1 MMBTU/HR BUT < 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT: RULE 1415
REFRIGERANT: 40CFR 82 SUBART F

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
CR^{*6}: RULE 1404

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
REFRIGERANT: RULE 1415
REFRIGERANT: 40CFR 82 SUBPART F

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
 - VOC: RULE 1136, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1107, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1168, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 109

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, FIRE EXTINGUISHING EQUIPMENT

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HALON: RULE 1418

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, NEGATIVE AIR MACHINES.

Periodic Monitoring:

- 1) FOR EACH COMMERCIAL ABATEMENT PROJECT, THE NEGATIVE AIR MACHINE(S) EXHAUST SHALL BE LOCATED A MINIMUM OF 3 METERS (10 FEET) FROM THE NEAREST RECEPTOR (ANY LOCATION WHERE THE PUBLIC CAN BE EXPOSED TO ASBESTOS FIBER EMISSIONS) AND SHALL BE LOCATED AT LEAST 10 FEET ABOVE THE GROUND.
[RULE 1403]
- 2) FOR EACH COMMERCIAL ABATEMENT PROJECT, LOCATED MORE THAN 3 METERS (10 FEET) BUT LESS THAN 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING, THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST MORE THAN A COMBINED TOTAL OF 4.8 MILLION CUBIC FEET OF AIR (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL).
[RULE 1403]
- 3) FOR EACH COMMERCIAL ABATEMENT PROJECT, LOCATED GREATER THAN OR EQUAL TO 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING, THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST AIR IN WHICH THE COMBINED TOTAL AIR VOLUME (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL) WILL EXCEED THE AMOUNT SPECIFIED ON TABLE 1.
[RULE 1403]

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
ASBESTOS: RULE 1403

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

ASBESTOS NEGATIVE AIR MACHINE WITH HEPA FILTER, CRITICAL SYSTEMS, MODEL NO. MACH II, SERIAL NO. 4445, 2000 CFM RATED.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) FOR EACH ABATEMENT PROJECT, THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED BY THE PHASE CONTRAST MICROSCOPY (PCM) METHOD DURING THE FIRST DAY OF ACTUAL ASBESTOS REMOVAL AND AFTER EACH HEPA FILTER REPLACEMENT. IF THIS NEGATIVE AIR MACHINE IS ADDED OR REPLACED DURING A SPECIFIC PROJECT, THE EXHAUST OF THIS ADDITION OR REPLACEMENT SHALL BE ANALYZED BY THE PCM METHOD DURING THE FIRST DAY OF ITS USE DURING ACTUAL ASBESTOS REMOVAL. EXHAUST SAMPLES TO BE ANALYZED SHALL ONLY BE TAKEN DURING ACTUAL ASBESTOS REMOVAL. DURING EACH LONG TERM ABATEMENT PROJECT (GREATER THAN 15 CALENDAR DAYS), THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED AT LEAST EVERY 15 CALENDAR DAYS.
[RULE 1403]
- 4) THE EXHAUST CONCENTRATION OF ASBESTOS FROM THE NEGATIVE AIR MACHINE SHALL NOT EXCEED 0.01 FIBER PER CUBIC CENTIMETER.
[RULE 1403]
- 5) THE NEGATIVE AIR MACHINE SHALL BE TESTED FOR LEAKAGE AFTER EACH HEPA FILTER CHANGE AND PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT.
[RULE 1403]
- 6) THE EXHAUST CONCENTRATION OF ASBESTOS FROM THE NEGATIVE AIR MACHINE SHALL NOT EXCEED 0.01 FIBER PER CUBIC CENTIMETER.
[RULE 1403]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

1. PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO₂) and be averaged over 15 consecutive minutes; [407]
 - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO₂) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O₂) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
- a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
- a. The results of the source test.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief description of the equipment tested.
 - c. Operating conditions under which the test was performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

NONE

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

SECTION J: AIR TOXICS

NOT APPLICABLE

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
- (B) The date(s) analyses were performed;
- (C) The company or entity that performed the analyses;
- (D) The analytical techniques or methods used;
- (E) The results of such analyses; and
- (F) The operating conditions as existing at the time of sampling or measurement.
[3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:

- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
 - (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
 - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1110.2	11-14-1997	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	6-9-2006	Non federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146.1	5-13-1994	Federally enforceable
RULE 1146.2	1-7-2005	Non federally enforceable
RULE 1146.2	1-9-1998	Federally enforceable
RULE 1168	7-12-2002	Non federally enforceable
RULE 1168	8-15-2000	Non federally enforceable
RULE 1168	9-15-2000	Federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	7-14-2006	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1470	4-2-2004	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 2202	11-8-1996	Non federally enforceable
RULE 3002	11-14-1997	Federally enforceable

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 3003	11-14-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	1-14-1982	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 461	4-21-2000	Federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 701	6-13-1997	Federally enforceable

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN
PERMIT PURSUANT TO RULE 219**

NONE

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 08-14-1998]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

The operator shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

<u>Coating</u>	LIMITS			
	Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds			
	<u>Air Dried</u>	<u>(lb/gal)</u>	<u>Baked</u>	<u>(lb/gal)</u>
General	340	(2.8)	275	(2.3)
<u>Effective 3/1/1999</u>				
One-Component	275	(2.3)	275	(2.3)
Multi-Component	340	(2.8)	275	(2.3)
Military Specification	340	(2.8)	275	(2.3)
Etching Filler	420	(3.5)	420	(3.5)
Solar-Absorbent	420	(3.5)	360	(3.0)
Heat-Resistant	420	(3.5)	360	(3.0)
Extreme High-Gloss	420	(3.5)	360	(3.0)
Metallic	420	(3.5)	420	(3.5)
Extreme Performance	420	(3.5)	360	(3.0)
Prefabricated Architectural Component	420	(3.5)	275	(2.3)
Touch Up	420	(3.5)	360	(3.0)
Repair	420	(3.5)	360	(3.0)
Silicone Release	420	(3.5)	420	(3.5)
High Performance Architectural	420	(3.5)	420	(3.5)
Camouflage	420	(3.5)	420	(3.5)
Vacuum-Metalizing	420	(3.5)	420	(3.5)
Mold-Seal	420	(3.5)	420	(3.5)
High-Temperature	420	(3.5)	420	(3.5)
Electric-Insulating Varnish	420	(3.5)	420	(3.5)
Pan Backing	420	(3.5)	420	(3.5)
Pretreatment Coatings	420	(3.5)	420	(3.5)

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 08-14-1998]

- (2) The operator shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 05-14-1999]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6) of Rule 1113, the operator shall not supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6) of Rule 1113, the operator shall not supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings for residential use; or of any rust-preventative coating for industrial use.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 05-14-1999] TABLE OF STANDARDS VOC LIMITS

**Grams of VOC Per Liter of Coating,
Less Water And Less Exempt Compounds**

COATING	Limit*	Effective 1/1/1998	Effective 1/1/1999	Effective 5/14/99	Effective 7/1/2001	Effective 7/1/2002	Effective 1/1/2005	Effective 7/1/2006	Effective 7/1/2008
Bond Breakers	350								
Chemical Storage Tank Coatings	420							100	
Clear Wood Finishes									
Varnish	350								
Sanding Sealers	350								
Lacquer	680	550					275		
Concrete-Curing Compounds	350								
Dry-Fog Coatings	400								
Essential Public Service Coating	420					340		100	
Fire-proofing Exterior Coatings	450		350						
Fire-Retardant Coatings									
Clear	650								
Pigmented	350								
Flats	250				100				50
Floor Coatings	420					100		50	
Graphic Arts (Sign) Coatings	500								
High Temperature Industrial Maintenance Coatings						550		420	
Industrial Maintenance Coatings	420					250		100	
Japans/Faux Finishing Coatings	700		350						
Magnesite Cement Coatings	600		450						
Mastic Coatings	300								
Metallic Pigmented Coatings	500								
Multi-Color Coatings	420	250							
Non-Flat Coatings	250					150		50	
Pigmented Lacquer	680	550					275		
Pre-Treatment Wash Primers	780								
Primers, Sealers, and Undercoaters	350					200		100	
Quick-Dry Enamels	400					250		50	

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 05-14-1999]

Quick-Dry Primers, Sealers, and Undercoaters	350**					200		100	
Recycled Coatings				250		250		100	
Roof Coatings	300			250					
Bituminous Roof Coatings	300					250			
Rust Preventative Coatings	420			400				100	
Shellac									
Clear	730								
Pigmented	550								
Specialty Primers	350							100	
Stains	350					250			
Swimming Pool Coatings									
Repair	650								
Other	340								
Traffic Coatings	250	150							
Waterproofing Sealers									
Wood	400					250			
Concrete/Masonry	400								
Wood Preservatives									
Below-Ground	350								
Other	350								

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

** The specified limit applies unless the manufacturer submits a report pursuant to Rule 1113(g)(2).

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 07-12-2002]

Except as otherwise provided in Rule 1168

- (1) Unless otherwise specified in paragraph (c)(2), a person shall not apply any adhesives, adhesive bonding primers, adhesive primers, or any other primer which have a VOC content in excess of 250 g/L less water and less exempt compounds.
- (2) A person shall not apply adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, or any other primer which have a VOC content in excess of the limits specified below:

VOC Limit*, Less Water and Less Exempt Compounds in Grams per Liter

Architectural Applications	Current VOC Limit
Indoor Carpet Adhesives	50
Carpet Pad Adhesives	50
Outdoor Carpet Adhesives	150
Wood Flooring Adhesive	100
Rubber Floor Adhesives	60
Subfloor Adhesives	50
Ceramic Tile Adhesives	65
VCT and Asphalt Tile Adhesives	50
Dry Wall and Panel Adhesives	50
Cove Base Adhesives	50
Multipurpose Construction Adhesives	70
Structural Glazing Adhesives	100
Single Ply Roof Membrane Adhesives	250

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 07-12-2002]

Specialty Applications	VOC Limits and Effective Dates**				
	Current VOC Limit	6-7-02	1-1-03	1-1-04	1-1-05
PVC Welding	510				285
CPVC Welding	490				270
ABS Welding	400				
Plastic Cement Welding	350				250
Adhesive Primer for Plastic	650				250
Computer Diskette Manufacturing	350				
Contact Adhesive	250		80		
Special Purpose Contact Adhesive	250				
Tire Retread	100				
Adhesive Primer for Traffic Marking Tape	150				
Structural Wood Member Adhesive	140				
Sheet Applied Rubber Lining Operations	850				
Top and Trim Adhesive	250	540		250	

** The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 07-12-2002]

Substrate Specific Applications	Current VOC Limit
Metal to Metal	30
Plastic Foams	50
Porous Material (except wood)	50
Wood	30
Fiberglass	80

If an adhesive is used to bond dissimilar substrates together the adhesive with the highest VOC content shall be allowed.

Sealants	Current VOC Limit
Architectural	250
Marine Deck	760
Nonmembrane Roof	300
Roadway	250
Single-Ply Roof Membrane	450
Other	420

Sealant Primers	Current VOC Limit
Architectural	
Non Porous	250
Porous	775
Modified Bituminous	500
Marine Deck	760
Other	750

* For low-solid adhesives or sealants the VOC limit is expressed in grams per liter of material as determined in paragraph (b)(32); for all other adhesives and sealants, VOC limits are expressed as grams of VOC per liter of adhesive or sealant less water and less exempt compounds as determined in paragraph (b)(31).

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 09-15-2000]

Except as otherwise provided in Rule 1168

- (1) Unless otherwise specified in paragraph (2), the operator shall not apply any adhesives, adhesive bonding primers, adhesive primers, or any other primer which have a VOC content in excess of 250 g/L less water and less exempt compounds.
- (2) The operator shall not apply adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, or any other primer which have a VOC content in excess of the limits specified below:

VOC Limit*, Less Water and Less Exempt Compounds in Grams per Liter

Architectural Applications	Current VOC Limit	VOC Limit Effective 9-1-01
Indoor Carpet Adhesives	150	50
Carpet Pad Adhesives	150	50
Outdoor Carpet Adhesives	250	150
Wood Flooring Adhesive	150	100
Rubber Floor Adhesives	150	60
Subfloor Adhesives	200	50
Ceramic Tile Adhesives	130	65
VCT and Asphalt Tile Adhesives	150	50
Dry Wall and Panel Adhesives	200	50
Cove Base Adhesives	150	50
Multipurpose Construction Adhesives	200	70
Structural Glazing Adhesives	100	100
Single Ply Roof Membrane Adhesives	250	250

Specialty Applications	Current VOC Limit	VOC Limit Effective 1-1-03
PVC Welding	510	285
CPVC Welding	490	270
ABS Welding	400	400
Plastic Cement Welding	350	250
Adhesive Primer for Plastic	650	250
Computer Diskette Manufacturing	350	350
Contact Adhesive	250	80

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 09-15-2000]

Special Purpose Contact Adhesive	250	250
Tire Retread	100	100
Adhesive Primer for Traffic Marking Tape	150	150
Structural Wood Member Adhesive	140	140
Sheet Applied Rubber Lining Operations	850	850

Substrate Specific Applications	Current VOC Limit	VOC Limit Effective 9-1-01
Metal to Metal	30	30
Plastic Foams	120	50
Porous Material (except wood)	120	50
Wood	30	30
Fiberglass	200	80

If an adhesive is used to bond dissimilar substrates together the adhesive with the highest VOC content shall be allowed.

Sealants	Current VOC Limit
Architectural	250
Marine Deck	760
Nonmembrane Roof	300
Roadway	250
Single-Ply Roof Membrane	450
Other	420
Sealant Primers	Current VOC Limit
Architectural	
Non Porous	250
Porous	775
Modified Bituminous	500
Marine Deck	760
Other	750

**FACILITY PERMIT TO OPERATE
LAC/USC MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1168 09-15-2000]**

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 09-15-2000]

- * For low-solid adhesives or sealants the VOC limit is expressed in grams per liter of material as determined in paragraph (b)(31) of Rule 1168; for all other adhesives and sealants, VOC limits are expressed as grams of VOC per liter of adhesive or sealant less water and less exempt compounds as determined in paragraph (b)(30) of Rule 1168.

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 10-08-1999]

Except as otherwise provided in Rule 1171, the operator shall not use a solvent to perform solvent cleaning unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	Current limits		Effective 12/1/2001	Effective 7/1/2005
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application				
(i) General	70 (0.58)		50 (0.42)	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)	33	500 (4.2)	100 (0.83)
(iii) Medical Devices & Pharmaceuticals	900 (7.5)	33	800 (6.7)	800 (6.7)
(B) Repair and Maintenance Cleaning				
(i) General	50 (0.42)		50 (0.42)	25 (0.21)

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 10-08-1999]

SOLVENT CLEANING ACTIVITY	Current limits		Effective 12/1/2001	Effective 7/1/2005
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)	20	900 (7.5)	100 (0.83)
(iii) Medical Devices & Pharmaceuticals	900 (7.5)	33		
(I) Tools, Equipment, & Machinery			800 (6.7)	800 (6.7)
(II) General Work Surfaces			600 (5.0)	600 (5.0)
(C) Cleaning of Coatings, or Adhesives Application Equipment	950 (7.9)	35	550 (4.6)	25 (0.21)
(D) Cleaning of Ink Application Equipment				
(i) General	100 (0.83)	3	50 (0.42)	25 (0.21)
(ii) Flexographic Printing	100 (0.83)	3	50 (0.42)	25 (0.21)
(iii) Gravure Printing				
(I) Publication	900 (7.5)	25	750 (6.3)	100 (0.83)
(II) Packaging	100 (0.83)	3	50 (0.42)	25 (0.21)

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 10-08-1999]

	Current limits		Effective 12/1/2001	Effective 7/1/2005
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
SOLVENT CLEANING ACTIVITY				
(iv) Lithographic or Letter Press Printing				
(I) Roller Wash – Step 1	900	10	600 (5.0)	100 (0.83)
(II) Roller Wash- Step 2, Blanket Wash, & On- Press Components	900	10	800 (6.7)	100 (0.83)
(III) Removable Press Components			50 (0.42)	25 (0.21)
(v) Screen Printing	1070 (8.9)	5	750 (6.3)	100 (0.83)
(vi) Ultraviolet Ink Application Equipment (except screen printing)	800 (6.7)	33	800 (6.7)	100 (0.83)
(vii) Specialty Flexographic Printing	810 (6.8)	21	600 (5.0)	100 (0.83)
(E) Cleaning of Polyester Resin Application Equipment	50 (0.42)		50 (0.42)	25 (0.21)

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 06-13-1997]

Except as otherwise provided in Rule 1171, the operator shall not use a solvent to perform solvent cleaning unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS		Effective 1/1/1999	
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application				
(i) General	70 (0.58)			
(ii) Electronic Components or Medical Devices	900 (7.5)	33		
(B) Repair and Maintenance Cleaning				
(i) General	900 (7.5)	20	50 (0.42)	
(ii) Electrical Apparatus Components	900 (7.5)	20		
(iii) Medical Devices	900 (7.5)	33		

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 06-13-1997]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS		Effective 1/1/1999	
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)
(C) Cleaning of Coatings, or Adhesives Application Equipment	950 (7.9)	35		
(D) Cleaning of Ink Application Equipment				
(i) General	100 (0.83)	3		
(ii) Flexographic or Gravure Printing	100 (0.83)	3		
(iii) Lithographic or Letter Press Printing	900 (7.5)	25		10
(iv) Screen Printing	1070 (8.9)	5		
(v) Ultraviolet Inks (except screen printing)	800 (6.7)	33		
(vi) Specialty Flexographic Printing	810 (6.8)	21		
(E) Cleaning of Polyester Resin Application Equipment	50 (0.42)			
or		1		

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

FACILITY PERMIT TO OPERATE LAC/USC MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter" Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100



South Coast Air Quality Management District
 P. O. Box 4944
 Diamond Bar, CA 91765
 (909) 396-2000

APPLICATION FOR PERMIT TO CONSTRUCT AND PERMIT TO OPERATE FORM 400 - A (5-Year Title V Renewal)

Non-Title V Facilities: This form must be accompanied by one or more 400-E-xx series form(s). Complete this side of form only.
Title V Facilities: Complete both sides of this form. Include additional forms as necessary.

NC/NOV NUMBER:	
INSPECTOR	SECTOR
ISSUE DATE	

Section I - Company Information

LEGAL NAME OF OPERATOR LAC+USC Medical Center	<input type="checkbox"/> IRS OR <input type="checkbox"/> S. S. NUMBER
PERMIT TO BE ISSUED TO (SEE INSTRUCTIONS)	
BUSINESS MAILING ADDRESS 1200 N. State St., Los Angeles, CA 90033	
PERMIT MAILING ADDRESS, IF DIFFERENT FROM BUSINESS MAILING ADDRESS	
TYPE OF ORGANIZATION <input type="checkbox"/> Corporation <input type="checkbox"/> Limited Partnership <input checked="" type="checkbox"/> Government Entity <input type="checkbox"/> Individual <input type="checkbox"/> General Partnership <input type="checkbox"/> Other (Fill in):	
ARE YOU A SMALL BUSINESS? (SEE INSTRUCTIONS) <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	AVERAGE ANNUAL GROSS RECEIPTS \$ _____ NUMBER OF EMPLOYEES _____
IS YOUR BUSINESS 51% OR MORE WOMAN/MINORITY OWNED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

THIS SECTION IS REQUIRED FOR ALL APPLICATIONS FOR NEW CONSTRUCTION OR MAJOR MODIFICATIONS.
 ARE ALL MAJOR SOURCES UNDER SAME OWNERSHIP IN CALIFORNIA IN COMPLIANCE WITH FEDERAL, STATE, AND LOCAL AIR POLLUTION CONTROL RULES? Yes No
 ARE YOU THE OWNER OF THE EQUIPMENT UNDER THIS APPLICATION? Yes No
 IF NO, ENTER THE LEGAL NAME OF OWNER _____

Section II - Facility Information

EQUIPMENT ADDRESS/LOCATION 1200 N. State St. Los Angeles, CA	FACILITY NAME LAC+USC Medical Center FACILITY ID NUMBER 020197
PRINT NAME OF CONTACT PERSON Brian Pettit	TITLE OF CONTACT PERSON _____
TYPE OF BUSINESS AT THIS FACILITY Hospital / Health Care Services	PRIMARY SIC CODE FOR THIS FACILITY _____ NUMBER OF EMPLOYEES AT THIS FACILITY _____
CONTACT PERSON'S TELEPHONE NUMBER (310) 409-3035	CONTACT PERSON'S FAX NUMBER _____ CONTACT PERSON'S E-MAIL ADDRESS _____

Section III - Application Type

DESCRIPTION OF EQUIPMENT: 5-Year Title V Renewal	PREVIOUS PERMIT #(S): _____																						
APPLICATION FOR (SEE INSTRUCTIONS): <input type="checkbox"/> NEW CONSTRUCTION <input type="checkbox"/> MODIFICATION <input type="checkbox"/> CHANGE OF LOCATION <input type="checkbox"/> EXISTING EQUIPMENT WITHOUT PERMIT <input type="checkbox"/> CHANGE OF PERMITTEE <input type="checkbox"/> CHANGE OF PERMIT CONDITION <input type="checkbox"/> EXISTING EQUIPMENT WITH EXPIRED PERMIT	ARE YOU SUBMITTING MULTIPLE APPLICATIONS FOR EQUIPMENT IDENTICAL TO THAT DESCRIBED ABOVE? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																						
<input checked="" type="checkbox"/> APPLICATION FOR NON-TITLE V EQUIPMENT PERMIT. CHECK THE SUPPLEMENTAL SERIES 400-E-xx FORM(S) SUBMITTED WITH THIS 400-A FORM: <table border="0"> <tr> <td>_____ 400-E-1 • PARTICULATE MATTER (PM₁₀) CONTROL EQUIPMENT</td> <td>_____ 400-E-13 • INTERNAL COMBUSTION EQUIPMENT</td> </tr> <tr> <td>_____ 400-E-2 • VOLATILE ORGANIC COMPOUND (VOC) CONTROL EQUIPMENT</td> <td>_____ 400-E-14 • OPEN PROCESS TANK</td> </tr> <tr> <td>_____ 400-E-3 • SCRUBBER</td> <td>_____ 400-E-14a • OPEN PROCESS TANK; PROCESS LINE</td> </tr> <tr> <td>_____ 400-E-4 • ABRASIVE BLASTING EQUIPMENT</td> <td>_____ 400-E-15 • PRINTING EQUIPMENT</td> </tr> <tr> <td>_____ 400-E-6 • DEGREASER</td> <td>_____ 400-E-16 • SOLID MATERIALS STORAGE EQUIPMENT</td> </tr> <tr> <td>_____ 400-E-7 • DRY CLEANING EQUIPMENT</td> <td>_____ 400-E-17 • SPRAY BOOTH/OPEN SPRAY</td> </tr> <tr> <td>_____ 400-E-8 • ETHYLENE OXIDE STERILIZER</td> <td>_____ 400-E-17a • POWDER SPRAY BOOTH</td> </tr> <tr> <td>_____ 400-E-9 • EXTERNAL COMBUSTION EQUIPMENT</td> <td>_____ 400-E-18 • STORAGE TANK (LIQUID & GASEOUS MAT'L)</td> </tr> <tr> <td>_____ 400-E-10 • FOOD BROILER/FRYER</td> <td>_____ 400-E-19 • WAVE SOLDER MACHINE</td> </tr> <tr> <td>_____ 400-E-11 • FUEL DISPENSING AND STORAGE EQUIPMENT</td> <td>_____ 400-E-20 • ASBESTOS REMOVAL EQUIPMENT</td> </tr> <tr> <td>_____ 400-E-12 • GAS TURBINE</td> <td>_____ NONE • ADDITIONAL INFORMATION SUBMITTED AS REQUESTED ON FORM 400-E-GI</td> </tr> </table>		_____ 400-E-1 • PARTICULATE MATTER (PM ₁₀) CONTROL EQUIPMENT	_____ 400-E-13 • INTERNAL COMBUSTION EQUIPMENT	_____ 400-E-2 • VOLATILE ORGANIC COMPOUND (VOC) CONTROL EQUIPMENT	_____ 400-E-14 • OPEN PROCESS TANK	_____ 400-E-3 • SCRUBBER	_____ 400-E-14a • OPEN PROCESS TANK; PROCESS LINE	_____ 400-E-4 • ABRASIVE BLASTING EQUIPMENT	_____ 400-E-15 • PRINTING EQUIPMENT	_____ 400-E-6 • DEGREASER	_____ 400-E-16 • SOLID MATERIALS STORAGE EQUIPMENT	_____ 400-E-7 • DRY CLEANING EQUIPMENT	_____ 400-E-17 • SPRAY BOOTH/OPEN SPRAY	_____ 400-E-8 • ETHYLENE OXIDE STERILIZER	_____ 400-E-17a • POWDER SPRAY BOOTH	_____ 400-E-9 • EXTERNAL COMBUSTION EQUIPMENT	_____ 400-E-18 • STORAGE TANK (LIQUID & GASEOUS MAT'L)	_____ 400-E-10 • FOOD BROILER/FRYER	_____ 400-E-19 • WAVE SOLDER MACHINE	_____ 400-E-11 • FUEL DISPENSING AND STORAGE EQUIPMENT	_____ 400-E-20 • ASBESTOS REMOVAL EQUIPMENT	_____ 400-E-12 • GAS TURBINE	_____ NONE • ADDITIONAL INFORMATION SUBMITTED AS REQUESTED ON FORM 400-E-GI
_____ 400-E-1 • PARTICULATE MATTER (PM ₁₀) CONTROL EQUIPMENT	_____ 400-E-13 • INTERNAL COMBUSTION EQUIPMENT																						
_____ 400-E-2 • VOLATILE ORGANIC COMPOUND (VOC) CONTROL EQUIPMENT	_____ 400-E-14 • OPEN PROCESS TANK																						
_____ 400-E-3 • SCRUBBER	_____ 400-E-14a • OPEN PROCESS TANK; PROCESS LINE																						
_____ 400-E-4 • ABRASIVE BLASTING EQUIPMENT	_____ 400-E-15 • PRINTING EQUIPMENT																						
_____ 400-E-6 • DEGREASER	_____ 400-E-16 • SOLID MATERIALS STORAGE EQUIPMENT																						
_____ 400-E-7 • DRY CLEANING EQUIPMENT	_____ 400-E-17 • SPRAY BOOTH/OPEN SPRAY																						
_____ 400-E-8 • ETHYLENE OXIDE STERILIZER	_____ 400-E-17a • POWDER SPRAY BOOTH																						
_____ 400-E-9 • EXTERNAL COMBUSTION EQUIPMENT	_____ 400-E-18 • STORAGE TANK (LIQUID & GASEOUS MAT'L)																						
_____ 400-E-10 • FOOD BROILER/FRYER	_____ 400-E-19 • WAVE SOLDER MACHINE																						
_____ 400-E-11 • FUEL DISPENSING AND STORAGE EQUIPMENT	_____ 400-E-20 • ASBESTOS REMOVAL EQUIPMENT																						
_____ 400-E-12 • GAS TURBINE	_____ NONE • ADDITIONAL INFORMATION SUBMITTED AS REQUESTED ON FORM 400-E-GI																						
<input checked="" type="checkbox"/> APPLICATION FOR TITLE V FACILITY PERMIT. PROVIDE INFORMATION REQUESTED ON REVERSE SIDE OF THIS FORM.																							

I HEREBY CERTIFY THAT ALL INFORMATION CONTAINED HEREIN AND INFORMATION SUBMITTED WITH THIS APPLICATION IS TRUE AND CORRECT.

SIGNATURE OF RESPONSIBLE OFFICIAL OF FIRM: <i>[Signature]</i>	TITLE OF RESPONSIBLE OFFICIAL OF FIRM: Director of Facilities Management
TYPE OR PRINT NAME OF RESPONSIBLE OFFICIAL OF FIRM: Luis Fonseca	RESPONSIBLE OFFICIAL'S TELEPHONE NUMBER (323) 226-2410
	DATE SIGNED: 4/29/11

I HEREBY CERTIFY THAT ALL INFORMATION CONTAINED HEREIN AND INFORMATION SUBMITTED WITH THIS APPLICATION IS TRUE AND CORRECT.

SIGNATURE OF PREPARER, IF PREPARED BY PERSON OTHER THAN RESPONSIBLE OFFICIAL OF FIRM: <i>[Signature]</i>	TITLE OF PREPARER: Senior Project Manager, SCEC
TYPE OR PRINT NAME OF PREPARER, IF PREPARED BY PERSON OTHER THAN RESPONSIBLE OFFICIAL OF FIRM: John Furlong	PREPARER'S TELEPHONE NUMBER (714) 282-8240
	DATE SIGNED: 4-27-11

TITLE V FACILITIES ONLY: COMPLETE OTHER SIDE

AQMD USE ONLY	APPLICATION/TRACKING # 922467	PROJECT #	TYPE B C D	EQUIPMENT CATEGORY CODE: 5550021	FEE SCHEDULE:	VALIDATION 5/11/11
ENG. DATE 6-23-11	ENG. A R DATE	CLASS I III IV	ASSIGNMENT UNIT E	ENF. SECT.	CHECK/MONEY ORDER AMOUNT #13953278	AMOUNT 1986.84

66 94590 B#11