

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Title V Permit Summary

AQMD Facility ID:	128243	Company Name:	BURBANK CITY, BURBANK WATER AND POWER, SCPPA	
Equipment Location:	164 W. MAGNOLIA BLVD, BURBANK, CA 91502		SIC Code:	4911
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected:		
Application #(s):	556920	Application Submittal Date(s):	10/8/13	
AQMD Contact Person:	CHRIS PERRI	Phone #:	E-Mail Address:	
		(909) 396-2696	cperri@aqmd.gov	
Project Description: This is an existing facility applying for a renewal to their Title V permit. The facility produces electrical power for it's member agencies. This facility operates 1 natural gas fired turbine equipped with SCR and CO catalysts. The approximate total facility generating capacity is 343 MWs.				
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal				
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input checked="" type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other _____ <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance				
Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for Reporting Year: 2013				
<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> The Following TACs Were Reported:				
	<u>TAC</u>	<u>LBS/YR</u>	<u>TAC</u>	<u>LBS/YR</u>
	1,3 BUTADIENE	3.538	FORMALDEHYDE	5435.4
	AMMONIA	145079	LEAD	0.006
	ARSENIC	0.014	NAPHTHALENE	10.719
	BENZENE	98.331	NICKEL	0.035
	CADMIUM	0.001	PAHS	7.399
	Chrome IV	0.001		
Health Risk From Toxic Air Contaminants:				
<input type="checkbox"/> Health Risk Reduction Plan in Force (AQMD Rule 1402) (date): _____ <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input checked="" type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input checked="" type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input type="checkbox"/> Final Facility Health Risk Approved Cancer Risk = _____ Acute Hazard Index = _____ Chronic Hazard Index = _____				
Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2013				
	<input checked="" type="checkbox"/> NOx	23.372	<input checked="" type="checkbox"/> PM	6.749
	<input checked="" type="checkbox"/> CO	8.704	<input checked="" type="checkbox"/> SOx	0.429
	<input checked="" type="checkbox"/> VOC	8.463	<input type="checkbox"/> Other:	_____
Compliance History: <input checked="" type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years (0) <input checked="" type="checkbox"/> Notices to Comply Issued in Last Two Calendar Years (0) <input checked="" type="checkbox"/> Notices of Violation Issued in Last Two Calendar Years (0)				
Comments:				