



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 7, 2011

Mr. Gerardo Rios
Chief - Permit Office
US EPA, Region IX Air 3
75 Hawthorne Street
San Francisco, CA 94105

Dear Mr. Rios:

Subject: Transmittal of Proposed Title V Renewal Permit
Cedars-Sinai Medical Center ID 16389

Enclosed are the proposed Title V renewal permit, permit summary, statement of basis, public notice, and the permit evaluation for Cedars-Sinai Medical Center, located at 8700 Beverly Blvd., Los Angeles, CA 90048. With your receipt of the proposed Title V renewal permit, we will note that the EPA's 45-day review period will begin on September 7, 2011.

If you have any questions concerning the proposed Title V renewal permit, please contact Ms. Vicky Lee, Air Quality Engineer, at (909) 396-2284 or by e-mail at vleel@aqmd.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Brian L. Yeh', is written over a diagonal line that extends from the signature area down towards the typed name.

Brian L. Yeh
Senior Manager
Mechanical, Chemical, and Public Services

BLY:AYL:JTY:VL

Enclosures:

Proposed Title V Renewal Permit
Permit Summary
Statement of Basis
Public Notice



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

NOTICE OF PROPOSED TITLE V RENEWAL PERMIT

The South Coast Air Quality Management District (AQMD) is proposing to renew the existing Title V permit that was previously issued to the following facility:

Cedars-Sinai Medical Center
8700 Beverly Blvd.
Los Angeles, CA 90048
Facility ID# 16389

Contact Person:

Jeffrey Deeter
VP, Clinical Support Services
8700 Beverly Blvd., TSB 190
Los Angeles, CA 90048

This is an existing facility applying for a Title V permit renewal. This hospital is operating 11 diesel fueled internal combustion engines driving emergency generators, four diesel fuel tanks, and three boilers that will be controlled with selective catalytic reduction systems. The selective catalytic reduction systems are under construction.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, the above facility has submitted a Title V renewal application and requested the AQMD to renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The proposed permit is available for public review at AQMD, 21865 Copley Dr., Diamond Bar, CA 91765 and at the Fairfax

Branch Library, 161 S. Gardner Street, Los Angeles, CA 90036. Information regarding the facility owner's compliance history submitted to the AQMD pursuant to California Health & Safety Code Section 42336, or otherwise known to the AQMD based on credible information, is also available from the AQMD for public review. For more information or to review additional supporting documents, call the AQMD's Title V hotline at (909) 396-3013. Written comments should be submitted to:

South Coast Air Quality Management District
Mechanical, Chemical, and Public Services Team
21865 Copley Drive
Diamond Bar, CA 91765
Attention: Vicky Lee

Comments must be received by October 9, 2011. The AQMD will consider all public comments and may revise the Title V permit in accordance with AQMD rules and regulations.

The public may request AQMD to conduct a public hearing on the proposed permit by submitting a Hearing Request Form (Form 500-G) to Vicky Lee at the above AQMD address. The AQMD will hold a public hearing if there is evidence that the proposed permit is not correct or is not adequate to ensure compliance with regulatory requirements, and a hearing will likely provide additional information that will affect the drafting and/or issuance of the permit. A public hearing request form and the public hearing schedule may be obtained from the AQMD by calling the Title V hotline at (909) 396-3013, or from the internet at <http://www.aqmd.gov/titlev>. The request for a public hearing is due by September 26, 2011. A copy of the hearing request must also be sent by first class mail to the appropriate facility contact person listed above.

South Coast Air Quality Management District

Statement of Basis

Proposed Renewal of Title V Permit

Facility Name: Cedars-Sinai Medical Center
Facility ID: 16389
NAICS Code: 622110
Equipment Location: 8700 Beverly Blvd., Los Angeles, CA 90048

Application #(s): 517705
Application Submittal Date(s): 12/30/10

AQMD Contact Person: Vicky Lee, Air Quality Engineer
Phone Number: (909) 396-2284
E-Mail Address: vlee1@aqmd.gov

1. Introduction and Scope of Permit

Title V is a national operating permit program for air pollution sources. Facilities subject to Title V must obtain a Title V permit and comply with specific Title V procedures to modify the permit. This permit replaces the facility's other existing permits. Title V does not necessarily include any new requirements for reducing emissions. It does, however, include new permitting, noticing, recordkeeping, and reporting requirements.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, each facility is required to submit a Title V renewal application and request the AQMD to renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The AQMD implements Title V through Regulation XXX – Title V Permits, adopted by the AQMD Governing Board in order to comply with EPA's requirement that local air permitting authorities develop a Title V program. Regulation XXX was developed with the participation of the public and affected facilities through a series of public workshops, working group meetings, public hearings and other meetings.

The Title V major source threshold for a particular pollutant depends on the attainment status of the pollutant. CO, NO₂, SO₂, and lead are in attainment with federal standards. The status for PM-10 is serious nonattainment. The status for ozone is currently extreme nonattainment.

A Title V renewal permit is proposed to be issued to cover the operations of Cedars-Sinai Medical Center at 8700 Beverly Blvd, Los Angeles, CA 90048. This facility is subject to Title V requirements because it is a major source.

2. Facility Description

Cedars-Sinai Medical Center is a Title V facility that provides healthcare services to patients, conducts biomedical research, and provides training to physicians and other healthcare professionals. The facility is operating 11 diesel fueled internal combustion engines driving emergency generators, four diesel fuel tanks, and three boilers that will be controlled with selective catalytic reduction systems. The selective catalytic reduction systems are under construction.

3. Construction and Permitting History

An initial Title V permit was issued to the facility on 3/21/2001 and expired on 3/20/2006. The first Title V renewal permit was issued on 7/5/06 and expired on 7/4/11. The facility has been in continuous operation.

4. Regulatory Applicability Determinations

Applicable legal requirements for which this facility is required to comply are required to be identified in the Title V permit (for example, Section D, E, and H of the proposed Title V permit). Applicability determinations (i.e., determinations made by the District with respect to what legal requirements apply to a specific piece of equipment, process, or operation) can be found in the Engineering Evaluations. There are no NSPS or NESHAP requirements that are applicable to this facility.

5. Monitoring and Operational Requirements

Applicable monitoring and operational requirements for which the facility is required to comply are identified in the Title V permit (for example, Section D, F, and J and Appendix B of the proposed Title V permit). Discussion of any applicable monitoring and operational requirements can be found in the Engineering Evaluations. All periodic monitoring requirements were developed using strict adherence to the following applicable guidance documents: SCAQMD Periodic Monitoring Guidelines for Title V Facilities (November 1997); CAPCOA/CARB/EPA Region IX Periodic Monitoring Recommendations for Generally Applicable Requirements in SIP (June 1999); and CAPCOA/CARB/EPA Region IX Recommended Periodic Monitoring for Generally Applicable Grain Loading Standards in SIP: Combustion Sources (July 2010).

The three boilers and selective catalytic reduction systems are not subject to the Compliance Assurance Monitoring (CAM) requirements of 40 CFR Part 64 because the uncontrolled NO_x emissions from each boiler is less than the major source threshold of 10 tons per year for NO_x as a result of the annual gas usage permit limit.

6. Permit Features

Permit Shield

A permit shield is an optional part of a Title V permit that gives the facility an explicit protection from requirements that do not apply to the facility. A permit shield is a provision in a permit that states that compliance with the conditions of the permit shall be deemed compliance with all identified regulatory requirements. To incorporate a permit shield into the Title V permit involves submission of applications for change of conditions for each equipment affected by the permit shield. Permit shields are addressed in Rule 3004 (c). This facility has not applied for a permit shield.

Streamlining Requirements

Some emission units may be subject to multiple requirements which are closely related or redundant. The conditions may be streamlined to simplify the permit conditions and compliance. Emission limits, work practice standards, and monitoring, recordkeeping, and reporting requirements may be streamlined. Compliance with a streamlined condition will be deemed compliance with the underlying requirements whether or not the emission unit is actually in compliance with the specific underlying requirement. This facility has not applied for any streamlined conditions.

7. Summary of Emissions and Health Risks

Criteria Pollutant Emissions (tons/year) Annual Reported Emissions for Reporting Period 2010

Pollutant	Emissions (tons/year)
NOx	3.449
CO	1.145
VOC	12.485
PM	5.366
SOx	0.080

Toxic Air Contaminants Emissions (TAC) Annual Reported Emissions for Reporting Period 2010

The Following TACs Were Reported	Emissions (lbs/yr)
1,3-Butadiene	1.974
Ammonia	492.924
Arsenic	0.033
Asbestos	0.105
Benzene	1.775
Cadmium	0.031
Chromium (VI)	0.002
Formaldehyde	18.995
Lead (inorganic)	0.172
Naphthalene	0.235
Nickel	0.080

PAHS, total, with components not reported	0.857
---	-------

Health Risk from Toxic Air Contaminants

The facility is subject to review by the Air Toxics Information and Assessment Act (AB2588). The AQMD is tracking the status of the facility under AB2588.

8. Compliance History

The facility has been subject to both self-reporting requirements and AQMD inspections. The facility has had no citizen complaints filed in the last two calendar years. No Notice to Comply (NC) and no Notice of Violation (NOV) have been issued in the last two calendar years. The facility is currently in compliance with all applicable rules and regulations.

9. Compliance Certification

By virtue of the Title V permit application and issuance of this permit, the reporting frequency for compliance certification for the facility shall be annual.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Title V Permit Summary

AQMD Facility ID:	16389	Company Name:	CEDARS-SINAI MEDICAL CENTER																										
Equipment Location:	8700 BEVERLY BLVD., LOS ANGELES, CA 90048		SIC Code: 8062																										
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected:																											
Application #(s):	517705	Application Submittal Date(s): December 30, 2010																											
AQMD Contact Person:	Vicky Lee	Phone #:	E-Mail Address:																										
		(909) 396-2284	vlee1@aqmd.gov																										
Project Description: This is an existing facility applying for a Title V permit renewal. This hospital is operating 11 diesel fueled internal combustion engines driving emergency generators, four diesel fuel storage tanks, and three natural gas fueled boilers that will be controlled by selective catalytic reduction systems. The selective catalytic reduction systems are under construction.																													
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal																													
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other: _____ <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance																													
Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for Reporting Year: 2010		<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> The Following TACs Were Reported: <table style="margin-left: 20px; width: 100%;"> <thead> <tr> <th style="text-align: left;"></th> <th style="text-align: right;">Emissions (lbs/yr):</th> </tr> </thead> <tbody> <tr><td>1,3-Butadiene</td><td style="text-align: right;">1.974</td></tr> <tr><td>Ammonia</td><td style="text-align: right;">492.924</td></tr> <tr><td>Arsenic</td><td style="text-align: right;">0.033</td></tr> <tr><td>Asbestos</td><td style="text-align: right;">0.105</td></tr> <tr><td>Benzene</td><td style="text-align: right;">1.775</td></tr> <tr><td>Cadmium</td><td style="text-align: right;">0.031</td></tr> <tr><td>Chromium (VI)</td><td style="text-align: right;">0.002</td></tr> <tr><td>Formaldehyde</td><td style="text-align: right;">18.995</td></tr> <tr><td>Lead (inorganic)</td><td style="text-align: right;">0.172</td></tr> <tr><td>Naphthalene</td><td style="text-align: right;">0.235</td></tr> <tr><td>Nickel</td><td style="text-align: right;">0.080</td></tr> <tr><td>PAHS, total, with components not reported</td><td style="text-align: right;">0.857</td></tr> </tbody> </table>			Emissions (lbs/yr):	1,3-Butadiene	1.974	Ammonia	492.924	Arsenic	0.033	Asbestos	0.105	Benzene	1.775	Cadmium	0.031	Chromium (VI)	0.002	Formaldehyde	18.995	Lead (inorganic)	0.172	Naphthalene	0.235	Nickel	0.080	PAHS, total, with components not reported	0.857
	Emissions (lbs/yr):																												
1,3-Butadiene	1.974																												
Ammonia	492.924																												
Arsenic	0.033																												
Asbestos	0.105																												
Benzene	1.775																												
Cadmium	0.031																												
Chromium (VI)	0.002																												
Formaldehyde	18.995																												
Lead (inorganic)	0.172																												
Naphthalene	0.235																												
Nickel	0.080																												
PAHS, total, with components not reported	0.857																												
Health Risk From Toxic Air Contaminants: <input type="checkbox"/> Health Risk Reduction Plan in Force (AQMD Rule 1402) (date): _____ <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input checked="" type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input checked="" type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input type="checkbox"/> Final Facility Health Risk Approved (date) _____ Cancer Risk = _____ in one million Acute Hazard Index = _____ Chronic Hazard Index = _____																													
Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2009 (2010 not available)		<input checked="" type="checkbox"/> NOx 3.449 <input checked="" type="checkbox"/> PM 5.366 <input checked="" type="checkbox"/> CO 1.145 <input checked="" type="checkbox"/> SOx 0.080 <input checked="" type="checkbox"/> VOC 12.485 <input type="checkbox"/> Other: _____																											
Compliance History: <input checked="" type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years (#0) <input checked="" type="checkbox"/> Notices to Comply (NC) Issued in Last Two Calendar Years (# 0) <input checked="" type="checkbox"/> Notices of Violation (NOV) Issued in Last Two Calendar Years (# 0)																													

FACILITY PERMIT TO OPERATE

**CEDARS-SINAI MEDICAL CTR
8700 BEVERLY BLVD.
LOS ANGELES, CA 90048**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By _____
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	09/06/2011
B	RECLAIM Annual Emission Allocation	DRAFT	09/06/2011
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	09/06/2011
E	Administrative Conditions	DRAFT	09/06/2011
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	09/06/2011
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	09/06/2011
H	Permit To Construct and Temporary Permit to Operate	DRAFT	09/06/2011
I	Compliance Plans & Schedules	DRAFT	09/06/2011
J	Air Toxics	DRAFT	09/06/2011
K	Title V Administration	DRAFT	09/06/2011
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	09/06/2011
B	Rule Emission Limits	DRAFT	09/06/2011

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: CEDARS-SINAI MEDICAL CTR

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 8700 BEVERLY BLVD.
LOS ANGELES, CA 90048

MAILING ADDRESS: 8700 BEVERLY BLVD TSB190
LOS ANGELES, CA 90048-0750

RESPONSIBLE OFFICIAL: JEFFREY DEETER

TITLE: VICE PRESIDENT, CLINICAL SUPPORT
SERVICE

TELEPHONE NUMBER: (310) 423-3252

CONTACT PERSON: VICTOR KENNEDY

TITLE: MANAGER ENV. SAFETY & INDUSTRIAL
HYGIENE

TELEPHONE NUMBER: (310) 423-4336

TITLE V PERMIT ISSUED: July 05, 2006

TITLE V PERMIT EXPIRATION DATE: July 04, 2011

TITLE V		RECLAIM	
YES	NOx:	NO	
	SOx:	NO	
	CYCLE:	0	
	ZONE:	COASTAL	

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

NOT APPLICABLE

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

**Facility Equipment and Requirements
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit to Operate number	Equipment description
223484	D61488	BOILER (>50 MMBTU/HR) NAT GAS-DISTL PP
223485	D61570	BOILER (>50 MMBTU/HR) NAT GAS-DISTL PP
223486	D61485	BOILER (>50 MMBTU/HR) NAT GAS-DISTL PP
249844	D45165	I C E (>500 HP) EM ELEC GEN DIESEL
249845	D45166	I C E (>500 HP) EM ELEC GEN DIESEL
290663	D81544	I C E (50-500 HP) EM ELEC GEN-DIESEL
329953	F9154	STORAGE TANK DIESEL
329954	F9157	STORAGE TANK DIESEL
329955	F9156	STORAGE TANK DIESEL
329956	F9155	STORAGE TANK DIESEL
343820	F16016	ICE (50-500 HP) EM ELEC GEN DIESEL
353727	F35019	ICE (50-500 HP) EM ELEC GEN DIESEL
378130	F36173	I C E (>500 HP) EM ELEC GEN DIESEL
410733	F62172	I C E (>500 HP) EM ELEC GEN DIESEL
410735	F62173	I C E (>500 HP) EM ELEC GEN DIESEL
410736	F62174	I C E (>500 HP) EM ELEC GEN DIESEL
410737	F62176	I C E (>500 HP) EM ELEC GEN DIESEL
410738	F62175	I C E (>500 HP) EM ELEC GEN DIESEL
497314		SELECTIVE CATALYTIC REDUCTION
501990		SELECTIVE CATALYTIC REDUCTION
501991		SELECTIVE CATALYTIC REDUCTION
503717		BOILER (>50 MMBTU/HR) NAT GAS-DISTL PP
503718		BOILER (>50 MMBTU/HR) NAT GAS-DISTL PP
503719		BOILER (>50 MMBTU/HR) NAT GAS-DISTL PP

NOTE: EQUIPMENT LISTED ABOVE THAT HAS NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGLEMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]
2. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 431.2]
3. AFTER JUNE 1, 2004, THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
[RULE 431.2]
4. THE OPERATOR SHALL NOT USE NATURAL GAS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H₂S, IN EXCESS OF 16 PARTS PER MILLION BY VOLUME (PPMV). THE OPERATOR SHALL NOT USE OTHER GASEOUS FUELS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H₂S, IN EXCESS OF 40 PPMV AS MEASURED OVER 4 HOURS AVERAGING PERIOD.
[RULE 431.1]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. D61488
A/N 223484

Equipment Description:

BOILER, TRANE-MURRAY, MODEL NO. MCF 4-49, SERIAL NUMBER 10440, WITH A COEN, MODEL DAF/FGR 26, LOW-NOX BURNER, 61,887,000 BTU/HR NATURAL GAS FIRED, AND 40,000,000 BTU/ LOW NOX FUEL OIL FIRED, WITH INDUCED FLUE GAS RECIRCULATION, AND A 20 HP COMBUSTION AIR BLOWER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL FIRED.
[RULE 1146]
5. THE BOILER OPERATOR SHALL RECORD THE DAILY FUEL USE IN A MANNER APPROVED IN WRITING BY THE DISTRICT. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1146].
6. IF THE BOILER BURNS MORE THAN 1,355,320 TONS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER SHALL MEET THE 30 PPM OXIDES OF NITROGEN LIMIT OF RULE 1146 BY MARCH 1 OF THE FOLLOWING YEAR.
[RULE 1146]
7. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AND OPERATE FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(B).
[RULE 1146]

Periodic Monitoring:

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
10. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.
- IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
- A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
 - D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
- [RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

11. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- CO: 2000 PPMV, RULE 407
 - SOX: 500 PPMV, RULE 407
 - PM: 0.1 GR/SCF, RULE 409
 - CO: 400 PPMV, RULE 1146
 - NOX 40 PPMV, RULE 1146
 - NOX: 30 PPMV, RULE 1146

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. D61570
A/N 223485

Equipment Description:

BOILER, TRANE-MURRAY, MODEL NO. 4-49, SERIAL NUMBER 10441, WITH A COEN, MODEL DAF/FGR 26, LOW-NO_x BURNER, 61,887,000 BTU/HR NATURAL GAS FIRED, AND 40,000,000 BTU/ LOW NO_x FUEL OIL FIRED, WITH INDUCED FLUE GAS RECIRCULATION, AND A 20 HP COMBUSTION AIR BLOWER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL BE EQUIPPED WITH A NON-RESETTING, TOTALIZING FLOW METER FOR EACH FUEL FIRED.
[RULE 1146]
5. THE BOILER OPERATOR SHALL RECORD THE DAILY FUEL USE IN A MANNER APPROVED IN WRITING BY THE DISTRICT. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
6. IF THE BOILER BURNS MORE THAN 1,355,320 THERMS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER SHALL MEET THE 30 PPM OXIDES OF NITROGEN LIMIT OF RULE 1146 BY MARCH 1 OF THE FOLLOWING YEAR.
[RULE 1146]
7. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AND OPERATE FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(B).
[RULE 1146]

Periodic Monitoring:

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
10. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- C. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - D. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.
- IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
- E. STACK OR EMISSION POINT IDENTIFICATION;
 - F. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
 - G. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
 - H. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
- [RULE 3004 (a)(4)]
11. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

B. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
CO: 400 PPMV, RULE 1146
NOX 40 PPMV, RULE 1146
NOX: 30 PPMV, RULE 1146

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. D61485
A/N 223486

Equipment Description:

BOILER, TRANE-MURRAY, MODEL NO. MCF 4-49, SERIAL NUMBER 10439, WITH A COEN, MODEL DAF/FGR 26, LOW-NOX BURNER, 61,887,000 BTU/HR NATURAL GAS FIRED, AND 40,000,000 BTU/ LOW NOX FUEL OIL FIRED, WITH INDUCED FLUE GAS RECIRCULATION, AND A 20 HP COMBUSTION AIR BLOWER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL FIRED.
[RULE 1146]
5. THE BOILER OPERATOR SHALL RECORD THE DAILY FUEL USE IN A MANNER APPROVED IN WRITING BY THE DISTRICT. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
6. IF THE BOILER BURNS MORE THAN 1,355,320 THERMS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER SHALL MEET THE 30 PPM OXIDES OF NITROGEN LIMIT OF RULE 1146 BY MARCH 1 OF THE FOLLOWING YEAR.
[RULE 1146]
7. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AND OPERATE FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(B).
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

Periodic Monitoring:

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

10. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
 - E. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;
OR
 - F. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
 - I. STACK OR EMISSION POINT IDENTIFICATION;
 - J. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
 - K. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
 - L. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.[RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

11. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

C. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- CO: 2000 PPMV, RULE 407
 - SOX: 500 PPMV, RULE 407
 - PM: 0.1 GR/SCF, RULE 409
 - CO: 400 PPMV, RULE 1146
 - NOX 40 PPMV, RULE 1146
 - NOX: 30 PPMV, RULE 1146

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. D45165
A/N 249844

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 1, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 9163-7316, DIESEL-FUELED, TURBOCHARGED, AFTERCOOLED, 16 CYLINDERS, 1745 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
 - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. D45166
A/N 249845

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 2, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 9163-7316, DIESEL-FUELED, TURBOCHARGED, AFTERCOOLED, 16 CYLINDERS, 1745 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204].
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. D81544
A/N 290663

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3054, DIESEL FUELED, 4 CYLINDERS, TURBOCHARGED, 96 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
 - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F9154
A/N 329953

Equipment Description:

AMBER 363 FUEL STORAGE TANK (TANK NO. 2), UNDERGROUND, CYLINDRICAL, 12'-0" DIA. X 60'-0" L., 50,000-GALLON CAPACITY.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE MAXIMUM QUANTITY OF AMBER 363 FUEL UNLOADED INTO THE UNDERGROUND STORAGE TANKS ISSUED A PERMIT TO CONSTRUCT AND OPERATE UNDER A/N'S 329953, 329954, 329955, AND 329956 SHALL NOT EXCEED 2.08MM GALLONS TOTAL IN ANY ONE CALENDAR MONTH.
[RULE 1303 (b)(2)-OFFSETS]
- 4) AN OPERATING LOG LISTING THE DATE AND THE AMOUNT IN GALLONS OF AMBER 363 FUEL UNLOADED SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2)-OFFSETS].

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F9157
A/N 329954

Equipment Description:

AMBER 363 FUEL STORAGE TANK (TANK NO. 3), UNDERGROUND, CYLINDRICAL, 12'-0" DIA. X 60'-0" L., 50,000-GALLON CAPACITY.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE MAXIMUM QUANTITY OF AMBER 363 FUEL UNLOADED INTO THE UNDERGROUND STORAGE TANKS ISSUED A PERMIT TO CONSTRUCT AND OPERATE UNDER A/N'S 329953, 329954, 329955, AND 329956 SHALL NOT EXCEED 2.08MM GALLONS TOTAL IN ANY ONE CALENDAR MONTH.
[RULE 1303 (b)(2) OFFSETS]
- 4) AN OPERATING LOG LISTING THE DATE AND THE AMOUNT IN GALLONS OF AMBER 363 FUEL UNLOADED SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303 (b)(2) -OFFSETS]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F9156
A/N 329955

Equipment Description:

AMBER 363 FUEL STORAGE TANK (TANK NO. 4), UNDERGROUND, CYLINDRICAL, 12'-0" DIA. X 60'-0" L., 50,000-GALLON CAPACITY.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE MAXIMUM QUANTITY OF AMBER 363 FUEL UNLOADED INTO THE UNDERGROUND STORAGE TANKS ISSUED A PERMIT TO CONSTRUCT AND OPERATE UNDER A/N'S 329953, 329954, 329955, AND 329956 SHALL NOT EXCEED 2.08MM GALLONS TOTAL IN ANY ONE CALENDAR MONTH.
[RULE 1303 (b)(2) OFFSETS]
- 4) AN OPERATING LOG LISTING THE DATE AND THE AMOUNT IN GALLONS OF AMBER 363 FUEL UNLOADED SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303 (b)(2) OFFSETS]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F9155
A/N 329956

Equipment Description:

AMBER 363 FUEL STORAGE TANK (TANK NO. 1), UNDERGROUND, CYLINDRICAL, 12'-0" DIA. X 60'-0" L., 50,000-GALLON CAPACITY.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204].
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE MAXIMUM QUANTITY OF AMBER 363 FUEL UNLOADED INTO THE UNDERGROUND STORAGE TANKS ISSUED A PERMIT TO CONSTRUCT AND OPERATE UNDER A/N'S 329953, 329954, 329955, AND 329956 SHALL NOT EXCEED 2.08MM GALLONS TOTAL IN ANY ONE CALENDAR MONTH.
[RULE 1303 (b)(2) OFFSETS]
- 4) AN OPERATING LOG LISTING THE DATE AND THE AMOUNT IN GALLONS OF AMBER 363 FUEL UNLOADED SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303 (b)(2) OFFSETS]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F16016
A/N 342840

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 8063-7405, DIESEL FUELED, 8 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 423 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F35019
A/N 353727

Equipment Description:

INTERNAL COMBUSTION ENGINE, JOHN DEERE, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6059, DIESEL FUELED, TURBOCHARGED, 166 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]
9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F36173
A/N 378130

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3508, DIESEL FUELED, 8 CLYINDERS, TURBOCHARGED, AFTERCOOLED, 1486 B.H.P.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
 - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F62172
A/N 410733

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T163-7K36 (16V-4000), SERIAL NO. 5272001580, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2935 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F62173
A/N 410735

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T163-7K36 (16V-4000), SERIAL NO. 5272001581, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2935 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F62174
A/N 410736

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T163-7K36 (16V-4000), SERIAL NO. 5272001582, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2935 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F62176
A/N 410737

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T163-7K36 (16V-4000), SERIAL NO. 5272001601, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2935 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO OPERATE

Permit No. F62175
A/N 410738

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T163-7K36 (16V-4000), SERIAL NO. 5272001602, DIESEL FUELED, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, 2935 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

6. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
 - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

8. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1110.2, RULE 1304 (a)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO CONSTRUCT

Permit No.
A/N 497314

Equipment Description:

SELECTIVE CATALYTIC REDUCTION SYSTEM, NO. 1, HOLDER TOPSOE, MODEL NO. DNX-929. WITH A CORRUGATED PLATE TYPE CATALYST BED, TWIN LAYER, 4,800 POUNDS OF CATALYST, WITH AN ANHYDROUS AMMONIA VAPOR/AIR INJECTION GRID, AND AN INTERCONNECTING AMMONIA STORAGE SYSTEM WITH A CAPACITY OF 150 GALLONS, SERVING BOILER NO. B-1 (SERIAL NO. 10440).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THIS SYSTEM SHALL BE IN OPERATION WHENEVER THE BOILER IT IS VENTING IS IN OPERATION, EXCEPT AS OTHERWISE NOTED IN THIS PERMIT.
[RULE 1146]
- 4) THE TEMPERATURE OF EXHAUST GASES ENTERING THE SCR UNIT SHALL NOT EXCEED 700 DEGREES FAHRENHEIT.
[RULE 1146]
- 5) A CHART RECORDER SHALL BE INSTALLED AND MAINTAINED TO RECORD THE FOLLOWING.
 - A. THE DATE AND TIME.
 - B. THE TYPE OF FUEL AND HOURLY AVERAGE AMOUNT OF FUEL USED.
 - C. THE EXHAUST GAS INLET TEMPERATURE TO THE SCR.

RECORDS FOR THE ABOVE SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

- 6) NOX MONITORS SHALL BE INSTALLED AND OPERATED TO MEASURE THE OUTLET NOX CONCENTRATION OF THE SELECTIVE CATALYTIC REDUCTION SYSTEM. THE NOX MONITORS SHALL BE MAINTAINED AND OPERATED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS. RECORDS OF ALL CALIBRATIONS AND MAINTENANCE SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO THE DISTRICT UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

- 7) THE HOURLY AVERAGE NOX EMISSIONS AT THE EXIT OF SCR UNIT SHALL NOT EXCEED 5 PPM (FIRING ON NATURAL GAS) AND 40 PPM (FIRING ON AMBER OIL) BOTH CORRECTED TO 3% O₂ WHEN THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT.
[RULE 1146]
- 8) THE AMMONIA INJECTION SYSTEM SHALL BE OPERATED WHENEVER THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT.
[RULE 1146]
- 9) THE HOURLY AVERAGE AMMONIA EMISSIONS AT THE EXIT OF THE SCR UNIT SHALL NOT EXCEED 5 PPM CORRECTED TO 3% O₂.
[RULE 1303(a) (1)- BACT]
- 10) THE OPERATOR OF THIS BOILER SHALL COMPLY WITH ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (D)--COMPLIANCE DETERMINATION OF RULE 1146. THE ANNUAL TESTING SHALL ALSO MEASURE AMMONIA EMISSIONS (1-HR TESTING) USING DISTRICT TEST METHOD 207.1 TO COMPLY WITH CONDITION NO. 9.
[RULE 1146]

Emissions and Requirements:

- 11). THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NH₃: 5 PPMV, RULE 1303(a)(1)

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO CONSTRUCT

Permit No.
A/N 501990

Equipment Description:

SELECTIVE CATALYTIC REDUCTION SYSTEM, NO. 2, HOLDER TOPSOE, MODEL NO. DNX-929. WITH A CORRUGATED PLATE TYPE CATALYST BED, TWIN LAYER, 4,800 POUNDS OF CATALYST, WITH AN ANHYDROUS AMMONIA VAPOR/AIR INJECTION GRID, AND AN INTERCONNECTING AMMONIA STORAGE SYSTEM WITH A CAPACITY OF 150 GALLONS, SERVING BOILER NO. B-2 (SERIAL NO. 10441).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THIS SYSTEM SHALL BE IN OPERATION WHENEVER THE BOILER IT IS VENTING IS IN OPERATION, EXCEPT AS OTHERWISE NOTED IN THIS PERMIT.
[RULE 1146]
- 4) THE TEMPERATURE OF EXHAUST GASES ENTERING THE SCR UNIT SHALL NOT EXCEED 700 DEGREES FAHRENHEIT.
[RULE 1146]
- 5) A CHART RECORDER SHALL BE INSTALLED AND MAINTAINED TO RECORD THE FOLLOWING.
 - A. THE DATE AND TIME.
 - B. THE TYPE OF FUEL AND HOURLY AVERAGE AMOUNT OF FUEL USED.
 - C. THE EXHAUST GAS INLET TEMPERATURE TO THE SCR.

RECORDS FOR THE ABOVE SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

- 6) NOX MONITORS SHALL BE INSTALLED AND OPERATED TO MEASURE THE OUTLET NOX CONCENTRATION OF THE SELECTIVE CATALYTIC REDUCTION SYSTEM. THE NOX MONITORS SHALL BE MAINTAINED AND OPERATED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS. RECORDS OF ALL CALIBRATIONS AND MAINTENANCE SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO THE DISTRICT UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

- 7) THE HOURLY AVERAGE NOX EMISSIONS AT THE EXIT OF SCR UNIT SHALL NOT EXCEED 5 PPM (FIRING ON NATURAL GAS) AND 40 PPM (FIRING ON AMBER OIL) BOTH CORRECTED TO 3% O₂ WHEN THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT.
[RULE 1146]
- 8) THE AMMONIA INJECTION SYSTEM SHALL BE OPERATED WHENEVER THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT.
[RULE 1146]
- 9) THE HOURLY AVERAGE AMMONIA EMISSIONS AT THE EXIT OF THE SCR UNIT SHALL NOT EXCEED 5 PPM CORRECTED TO 3% O₂.
[RULE 1303(a)(1)- BACT]
- 10) THE OPERATOR OF THIS BOILER SHALL COMPLY WITH ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (D)--COMPLIANCE DETERMINATION OF RULE 1146. THE ANNUAL TESTING SHALL ALSO MEASURE AMMONIA EMISSIONS (1-HR TESTING) USING DISTRICT TEST METHOD 207.1 TO COMPLY WITH CONDITION NO. 9.
[RULE 1146]

Emissions and Requirements:

- 11) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NH₃: 5 PPMV, RULE 1303(a)(1)

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO CONSTRUCT

Permit No.
A/N 501991

Equipment Description:

SELECTIVE CATALYTIC REDUCTION SYSTEM, NO. 3, HOLDER TOPSOE, MODEL NO. DNX-929. WITH A CORRUGATED PLATE TYPE CATALYST BED, TWIN LAYER, 4,800 POUNDS OF CATALYST, WITH AN ANHYDROUS AMMONIA VAPOR/AIR INJECTION GRID, AND AN INTERCONNECTING AMMONIA STORAGE SYSTEM WITH A CAPACITY OF 150 GALLONS, SERVING BOILER NO. B-3 (SERIAL NO. 10439)

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THIS SYSTEM SHALL BE IN OPERATION WHENEVER THE BOILER IT IS VENTING IS IN OPERATION, EXCEPT AS OTHERWISE NOTED IN THIS PERMIT.
[RULE 1146]
- 4) THE TEMPERATURE OF EXHAUST GASES ENTERING THE SCR UNIT SHALL NOT EXCEED 700 DEGREES FAHRENHEIT.
[RULE 1146]
- 5) A CHART RECORDER SHALL BE INSTALLED AND MAINTAINED TO RECORD THE FOLLOWING.
 - A. THE DATE AND TIME.
 - B. THE TYPE OF FUEL AND HOURLY AVERAGE AMOUNT OF FUEL USED.
 - C. THE EXHAUST GAS INLET TEMPERATURE TO THE SCR.

RECORDS FOR THE ABOVE SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

- 6) NOX MONITORS SHALL BE INSTALLED AND OPERATED TO MEASURE THE OUTLET NOX CONCENTRATION OF THE SELECTIVE CATALYTIC REDUCTION SYSTEM. THE NOX MONITORS SHALL BE MAINTAINED AND OPERATED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS. RECORDS OF ALL CALIBRATIONS AND MAINTENANCE SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO THE DISTRICT UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

- 7) THE HOURLY AVERAGE NOX EMISSIONS AT THE EXIT OF SCR UNIT SHALL NOT EXCEED 5 PPM (FIRING ON NATURAL GAS) AND 40 PPM (FIRING ON AMBER OIL) BOTH CORRECTED TO 3% O2 WHEN THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT.
[RULE 1146]
- 8) THE AMMONIA INJECTION SYSTEM SHALL BE OPERATED WHENEVER THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT.
[RULE 1146]
- 9) THE HOURLY AVERAGE AMMONIA EMISSIONS AT THE EXIT OF THE SCR UNIT SHALL NOT EXCEED 5 PPM CORRECTED TO 3% O2.
[RULE 1303(a)(1)- BACT]
- 10) THE OPERATOR OF THIS BOILER SHALL COMPLY WITH ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (D)--COMPLIANCE DETERMINATION OF RULE 1146. THE ANNUAL TESTING SHALL ALSO MEASURE AMMONIA EMISSIONS (1-HR TESTING) USING DISTRICT TEST METHOD 207.1 TO COMPLY WITH CONDITION NO. 9.
[RULE 1146]

Emissions and Requirements:

- 11). THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NH3: 5 PPMV, RULE 1303(a)(1)

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO CONSTRUCT

Permit No.
A/N 503717

Equipment Description:

BOILER, TRANE-MURRAY, MODEL NO. MCF 4-49, SERIAL NUMBER 10440, WITH A COEN, MODEL DAF/FGR 26, LOW-NOX BURNER, 61,887,000 BTU/HR NATURAL GAS FIRED, AND 40,000,000 BTU/ LOW NOX FUEL OIL FIRED, WITH INDUCED FLUE GAS RECIRCULATION, AND VENTED TO A SELECTIVE CATALYTIC REDUCTION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH, AND COMPLIANCE TESTING WITH LOW SULFUR FUEL OIL.
[RULE 1146]
4. THIS BOILER SHALL NOT BE OPERATED UNLESS IT IS VENTED TO A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM WHICH IS IN OPERATION AND HAS A PERMIT TO CONSTRUCT ISSUED BY THE EXECUTIVE OFFICER, UNLESS OPERATING FROM COLD START-UP OR LOW LOAD CONDITIONS WHEN THE EXHAUST FROM THE BOILER IS LESS THAN 300 DEGREES FAHRENHEIT.
[RULE 1146]
5. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (D)--COMPLIANCE DETERMINATION OF RULE 1146, ONCE EVERY THREE YEARS.
[RULE 1146]
7. THE SULFUR CONTENT OF LOW SULFUR FUEL OIL SUPPLIED TO THE BOILER SHALL NOT EXCEED 15 PARTS PER MILLION BY WEIGHT.
[RULE 431.2]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

8. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AN OXIDES OF NITROGEN CONTINUOUS EMISSIONS MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218 (B).
[RULE 1146]
9. WHEN THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT, THIS BOILER SHALL NOT EMIT MORE THAN 5 PART PER MILLION (PPM) OF OXIDES OF NITROGEN (NOX) AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME OF ON DRY BASIS AT 3% O2 AVERAGE OVER 15 MINUTES FOR EACH FUEL USED.
[RULE 1146]
10. THE OPERATOR SHALL CONDUCT NOX EMISSIONS CHECK ON THE BOILER MONTHLY OR EVERY 750 HOURS OF OPERATION ACCORDING TO THE PROTOCOL FOR PERIODIC MONITORING OF NOX, CO, AND O2 OUTLINED IN SECTION (D)(8) OF RULE 1146.
[RULE 1146]
11. THIS BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL FIRED.
[RULE 1146]
12. THE TOTAL AMOUNT OF NATURAL GAS FUEL SUPPLIED TO THIS BOILER SHALL NOT EXCEED 190,476,190 CUBIC FEET IN ANY ONE YEAR.
[RULE 1146]
13. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT FOR AT LEAST 5 YEARS AND MADE AVAILABLE TO THE DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

Periodic Monitoring:

14. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
15. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
16. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
- B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- C. STACK OR EMISSION POINT IDENTIFICATION;
- D. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- E. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- F. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

- 17. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

- 18. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - A) SOURCE TESTING SHALL BE CONDUCTED WITHIN 180 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
 - B) THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NO_x AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT WHEN FIRED WITH NATURAL GAS AND .
 - C) THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE FIRING RATES.
 - D) A WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 14 DAYS PRIOR TO TESTING SO THAT AN

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

OBSERVER MAY BE PRESENT.

- E) TWO COMPLETE COPIES OF SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 45 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:
- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM),
 - II. THE FIRING RATES, IN BTU PER HOUR,
 - III. THE EXHAUST TEMPERATURE, IN DEGREE F,
 - IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT, AND
 - V. THE FUEL FLOW RATE.
- F) THE TEST SHALL BE CONDUCTED BY A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH RULE 304 (NO CONFLICT OF INTEREST).
- G) SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217.

Emissions And Requirements:

18. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- CO: 2000 PPMV, RULE 407
 - SOX: 500 PPMV, RULE 407
 - PM: 0.1 GR/SCF, RULE 409
 - CO: 400 PPMV, RULE 1146
 - NOX: 40 PPMV, RULE 1146
 - NOX: 30 PPMV, RULE 1146
 - NOX: 5 PPMV, RULE 1146

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO CONSTRUCT

Permit No.
A/N 503718

Equipment Description:

BOILER, TRANE-MURRAY, MODEL NO. MCF 4-49, SERIAL NUMBER 10441, WITH A COEN, MODEL DAF/FGR 26, LOW-NOX BURNER, 61,887,000 BTU/HR NATURAL GAS FIRED, AND 40,000,000 BTU/ LOW NOX FUEL OIL FIRED, WITH INDUCED FLUE GAS RECIRCULATION, AND VENTED TO A SELECTIVE CATALYTIC REDUCTION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH, AND COMPLIANCE TESTING WITH LOW SULFUR FUEL OIL.
[RULE 1146]
4. THIS BOILER SHALL NOT BE OPERATED UNLESS IT IS VENTED TO A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM WHICH IS IN OPERATION AND HAS A PERMIT TO CONSTRUCT ISSUED BY THE EXECUTIVE OFFICER, UNLESS OPERATING FROM COLD START-UP OR LOW LOAD CONDITIONS WHEN THE EXHAUST FROM THE BOILER IS LESS THAN 300 DEGREES FAHRENHEIT.
[RULE 1146]
5. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (D)--COMPLIANCE DETERMINATION OF RULE 1146, ONCE EVERY THREE YEARS.
[RULE 1146]
7. THE SULFUR CONTENT OF LOW SULFUR FUEL OIL SUPPLIED TO THE BOILER SHALL NOT EXCEED 15 PARTS PER MILLION BY WEIGHT.
[RULE 431.2]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

8. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AN OXIDES OF NITROGEN CONTINUOUS EMISSIONS MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218 (B).
[RULE 1146]
9. WHEN THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT, THIS BOILER SHALL NOT EMIT MORE THAN 5 PART PER MILLION (PPM) OF OXIDES OF NITROGEN (NOX) AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME OF ON DRY BASIS AT 3% O2 AVERAGE OVER 15 MINUTES FOR EACH FUEL USED.
[RULE 1146]
10. THE OPERATOR SHALL CONDUCT NOX EMISSIONS CHECK ON THE BOILER MONTHLY OR EVERY 750 HOURS OF OPERATION ACCORDING TO THE PROTOCOL FOR PERIODIC MONITORING OF NOX, CO, AND O2 OUTLINED IN SECTION (D)(8) OF RULE 1146.
[RULE 1146]
11. THIS BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL FIRED.
[RULE 1146]
12. THE TOTAL AMOUNT OF NATURAL GAS FUEL SUPPLIED TO THIS BOILER SHALL NOT EXCEED 190,476,190 CUBIC FEET IN ANY ONE YEAR.
[RULE 1146]
13. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT FOR AT LEAST 5 YEARS AND MADE AVAILABLE TO THE DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

Periodic Monitoring:

14. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
15. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
16. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
- B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- C. STACK OR EMISSION POINT IDENTIFICATION;
- D. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- E. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- F. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

- 17. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 18. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- CO: 2000 PPMV, RULE 407
- SOX: 500 PPMV, RULE 407
- PM: 0.1 GR/SCF, RULE 409
- CO: 400 PPMV, RULE 1146
- NOX 40 PPMV, RULE 1146
- NOX: 30 PPMV, RULE 1146
- NOX: 5 PPMV, RULE 1146

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

PERMIT TO CONSTRUCT

Permit No.
A/N 503719

Equipment Description:

BOILER, TRANE-MURRAY, MODEL NO. MCF 4-49, SERIAL NUMBER 10439, WITH A COEN, MODEL DAF/FGR 26, LOW-NOX BURNER, 61,887,000 BTU/HR NATURAL GAS FIRED, AND 40,000,000 BTU/ LOW NOX FUEL OIL FIRED, WITH INDUCED FLUE GAS RECIRCULATION, AND VENTED TO A SELECTIVE CATALYTIC REDUCTION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, MAINTENANCE TESTING NOT TO EXCEED 30 MINUTES A MONTH, AND COMPLIANCE TESTING WITH LOW SULFUR FUEL OIL.
[RULE 1146]
4. THIS BOILER SHALL NOT BE OPERATED UNLESS IT IS VENTED TO A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM WHICH IS IN OPERATION AND HAS A PERMIT TO CONSTRUCT ISSUED BY THE EXECUTIVE OFFICER, UNLESS OPERATING FROM COLD START-UP OR LOW LOAD CONDITIONS WHEN THE EXHAUST FROM THE BOILER IS LESS THAN 300 DEGREES FAHRENHEIT.
[RULE 1146]
5. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (D)--COMPLIANCE DETERMINATION OF RULE 1146, ONCE EVERY THREE YEARS.
[RULE 1146]
7. THE SULFUR CONTENT OF LOW SULFUR FUEL OIL SUPPLIED TO THE BOILER SHALL NOT EXCEED 15 PARTS PER MILLION BY WEIGHT.
[RULE 431.2]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

8. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AN OXIDES OF NITROGEN CONTINUOUS EMISSIONS MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218 (B).
[RULE 1146]
9. WHEN THE SCR INLET TEMPERATURE IS ABOVE 300 DEGREES FAHRENHEIT, THIS BOILER SHALL NOT EMIT MORE THAN 5 PART PER MILLION (PPM) OF OXIDES OF NITROGEN (NOX) AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME OF ON DRY BASIS AT 3% O₂ AVERAGE OVER 15 MINUTES FOR EACH FUEL USED.
[RULE 1146]
10. THE OPERATOR SHALL CONDUCT NOX EMISSIONS CHECK ON THE BOILER MONTHLY OR EVERY 750 HOURS OF OPERATION ACCORDING TO THE PROTOCOL FOR PERIODIC MONITORING OF NOX, CO, AND O₂ OUTLINED IN SECTION (D)(8) OF RULE 1146.
[RULE 1146]
11. THIS BOILER SHALL BE EQUIPPED WITH A NON-RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL FIRED.
[RULE 1146]
12. THE TOTAL AMOUNT OF NATURAL GAS FUEL SUPPLIED TO THIS BOILER SHALL NOT EXCEED 190,476,190 CUBIC FEET IN ANY ONE YEAR.
[RULE 1146]
13. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT FOR AT LEAST 5 YEARS AND MADE AVAILABLE TO THE DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

Periodic Monitoring:

14. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
15. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
16. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
- B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- C. STACK OR EMISSION POINT IDENTIFICATION;
D. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
E. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
F. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

17. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

18. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
CO: 400 PPMV, RULE 1146
NOX: 40 PPMV, RULE 1146
NOX: 30 PPMV, RULE 1146
NOX: 5 PPMV, RULE 1146

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
CR¹⁶: RULE 1404

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HALON FIRE EXTINGUISHING SYSTEM

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
HALON: RULE 1418
HALON: 40 CFR 82 SUBPART H

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERATION SYSTEMS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:	RULE 1415
REFRIGERANT:	40 CFR 82 SUBPART F

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 400,000 BTU/HR BUT < 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statues of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO₂) and be averaged over 15 consecutive minutes; [407]
 - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO₂) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O₂) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
 - a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
 - a. The results of the source test.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief description of the equipment tested.
 - c. Operating conditions under which the test was performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

NOT APPLICABLE

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

**SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR
RECLAIM SOURCES**

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

SECTION J: AIR TOXICS

NOT APPLICABLE

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
 - (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
 - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 109	5-2-2003	Federally enforceable
RULE 1110.2	7-9-2010	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	6-3-2011	Non federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1146.1	5-13-1994	Federally enforceable
RULE 1146.1	9-5-2008	Non federally enforceable
RULE 1146.2	5-5-2006	Federally enforceable
RULE 1168	1-7-2005	Federally enforceable
RULE 1168	8-15-2000	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	9-10-2010	Non federally enforceable
RULE 1403	10-5-2007	Non federally enforceable

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1404	4-6-1990	Non federally enforceable
RULE 1415	12-3-2010	Non federally enforceable
RULE 1418	9-10-1999	Non federally enforceable
RULE 1470	6-1-2007	Non federally enforceable
RULE 1472	3-7-2008	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 218	5-14-1999	Federally enforceable
RULE 219	6-1-2007	Non federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3002	11-5-2010	Non federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3003	11-5-2010	Non federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3005	11-5-2010	Non federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	5-6-2011	Non federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 429	12-21-1990	Non federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 442	12-15-2000	Federally enforceable

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 481	1-11-2002	Federally enforceable
RULE 701	6-13-1997	Federally enforceable
40CFR 63 Subpart DDDDD	12-6-2006	Federally enforceable
40CFR 63 Subpart ZZZZ	1-18-2008	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable
40CFR 82SubpartH	3-5-1998	Federally enforceable

**FACILITY PERMIT TO OPERATE
CEDARS-SINAI MEDICAL CTR**

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN
PERMIT PURSUANT TO RULE 219**

NONE

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550			275
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-03-2011]

- (1) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6) of Rule 1113, no person shall supply, sell, offer for sale, market, manufacture, blend, repackage, apply, store at a worksite, or solicit the application of any architectural coating within the District:
 - (A) That is listed in the Table of Standards 1 and contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified; or
 - (B) That is not listed in the Table of Standards 1, and contains VOC (excluding any colorant added to tint bases) in excess of 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, until January 1, 2014, at which time the limit drops to 50 grams of VOC per liter of coating, less water, less exempt compounds (0.42 pounds per gallon).
- (2) No person within the District shall add colorant at the point of sale that is listed in the Table of Standards 2 and contains VOC in excess of the corresponding VOC limit specified in the Table of Standards 2, after the effective date specified.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-03-2011]

TABLE OF STANDARDS 1 VOC LIMITS

**Grams of VOC Per Liter of Coating,
 Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit ¹	Current Limit ²	Effective Date		
			7/1/08	1/1/12	1/1/14
Bond Breakers		350			
Clear Wood Finishes		275			
Varnish	350	275			
Sanding Sealers	350	275			
Lacquer		275			
Concrete-Curing Compounds		100			
Concrete-Curing Compounds For Roadways and Bridges ³		350			
Concrete Surface Retarder		250			50
Driveway Sealer		100		50	
Dry-Fog Coatings		150			50
Faux Finishing Coatings					
Clear Topcoat		350		200	
Decorative Coatings		350			100
Glazes		350			
Japan		350			
Trowel Applied Coatings		350		150	50
Fire-Proofing Coatings		350			150
Flats	250	50	50		
Floor Coatings	100	50			
Form Release Compound		250			100
Graphic Arts (Sign) Coatings		500			150
Industrial Maintenance (IM) Coatings	420	100			
High Temperature IM Coatings		420			
Non-Sacrificial Anti-Graffiti Coatings		100			
Zinc-Rich IM Primers	340	100			
Magnesite Cement Coatings		450			
Mastic Coatings		300			100
Metallic Pigmented Coatings	500	500			150
Multi-Color Coatings		250			
Nonflat Coatings	150	50			
Pre-Treatment Wash Primers		420			
Primers, Sealers, and Undercoaters	200	100			
Reactive Penetrating Sealers		350			
Recycled Coatings		250			
Roof Coatings	250	50			
Roof Coatings, Aluminum		100			

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-03-2011]

Roof Primers, Bituminous	350	350		
Rust Preventative Coatings	400	100		
Stone Consolidant		450		
Sacrificial Anti-Graffiti Coatings		100		50
Shellac				
Clear		730		
Pigmented		550		
Specialty Primers	350	100		
Stains		100		

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-03-2011]

COATING CATEGORY	Ceiling Limit ¹	Current Limit ²	Effective Date		
			7/1/08	1/1/12	1/1/14
Stains, Interior	250	250			
Swimming Pool Coatings					
Repair		340			
Other		340			
Traffic Coatings		100			
Waterproofing Sealers	250	100			
Waterproofing Concrete/Masonry Sealers	400	100			
Wood Preservatives		350			

1. The specified ceiling limits are applicable to products sold under the Averaging Compliance Option.
2. The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.
3. Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

TABLE OF STANDARDS 1 (cont.) VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

TABLE OF STANDARDS 2 VOC LIMITS FOR COLORANTS

Grams of VOC Per Liter of Colorant Less Water and Less Exempt Compounds

COLORANT	Limit ⁴
Architectural Coatings, excluding IM Coatings	50
Solvent-Based IM	600
Waterborne IM	50

4. Effective January 1, 2014.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

- (1) Unless otherwise specified in paragraph (c)(2), a person shall not apply any adhesives, adhesive bonding primers, adhesive primers, or any other primer which have a VOC content in excess of 250 g/L less water and less exempt compounds.
- (2) A person shall not apply adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, or any other primer which have a VOC content in excess of the limits specified below:

VOC Limit*, Less Water and Less Exempt Compounds in Grams per Liter

Architectural Applications	Current VOC Limit*
Indoor Carpet Adhesives	50
Carpet Pad Adhesives	50
Outdoor Carpet Adhesives	150
Wood Flooring Adhesive	100
Rubber Floor Adhesives	60
Subfloor Adhesives	50
Ceramic Tile Adhesives	65
VCT and Asphalt Tile Adhesives	50
Dry Wall and Panel Adhesives	50
Cove Base Adhesives	50
Multipurpose Construction Adhesives	70
Structural Glazing Adhesives	100
Single Ply Roof Membrane Adhesives	250

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

Specialty Applications	VOC Limits and Effective Dates**			
	Current VOC Limit*	1-1-05	7-1-05	1-1-07
PVC Welding	510			
CPVC Welding	490			
ABS Welding	400		325	
Plastic Cement Welding	350	250		
Adhesive Primer for Plastic	650		550	
Computer Diskette Manufacturing	350			
Contact Adhesive	80			
Special Purpose Contact Adhesive	250			
Tire Retread	100			
Adhesive Primer for Traffic Marking Tape	150			
Structural Wood Member Adhesive	140			
Sheet Applied Rubber Lining Operations	850			
Top and Trim Adhesive	540			250

** The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

For adhesives, adhesive bonding primers, or any other primer not regulated by the above two tables and applied to the following substrates, the following limits shall apply:

Substrate Specific Applications	Current VOC Limit*
Metal to Metal	30
Plastic Foams	50
Porous Material (except wood)	50
Wood	30
Fiberglass	80

If an adhesive is used to bond dissimilar substrates together the adhesive with the highest VOC content shall be allowed.

Sealants	Current VOC Limit*
Architectural	250
Marine Deck	760
Nonmembrane Roof	300
Roadway	250
Single-Ply Roof Membrane	450
Other	420

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

Sealant Primers	Current VOC Limit*
Architectural	
Non Porous	250
Porous	775
Modified Bituminous	500
Marine Deck	760
Other	750

* For low-solid adhesives or sealants the VOC limit is expressed in grams per liter of material as determined in paragraph (b)(32); for all other adhesives and sealants, VOC limits are expressed as grams of VOC per liter of adhesive or sealant less water and less exempt compounds as determined in paragraph (b)(31).

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)

**FACILITY PERMIT TO OPERATE
 CEDARS-SINAI MEDICAL CTR**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS*	EFFECTIVE 1/1/2010
	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

SOLVENT CLEANING ACTIVITY (cont.)	CURRENT LIMITS*	EFFECTIVE 1/1/2010
	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a).

Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

FACILITY PERMIT TO OPERATE CEDARS-SINAI MEDICAL CTR

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

**FACILITY PERMIT TO OPERATE
 CEDARS-SINAI MEDICAL CTR**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter ² Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100