

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Title V Permit Summary

AQMD Facility ID:	129661	Company Name:	NM MILLIKEN GENCO LLC	
Equipment Location:	2050 MILLIKEN AVE., ONTARIO, CA 91761			SIC Code: 4953
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected:		
Application #(s):	538321	Application Submittal Date(s):	05/24/12	
AQMD Contact Person:	ABDI MAJIDIFAR	Phone #:	(909) 396-2449	E-Mail Address: amajidifar@aqmd.gov
Project Description: This is an existing facility, applying for a Title V permit renewal that uses landfill gas as fuel for generating electricity. This facility is operating internal combustion engines driving electric generators.				
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal				
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other: _____ <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance				
Toxic Air Contaminant Emissions (TAC) – Annual Reported Emiss. for 2012		<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> TACs Reported:		Emissions (lbs/yr)
				Benzene 4.989
				Carbon Tetrachloride 0.427
				Methylene Chloride 0.546
				Perchloroethylene 0.594
				Trichloroethylene 0.451
				Vinyl Chloride 0.380
Health Risk From Toxic Air Contaminants: <input type="checkbox"/> Health Risk Reduction Plan in Force (AQMD Rule 1402) (date): _____ <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input checked="" type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input type="checkbox"/> Final Facility Health Risk Approved (date) _____ Cancer Risk = <u>in one million</u> Acute Hazard Index = _____ Chronic Hazard Index = _____				
Criteria Pollutant Emissions <input checked="" type="checkbox"/> NOX 12.735 <input checked="" type="checkbox"/> PM 1.746 Annual Reported Emissions <input checked="" type="checkbox"/> CO 49.549 <input checked="" type="checkbox"/> SOx 1.269 (tons/year) for Reporting Year: 2012 <input checked="" type="checkbox"/> VOC 2.416 <input type="checkbox"/> Other: _____				
Compliance History: <input type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years (0) Year 2011 - 2013 <input checked="" type="checkbox"/> Notices to Comply Issued in Last Two Calendar Years (1) <input checked="" type="checkbox"/> Notices of Violation Issued in Last Two Calendar Years (1)				
Comments: The facility has been issued one Notice to Comply (NC) and one Notice of Violation (NOV) in the last two calendar years. However, the issues regarding the NC & NOV have been resolved and the facility is determined to be in compliance.				