

Date TBD

Mr. Marshall G. Waller
Superintendent, Environmental Services
Phillips 66 Company, LA Refinery, Wilmington Plt
1660 W Anaheim St
Wilmington, CA 90744

SUBJECT: Rule 463 Inspection & Maintenance Plan Approval
A/N 539605
Phillips 66 Company, LA Refinery, Wilmington Plant, Facility ID 171107

Dear Mr. Waller:

The South Coast Air Quality Management District has reviewed your Rule 463 Inspection & Maintenance plan dated September 27, 2010. In accordance with requirements in Rule 463(e)(1)(A), your facility submitted this plan for Executive Officer approval. This plan includes an inventory and self-inspection schedule for floating-roof storage tanks, as well as safety procedures for floating roof tanks and the number of certified persons dedicated to the inspection and maintenance program.

Based on the information submitted, your Rule 463 Inspection and Maintenance Plan has been reviewed and approved, subject to the following conditions.

1. The operator shall conduct the operation of the storage equipment in compliance with all data and specifications submitted with the plan application under which this approval is granted.
2. Floating roof tank seals shall be properly installed and continuously maintained in good operating condition.

This facility shall be subject to the terms and conditions of this plan unless this plan is suspended, revoked, modified, reissued or denied. Failure to maintain a valid plan is a violation of Rule 463.

It is the responsibility of the facility to comply with other District Rules and Regulations and with all laws, ordinances and regulations of other government agencies which are applicable to the operation of the equipment.

This plan does not authorize the emission of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This plan cannot be considered as permission to violate existing laws, ordinances, regulation, or statutes of the other governmental agencies.

If you have any questions, regarding this plan, please contact Ms. Janice West at 909-396-3763.

Sincerely,

Jay Chen
Senior Manager
Refinery and Waste Management
Engineering & Compliance

JC:JW

cc: Ed Pupka