



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • [www.aqmd.gov](http://www.aqmd.gov)

March 22, 2012

Mr. Gerardo Rios  
U.S. EPA, Region IX  
75 Hawthorne Street  
San Francisco, CA 94105

**SUBJECT:** Transmittal of Proposed Title V Renewal Permit

Dear Mr. Rios:

Enclosed are the proposed Title V renewal permit, permit summary, and statement of basis for **SCE, BARRE SUBSTATION**, located at 8662 Cerritos Ave., Stanton, CA 90680. With your receipt of the proposed Title V renewal permit, we will note that the EPA 45-day period begins on March 22, 2012.

Questions on the proposed permit should be directed to Mr. Chris Perri, Air Quality Engineer, at (909) 396-2696 or [cperri@aqmd.gov](mailto:cperri@aqmd.gov).

Sincerely,

A handwritten signature in black ink, appearing to read 'Brian L. Yeh', is written over a horizontal line.

Brian L. Yeh, P.E.  
Senior Engineering Manager  
Mechanical, Chemical & Public Services

BLY:AYL:JTY:CGP

Enclosures:

Facility Permit (Proposed Renewal)  
Public Notice  
Statement of Basis  
Facility Permit Application

## **FACILITY PERMIT TO OPERATE**

**SO CAL EDISON CO  
8662 CERRITOS AVE  
STANTON, CA 90680**

### **NOTICE**

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.  
EXECUTIVE OFFICER

By \_\_\_\_\_  
Mohsen Nazemi, P.E.  
Deputy Executive Officer  
Engineering & Compliance

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **TABLE OF CONTENTS**

<b>Section</b>	<b>Description</b>	<b>Revision #</b>	<b>Date Issued</b>
A	Facility Information	DRAFT	03/21/2012
B	RECLAIM Annual Emission Allocation	DRAFT	03/21/2012
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	03/21/2012
E	Administrative Conditions	DRAFT	03/21/2012
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	03/21/2012
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	03/21/2012
H	Permit To Construct and Temporary Permit to Operate	DRAFT	03/21/2012
I	Compliance Plans & Schedules	DRAFT	03/21/2012
J	Air Toxics	DRAFT	03/21/2012
K	Title V Administration	DRAFT	03/21/2012
<b>Appendix</b>			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	03/21/2012
B	Rule Emission Limits	DRAFT	03/21/2012

**FACILITY PERMIT TO OPERATE  
 SO CAL EDISON CO**

**SECTION A: FACILITY INFORMATION**

**LEGAL OWNER &/OR OPERATOR:** SO CAL EDISON CO

**LEGAL OPERATOR (if different than owner):**

**EQUIPMENT LOCATION:** 8662 CERRITOS AVE  
 STANTON, CA 90680

**MAILING ADDRESS:** 2244 WALNUT GROVE AVENUE  
 ROSEMEAD, CA 91770

**RESPONSIBLE OFFICIAL:** RUSS KREIGER

**TITLE:** VICE PRESIDENT

**TELEPHONE NUMBER:** (909) 394-8667

**CONTACT PERSON:** ALLEN LAVEN

**TITLE:** PLANT MANAGER

**TELEPHONE NUMBER:** (714) 895-0780

**INITIAL TITLE V PERMIT ISSUED:** April 03, 2007

**TITLE V PERMIT EXPIRATION DATE:** April 02, 2012

<b>TITLE V</b>		<b>RECLAIM</b>	
<b>YES</b>		<b>NOx:</b>	<b>NO</b>
		<b>SOx:</b>	<b>NO</b>
		<b>CYCLE:</b>	<b>0</b>
		<b>ZONE:</b>	<b>COASTAL</b>

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION**

NOT APPLICABLE

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION C: FACILITY PLOT PLAN**

(TO BE DEVELOPED)

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: POWER GENERATION</b>					
<b>System 2: EMERGENCY IC ENGINE</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, DETROIT DIESEL, MODEL 6063-TK35, WITH AFTERCOOLER, TURBOCHARGER, 415 BHP A/N: 375764	D7			CO: 8.5 GRAM/BHP-HR (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 6.9 GRAM/BHP-HR (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; PM10: 0.38 GRAM/BHP-HR (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; VOC: 1 GRAM/BHP-HR (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.5, E193.3, K67.3
<b>System 4: RULE 219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES</b>					
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E8			VOC: (9) [RULE 1113, 11-8-1996; RULE 1113, 6-9-2006; RULE 1171, 11-7-2003; RULE 1171, 7-14-2006]	K67.4
RULE 219 EXEMPT EQUIPMENT, EXEMPT HAND WIPING OPERATIONS	E9			VOC: (9) [RULE 1171, 11-7-2003; RULE 1171, 7-14-2006]	
RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS	E10				H23.2

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION D: DEVICE ID INDEX**

**The following sub-section provides an index  
to the devices that make up the facility  
description sorted by device ID.**

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION D: DEVICE ID INDEX**

<b>Device Index For Section D</b>			
<b>Device ID</b>	<b>Section D Page No.</b>	<b>Process</b>	<b>System</b>
D7	1	1	2
E8	1	1	4
E9	1	1	4
E10	1	1	4

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

#### FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

F14.1 The operator shall not use diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive Officer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).

b). The operator shall submit any additional relevant information requested by the Executive Officer or designated agency.

[40CFR 68 - Accidental Release Prevention, 5-24-1996]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

#### **DEVICE CONDITIONS**

##### **C. Throughput or Operating Parameter Limits**

C1.5 The operator shall limit the operating time to no more than 199 hour(s) in any one year.

The 199 hours per year limit may include up to 20 hours per year operating time to maintain engine readiness..

To comply with this condition, the operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;**  
RULE 1401, 3-4-2005]

[Devices subject to this condition : D7]

##### **E. Equipment Operation/Construction Requirements**

E193.3 The operator shall operate and maintain this equipment according to the following specifications:

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

The operation of this equipment beyond 20 hours per year for testing and maintenance and performance testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the utility distribution company has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[RULE 1470, 11-3-2005]

[Devices subject to this condition : D7]

#### **H. Applicable Rules**

H23.2 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415

[RULE 1415, 10-14-1994]

[Devices subject to this condition : E10]

#### **K. Record Keeping/Reporting**

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

The date of operation

Indication of whether the engine is started manually or automatically

Time reading in hours at the beginning and end of operation

The elapsed time in hours

The reason for operation

The annual total hours of operation (include hours for manual and automatic operation) which shall be recorded no later than January 15th of the following year

The records shall be kept for a minimum of five calendar years prior to the current year and made available to District personnel upon request.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;**  
RULE 1401, 3-4-2005; RULE 1470, 11-3-2005]

[Devices subject to this condition : D7]

**K67.4** The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : E8]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION E: ADMINISTRATIVE CONDITIONS**

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
  - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
  - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
  - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION E: ADMINISTRATIVE CONDITIONS**

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
  - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
  - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
  - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
  - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO<sub>2</sub>) and be averaged over 15 consecutive minutes; [407]
  - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO<sub>2</sub>) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O<sub>2</sub>) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
  - a. Brief description of the equipment tested.
  - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
  - c. Operating conditions under which the test will be performed.
  - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
  - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
  - f. Description of calibration and quality assurance procedures.
  - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
  - a. The results of the source test.

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION E: ADMINISTRATIVE CONDITIONS**

- b. Brief description of the equipment tested.
  - c. Operating conditions under which the test was performed.
  - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
  - e. Field and laboratory data forms, strip charts and analyses.
  - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS**

**NOT APPLICABLE**

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR  
RECLAIM SOURCES**

**NOT APPLICABLE**



## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: POWER GENERATION</b>					
CO OXIDATION CATALYST, BASF, 80 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 462015 Permit to Construct Issued: 04/03/07	C3	D1			E193.1
SELECTIVE CATALYTIC REDUCTION, CORMETECH CMHT-21, WITH 547 CUBIC FEET OF TOTAL CATALYST VOLUME, WIDTH: 18 FT ; HEIGHT: 25 FT 9 IN; LENGTH: 2 FT 6 IN WITH A/N: 462015 Permit to Construct Issued: 04/03/07  AMMONIA INJECTION	C4	D1		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.4, D12.2, D12.3, D12.4, E179.1, E179.2, E193.1
STACK, HEIGHT: 80 FT ; DIAMETER: 13 FT A/N: 499009 Permit to Construct Issued: 01/06/10	S5	D1			
<b>System 2: EMERGENCY IC ENGINE</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, WAUKESHA, MODEL VGF36 GL/GLD, WITH TURBOCHARGER, 924 BHP A/N: 479360 Permit to Construct Issued: 12/10/08	D6			CO: 224 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 107 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1) -BACT, 12-6-2002]; VOC: 111 PPMV (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A63.2, A63.3, A63.5, C1.4, D12.5, D29.4, E162.1, E193.1, E193.2, K67.2
<b>System 3: INORGANIC CHEMICAL STORAGE</b>					

- \* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: POWER GENERATION</b>					
STORAGE TANK, 19% AQUEOUS AMMONIA, HORIZONTAL, 10500 GALS A/N: 462012 Permit to Construct Issued: 04/03/07	D11				C157.1, E144.1, E193.1

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION H: DEVICE ID INDEX**

**The following sub-section provides an index  
to the devices that make up the facility  
description sorted by device ID.**

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION H: DEVICE ID INDEX**

<b>Device Index For Section H</b>			
<b>Device ID</b>	<b>Section H Page No.</b>	<b>Process</b>	<b>System</b>
D1	1	1	1
C3	2	1	1
C4	2	1	1
S5	2	1	1
D6	2	1	2
D11	3	1	3

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

#### FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

F14.1 The operator shall not use diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive Officer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).

b). The operator shall submit any additional relevant information requested by the Executive Officer or designated agency.

[40CFR 68 - Accidental Release Prevention, 5-24-1996]

#### DEVICE CONDITIONS

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

#### A. Emission Limits

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 1584 LBS IN ANY ONE MONTH
PM10	Less than 1499 LBS IN ANY ONE MONTH
CO	Less than 2068 LBS IN ANY ONE MONTH
SOX	Less than 89 LBS IN ANY ONE MONTH
VOC	Less than 398 LBS IN ANY ONE MONTH

The operator shall calculate the emission limit(s) by using fuel use data and the following emission factors: VOC: 2.95 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf.

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If CO CEMS data is not available, CO emissions shall be calculated using fuel usage and a factor of 14.12 lbs/mmcf during normal operations, 8.74 lbs/hr during any start up hour, and 7.86 lbs/hr during any shutdown hour. The operator shall use the appropriate missing data procedures if NOx data is not available.

If a CEMS calibration occurs within 60 minutes of a start up, NOx emissions for the calibration period shall be calculated using the actual duration of the calibration in minutes times a factor of 0.0802 lb/min, and shall only occur when NOx emissions are at or below BACT levels.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D1]

A63.2 The operator shall limit emissions from this equipment as follows:

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 6783 LBS IN ANY ONE YEAR
PM10	Less than 5454 LBS IN ANY ONE YEAR
CO	Less than 8885 LBS IN ANY ONE YEAR
SOX	Less than 324 LBS IN ANY ONE YEAR
VOC	Less than 1702 LBS IN ANY ONE YEAR

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

#### The operator shall comply with the terms and conditions set forth below:

The operator shall calculate the emission limit(s) by using fuel use data and the following emission factors for the turbine: During commissioning with no control- NOx: 245.71 lbs/mmcf; CO: 115.57 lbs/mmcf, VOC: 11.17 lbs/mmcf; PM10: 10.63 lbs/mmcf, and SOx: 0.63 lb/mmcf . During commissioning with water injection- NOx: 100.7 lbs/mmcf, all other factors remain the same. During normal operation- VOC: 3.07 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf.

The operator shall calculate the annual emission limit(s) by using hourly operation data and the following emission factors for the engine: NOx: 2.55 lbs/hr, CO: 3.24 lbs/hr, VOC: 0.92 lbs/hr, PM10: 0.25 lbs/hr, SOx: 0.0038 lbs/hr.

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If CO CEMS data is not available, CO emissions shall be calculated using fuel usage and a factor of 14.12 lbs/mmcf during normal operations, 8.74 lbs/hr during any start up hour, and 7.86 lbs/hr during any shutdown hour. The operator shall use the appropriate missing data procedures if NOx data is not available.

If a CEMS calibration occurs within 60 minutes of a start up, NOx emissions for the calibration period shall be calculated using the actual duration of the calibration in minutes times a factor of 0.0802 lb/min, and shall only occur when NOx emissions are at or below BACT levels.

For the purposes of this condition, the yearly emission limit shall be defined as a period of twelve (12) consecutive months determined on a rolling basis with a new 12 month period beginning on the first day of each calendar month. The limits apply to the total emissions from the turbine plus the engine. THIS CONDITION APPLIES DURING THE 1ST 12 MONTHS OF OPERATION ONLY.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D1, D6]

A63.3 The operator shall limit emissions from this equipment as follows:

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 6428 LBS IN ANY ONE YEAR
PM10	Less than 5219 LBS IN ANY ONE YEAR
CO	Less than 7709 LBS IN ANY ONE YEAR
SOX	Less than 308 LBS IN ANY ONE YEAR
VOC	Less than 1525 LBS IN ANY ONE YEAR

The operator shall calculate the emission limit(s) by using fuel use data and the following emission factors for the turbine: VOC: 2.95 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf.

The operator shall calculate the emission limit(s) by using hourly operation data and the following emission factors for the engine: NOx: 2.55 lbs/hr, CO: 3.24 lbs/hr, VOC: 0.92 lbs/hr, PM10: 0.25 lbs/hr, SOx: 0.0038 lbs/hr.

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If CO CEMS data is not available, CO emissions shall be calculated using fuel usage and a factor of 14.12 lbs/mmcf during normal operations, 8.74 lbs/hr during any start up hour, and 7.86 lbs/hr during any shutdown hour. The operator shall use the appropriate missing data procedures if NOx data is not available.

If a CEMS calibration occurs within 60 minutes of a start up, NOx emissions for the calibration period shall be calculated using the actual duration of the calibration in minutes times a factor of 0.0802 lb/min, and shall only occur when NOx emissions are at or below BACT levels.

For the purposes of this condition, the yearly emission limit shall be defined as a period of twelve (12) consecutive months determined on a rolling basis with a new 12 month period beginning on the first day of each calendar month. The limits apply to the total emissions from the turbine plus the engine. THIS CONDITION APPLIES AFTER THE 1st 12 MONTHS OF OPERATION.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

**FACILITY PERMIT TO OPERATE  
 SO CAL EDISON CO**

**SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE**

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D1, D6]

A63.4 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 2867 LBS IN ANY ONE MONTH
PM10	Less than 1499 LBS IN ANY ONE MONTH
CO	Less than 3277 LBS IN ANY ONE MONTH
SOX	Less than 89 LBS IN ANY ONE MONTH
VOC	Less than 540 LBS IN ANY ONE MONTH

The operator shall calculate the emission limit(s) ) by using fuel use data and the following emission factors: During commissioning with no control- NOx: 245.71 lbs/mmcf; CO: 115.57 lbs/mmcf, VOC: 11.17 lbs/mmcf; PM10: 10.63 lbs/mmcf, and SOx: 0.63 lb/mmcf . During commissioning with water injection- NOx: 100.7 lbs/mmcf, all other factors remain the same. During normal operation- VOC: 3.07 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf. THIS CONDITION APPLIES DURING THE 1ST 12 MONTHS OF OPERATION ONLY.

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If NOx and CO CEMS data is not available, NOx and CO emissions shall be calculated using fuel usage and the following factors- NOx: 10.07 lb/mmcf and CO: 14.75 lbs/mmcf during normal operations, and NOx: 7.74 lbs/start, 6.53 lbs/shutdown, CO: 8.74 lbs/start, 7.86 lbs/shutdown.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D1]

A63.5 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
-------------	-----------------

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

NOX

| Less than 55 LBS IN ANY ONE DAY

The purpose of this condition is to ensure that the facility emissions are below the CEQA thresholds, and the limit is based on the total emissions from the turbine and the black start generator.

The 55 lbs/day limit shall not apply when the unit undergoes CAL-ISO required black start testing, which shall not occur more than once per 12 month period. During CAL-ISO required black start testing the daily total NOx from all operations shall not exceed 90 lbs/day

[RULE 212, 12-7-1995; RULE 212, 11-14-1997]

[Devices subject to this condition : D1, D6]

- A99.1 The 2.5 PPM NOX emission limit(s) shall not apply during commissioning, start-up, shutdown, an emergency electrical grid system blackout when the turbine is used to start another major generating station, and during cal-iso required testing. commissioning shall not exceed 25 hrs total, with no more than 5 hrs uncontrolled and no more than 20 hrs with water injection. each start-up shall not exceed 15 min. each shutdown shall not exceed 10 min. There shall be no more than 60 start ups/yr in the first year of operation, and 200 start-ups/yr thereafter.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

NOx emissions for the hour which includes a start shall not exceed 10.52 lbs, and for the hour which includes a shutdown 6.53 lbs.

In the case of a start during an emergency electrical grid system blackout, total NOx shall not exceed 28.23 lbs/hr.

In case of a turbine shutdown which occurs less than 75 minutes from a start up, the emissions calculated for the shutdown shall not include any of the first 15 minutes of the start up, and the emissions calculated for the start up shall not include any of the last 10 minutes of the shutdown.

A shutdown is defined as a reduction in turbine load ending in a period of zero fuel flow. The hour which includes a shutdown is defined as the 60 minutes counted back from the period of zero fuel flow.

During CAL-ISO required testing, NOx emissions shall not exceed 40 lbs/hr, including the start up and shutdown hours. In any 12 month period, there shall be no more than 1 completed successful test, and no more than 2 hours of total test time (including any aborted test time)

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(1)-Modeling, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

- A99.2 The 6.0 PPM CO emission limit(s) shall not apply during commissioning, start-up, shutdown, an emergency electrical grid system blackout when the turbine is used to start another major generating station, and during cal-iso required testing. commissioning shall not exceed 25 hrs total, with no more than 5 hrs uncontrolled and no more than 20 hrs with water injection. each start-up shall not exceed 15 min. each shutdown shall not exceed 10 min. there shall be no more than 60 start ups/yr in the 1st year of operation, and 200 start-ups/ yr thereafter.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

In the case of a start during an emergency electrical grid system blackout, total NOx shall not exceed 28.23 lbs/hr.

In case of a turbine shutdown which occurs less than 75 minutes from a start up, the emissions calculated for the shutdown shall not include any of the first 15 minutes of the start up, and the emissions calculated for the start up shall not include any of the last 10 minutes of the shutdown.

A shutdown is defined as a reduction in turbine load ending in a period of zero fuel flow. The hour which includes a shutdown is defined as the 60 minutes counted back from the period of zero fuel flow.

During CAL-ISO required testing, CO emissions shall not exceed 5 lbs/hr, including the start up and shutdown hours. In any 12 month period, there shall be no more than 1 completed successful test, and no more than 2 hours of total test time (including any aborted test time)

CO emissions for the hour which includes a start shall not exceed 8.74 lbs, and for the hour which includes a shutdown 7.86 lbs

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(1)-Modeling, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

A195.1 The 2.5 PPM NOX emission limit(s) is averaged over 60 minutes at 15 percent O2, dry.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(1)-Modeling, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

A195.2 The 6.0 PPM CO emission limit(s) is averaged over 60 minutes at 15 percent O2, dry.

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE**

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(1)-Modeling, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

A195.3 The 2.0 PPM VOC emission limit(s) is averaged over 60 minutes at 15 percent O<sub>2</sub>, dry.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(1)-Modeling, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

A195.4 The 5 PPMV NH<sub>3</sub> emission limit(s) is averaged over over 60 minutes at 15% O<sub>2</sub>, dry basis.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

The operator shall calculate and continuously record the NH<sub>3</sub> slip concentration using the following:

$NH_3$  (ppmv) =  $[a-b*c/1E+06]*1E+06/b$ , where

1. a = NH<sub>3</sub> injection rate (lbs/hr)/17(lb/lb-mol)
2. b = dry exhaust gas flow rate (scf/hr)/385.3 scf/lb-mol)
3. c = change in measured NO<sub>x</sub> across the SCR (ppmv at 15% O<sub>2</sub>)

The operator shall install and maintain a NO<sub>x</sub> analyzer to measure the SCR inlet NO<sub>x</sub> ppmv accurate to plus or minus 5 percent calibrated at least once every twelve months. The NO<sub>x</sub> analyzer shall be installed and operated within 90 days of initial start-up.

The operator shall use the above described method or another alternative method approved by the Executive Officer. The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information without corroborative data using an approved reference method for the determination of ammonia.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

A327.1 For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[RULE 475, 10-8-1976; RULE 475, 8-7-1978]

[Devices subject to this condition : D1]

#### **C. Throughput or Operating Parameter Limits**

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

C1.1 The operator shall limit the fuel usage to no more than 4.70 MM cubic feet per day.

The operator shall maintain records in a manner approved by the District to demonstrate compliance with this condition.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D1]

C1.2 The operator shall limit the fuel usage to no more than 513 MM cubic feet per year.

The operator shall maintain records in a manner approved by the District to demonstrate compliance with this condition and the records shall be made available upon AQMD request.

For the purpose of this condition, the yearly fuel use limit shall apply only during the 1st 12 months of operation.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D1]

C1.3 The operator shall limit the fuel usage to no more than 489 MM cubic feet per year.

The operator shall maintain records in a manner approved by the District to demonstrate compliance with this condition and the records shall be made available upon AQMD request.

For the purpose of this condition, the yearly fuel use limit shall apply after the 1st 12 months of operation. The yearly emission limit shall be defined as a period of twelve (12) consecutive months determined on a rolling basis with a new 12 month period beginning on the first day of each calendar month.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D1]

C1.4 The operator shall limit the operating time to no more than 90 hour(s) in any one year.

The 90 hours per year limit may include up to 64 hours per year operating time to maintain engine readiness or testing.

[RULE 1110.2, 6-3-2005; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;  
RULE 1401, 3-4-2005]

[Devices subject to this condition : D6]

C157.1 The operator shall install and maintain a pressure relief valve set at 50 psig.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D11]

#### D. Monitoring/Testing Requirements

D12.1 The operator shall install and maintain a(n) flow meter to accurately indicate the fuel usage being supplied to the turbine.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D1]

D12.2 The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C4]

D12.3 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C4]

D12.4 The operator shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C4]

D12.5 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

**[RULE 1110.2, 6-3-2005; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;  
RULE 1401, 3-4-2005]**

[Devices subject to this condition : D6]

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet of the SCR serving this equipment
CO emissions	District method 100.1	1 hour	Outlet of the SCR serving this equipment
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample
VOC	Approved District method	1 hour	Outlet of the SCR serving this equipment
PM10 emissions	Approved District method	District-approved averaging time	Outlet of the SCR serving this equipment
NH3 emissions	District method 207.1 and 5.3 or EPA method	1 hour	Outlet of the SCR serving this equipment

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

The test shall be conducted after AQMD approval of the source test protocol, but no later than 180 days after initial start-up. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted in accordance with AQMD approved test protocol. The protocol shall be submitted to the AQMD engineer no later than 45 days before the proposed test date and shall be approved by the AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at loads of 100, 75, and 50 percent.

For natural gas fired turbines only, VOC compliance shall be demonstrated as follows: a) Stack gas samples are extracted into Summa canisters maintaining a final canister pressure between 400-500 mm Hg absolute, b) Pressurization of canisters are done with zero gas analyzed/certified to contain less than 0.05 ppmv total hydrocarbon as carbon, and c) Analysis of canisters are per EPA Method TO-12 (with pre concentration) and temperature of canisters when extracting samples for analysis is not below 70 deg F.

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval except for the determination of compliance with the VOC BACT level of 2.0 ppmv calculated as carbon for natural gas fired turbines.

Because the VOC BACT level was set using data derived from various source test results, this alternate VOC compliance method provides a fair comparison and represents the best sampling and analysis technique for this purpose at this time. The test results shall be reported with two significant digits.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D1]

D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment

The test shall be conducted and the results submitted to the District within 45 days after the test date. The AQMD shall be notified of the date and time of the test at least 7 days prior to the test.

The test(s) shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The NOx concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NOx emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1]

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

VOC emissions		Approved District method		1 hour		Outlet of the SCR serving this equipment
PM10 emissions		Approved District method		District-approved averaging time		Outlet of the SCR serving this equipment

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE**

**The operator shall comply with the terms and conditions set forth below:**

The test(s) shall be conducted at least once every three years.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine generating output in MW.

The test shall be conducted in accordance with AQMD approved test protocol. The protocol shall be submitted to the AQMD engineer no later than 45 days before the proposed test date and shall be approved by the AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at 100 percent load.

The test shall be conducted for compliance verification of the BACT VOC 2.0 ppmv limit.

For natural gas fired turbines only, VOC compliance shall be demonstrated as follows: a) Stack gas samples are extracted into Summa canisters maintaining a final canister pressure between 400-500 mm Hg absolute, b) Pressurization of canisters are done with zero gas analyzed/certified to contain less than 0.05 ppmv total hydrocarbon as carbon, and c) Analysis of canisters are per EPA Method TO-12 (with pre concentration) and temperature of canisters when extracting samples for analysis is not below 70 deg F.

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval except for the determination of compliance with the VOC BACT level of 2.0 ppmv calculated as carbon for natural gas fired turbines.

Because the VOC BACT level was set using data derived from various source test results, this alternate VOC compliance method provides a fair comparison and represents the best sampling and analysis technique for this purpose at this time.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

The test results shall be reported with two significant digits.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

D29.4 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet
CO emissions	District method 100.1	1 hour	Outlet
VOC emissions	Approved District method	1 hour	Outlet

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

The test shall be conducted after AQMD approval of the source test protocol, but no later than 180 days after initial start-up. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the engine output in hp.

The test shall be conducted in accordance with AQMD approved test protocol. The protocol shall be submitted to the AQMD engineer no later than 45 days before the proposed test date and shall be approved by the AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at a load of 100 percent.

The test shall be conducted for compliance verification of the NO<sub>x</sub>, CO, and VOC BACT limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D6]

D82.1 The operator shall install and maintain a CEMS to measure the following parameters:

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

NOx and CO concentration in ppmv.

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the turbine, in accordance with an approved AQMD Rule 218 CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from AQMD.

The CEMS will convert the actual NOX and CO concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS shall be installed and operated to measure the NOx and CO concentration over a 15 minute, or more frequent, averaging time period. The CEMS shall convert the actual CO concentrations to mass emission rates (lbs/hr) using the equation below and record the hourly emission rates on a continuous basis.

CO Emission Rate, lbs/hr =  $K \cdot C_{co} \cdot F_d \left[ \frac{20.9}{20.9\% - \%O_2 d} \right] \left[ \frac{Q_g \cdot HHV}{10E6} \right]$ ,  
where

1.  $K = 7.267 \cdot 10^{-8}$  (lbs/scf)/ppm
2.  $C_{co}$  = Average of 4 consecutive 15 min. average CO concentrations, ppm
3.  $F_d = 8710$  dscf/MMBTU natural gas
4.  $\%O_2, d$  = Hourly average % by volume O2 dry, corresponding to  $C_{co}$
5.  $Q_g$  = Fuel gas usage during the hour, scf/hr
6. HHV = Gross high heating value of the fuel gas, BTU/scf

When the measured O2 concentration is > 19 percent, a default of 19 percent O2 shall be used in the calculation of NOx and CO mass emissions

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 218, 8-7-1981; RULE 218, 5-14-1999]**

[Devices subject to this condition : D1]

#### **E. Equipment Operation/Construction Requirements**

E57.1 The operator shall vent this equipment to the SCR and oxidation catalyst whenever the turbine is in operation.

Ammonia injection shall commence once the exhaust temperature into the SCR catalyst has reached 540 degrees F

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

E144.1 The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D11]

E162.1 The operator shall use this equipment only during utility failure periods, except for maintenance purposes.

**[RULE 1110.2, 6-3-2005; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 1401, 3-4-2005]**

[Devices subject to this condition : D6]

E179.1 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

Condition Number D 12- 2

Condition Number D 12- 3

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C4]

E179.2 For the purpose of the following condition number(s), continuous monitoring shall be defined as measuring at least once every month and shall be calculated based upon the average of the continuous monitoring for that month.

Condition Number D 12- 4

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C4]

E193.1 The operator shall upon completion of construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the Negative Declaration prepared for this project (CEQA State Clearinghouse No. 2006121113).

[CA PRC CEQA, 11-23-1970]

[Devices subject to this condition : D1, C3, C4, D6, D11]

E193.2 The operator shall operate and maintain this equipment according to the following specifications:

The TA Luft carburetor settings shall be maintained at all times.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D6]

**FACILITY PERMIT TO OPERATE  
 SO CAL EDISON CO**

**SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE**

**The operator shall comply with the terms and conditions set forth below:**

**H. Applicable Rules**

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
SOX	40CFR60, SUBPART	KKKK
NOX	40CFR60, SUBPART	KKKK

**[40CFR 60 Subpart KKKK, 7-6-2006]**

[Devices subject to this condition : D1]

**K. Record Keeping/Reporting**

K40.1 The operator shall provide to the District a source test report in accordance with the following specifications:

Source test results shall be submitted to the District no later than 60 days after the source test was conducted.

Emission data shall be expressed in terms of (ppmv) corrected to 15 percent oxygen (dry basis). In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains per DSCF.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM).

All moisture concentration shall be expressed in terms of percent corrected to 15 percent oxygen.

Source test results shall also include the oxygen levels in the exhaust, fuel flow rate (CFH), the flue gas temperature, and the generator power output (MW) under which the test was conducted.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE  
1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D1]

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Commissioning hours and type of control and fuel use

Date and time of each start-up and shutdown

Natural gas fuel use after the commissioning period and prior to CEMS certification

CEMS minute data during start up and shutdown

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D1]

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Date of operation, the elapsed time, in hours, and the reason for operation.  
Records shall be kept and maintained on file for a minimum of two years and made available to district personnel upon request.

**[RULE 1110.2, 6-3-2005; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;  
RULE 1401, 3-4-2005]**

[Devices subject to this condition : D6]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION I: PLANS AND SCHEDULES**

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**SECTION J: AIR TOXICS**

**NOT APPLICABLE**

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION K: TITLE V Administration**

#### **GENERAL PROVISIONS**

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

#### **Permit Renewal and Expiration**

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]  
  
(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

#### **Duty to Provide Information**

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

#### **Payment of Fees**

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION K: TITLE V Administration

#### Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
  - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
  - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

#### COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
  - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION K: TITLE V Administration**

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
  - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
  - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
  - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
  - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
  
10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
  
11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
  
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
  
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
  - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
  - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
  - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
  - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
  - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency<sup>1</sup> constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
    - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
    - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
    - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
    - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
  - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

<sup>1</sup> "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS**

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
  - (B) The date(s) analyses were performed;
  - (C) The company or entity that performed the analyses;
  - (D) The analytical techniques or methods used;
  - (E) The results of such analyses; and
  - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

### **REPORTING PROVISIONS**

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **SECTION K: TITLE V Administration**

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:  
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

### **PERIODIC MONITORING**

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION K: TITLE V Administration

#### *FACILITY RULES*

*This facility is subject to the following rules and regulations*

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 1110.2	6-3-2005	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	6-9-2006	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	7-14-2006	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	12-6-2002	Non federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 1470	11-3-2005	Non federally enforceable
RULE 212	11-14-1997	Non federally enforceable
RULE 212	12-7-1995	Federally enforceable
RULE 218	5-14-1999	Federally enforceable
RULE 218	8-7-1981	Federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### SECTION K: TITLE V Administration

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 3003	3-16-2001	Non federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3005	3-16-2001	Non federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
CA PRC CEQA	11-23-1970	Non federally enforceable
40CFR 60 Subpart GG	2-24-2006	Federally enforceable
40CFR 60 Subpart KKKK	7-6-2006	Federally enforceable
40CFR 68 - Accidental Release Prevention	5-24-1996	Federally enforceable
40CFR 72 - Acid Rain Provisions	11-24-1997	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable

**FACILITY PERMIT TO OPERATE  
SO CAL EDISON CO**

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN  
PERMIT PURSUANT TO RULE 219**

NONE

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

### TABLE OF STANDARDS

#### VOC LIMITS

#### Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250						
Graphic Arts (Sign) Coatings	500				100		50

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550		275	
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

### TABLE OF STANDARDS (cont.)

#### VOC LIMITS

#### Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-09-2006]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-09-2006] TABLE OF STANDARDS VOC LIMITS

**Grams of VOC Per Liter of Coating,  
Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-09-2006]

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing Concrete/Masonry Sealers	400					100		
Wood Preservatives								
Below-Ground	350							
Other	350							

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 06-09-2006]

- \* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.
- \*\* Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.
- \*\*\* The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.

### TABLE OF STANDARDS (cont.) VOC LIMITS

#### Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)

**FACILITY PERMIT TO OPERATE  
 SO CAL EDISON CO**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

**FACILITY PERMIT TO OPERATE  
 SO CAL EDISON CO**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 07-14-2006]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2008</b>
<b>SOLVENT CLEANING ACTIVITY</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 07-14-2006]

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2008</b>
<b>SOLVENT CLEANING ACTIVITY (cont.)</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components		
(I) Newsprint	100 (0.83)	

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 07-14-2006]

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2008</b>
<b>SOLVENT CLEANING ACTIVITY (cont.)</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(II) Other Substrates	500 (4.2)	100 (0.83)
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	500 (4.2)	100 (0.83)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

\* The specified limits remain in effect unless revised limits are listed in subsequent columns.

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]**

1. A Title V permit revision is not required for emission increases that are authorized by allowances acquired under the Acid Rain Program, provided that the increases do not trigger a Title V permit revision under any other applicable requirement. [70.6 (a)(4)(ii)]

#### **Monitoring Requirements**

2. The owners and operators and, to the extent applicable, the designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Parts 74, 75, and 76. [40 CFR 72.50, 72.31, 72.9(b)(1)]
3. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the acid rain emissions limitations and emissions reduction requirements for sulfur dioxide (SO<sub>2</sub>) under the Acid Rain Program. [40 CFR 72.9(b)(2), 40 CFR 75.2]
4. The requirements of 40 CFR Parts 74 and 75 shall not affect the responsibility of the operator to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements and other provisions of this permit. [40 CFR 72.9(b)(3), 40 CFR 72.5]

#### **Sulfur Dioxide Requirements**

5. The owners and operators of each source and each affected unit at the source shall:
  - (A) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR Part 73, Section 73.34(C)) not less than the total annual emissions of SO<sub>2</sub> for the previous calendar year from the unit; and, [40 CFR 72.9(c)(i)],
  - (B) Comply with the applicable acid rain emissions limitations for SO<sub>2</sub>. [40 CFR 72.9(c)(ii)]
6. Each ton of SO<sub>2</sub> emitted in excess of the acid rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72.9(g)(7)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

7. SO<sub>2</sub> allowances shall be held in, deducted from, or transferred among allowance tracking system accounts in accordance with the Acid Rain Program. [40 CFR 72.9(g)(4)]
8. A SO<sub>2</sub> allowance shall not be deducted in order to comply with the requirements under paragraph 41(A) of the SO<sub>2</sub> requirements prior to the calendar year for which the allowance was allocated. [40 CFR 72.9(g)(5)]
9. An affected unit shall be subject to the SO<sub>2</sub> requirements under the Acid Rain Program as follows:[40 CFR 72.6(a)]
  - (A) Starting January 1, 2000, an affected unit under 40 CFR Part 72, Section 72.6(a)(2); or [40 CFR 72.6(a)(2)]
  - (B) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR Part 75, an affected unit under 40 CFR Part 72, Section 72.6(a)(3). [40CFR 72.6(a)(3)]
10. An allowance allocated by the EPA administrator under the Acid Rain Program is a limited authorization to emit SO<sub>2</sub> in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the acid rain permit application, the acid rain permit, or the written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14, and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72.9 (c)(6)]
11. An allowance allocated by the EPA Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72.9(c)(7)]

### **Excess Emissions Requirements**

12. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 72.9(e)]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]**

13. The owners and operators of an affected unit that has excess emissions in any calendar year shall: [40 CFR 72.9(e)(2)]
- (A) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and [40 CFR 72.9(e)(2)(i)]
- (B) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77. [40 CFR 72.9(e)(2)(ii)]

### **Recordkeeping and Reporting Requirements**

14. Unless otherwise provided, the owners and operators of the source and each affected unit at the source that are subject to the acid rain provisions under Title IV shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the EPA Administrator or the Executive Officer: [40 CFR 72.9(f)(1)]
- (A) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative; [40 CFR 72.9(f)(1)(i)]
- (B) All emissions monitoring information, in accordance with 40 CFR Part 75; [40 CFR 72.9(f)(1)(ii)]
- (C) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and, [40 CFR 72.9(f)(1)(iii)]
- (D) Copies of all documents used to complete an acid rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program. [40 CFR 72.9(f)(1)(iv)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

15. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72 Subpart I and 40 CFR Part 75. [40 CFR 72.9(f)(2)]

#### Liability

16. Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete acid rain permit application, an acid rain permit, or a written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to Section 113(c) of the Act. [40 CFR 72.9 (g)(1)]
17. Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to Section 113(c) of the Act and 18 U.S.C. 1001. [40 CFR 72.9 (g)(2)]
18. No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect. [40 CFR 72.9 (g)(3)]
19. Each affected source and each affected unit shall meet the requirements of the Acid Rain Program. [40 CFR 72.9 (g)(4)]
20. Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source. [40 CFR 72.9 (g)(5)]

## FACILITY PERMIT TO OPERATE SO CAL EDISON CO

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

21. Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR Part 72, Section 72.44 (Phase II repowering extension plans) and 40 CFR Part 76, Section 76.11 (NOx averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR Part 75, Sections 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative. [40 CFR 72.9 (g)(6)]
22. Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act. [40 CFR 72.9 (g)(7)]

### Effect on Other Authorities

23. No provision of the Acid Rain Program, an acid rain permit application, an acid rain permit, or a written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14 shall be construed as: [40 CFR 72.9 (h)]
  - (A) Except as expressly provided in Title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of Title I of the Act relating to applicable National Ambient Air Quality Standards or state implementation plans; [40 CFR 72.9 (h)(1)]
  - (B) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act; [40 CFR 72.9 (h)(2)]

## **FACILITY PERMIT TO OPERATE SO CAL EDISON CO**

### **APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]**

(C) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law; [40 CFR 72.9 (h)(3)]

(D) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or, [40 CFR 72.9 (h)(4)]

(E) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established. [40 CFR 72.9 (h)(5)]



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • [www.aqmd.gov](http://www.aqmd.gov)

## **NOTICE OF PROPOSED RENEWAL TITLE V PERMIT**

The South Coast Air Quality Management District (AQMD) is proposing to renew the existing Title V permit previously issued to the facility listed below:

### **Facility Locations and Contact Person**

**SOUTHERN CALIFORNIA EDISON, BARRE**  
8662 Cerritos Ave.  
Stanton, CA 90680  
Facility ID 51475

#### *Contact Person:*

Kishore Billapati  
Environmental Specialist  
7301 Fenwick Lane  
Westminster, CA 92683

The facility operates 1 natural gas fired turbine along with auxiliary equipment in the production of electrical power.

Pursuant to Title V of the federal Clean Air Act and the AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, this facility has submitted a Title V renewal application and requested the AQMD to renew their Title V permits. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to this facility.

The proposed permit is available for public review at the AQMD, 21865 Copley Dr., Diamond Bar, CA, and at the Stanton Library, 7850 Katella Avenue, Stanton, CA 90680. Information

regarding the facility owner's compliance history submitted to the AQMD pursuant to California Health & Safety Code Section 42336, or otherwise known to the AQMD based on credible information, is also available from the AQMD for public review. For more information or to review additional supporting documents, call the AQMD's Title V hotline at (909) 396-3013. Written comments should be submitted to Mr. Chris Perri, Air Quality Engineer, 21865 Copley Drive, Diamond Bar, CA 91765-4178. Comments must be received by April 30, 2012. The AQMD will consider all public comments and may revise the Title V permit in accordance with AQMD rules and regulations.

The public may request the AQMD to conduct a public hearing on the proposed permit by submitting a Hearing Request Form (Form 500-G) to Chris Perri at the above AQMD address. The AQMD will hold a public hearing if there is evidence that the proposed permit is not correct or is not adequate to ensure compliance with regulatory requirements, and a hearing will likely provide additional information that will affect the drafting and/or issuance of the permit. Public hearing request forms and the schedule of public hearings may be obtained from the AQMD by calling the Title V hotline at (909) 396-3013, or from the Internet at <http://www.aqmd.gov/titlev>. Requests for public hearings are due by April 13, 2012. A copy of the hearing request must also be sent by first class mail to the appropriate facility contact person listed above

# South Coast Air Quality Management District

## Statement of Basis

### Proposed Title V Renewal Permit

<b>Facility Name:</b>	<b>Southern California Edison, Barre Substation</b>
<b>Facility ID:</b>	<b>51475</b>
<b>SIC Code:</b>	<b>4911</b>
<b>Equipment Location:</b>	<b>8662 Cerritos Ave Stanton, CA 90680</b>
<b>Application #(s):</b>	<b>526863</b>
<b>Application Submittal Date(s):</b>	<b>08/31/11</b>
<b>AQMD Contact Person:</b>	<b>Chris Perri, Air Quality Engineer</b>
<b>Phone Number:</b>	<b>(909) 396-2696</b>
<b>E-Mail Address:</b>	<b>cperri@aqmd.gov</b>

---

#### 1. Introduction and Scope of Permit

Title V is a national operating permit program for air pollution sources. Facilities subject to Title V must obtain a Title V permit and comply with specific Title V procedures to modify the permit. This permit replaces the facility's other existing permits. Title V does not necessarily include any new requirements for reducing emissions. It does, however, include new permitting, noticing, record keeping, and reporting requirements.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years after the date of issuance, unless such permit has been renewed. Accordingly, each facility is required to submit a Title V renewal application and request that the AQMD renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The AQMD implements Title V through Regulation XXX – Title V Permits, adopted by the AQMD Governing Board in order to comply with EPA's requirement that local air permitting authorities develop a Title V program. Regulation XXX was developed with the participation of the public and affected facilities through a series of public workshops, working group meetings, public hearings and other meetings.

The Title V major source threshold for a particular pollutant depends on the attainment status of the pollutant. NO<sub>2</sub>, SO<sub>2</sub>, CO, and lead are in attainment with federal standards. The status for

PM-10 is serious nonattainment. The status for ozone is currently extreme nonattainment. For the South Coast Air Basin (SOCAB) the threshold levels are as follows:

Pollutant	SOCAB Major Source Thresholds
VOC	10
NOx	10
SOx	100
CO	50
PM-10	70
Single HAP	10
Combination of HAPS	25

A Title V permit is proposed to be issued to cover the operations of SCE, Barre Substation, 8662 Cerritos Ave, Stanton. This facility is subject to Title V requirements because the gas turbine is greater than 25 MW and is subject to Acid Rain. The facility is not a major source of either criteria pollutants or HAPs.

## **2. Facility Description**

This is an existing facility that is in the business of producing electrical power. The facility operates 1 gas turbine generator to produce power for use in the State of California. The turbine's maximum rating is 49 MW and it is fired on natural gas exclusively. The turbine employs water injection and SCR for NOx control, and an oxidation catalyst for CO control. The equipment was constructed with BACT at the time the original permit to construct was issued in 2007. The NOx BACT limit is 2.5 ppmv, the CO BACT limit is 6.0 ppmv, the VOC BACT limit is 2.0 ppmv, and the ammonia slip limit is 5 ppmv, all on a 1 hour average basis. There is also 1 natural gas fired emergency generator engine, rated at 924 hp, 1 diesel fired emergency generator, rated at 415 bhp, and a 10,500 gallon aqueous ammonia storage tank at the facility

## **3. Construction and Permitting History**

The gas turbine generator at this facility received its initial permit in on April 3, 2007. Construction was complete on the unit in the summer of 2007, and first fire twas around July 20 of that year. There have been 2 de minimis significant revisions to the permit since its original construction permit was issued. The first was in 2008 to address start up limits, equipment description, and hours of operation for the turbine and emergency generator. The second was in 2009 to allow an exemption from BACT during black start testing of the turbine as required by Cal-ISO.

## **4. Regulatory Applicability Determinations**

Applicable legal requirements for this facility are required to be identified in the Title V permit (for example, Section D, E, and H of the proposed Title V permit). Applicability determinations

(i.e., determinations made by the District with respect to what legal requirements apply to a specific piece of equipment, process, or operation) can be found in the Engineering Evaluations.

The following summarizes the key rules that apply to the major equipment at this site:

Gas Turbine

- 218 – Continuous Emission Monitoring
- 401 – Visible Emissions
- 402 - Nuisance
- 407 – Liquid and Gaseous Air Contaminants (CO and SO<sub>2</sub> emissions)
- 409 – Combustion Contaminants (PM emissions)
- 431.1 – Sulfur Content of Natural Gas (SO<sub>x</sub> emissions)
- 475 – Electric Power Generating Equipment (PM emissions)
- Regulation XIII – BACT ((NO<sub>x</sub>, CO, ROG, PM<sub>10</sub>, SO<sub>x</sub>, NH<sub>3</sub>)
- Regulation XXX – Title V
- 40CFR 60 Subpart KKKK (Federal New Source Performance Standards)
- 40CFR 72 – Acid Rain

Natural Gas Emergency Engine

- 401 – Visible Emissions
- 402 – Nuisance
- 431.1 – Sulfur Content of Natural Gas (SO<sub>x</sub>)
- Regulation XIII – BACT (NO<sub>x</sub>, CO, ROG, PM<sub>10</sub>, SO<sub>x</sub>)
- Regulation XXX – Title V

Diesel Emergency Engine

- 401 – Visible Emissions
- 402 - Nuisance
- 404 – Particulate Matter (PM)
- 431.2 – Sulfur Content of Liquid Fuels (SO<sub>x</sub>)
- Rule 1470 – Air Toxic Control Measure
- Regulation XXX – Title V

The facility is not a major source of HAPs and therefore is not subject to any MACT standards. Total potential HAP emissions are less than 1 tpy, and there is no single HAP over 600 lbs/yr (not including ammonia). There are no area source MACT standards which apply to this facility.

NSPS requirements of 40CFR Part 60 subpart KKKK apply to the gas turbine. Under subpart KKKK, the NO<sub>x</sub> is limited to 25 ppm, and the SO<sub>x</sub> is limited to 0.9 lbs/MWh discharge, or 0.060 lbs/mmbtu potential in the fuel. There is a requirement to measure the water to fuel ratio and the fuel consumption rate, or alternatively, the unit can use a NO<sub>x</sub> and O<sub>2</sub> CEMS. Also, daily monitoring of the sulfur content of the fuel is required if the fuel limit is selected. However, if the operator can provide supplier data showing the sulfur content of the fuel is less than 20 grains/100cf (for natural gas), then daily fuel monitoring is not required.

The equipment complies with the NOx limit since the BACT limit is lower. With the use of natural gas fuel exclusively, the equipment complies with the SOx limit. The equipment also uses continuous monitoring for NOx and CO. Therefore, the equipment complies with the requirements of Subpart KKKK.

CFR Parts 72-78 (Acid Rain) requirements apply to the turbine. Under the Acid Rain regulations, SO2 emissions from the unit are required to be offsets with SO2 allowances. In order to determine the amount of SO2 emitted from the turbine, the SO2 emissions are required to be monitored through use of fuel gas meters and gas constituent analyses, or, if fired with pipeline quality natural gas, as in the case of this facility, a default emission factor of 0.0006 lbs/mmBtu is allowed. SO2 mass emissions are to be recorded every hour. NOx and O2 must be monitored with CEMS in accordance with the specifications of Part 75. Under this program, NOx and SOx emissions will be reported directly to the U.S. EPA.

Compliance Assurance Monitoring (CAM) requirements of 40 CFR Part 64 do not apply to the turbine because it is not a major source of criteria pollutants.

The permit terms and conditions may be found in Section D of the Title V permit.

## **5. Monitoring and Operational Requirements**

Applicable monitoring and operational requirements for which the facility is required to comply are identified in the Title V permit (for example, Section D, J, and K, and Appendix B). Discussion of any applicable monitoring and operational requirements can be found in the Engineering Evaluations. All periodic monitoring requirements were developed using strict adherence to the following applicable guidance documents: SCAQMD Periodic Monitoring Guidelines for Title V Facilities (November 1997), CAPCOA/CARB/EPA region IX Periodic Monitoring Recommendations for Generally Applicable Requirements in SIP (June 1999), and CAPCOA/CARB/EPA Region IX Recommended Periodic Monitoring for Generally Applicable Grain Loading Standards in the SIP: Combustion Sources (July 2001).

Under the Acid Rain program, the turbine is required to maintain a CEMS for NOx emissions, measure the exhaust O2, and report mass emissions directly to EPA. Also under Acid Rain (and Subpart KKKK), the plant is allowed to report SOx emissions based on an emission factor since natural gas is used exclusively. Under SCAQMD BACT requirements, the turbine is required to maintain a NOx and CO CEMS for determination of compliance with the BACT concentrations and mass emission limits for these pollutants.

## **6. Permit Features**

### Permit Shield

A permit shield is an optional part of a Title V permit that gives the facility explicit protection from requirements that may be incorrectly specified in the permit. A permit shield is a provision in a permit that states that compliance with the conditions contained in the permit shall be deemed compliance with all identified regulatory requirements. To incorporate a permit shield into the Title V permit involves submission of applications for change of conditions for each

equipment affected by the permit shield. Permit shields are addressed in Rule 3004 (c). This facility has not applied for a permit shield.

#### Streamlining Requirements

Some emission units may be subject to multiple requirements which are closely related or redundant. The conditions may be streamlined to simplify the permit conditions and compliance. Emission limits, work practice standards, and monitoring, recordkeeping, and reporting requirements may be streamlined. Compliance with a streamlined condition will be deemed compliance with the underlying requirements whether or not the emission unit is actually in compliance with the specific underlying requirement. This facility has not applied for any streamlined conditions.

### 7. Summary of Emissions and Health Risks

**Criteria Pollutant Emissions (tons/year)**  
**Annual Reported Emissions for Reporting Period 2010**

Pollutant	Emissions (tons/year)
NO <sub>x</sub>	0.487
CO	0.422
VOC	0.113
PM	0.387
SO <sub>x</sub>	0.023

**Toxic Air Contaminants Emissions (TAC)**  
**Annual Reported Emissions for Reporting Period 2010**

The Following TACs Were Reported	Emissions (lbs/yr)
1,3 Butadiene	0.084
Ammonia	658
Benzene	0.993
Formaldehyde	17
Naphthalene	0.102
Polynuclear aromatic hydrocarbons (PAHs)	0.073

#### Health Risk from Toxic Air Contaminants

The facility is subject to review by the Air Toxics Information and Assessment Act (AB2588). The facility is not currently defined as high risk, and therefore is not required to perform a Health Risk Assessment at this time.

### 8. Compliance History

As noted, the facility has been in operation since about 2007. The facility has been subject to both self-reporting requirements and AQMD inspections. The facility has had 0 citizen

complaints filed, 0 NoticeS to Comply issued, and 0 Notices of Violation issued in the last two calendar years.

**9. Compliance Certification**

By virtue of the Title V permit application and renewal of this permit, the reporting frequency for compliance certification for the facility shall be annual.

# SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

## Title V Permit Summary

AQMD Facility ID:	51475	Company Name:	SCE, BARRE SUBSTATION															
Equipment Location:	8662 CERRITOS AVE, STANTON, CA 90680			SIC Code: 4911														
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected:																
Application #(s):	526863	Application Submittal Date(s):	08/31/11															
AQMD Contact Person:	CHRIS PERRI	Phone #:	(909) 396- 2696															
		E-Mail Address:	cperry@aqmd.gov															
Project Description: This is an existing facility applying for a renewal to their Title V permit. The facility produces electrical power for the State of California. This facility operates 1 natural gas fired turbine equipped with an SCR and oxidation catalyst. There is also 1 natural gas fired emergency generator engine, 1 diesel fired emergency generator, and an aqueous ammonia storage tank. The approximate total facility generating capacity is 49 MWs.																		
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal																		
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance																		
Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for Reporting Year: 2010		<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> The Following TACs Were Reported:																
		<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 80%;"></th> <th style="text-align: right; border-bottom: 1px solid black;">Emissions (lbs/yr):</th> </tr> </thead> <tbody> <tr> <td>AMMONIA</td> <td style="text-align: right;">658</td> </tr> <tr> <td>BENZENE</td> <td style="text-align: right;">0.993</td> </tr> <tr> <td>FORMALDEHYDE</td> <td style="text-align: right;">17</td> </tr> <tr> <td>NAPHTHALENE</td> <td style="text-align: right;">0.102</td> </tr> <tr> <td>PAH</td> <td style="text-align: right;">0.073</td> </tr> <tr> <td>1,3 BUTADIENE</td> <td style="text-align: right;">0.084</td> </tr> </tbody> </table>				Emissions (lbs/yr):	AMMONIA	658	BENZENE	0.993	FORMALDEHYDE	17	NAPHTHALENE	0.102	PAH	0.073	1,3 BUTADIENE	0.084
	Emissions (lbs/yr):																	
AMMONIA	658																	
BENZENE	0.993																	
FORMALDEHYDE	17																	
NAPHTHALENE	0.102																	
PAH	0.073																	
1,3 BUTADIENE	0.084																	
Health Risk From Toxic Air Contaminants: <input type="checkbox"/> Health Risk Reduction Plan in Force (AQMD Rule 1402) (date): _____ <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input checked="" type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input checked="" type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input type="checkbox"/> Final Facility Health Risk Approved Cancer Risk = _____ Acute Hazard Index = _____ Chronic Hazard Index = _____																		
Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2010		<input checked="" type="checkbox"/> NOx    0.487 <input checked="" type="checkbox"/> PM    0.387 <input checked="" type="checkbox"/> CO    0.422 <input checked="" type="checkbox"/> SOx    0.023 <input checked="" type="checkbox"/> VOC    0.113 <input type="checkbox"/> Other: _____																
Compliance History: <input checked="" type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years ( 0 ) <input checked="" type="checkbox"/> Notices to Comply Issued in Last Two Calendar Years ( 0 ) <input checked="" type="checkbox"/> Notices of Violation Issued in Last Two Calendar Years ( 0 )																		
Comments:																		



South Coast Air Quality Management District

Form 400-A

Application Form for Permit or Plan Approval

List only one piece of equipment or process per form.

Mail To: SCAQMD, P.O. Box 4944, Diamond Bar, CA 91765-0944, Tel: (909) 396-3385, www.aqmd.gov

Section A - Operator Information

1. Facility Name (Business Name of Operator to Appear on the Permit): Southern California Edison Company
2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 051475
3. Owner's Business Name (If different from Business Name of Operator):

Section B - Equipment Location Address

4. Equipment Location Is: Fixed Location (For equipment operated at various locations, provide address of initial site.)
8662 Cerritos Ave.
Stanton, CA 90680
Kishore Billapati, Envr. Spec.
(714) 379-7919, (714) 895-0259
E-Mail: Kishore.Billapati@SCE.com

Section C - Permit Mailing Address

5. Permit and Correspondence Information:
7301 Fenwick Lane - Peaker and Solar Generation Division
Westminster, CA 92683
Kishore Billapati, Envr. Spec.
(714) 379-7919, (714) 895-0259
E-Mail: Kishore.Billapati@SCE.com

Section D - Application Type

6. The Facility Is: In Title V
7. Reason for Submitting Application (Select only ONE):
7a. New Equipment or Process Application: Streamlined Standard Permit
7b. Facility Permits: Title V Application or Amendment (Also submit Form 500-A1)
7c. Equipment or Process with an Existing/Previous Application or Permit: Existing or Previous Permit/Application

8a. Estimated Start Date of Construction (mm/dd/yyyy):
8b. Estimated End Date of Construction (mm/dd/yyyy):
8c. Estimated Start Date of Operation (mm/dd/yyyy):

9. Description of Equipment or Reason for Compliance Plan (list applicable rule): Title V Permit Renewal
10. For identical equipment, how many additional applications are being submitted with this application?
11. Are you a Small Business as per AQMD's Rule 102 definition? No
12. Has a Notice of Violation (NOV) or a Notice to Comply (NC) been issued for this equipment? No

Section E - Facility Business Information

13. What type of business is being conducted at this equipment location? Electric Power Generation
14. What is your business primary NAICS Code? 221112
15. Are there other facilities in the SCAQMD jurisdiction operated by the same operator? No
16. Are there any schools (K-12) within 1000 feet of the facility property line? No

Section F - Authorization/Signature

17. Signature of Responsible Official: Russ W. Krieger
18. Title of Responsible Official: V.P., Power Production
19. I wish to review the permit prior to issuance. Yes
20. Print Name: Russ W. Krieger
21. Date: 8/26/11
22. Do you claim confidentiality of data? No

23. Check List: Authorized Signature/Date, Form 400-CEQA, Supplemental Form(s), Fees Enclosed

Table with columns: AQMD USE ONLY, APPLICATION TRACKING #, CHECK #, AMOUNT RECEIVED, PAYMENT TRACKING #, VALIDATION, DATE, APP. DATE, APP. REJ., CLASS, BASIC CONTROL, EQUIPMENT CATEGORY CODE, TEAM, ENGINEER, REASON/ACTION TAKEN

South Coast Air Quality Management District, Form 400-A (2009.04)
Handwritten notes: (90622), Chrisp., 484



South Coast Air Quality Management District

Form 400-CEQA

California Environmental Quality Act (CEQA) Applicability

Mail To: SCAQMD, P.O. Box 4944, Diamond Bar, CA 91765-0944. Tel: (909) 396-3385, www.aqmd.gov

The SCAQMD is required by state law, the California Environmental Quality Act (CEQA), to review discretionary permit project applications for potential air quality and other environmental impacts. This form is a screening tool to assist the SCAQMD in clarifying whether or not the project has the potential to generate significant adverse environmental impacts that might require preparation of a CEQA document [CEQA Guidelines §15060(a)]. Refer to the attached instructions for guidance in completing this form. For each Form 400-A application, also complete and submit one Form 400-CEQA. If submitting multiple Form 400-A applications for the same project at the same time, only one 400-CEQA form is necessary for the entire project. If you need assistance completing this form, contact Permit Services at (909) 396-3385 or (909) 396-2668.

Section A - Facility Information
1. Facility Name (Business Name of Operator To Appear On The Permit): Southern California Edison Company
2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 051475
3. Project Description: Title V Permit Renewal

Section B - Review For Exemption From Further CEQA Action
Check "Yes" or "No" as applicable
Table with 8 rows of questions regarding CEQA exemptions, such as 'A CEQA and/or NEPA document previously or currently prepared that specifically evaluates this project?' and 'A request for a change of permittee only (without equipment modifications)?'

If "Yes" is checked for any question in Section B, your application does not require additional evaluation for CEQA applicability. Skip to Section D - Signatures on page 2 and sign and date this form.

Section C - Review of Impacts Which May Trigger CEQA
Complete Parts I-VI by checking "Yes" or "No" as applicable. To avoid delays in processing your application(s), explain all "Yes" responses on a separate sheet and attach it to this form.
Table with 4 rows of questions regarding public controversy, larger projects, and air quality impacts.

1 A "project" means the whole of an action which has a potential for resulting in physical change to the environment, including construction activities, clearing or grading of land, improvements to existing structures, and activities or equipment involving the issuance of a permit. For example, a project might include installation of a new, or modification of an existing internal combustion engine, dry-cleaning facility, boiler, gas turbine, spray coating booth, solvent cleaning tank, etc.
2 To download the CEQA guidelines, visit http://ceres.ca.gov/env\_law/state.html.
3 To download this form and the instructions, visit http://www.aqmd.gov/ceqa or http://www.aqmd.gov/permit


**Section C - Review of Impacts Which May Trigger CEQA (cont.)**

	Yes	No	Part II - Air Quality (cont.)
5.	<input type="radio"/>	<input type="radio"/>	Would this project result in noticeable off-site odors from activities that may not be subject to SCAQMD permit requirements? For example, compost materials or other types of greenwaste (i.e., lawn clippings, tree trimmings, etc.) have the potential to generate odor complaints subject to Rule 402 - Nuisance.
6.	<input type="radio"/>	<input type="radio"/>	Does this project cause an increase of emissions from marine vessels, trains and/or airplanes?
7.	<input type="radio"/>	<input type="radio"/>	Will the proposed project increase the QUANTITY of hazardous materials stored aboveground onsite or transported by mobile vehicle to or from the site by greater than or equal to the amounts associated with each compound on the attached Table 1? <sup>4</sup>
Part III - Water Resources			
8.	<input type="radio"/>	<input type="radio"/>	Will the project increase demand for water at the facility by more than 5,000,000 gallons per day? The following examples identify some, but not all, types of projects that may result in a "yes" answer to this question: 1) projects that generate steam; 2) projects that use water as part of the air pollution control equipment; 3) projects that require water as part of the production process; 4) projects that require new or expansion of existing sewage treatment facilities; 5) projects where water demand exceeds the capacity of the local water purveyor to supply sufficient water for the project; and 6) projects that require new or expansion of existing water supply facilities.
9.	<input type="radio"/>	<input type="radio"/>	Will the project require construction of new water conveyance infrastructure? Examples of such projects are when water demands exceed the capacity of the local water purveyor to supply sufficient water for the project, or require new or modified sewage treatment facilities such that the project requires new water lines, sewage lines, sewage hook-ups, etc.
Part IV - Transportation/Circulation			
10.	Will the project result in (Check all that apply):		
	<input type="radio"/>	<input type="radio"/>	a. the need for more than 350 new employees?
	<input type="radio"/>	<input type="radio"/>	b. an increase in heavy-duty transport truck traffic to and/or from the facility by more than 350 truck round-trips per day?
	<input type="radio"/>	<input type="radio"/>	c. increase customer traffic by more than 700 visits per day?
Part V - Noise			
11.	<input type="radio"/>	<input type="radio"/>	Will the project include equipment that will generate noise GREATER THAN 90 decibels (dB) at the property line?
Part VI - Public Services			
12.	Will the project create a permanent need for new or additional public services in any of the following areas (Check all that apply):		
	<input type="radio"/>	<input type="radio"/>	a. Solid waste disposal? Check "No" if the projected potential amount of wastes generated by the project is less than five tons per day.
	<input type="radio"/>	<input type="radio"/>	b. Hazardous waste disposal? Check "No" if the projected potential amount of hazardous wastes generated by the project is less than 42 cubic yards per day (or equivalent in pounds).

**\*\*REMINDER:** For each "Yes" response in Section C, attach all pertinent information including but not limited to estimated quantities, volumes, weights, etc.\*\*

**Section D - Signatures**

I HEREBY CERTIFY THAT ALL INFORMATION CONTAINED HEREIN AND INFORMATION SUBMITTED WITH THIS APPLICATION IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE. I UNDERSTAND THAT THIS FORM IS A SCREENING TOOL AND THAT THE SCAQMD RESERVES THE RIGHT TO CONSIDER OTHER PERTINENT INFORMATION IN DETERMINING CEQA APPLICABILITY.

1. Signature of Responsible Official of Firm: 		2. Title of Responsible Official of Firm: Vice President, Power Production	
3. Print Name of Responsible Official of Firm: Russ W. Krieger		4. Date Signed: 8/26/11	
5. Phone # of Responsible Official of Firm: (909) 394-8667	6. Fax # of Responsible Official of Firm: (909) 394-8966	7. Email of Responsible Official of Firm: Russ.Krieger@SCE.com	
8. Signature of Preparer, (If prepared by person other than responsible official of firm): 		9. Title of Preparer: Environmental Specialist	
10. Print Name of Preparer: Kishore Billapati		11. Date Signed: 8/26/11	
12. Phone # of Preparer: (714) 379-7919	13. Fax # of Preparer: (714) 895-0259	14. Email of Preparer: Kishore.Billapati@SCE.com	

THIS CONCLUDES FORM 400-CEQA. INCLUDE THIS FORM AND ANY ATTACHMENTS WITH FORM 400-A.

<sup>4</sup> Table 1 - Regulated Substances List and Threshold Quantities for Accidental Release Prevention can be found in the instructions for Form 400-CEQA.



South Coast Air Quality Management District

**Form 500-A1**

**Title V Permit Application Supplemental**

Mail To:  
SCAQMD  
P.O. Box 4944  
Diamond Bar, CA 91765-0944  
Tel: (909) 396-3385  
www.aqmd.gov

**Section I - Operator Information**

1. Facility Name (Business Name of Operator That Appears On Permit):

Southern California Edison Company

2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD):

051475

3. Facility Is Located In Title V Area:

- 1 All other zip codes not listed below
- 2
 

92201	92202	92203	92210	92211	92234	92235	92236	92239*	92240	92241	92247	92248
92253	92254	92255	92258	92260	92261	92262	92263	92264	92270	92274	92275	92276
92282	92292	92561										
- 3 92239\*

\* If your zip code is 92239, please call (909) 396-3385 to verify your Title V area.

**Section II - Title V Application**

1. This is an application for a(n) (Check all applicable boxes and provide the requested information as appropriate):

- a.  Initial Title V Permit
- b.  Permit Renewal: (Provide current permit expiration date) 04/03/12
- c.  Administrative Change (check all that apply)
  - Change of Operator. (Complete and attach equipment-specific Form 400-E-XX series forms)
  - Change of Facility Information
  - Other, Please specify: \_\_\_\_\_
- d.  Title V Permit Revision
- e.  Title V Exemption Plan
- f.  MACT Part 1
- g.  Permit Shield

Complete and attach equipment specific Form 400-E-XX series form(s) to this form if your application involves permit action for new construction, change of location, non-administrative permit revision, alternative operating scenario (AOS), permit shield, streamlined permit conditions, or temporary source permit.

2. Is this facility required to prepare a Risk Management Plan (RMP) for another agency?  Yes  No

**Section III - Title V Submittal Checklist**

1. Enter the quantity of each type form submitted in the space provided:

<u>1</u> 400-A (REQUIRED)	<u>1</u> 500-C1 (REQUIRED)	<u>1</u> 500-F1	<u>1</u> 500-H (REQUIRED)
<u>1</u> 400-CEQA (REQUIRED)	_____ 500-C2	_____ 500-F2	_____ 500-MACT PART 1
<u>1</u> 500-A2 (REQUIRED)	_____ 500-D	_____ 500-F3	_____ OTHER (SPECIFY): _____
<u>1</u> 500-B (REQUIRED)	_____ 500-E	_____ 500-F4	

2. Additional information referenced in this application submitted:



South Coast Air Quality Management District  
**Form 500-A2**  
**Title V Application Certification**

Mail To:  
 SCAQMD  
 P.O. Box 4944  
 Diamond Bar, CA 91765-0944  
 Tel: (909) 396-3385  
 www.aqmd.gov

**Section I - Operator Information**

1. Facility Name (Business Name of Operator That Appears On Permit): Southern California Edison Company  
 2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 051475

3. This Certification is submitted with a (Check one):  
 a.  Title V Application (Initial, Revision or Renewal)  
 b.  Supplement/Correction to a Title V Application  
 c.  MACT Part 1

4. Is Form 500-C2 included with this Certification?  Yes  No

**Section II - Responsible Official Certification Statement**

Read each statement carefully and check each that applies - You must check 3a or 3b.

**1. For Initial, Permit Renewal, and Administrative Application Certifications:**

- a.  The facility, including equipment that are exempt from written permit per Rule 219, is currently operating and will continue to operate in compliance with all applicable requirement(s) identified in Section II and Section III of Form 500-C1,
  - i.  except for those requirements that do not specifically pertain to such devices or equipment and that have been identified as "Remove" on Section III of Form 500-C1.
  - ii.  except for those devices or equipment that have been identified on the completed and attached Form 500-C2 that will not be operating in compliance with the specified applicable requirement(s).
- b.  The facility, including equipment that are exempt from written permit per Rule 219, will meet in a timely manner, all applicable requirements with future effective dates.

**2. For Permit Revision Application Certifications:**

- a.  The equipment or devices to which this permit revision applies, will in a timely manner comply with all applicable requirements identified in Section II and Section III of Form 500-C1.

**3. For MACT Hammer Certifications:**

- a.  The facility is subject to Section 112(j) of the Clean Air Act (Subpart B of 40 CFR part 63), also known as the MACT "hammer." The following information is submitted with a Title V application to comply with the Part 1 requirements of Section 112(j).
- b.  The facility is not subject to Section 112(j) of the Clean Air Act (Subpart B of 40 CFR part 63).

**Section III - Authorization/Signature**


I certify under penalty of law that I am the responsible official for this facility as defined in AQMD Regulation XXX and that based on information and belief formed after reasonable inquiry, the statement and information in this document and in all attached application forms and other materials are true, accurate, and complete.

1. Signature of Responsible Official: 	2. Title of Responsible Official: Vice President, Power Production
3. Print Name: Russ W. Krieger	4. Date: 8/26/11
5. Phone #: (909) 394-8667	6. Fax #: (909) 394-8966

7. Address of Responsible Official:  
 300 N. Lone Hill Ave. San Dimas CA 91773  
 Street # City State Zip

**Acid Rain Facilities Only: Please Complete Section IV**

Acid Rain facilities must certify their compliance status of the devices subject to applicable requirements under Title IV by an individual who meets the definition of Designated (or Alternate) Representative in 40 CFR Part 72.

Section IV - Designated Representative Certification Statement	
<p><i>For Acid Rain Facilities Only:</i> I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.</p>	
1. Signature of Designated Representative or Alternate: 	2. Title of Designated Representative or Alternate: Vice President, Power Production
3. Print Name of Designated Representative or Alternate: Russ W. Krieger	4. Date: 8/26/11
5. Phone #: (909) 394-8667	6. Fax #: (909) 394-8966
7. Address of Designated Representative or Alternate: 300 N. Lone Hill Ave. San Dimas CA 91773	
Street #	City State Zip



**Trivial Activities**

- |  |   |
|--|---|
| <ul style="list-style-type: none"> <li>• Combustion emissions from propulsion of mobile sources, except for vessel emissions from Outer Continental Shelf sources</li> <li>• Air-conditioning units used for human comfort that do not have applicable requirements under Title VI of the Act</li> <li>• Ventilating units used for human comfort that do not exhaust air pollutants into the ambient air from any manufacturing/industrial or commercial process</li> <li>• Non-commercial food preparation</li> <li>• Consumer use of office equipment and products, not including printers or businesses primarily involved in photographic reproduction</li> <li>• Janitorial services and consumer use of janitorial products</li> <li>• Internal combustion engines used for landscaping purposes</li> <li>• Laundry activities, except for dry-cleaning and steam boilers</li> <li>• Bathroom/toilet vent emissions</li> <li>• Emergency (backup) electrical generators at residential locations</li> <li>• Tobacco smoking rooms and areas</li> <li>• Blacksmith forges</li> <li>• Plant maintenance and upkeep activities (e.g., grounds-keeping, general repairs, cleaning, painting, welding, plumbing, re-tarring roofs, installing insulation, and paving parking lots) provided these activities are not conducted as part of a manufacturing process, are not related to the source's primary business activity, and not otherwise triggering a permit modification<sup>1</sup></li> <li>• Repair or maintenance shop activities not related to the source's primary business activity, not including emissions from surface coating or de-greasing (solvent metal cleaning) activities, and not otherwise triggering a permit modification</li> <li>• Portable electrical generators that can be moved by hand from one location to another<sup>2</sup></li> <li>• Hand-held equipment for buffing, polishing, cutting, drilling, sawing, grinding, turning or machining wood, metal or plastic</li> <li>• Brazing, soldering and welding equipment, and cutting torches related to manufacturing and construction activities that do not result in emission of HAP metals<sup>3</sup></li> <li>• Bench-scale laboratory equipment used for physical or chemical analysis, but not lab fume hoods or vents<sup>4</sup></li> <li>• Routine calibration and maintenance of laboratory equipment or other analytical instruments</li> <li>• Equipment used for quality control/assurance or inspection purposes, including sampling equipment used to withdraw materials for analysis</li> <li>• Hydraulic and hydrostatic testing equipment</li> <li>• Environmental chambers not using hazardous air pollutant (HAP) gasses</li> <li>• Shock chambers</li> <li>• Humidity chambers</li> <li>• Solar simulators</li> </ul> | <ul style="list-style-type: none"> <li>• Fugitive emission related to movement of passenger vehicles, provided any required fugitive dust control plan or its equivalent is submitted</li> <li>• Process water filtration systems and demineralizers</li> <li>• Demineralized water tanks and demineralizer vents Air compressors and pneumatically operated equipment, including hand tools</li> <li>• Batteries and battery charging stations, except at battery manufacturing plants</li> <li>• Storage tanks, vessels and containers holding or storing liquid substances that will not emit any VOC or HAP<sup>5</sup></li> <li>• Storage tanks, reservoirs, and pumping and handling equipment of any size containing soaps, vegetable oil, grease, animal fat and nonvolatile aqueous salt solutions, provided appropriate lids and covers are utilized</li> <li>• Equipment used to mix and package soaps, vegetable oil, grease, animal fat, and nonvolatile aqueous salt solutions, provided appropriate lids and covers are utilized</li> <li>• Drop hammers or hydraulic presses for forging or metalworking</li> <li>• Equipment used exclusively to slaughter animals, but not including other equipment at slaughterhouses, such as rendering cookers, boilers, heating plants, incinerators, and electrical power generating equipment</li> <li>• Vents from continuous emissions monitors and other analyzers</li> <li>• Natural gas pressure regulator vents, excluding venting at oil and gas production facilities</li> <li>• Hand-held applicator equipment for hot melt adhesives with no VOC in the adhesive formulation</li> <li>• Equipment used for surface coating, painting, dipping or spraying operations, except those that will emit VOC or HAP</li> <li>• CO<sub>2</sub> lasers, used only on metals and other materials which do not emit HAP in the process</li> <li>• Consumer use of paper trimmers/binders</li> <li>• Electric or steam-heated drying ovens and autoclaves, but not the emissions from the articles or substance being processed in the ovens or autoclaves or the boilers delivering the steam</li> <li>• Salt baths using nonvolatile salts that do not result in emissions of any regulated air pollutants</li> <li>• Laser trimmers using dust collection to prevent fugitive emissions</li> <li>• Boiler water treatment operations, not including cooling towers</li> <li>• Oxygen scavenging (de-aeration) of water</li> <li>• Ozone generators</li> <li>• Fire suppression systems</li> <li>• Emergency road flares</li> <li>• Steam vents and safety relief valves</li> <li>• Steam leaks</li> <li>• Steam cleaning operations</li> <li>• Steam sterilizers</li> </ul> |
|--|---|

<sup>1</sup> Cleaning and painting activities qualify as trivial if they are not subject to VOC or HAP control requirements. Asphalt batch plant owners/operators must still get a permit if otherwise required.

<sup>2</sup> "Moved by hand" means it can be moved without the assistance of any motorized or non-motorized vehicle, conveyance or device.

<sup>3</sup> Brazing, soldering and welding equipment, and cutting torches related to manufacturing and construction activities that emit HAP metals are more appropriate for treatment as unpermitted equipment. Brazing, soldering, welding and cutting torches directly related to plant maintenance and upkeep and repair or maintenance shop activities that emit HAP metals are treated as trivial and listed separately in this appendix.

<sup>4</sup> Many lab fume hoods or vents might qualify for treatment as unpermitted equipment.

<sup>5</sup> Exemptions for storage tanks containing petroleum liquids or other volatile organic liquids should be based on size limits such as storage tank capacity and vapor pressure of liquids stored and are not appropriate for this list.



South Coast Air Quality Management District

**Form 500-C1**

**Title V Compliance Status Report**

To provide the compliance status of your facility with applicable federally enforceable requirements and identify other local-only requirements, complete this form and attach it to a completed compliance certification Form 500-A2. As appropriate, all submittals of Form 500-C2 as appropriate should also be attached to this form.

Mail To:  
SCAQMD  
P.O. Box 4944  
Diamond Bar, CA 91765-0944

Tel: (909) 396-3385  
www.aqmd.gov

**Section I - Operator Information**

**1. Facility Name** (Business Name of Operator That Appears On Permit):

Southern California Edison Company

**2. Valid AQMD Facility ID** (Available On Permit Or Invoice

Issued By AQMD):

051475

**PROCEDURES FOR DETERMINING COMPLIANCE STATUS**

1. **Equipment verification:** Review the list of pending applications, and either the preliminary Title V facility permit or the list of current permits to operate that the AQMD provided you, to determine if they completely and accurately describe all equipment operating at the facility. Attach a statement to describe any discrepancies.
2. **Identify applicable requirements\*:** Use the checklist in Section II to identify all applicable and federally-enforceable local, state, and federal rules and regulations, test methods, and monitoring, recordkeeping and reporting (MRR) requirements that apply to any equipment or process (including equipment exempt from a permit by Rule 219) at your facility. The potential applicable requirements, test methods and MRR requirements are identified and listed adjacent to each given equipment/process description. Check off each box adjacent to the corresponding requirement as it applies to your particular equipment/process.  
Note: Even if there is only one piece of equipment that is subject to a particular requirement, the appropriate box should be checked.
3. **Identify additional applicable requirements\*:** Use Section III to identify any additional requirements not found in Section II. Section II is not a complete list of all applicable requirements. It does not include recently adopted NESHAP regulations by EPA or recent amendments to AQMD rules. Do not add rules listed in Section V here.
4. **Identify any requirements that do not apply to a specific piece of equipment or process:** Also use Section III to identify any requirements that are listed in Section II but that do not apply to a specific piece of equipment or process. Fill out Section III of this form and attach a separate sheet to explain the reason(s) why the identified rules do not apply. Note: Listing any requirement that does not apply to a specific piece of equipment will not provide the facility with a permit shield unless one is specifically requested by completing Form 500-D and is approved by AQMD.
5. **Identify SIP-approved rules that are not current AQMD rules:** Use Section IV to identify older versions of current AQMD rules that are the EPA-approved versions in the State Implementation Plan (SIP), and that are still applicable requirements as defined by EPA. The facility is not required to certify compliance with the items checked in Section IV provided that the non-SIP approved rule in Section II is at least as stringent as the older SIP-approved version in Section IV. \*\*
6. **Identify Local-Only Enforceable Regulatory Requirements:** Use Section V to identify AQMD rules that are not SIP-approved and are not federally enforceable.
7. **Determine compliance:** Determine if all equipment and processes are complying with all requirements identified in Sections II and III. If each piece of equipment complies with all applicable requirements, complete and attach Form 500-A2 to certify the compliance status of the facility. If any piece of equipment is not in compliance with any of the applicable requirements, complete and attach Form 500-C2 in addition to Form 500-A2.

\* The following AQMD rules and regulations are not required to be included in Section II and do not have to be added to Section III: Regulation I, List and Criteria in Regulation II, Rule 201, Rule 201.1, Rule 202, Rule 203, Rule 205, Rule 206, Rule 207, Rule 208, Rule 209, Rule 210, Rule 212, Rule 214, Rule 215, Rule 216, Rule 217, Rule 219, Rule 220, Rule 221, Regulation III, Regulation V, Regulation VIII, Regulation XII, Regulation XV, Regulation XVI, Regulation XIX, Regulation XXI, Regulation XXII, and Regulation XXX.

\*\* Emission units adversely affected by the gap between current and SIP-approved versions of rules may initially be placed in a non-Title V portion of the permit

Section II - Applicable Requirements, Test Methods, & MRR Requirements			
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input checked="" type="checkbox"/> All Air Pollution Control Equipment Using Combustion (RECLAIM & non-RECLAIM sources)	<input checked="" type="checkbox"/> Rule 480 (10/07/77)	N/A	N/A
<input checked="" type="checkbox"/> All Coating Operations (12/15/00)	<input checked="" type="checkbox"/> Rule 442	<input checked="" type="checkbox"/> Rule 442(f)	<input checked="" type="checkbox"/> Rule 442(g)
<input checked="" type="checkbox"/> All Combustion Equipment, ≥ 555 Mmbtu/Hr (except for NOx RECLAIM sources)	<input checked="" type="checkbox"/> Rule 474 (12/04/81)	<input checked="" type="checkbox"/> AQMD TM 7.1 or 100.1	
<input type="checkbox"/> All Combustion Equipment Except Internal Combustion Engines (RECLAIM & non-RECLAIM sources)	<input type="checkbox"/> Rule 407 (04/02/82) <input type="checkbox"/> Rule 409 (08/07/81)	<input type="checkbox"/> AQMD TM 100.1 or 10.1, 307-91 <input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3	
<input checked="" type="checkbox"/> All Combustion Equipment Using Gaseous Fuel (except SOx RECLAIM sources)	<input checked="" type="checkbox"/> Rule 431.1 (06/12/98)	<input checked="" type="checkbox"/> Rule 431.1(f)	<input checked="" type="checkbox"/> Rule 431.1(d) & (e)
<input type="checkbox"/> All Combustion Equipment Using Liquid Fuel (except SOx RECLAIM sources)	<input type="checkbox"/> Rule 431.2 (09/15/00)	<input type="checkbox"/> Rule 431.2(g)	<input type="checkbox"/> Rule 431.2(f)
<input checked="" type="checkbox"/> All Combustion Equipment Using Fossil Fuel (except SOx RECLAIM sources)	<input checked="" type="checkbox"/> Rule 431.3 (05/07/76)		
<input checked="" type="checkbox"/> All Equipment	<input checked="" type="checkbox"/> Rule 401 (11/09/01) <input checked="" type="checkbox"/> Rule 405 (02/07/86) <input checked="" type="checkbox"/> Rule 408 (05/07/76) <input checked="" type="checkbox"/> Rule 430 (07/12/96) <input type="checkbox"/> Rule 701 (06/13/97) <input checked="" type="checkbox"/> New Source Review, BACT <input type="checkbox"/> Rule 1703 (10/07/88) <input checked="" type="checkbox"/> 40 CFR68 - Accidental Release Prevention	<input checked="" type="checkbox"/> California Air Resources Board Visible Emission Evaluation <input checked="" type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3  N/A  See Applicable Subpart	<input checked="" type="checkbox"/> Rule 430(b)      See Applicable Subpart
<input type="checkbox"/> All Equipment Processing Solid Materials	<input type="checkbox"/> Rule 403 (06/03/05)	<input type="checkbox"/> Rule 403(d)(3)	<input type="checkbox"/> Rule 403(f)
<input type="checkbox"/> All Equipment With Exhaust Stack (except cement kilns subject to Rule 1112.1)	<input type="checkbox"/> Rule 404 (02/07/86)	<input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3	
<input checked="" type="checkbox"/> All Facilities Using Solvents to Clean Various Items or Equipment	<input checked="" type="checkbox"/> Rule 109 (05/02/03) <input checked="" type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART T	<input checked="" type="checkbox"/> Rule 109(g) <input checked="" type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input checked="" type="checkbox"/> Rule 109(c) <input checked="" type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> All RECLAIM Equipment (NOx & SOx)	<input type="checkbox"/> Reg. XX - RECLAIM	<input type="checkbox"/> Rule 2011, App. A (05/06/05) <input type="checkbox"/> Rule 2012, App. A (05/06/05)	<input type="checkbox"/> Rule 2011, App. A (05/06/05) <input type="checkbox"/> Rule 2012, App. A (05/06/05)
<input type="checkbox"/> Abrasive Blasting	<input type="checkbox"/> Rule 1140 (08/02/85)	<input type="checkbox"/> Rule 1140(d) & (e), AQMD Visible Emission Method	

**KEY ABBREVIATIONS:**

 Reg. = AQMD Regulation  
 Rule = AQMD Rule

 App. = Appendix  
 AQMD TM = AQMD Test Method

 CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

## Section II - Applicable Requirements, Test Methods, & MRR Requirements

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Aggregate and Related Operations	<input type="checkbox"/> Rule 1157 (09/08/06)	<input type="checkbox"/> Rule 1157(f)	<input type="checkbox"/> Rule 1157(e)
<input checked="" type="checkbox"/> Appliances Containing Ozone Depleting Substances (except Motor Vehicle Air Conditioners): Manufacturing, Repair, Maintenance, Service, & Disposal	<input checked="" type="checkbox"/> 40 CFR82 SUBPART F	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Asphalt	See Manufacturing, Asphalt Processing & Asphalt Roofing		
<input type="checkbox"/> Asphalt Concrete/Batch Plants	<input type="checkbox"/> 40 CFR60 SUBPART I	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Benzene Emissions, Maleic Anhydride Plants, Ethylbenzene/Styrene Plants, Benzene Storage Vessels, Benzene Equipment Leaks, & Coke By-Product Recovery Plants	<input type="checkbox"/> Rule 1173 (02/06/09) <input type="checkbox"/> Rule 1176 (09/13/96) <input type="checkbox"/> 40 CFR61 SUBPART L <input type="checkbox"/> 40 CFR61 SUBPART Y <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 1173(j) <input type="checkbox"/> Rule 1176(h) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1173(i) <input type="checkbox"/> Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Benzene Transfer Operations	<input type="checkbox"/> Rule 1142 (07/19/91) <input type="checkbox"/> 40 CFR61 SUBPART BB <input type="checkbox"/> 40 CFR63 SUBPART Y	<input type="checkbox"/> Rule 1142(e) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1142(h) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Benzene Waste Operations	<input type="checkbox"/> Rule 1176 (09/13/96) <input type="checkbox"/> 40 CFR61 SUBPART FF <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 1176(h) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Beryllium Emissions	<input type="checkbox"/> 40 CFR61 SUBPART C	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Beryllium Emissions, Rocket Motor Firing	<input type="checkbox"/> 40 CFR61 SUBPART D	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Boiler, < 5 Mmbtu/Hr (non-RECLAIM sources)	<input type="checkbox"/> Rule 1146.1 (09/05/08) <input type="checkbox"/> Rule 1146.2 (05/05/06) <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> Rule 1146.1(d) N/A See Applicable Subpart	<input type="checkbox"/> Rule 1146.1(c)(2) & (c)(3) N/A See Applicable Subpart
<input type="checkbox"/> Boiler, < 5 Mmbtu/Hr (RECLAIM sources)	<input type="checkbox"/> Rule 1146.1 (09/05/08) - excluding NOx requirements <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> Rule 1146.1(d) See Applicable Subpart	<input type="checkbox"/> Rule 1146.1(c)(2) & (c)(3) See Applicable Subpart

### KEY ABBREVIATIONS:

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Boiler, ≥ 5 Mmbtu/Hr (non-RECLAIM sources)	<input type="checkbox"/> Rule 218 (05/14/99) <input type="checkbox"/> Rule 429 (12/21/90) <input type="checkbox"/> Rule 475 (08/07/78) <input type="checkbox"/> Rule 476 (10/08/76) <input type="checkbox"/> Rule 1146 (09/05/08) <input type="checkbox"/> 40 CFR60 SUBPART D <input type="checkbox"/> 40 CFR60 SUBPART Da <input type="checkbox"/> 40 CFR60 SUBPART Dc <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> AQMD TM 100.1 N/A <input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3 <input type="checkbox"/> AQMD TM 7.1, 100.1, 5.1, 5.2, or 5.3 <input type="checkbox"/> Rule 1146(d) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 218(e) & (f) <input type="checkbox"/> Rule 429(d)  <input type="checkbox"/> Rule 1146(c)(6) & (c)(7) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Boiler, ≥ 5 Mmbtu/Hr (RECLAIM sources)	<input type="checkbox"/> Rule 475 (08/07/78) <input type="checkbox"/> Rule 476 (10/08/76) - excluding NOx requirements <input type="checkbox"/> Rule 1146 (09/05/08) - excluding NOx requirements <input type="checkbox"/> Rule 2011 (05/06/05) <input type="checkbox"/> or <input type="checkbox"/> Rule 2012 (05/06/05) <input type="checkbox"/> 40 CFR60 SUBPART D <input type="checkbox"/> 40 CFR60 SUBPART Da <input type="checkbox"/> 40 CFR60 SUBPART Dc <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3 <input type="checkbox"/> AQMD TM 7.1, 100.1, 5.1, 5.2, or 5.3 <input type="checkbox"/> Rule 1146(d) <input type="checkbox"/> Rule 2011, App. A (05/06/05) <input type="checkbox"/> or <input type="checkbox"/> Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1146(c)(6) & (c)(7) <input type="checkbox"/> Rule 2011, App. A (05/06/05) <input type="checkbox"/> or <input type="checkbox"/> Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Boiler, Petroleum Refining (non-RECLAIM sources)	<input type="checkbox"/> Rule 218 (05/14/99) <input type="checkbox"/> Rule 429 (12/21/90) <input type="checkbox"/> Rule 431.1 (06/12/98) <input type="checkbox"/> Rule 475 (08/07/78) <input type="checkbox"/> Rule 1146 (09/05/08) <input type="checkbox"/> 40 CFR60 SUBPART J <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> AQMD TM 100.1 N/A <input type="checkbox"/> Rule 431.1(f) <input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3 <input type="checkbox"/> Rule 1146(d) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 218(e) & (f) <input type="checkbox"/> Rule 429(d) <input type="checkbox"/> Rule 431.1(d) & (e)  <input type="checkbox"/> Rule 1146(c)(6) & (c)(7) See Applicable Subpart See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Boiler, Petroleum Refining (RECLAIM sources)	<input type="checkbox"/> Rule 1146 (09/05/08) - excluding NOx requirements <input type="checkbox"/> Rule 2011 (05/06/05) <input type="checkbox"/> or <input type="checkbox"/> Rule 2012 (05/06/05) <input type="checkbox"/> 40 CFR60 SUBPART J <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> Rule 1146(d) <input type="checkbox"/> Rule 2011, App. A (05/06/05) <input type="checkbox"/> or <input type="checkbox"/> Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1146(c)(6) & (c)(7) <input type="checkbox"/> Rule 2011, App. A (05/06/05) <input type="checkbox"/> or <input type="checkbox"/> Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Boilers, Electric Utility (non-RECLAIM sources)	<input type="checkbox"/> Rule 218 (05/14/99) <input type="checkbox"/> Rule 429 (12/21/90) <input type="checkbox"/> Rule 1135 (07/19/91) <input type="checkbox"/> 40 CFR60 SUBPART Db <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> AQMD TM 100.1 N/A <input type="checkbox"/> Rule 1135(e) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 218(e) & (f) <input type="checkbox"/> Rule 429(d) <input type="checkbox"/> Rule 1135(e) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Boilers, Electric Utility (RECLAIM sources)	<input type="checkbox"/> Rule 2012 (05/06/05) <input type="checkbox"/> 40 CFR60 SUBPART Db <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	<input type="checkbox"/> Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Bulk Loading Of Organic Liquids	<input type="checkbox"/> Rule 462 (05/14/99) <input type="checkbox"/> 40 CFR60 SUBPART XX <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART BBBB <input type="checkbox"/> 40 CFR63 SUBPART EEEE	<input type="checkbox"/> Rule 462(f) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 462(g) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Cadmium Electroplating Operation	<input type="checkbox"/> Rule 1426 (05/02/03)		<input type="checkbox"/> Rule 1426(e)
<input type="checkbox"/> Calciner, Mineral Industries	<input type="checkbox"/> 40 CFR60 SUBPART UUU	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Calciner, Petroleum Coke	<input type="checkbox"/> Rule 477 (04/03/81) <input type="checkbox"/> Rule 1119 (03/02/79) <input type="checkbox"/> 40 CFR63 SUBPART L	<input type="checkbox"/> AQMD Visible Emissions, AQMD TM 5.1, 5.2, or 5.3 <input type="checkbox"/> AQMD TM 6.1 or 100.1 See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Charbroilers	<input type="checkbox"/> Rule 1174 (10/05/90) <input type="checkbox"/> Rule 1138 (11/14/97)	<input type="checkbox"/> AQMD Test Protocol <input type="checkbox"/> Rule 1138(g)	<input type="checkbox"/> Rule 1138(d)
<input type="checkbox"/> Chrome Plating & Chromic Acid Anodizing Operation	<input type="checkbox"/> Rule 1426 (05/02/03) <input type="checkbox"/> Rule 1469 (12/05/08)	<input type="checkbox"/> Rule 1469(e)	<input type="checkbox"/> Rule 1426(e) <input type="checkbox"/> Rule 1469(g), (j) & (k)

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Coating Operation, Adhesive Application Operation	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1168 (01/07/05) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART RR	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1168(f) & (e) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1168(d) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Coating Operation, Aerospace Assembly & Component Manufacturing	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1124 (09/21/01) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART GG	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1124(e) & (f) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1124(j) & (d) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Coating Operation, Graphic Arts (Gravure, Letter Press, Flexographic & Lithographic Printing Process, Etc.)	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1130 (10/08/99) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART QQ <input type="checkbox"/> 40 CFR60 SUBPART RR <input type="checkbox"/> 40 CFR60 SUBPART FFF <input type="checkbox"/> 40 CFR60 SUBPART VVV <input type="checkbox"/> 40 CFR63 SUBPART KK <input type="checkbox"/> 40 CFR63 SUBPART JJJJ	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1130(h) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1130(e) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Coating Operation, Magnet Wire Coating	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1126 (01/13/95) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09)	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1126(d) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e)	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1126(c)(4) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6)

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Coating Operation, Marine Coating (Except for recreational equipment)	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1106 (01/13/95) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART II	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1106(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1106(c)(5) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Coating Operation, Metal Coating	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1107 (01/06/06) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART EE <input type="checkbox"/> 40 CFR60 SUBPART SS <input type="checkbox"/> 40 CFR63 SUBPART NNNN <input type="checkbox"/> 40 CFR63 SUBPART MMMM <input type="checkbox"/> 40 CFR63 SUBPART RRRR	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1107(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1107(j) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Coating Operation, Metal Containers, Closure, & Coil Coating Operations	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1125 (03/07/08) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART TT <input type="checkbox"/> 40 CFR60 SUBPART WW <input type="checkbox"/> 40 CFR63 SUBPART KKKK <input type="checkbox"/> 40 CFR63 SUBPART SSSS	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1125(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1125(c)(6) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Coating Operation, Motor Vehicle & Mobile Equipment Non-Assembly Line Coating Operation	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1151 (12/02/05) <input type="checkbox"/> Rule 1171 (05/01/09)	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1151(h) <input type="checkbox"/> Rule 1171(e)	<input type="checkbox"/> Rule 109© <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1151(f) <input type="checkbox"/> Rule 1171(c)(6)

**KEY ABBREVIATIONS:**

**Reg.** = AQMD Regulation  
**Rule** = AQMD Rule

**App.** = Appendix  
**AQMD TM** = AQMD Test Method

**CFR** = Code of Federal Regulations  
**CCR** = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Coating Operation, Motor Vehicle Assembly Line	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1115 (05/12/95) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART MM <input type="checkbox"/> 40 CFR63 SUBPART IIII	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1115(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1115(g) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Coating Operation, Paper, Fabric, & Film Coating Operations	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1128 (03/08/96) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART VVV <input type="checkbox"/> 40 CFR63 SUBPART OOOO	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1128(f) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1128(e) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Coating Operation, Plastic, Rubber, & Glass	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1145 (12/04/09) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR60 SUBPART TTT <input type="checkbox"/> 40 CFR63 SUBPART NNNN <input type="checkbox"/> 40 CFR63 SUBPART PPPP	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1145(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1145(d) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Coating Operation, Pleasure Craft	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1106.1 (02/12/99) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART II	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1106.1(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1106.1(d) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

<b>Section II - Applicable Requirements, Test Methods, &amp; MRR Requirements</b>			
<b>Equipment/Process</b>	<b>Applicable Requirement</b>	<b>Test Method</b>	<b>MRR Requirement</b>
<input type="checkbox"/> Coating Operation, Screen Printing	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 1130.1 (12/13/96) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART KK	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 1130.1(g) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1130.1(c)(5) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input checked="" type="checkbox"/> Coating Operation, Use Of Architectural Coating (Stationary Structures)	<input checked="" type="checkbox"/> Rule 109 (05/02/03) <input checked="" type="checkbox"/> Rule 481 (01/11/02) <input checked="" type="checkbox"/> Rule 1113 (07/13/07) <input type="checkbox"/> Rule 1132 (05/05/06) <input checked="" type="checkbox"/> Rule 1171 (05/01/09)	<input checked="" type="checkbox"/> Rule 109(g) <input checked="" type="checkbox"/> Rule 481(d) <input checked="" type="checkbox"/> Rule 1113(e) <input type="checkbox"/> Rule 1132(f) <input checked="" type="checkbox"/> Rule 1171(e)	<input checked="" type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1132(g) <input checked="" type="checkbox"/> Rule 1171(c)(6)
<input type="checkbox"/> Coating Operation, Wood Flat Stock	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1104 (08/13/99) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART II	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1104(e) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1104(d) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Coating Operation, Wood Products (Commercial Furniture, Cabinets, Shutters, Frames, Toys)	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 481 (01/11/02) <input type="checkbox"/> Rule 1132 (05/05/06) <input type="checkbox"/> Rule 1136 (06/14/96) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART JJ	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 481(d) <input type="checkbox"/> Rule 1132(f) <input type="checkbox"/> Rule 1136(f) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1132(g) <input type="checkbox"/> Rule 1136(d) & (g) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Coater	See Coating Operations		
<input type="checkbox"/> Columns	See Petroleum Refineries, Fugitive Emissions		
<input type="checkbox"/> Composting Operation	<input type="checkbox"/> Rule 1133 (01/10/03) <input type="checkbox"/> Rule 1133.1 (01/10/03) <input type="checkbox"/> Rule 1133.2 (01/10/03)	<input type="checkbox"/> Rule 1133.1(e) <input type="checkbox"/> Rule 1133.2(g)	<input type="checkbox"/> Rule 1133.1(d) <input type="checkbox"/> Rule 1133.2(h)
<input type="checkbox"/> Compressors	See Fugitive Emissions or Petroleum Refineries, Fugitive Emissions		
<input type="checkbox"/> Concrete Batch Plants	See Nonmetallic Mineral Processing Plants		
<input type="checkbox"/> Consumer Product Manufacturing	See Manufacturing, Consumer Product		
<input type="checkbox"/> Cooling Tower, Hexavalent Chromium	<input type="checkbox"/> 40 CFR63 SUBPART Q	See Applicable Subpart	See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Copper Electroplating Operation	<input type="checkbox"/> Rule 1426 (05/02/03)		<input type="checkbox"/> Rule 1426(e)
<input type="checkbox"/> Crude Oil Production	See Oil Well Operations		
<input type="checkbox"/> Crusher	See Nonmetallic Mineral Processing Plants		
<input type="checkbox"/> Dairy Farms and Related Operations	<input type="checkbox"/> Rule 1127 (08/06/04)	<input type="checkbox"/> Rule 1127(h)	<input type="checkbox"/> Rule 1127(g)
<input type="checkbox"/> Degreasers	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 1122 (05/01/09) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART T	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 1122(h) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1122(i) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Dry Cleaning, Perchloroethylene	<input type="checkbox"/> Rule 1421 (12/06/02)	<input type="checkbox"/> Rule 1421(e) & (i)	<input type="checkbox"/> Rule 1421(g) & (h)
<input type="checkbox"/> Dry Cleaning, Petroleum Solvent	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 1102 (11/17/00) <input type="checkbox"/> 40 CFR60 SUBPART JJJ	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 1102(g) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1102(f) See Applicable Subpart
<input type="checkbox"/> Dryers, Mineral Industries	<input type="checkbox"/> 40 CFR60 SUBPART UUU	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Ethylene Oxide Sterilizer	See Sterilizer, Ethylene Oxide		
<input type="checkbox"/> Flanges	See Fugitive Emissions or Petroleum Refineries, Fugitive Emissions		
<input type="checkbox"/> Fluid Catalytic Cracking Unit	<input type="checkbox"/> Rule 218 (05/14/99) <input type="checkbox"/> Rule 1105 (09/01/84) <input type="checkbox"/> Rule 1105.1 (11/07/03)	<input type="checkbox"/> AQMD TM 100.1 <input type="checkbox"/> Rule 1105(c)(1) <input type="checkbox"/> Rule 1105.1(f)	<input type="checkbox"/> Rule 218(e) & (f) <input type="checkbox"/> Rule 1105(c)(2) <input type="checkbox"/> Rule 1105.1(e)
<input type="checkbox"/> Foundries, Iron and Steel	<input type="checkbox"/> 40 CFR63 SUBPART EEEEE	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Friction Materials Manufacturing	See Manufacturing, Friction Materials		
<input type="checkbox"/> Fugitive Emissions, Benzene	<input type="checkbox"/> Rule 1173 (12/06/02) <input type="checkbox"/> 40 CFR61 SUBPART L <input type="checkbox"/> 40 CFR61 SUBPART V <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 1173(j) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1173(i) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Fugitive Emissions, Chemical Plant	<input type="checkbox"/> Rule 466 (10/07/83) <input type="checkbox"/> Rule 466.1 (03/16/84) <input type="checkbox"/> Rule 467 (03/05/82) <input type="checkbox"/> Rule 1173 (02/06/09) <input type="checkbox"/> 40 CFR60 SUBPART VV <input type="checkbox"/> 40 CFR61 SUBPART V <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 466(f) <input type="checkbox"/> Rule 466.1(g) <input type="checkbox"/> Rule 467(f) <input type="checkbox"/> Rule 1173(j) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 466(e) <input type="checkbox"/> Rule 466.1(h) <input type="checkbox"/> Rule 467(e) <input type="checkbox"/> Rule 1173(i) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Fugitive Emissions, Natural Gas Processing Plant	<input type="checkbox"/> Rule 466 (10/07/83) <input type="checkbox"/> Rule 466.1 (03/16/84) <input type="checkbox"/> Rule 467 (03/05/82) <input type="checkbox"/> Rule 1173 (02/06/09) <input type="checkbox"/> 40 CFR60 SUBPART KKK <input type="checkbox"/> 40 CFR61 SUBPART V <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 466(f) <input type="checkbox"/> Rule 466.1(g) <input type="checkbox"/> Rule 467(f) <input type="checkbox"/> Rule 1173(j) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 466(e) <input type="checkbox"/> Rule 466.1(h) <input type="checkbox"/> Rule 467(e) <input type="checkbox"/> Rule 1173(i) See Applicable Subpart See Applicable Subpart

**KEY ABBREVIATIONS:**

**Reg.** = AQMD Regulation  
**Rule** = AQMD Rule

**App.** = Appendix  
**AQMD TM** = AQMD Test Method

**CFR** = Code of Federal Regulations  
**CCR** = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Fugitive Emissions, Oil & Gas Production Facility	Rule 466 (10/07/83) Rule 466.1 (03/16/84) Rule 467 (03/05/82) Rule 1173 (02/06/09) 40 CFR61 SUBPART V 40 CFR63 SUBPART F 40 CFR63 SUBPART G 40 CFR63 SUBPART H 40 CFR63 SUBPART I 40 CFR63 SUBPART R 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 466(f) <input type="checkbox"/> Rule 466.1(g) <input type="checkbox"/> Rule 467(f) <input type="checkbox"/> Rule 1173(j) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 466(e) <input type="checkbox"/> Rule 466.1(h) <input type="checkbox"/> Rule 467(e) <input type="checkbox"/> Rule 1173(j) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Fugitive Emissions, Pipeline Transfer Station	Rule 466 (10/07/83) Rule 466.1 (03/16/84) Rule 467 (03/05/82) Rule 1173 (02/06/09) 40 CFR61 SUBPART V 40 CFR63 SUBPART F 40 CFR63 SUBPART G 40 CFR63 SUBPART H 40 CFR63 SUBPART I 40 CFR63 SUBPART R 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 466(f) <input type="checkbox"/> Rule 466.1(g) <input type="checkbox"/> Rule 467(f) <input type="checkbox"/> Rule 1173(j) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 466(e) <input type="checkbox"/> Rule 466.1(h) <input type="checkbox"/> Rule 467(e) <input type="checkbox"/> Rule 1173(i) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Furnace, Basic Oxygen Process	<input type="checkbox"/> 40 CFR60 SUBPART Na	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Furnace, Electric Arc, For Steel Plants: Constructed After August 17, 1983	<input type="checkbox"/> 40 CFR60 SUBPART AAa	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Furnace, Electric Arc, For Steel Plants: Constructed After Oct. 21, 1974, & On Or Before Aug. 17, 1983	<input type="checkbox"/> 40 CFR60 SUBPART AA	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Furnace, Glass Melting	<input type="checkbox"/> Rule 1117 (01/06/84) <input type="checkbox"/> 40 CFR60 SUBPART CC	<input type="checkbox"/> Rule 1117(c), AQMD TM 7.1 or 100.1 See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Furnace, Lead Melting, Automotive Batteries	<input type="checkbox"/> Rule 1101 (10/07/77) <input type="checkbox"/> 40 CFR63 SUBPART X	<input type="checkbox"/> AQMD TM 6.1 See Applicable Subpart	See Applicable Subpart

**KEY ABBREVIATIONS:**    **Reg.** = AQMD Regulation    **App.** = Appendix    **CFR** = Code of Federal Regulations  
                                  **Rule** = AQMD Rule                                   **AQMD TM** = AQMD Test Method                                   **CCR** = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Gasoline Transfer & Dispensing Operation	<input type="checkbox"/> Rule 461 (06/03/05)	<input type="checkbox"/> Rule 461(f)	<input type="checkbox"/> Rule 461(e)(6) & (e)(7)
<input type="checkbox"/> Glass Manufacturing	See Manufacturing, Glass		
<input type="checkbox"/> Grain Elevators	<input type="checkbox"/> 40 CFR60 SUBPART DD	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Halon-containing Equipment, Use for Technician Training, Testing, Maintenance, Service, Repair, or Disposal	<input type="checkbox"/> 40 CFR82 SUBPART H	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Hazardous Waste Combustors	<input type="checkbox"/> 40 CFR63 SUBPART EEE	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Heater, Asphalt Pavement	<input type="checkbox"/> Rule 1120 (08/04/78)	<input type="checkbox"/> AQMD Visible Emissions, AQMD TM 6.2	<input type="checkbox"/> Rule 1120(f)
<input type="checkbox"/> Heaters, Petroleum Refinery Process	<input type="checkbox"/> Rule 429 (12/21/90) <input type="checkbox"/> Rule 431.1 (06/12/98) <input type="checkbox"/> Rule 1146 (09/05/08) <input type="checkbox"/> 40 CFR60 SUBPART J <input type="checkbox"/> 40 CFR63 SUBPART DDDDD	N/A <input type="checkbox"/> Rule 431.1(f) <input type="checkbox"/> Rule 1146(d) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 429(d) <input type="checkbox"/> Rule 431.1(d) & (e) <input type="checkbox"/> Rule 1146(c)(6) & (c)(7) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Heaters, Process	See Boilers		
<input type="checkbox"/> Incinerators	<input type="checkbox"/> 40 CFR60 SUBPART E <input type="checkbox"/> 40 CFR60 SUBPART CCCC	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Inorganic Arsenic Emissions, Arsenic Trioxide & Metallic Arsenic Production Facilities	<input type="checkbox"/> 40 CFR61 SUBPART P	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Internal Combustion Engines, Reciprocating	<input type="checkbox"/> Rule 1110.2 (07/09/10) <input type="checkbox"/> 40 CFR60 SUBPART IIII and JJJJ <input type="checkbox"/> 40 CFR63 SUBPART ZZZZ	Rule 1110.2(g) See Applicable Subpart See Applicable Subpart	Rule 1110.2(f) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Kiln, Cement Plant	<input type="checkbox"/> Rule 1112 (06/06/86) <input type="checkbox"/> Rule 1112.1 (12/04/09) <input type="checkbox"/> 40 CFR60 SUBPART F	N/A N/A See Applicable Subpart	N/A N/A See Applicable Subpart

**KEY ABBREVIATIONS:**

 Reg. = AQMD Regulation  
 Rule = AQMD Rule

 App. = Appendix  
 AQMD TM = AQMD Test Method

 CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

<b>Section II - Applicable Requirements, Test Methods, &amp; MRR Requirements</b>			
<b>Equipment/Process</b>	<b>Applicable Requirement</b>	<b>Test Method</b>	<b>MRR Requirement</b>
<input type="checkbox"/> Landfills	<input type="checkbox"/> Rule 1150 (10/15/82) <input type="checkbox"/> Rule 1150.1 (03/17/00) <input type="checkbox"/> 40 CFR60 SUBPART WWW <input type="checkbox"/> 40 CFR63 SUBPART AAAA	<input type="checkbox"/> Rule 1150.1(j) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1150.1(e) & (f) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Lead Acid Battery Manufacturing Plants	See Manufacturing, Lead Acid Battery		
<input type="checkbox"/> Lead Electroplating Operation	<input type="checkbox"/> Rule 1426 (05/02/03)		<input type="checkbox"/> Rule 1426(e)
<input type="checkbox"/> Manufacturing, Asphalt Processing & Asphalt Roofing	<input type="checkbox"/> Rule 470 (05/07/76) <input type="checkbox"/> Rule 1108 (02/01/85) <input type="checkbox"/> Rule 1108.1 (11/04/83) <input type="checkbox"/> 40 CFR60 SUBPART UU <input type="checkbox"/> 40 CFR63 SUBPART LLLLL	N/A <input type="checkbox"/> Rule 1108(b) <input type="checkbox"/> Rule 1108.1 (b) See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Brick & Structural Clay Products	<input type="checkbox"/> 40 CFR63 SUBPART JJJJJ	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Cement	<input type="checkbox"/> Rule 1156 (03/06/09)	<input type="checkbox"/> Rule 1156(g)	<input type="checkbox"/> Rule 1156(f)
<input type="checkbox"/> Manufacturing, Clay Ceramics	<input type="checkbox"/> 40 CFR63 SUBPART KKKKK	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Coatings & Ink (SIC Code 2851)	<input type="checkbox"/> Rule 1141.1 (11/17/00) <input type="checkbox"/> 40 CFR63 SUBPART HHHHH	N/A See Applicable Subpart	<input type="checkbox"/> Rule 1141.1(c) See Applicable Subpart
<input type="checkbox"/> Manufacturing, Consumer Product	<input type="checkbox"/> Title 17 CCR 94500		
<input type="checkbox"/> Manufacturing, Food Product	<input type="checkbox"/> Rule 1131 (06/06/03)	<input type="checkbox"/> Rule 1131(e)	<input type="checkbox"/> Rule 1131(d)
<input type="checkbox"/> Manufacturing, Friction Materials	<input type="checkbox"/> 40 CFR63 SUBPART QQQQQ	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Glass	<input type="checkbox"/> Rule 1117 (01/06/84) <input type="checkbox"/> 40 CFR60 SUBPART CC <input type="checkbox"/> 40 CFR61 SUBPART N	<input type="checkbox"/> Rule 1117(c), AQMD TM 7.1 or 100.1 See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Hydrochloric Acid	<input type="checkbox"/> 40 CFR63 SUBPART NNNNN	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Lead-Acid Battery	<input type="checkbox"/> 40 CFR60 SUBPART KK	See Applicable Subpart	See Applicable Subpart

<b>KEY ABBREVIATIONS:</b>	<b>Reg.</b> = AQMD Regulation <b>Rule</b> = AQMD Rule	<b>App.</b> = Appendix <b>AQMD TM</b> = AQMD Test Method	<b>CFR</b> = Code of Federal Regulations <b>CCR</b> = California Code of Regulations
---------------------------	--	---	---

<b>Section II - Applicable Requirements, Test Methods, &amp; MRR Requirements</b>			
<b>Equipment/Process</b>	<b>Applicable Requirement</b>	<b>Test Method</b>	<b>MRR Requirement</b>
<input type="checkbox"/> Manufacturing, Lime	<input type="checkbox"/> 40 CFR63 SUBPART AAAAA	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Magnetic Tape Industry	<input type="checkbox"/> 40 CFR60 SUBPART SSS <input type="checkbox"/> 40 CFR63 SUBPART EE	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Miscellaneous Organic Chemical	<input type="checkbox"/> 40 CFR63 SUBPART FFFF	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Nitric Acid	<input type="checkbox"/> Rule 218 (05/14/99) <input type="checkbox"/> Rule 1159 (12/06/85) <input type="checkbox"/> 40 CFR60 SUBPART G	<input type="checkbox"/> AQMD TM 100.1 <input type="checkbox"/> AQMD TM 7.1 or 100.1 See Applicable Subpart	<input type="checkbox"/> Rule 218(e) & (f)  See Applicable Subpart
<input type="checkbox"/> Manufacturing, Plywood & Composite Wood Products	<input type="checkbox"/> Rule 1137 (02/01/02) <input type="checkbox"/> 40 CFR63 SUBPART DDDD	N/A See Applicable Subpart	<input type="checkbox"/> Rule 1137(e) See Applicable Subpart
<input type="checkbox"/> Manufacturing, Polymer Industry	<input type="checkbox"/> 40 CFR60 SUBPART DDD <input type="checkbox"/> 40 CFR63 SUBPART W <input type="checkbox"/> 40 CFR63 SUBPART J	See Applicable Subpart See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Polymeric Cellular Foam	<input type="checkbox"/> Rule 1175 (09/07/07) <input type="checkbox"/> 40 CFR63 SUBPART UUUU	<input type="checkbox"/> Rule 1175(f) See Applicable Subpart	<input type="checkbox"/> Rule 1175(e) See Applicable Subpart
<input type="checkbox"/> Manufacturing, Products Containing Halon Blends	<input type="checkbox"/> 40 CFR82 SUBPART H	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Products Containing Organic Solvents	<input type="checkbox"/> Rule 443.1 (12/05/86)	N/A	N/A
<input type="checkbox"/> Manufacturing, Products Containing Ozone Depleting Substances (ODS)	<input type="checkbox"/> 40 CFR82 SUBPART A <input type="checkbox"/> 40 CFR82 SUBPART E	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Reinforced Plastic Composites	<input type="checkbox"/> 40 CFR63 SUBPART WWWW	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Refractory Products	<input type="checkbox"/> 40 CFR63 SUBPART SSSSS	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Resin	<input type="checkbox"/> Rule 1141 (11/17/00) <input type="checkbox"/> 40 CFR63 SUBPART W	<input type="checkbox"/> Rule 1141(d) See Applicable Subpart	<input type="checkbox"/> Rule 1141(c) See Applicable Subpart
<input type="checkbox"/> Manufacturing, Rubber Tire	<input type="checkbox"/> 40 CFR63 SUBPART XXXX	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Semiconductors	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 1164 (01/13/95) <input type="checkbox"/> Rule 1171 (05/01/09) <input type="checkbox"/> 40 CFR63 SUBPART BBBBB	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 1164(e) <input type="checkbox"/> Rule 1171(e) See Applicable Subpart	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1164(c)(5) <input type="checkbox"/> Rule 1171(c)(6) See Applicable Subpart
<input type="checkbox"/> Manufacturing, Solvent	<input type="checkbox"/> Rule 443 (05/07/76)	N/A	N/A

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
Rule = AQMD Rule

App. = Appendix  
AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
CCR = California Code of Regulations

Section II - Applicable Requirements, Test Methods, & MRR Requirements			
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Manufacturing, Sulfuric Acid	<input type="checkbox"/> Rule 469 (02/13/81) <input type="checkbox"/> 40 CFR60 SUBPART H <input type="checkbox"/> 40 CFR60 SUBPART Cd	<input type="checkbox"/> AQMD TM 6.1 or 6.2 See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Surfactant	<input type="checkbox"/> Rule 1141.2 (01/11/02)	<input type="checkbox"/> Rule 1141.2(e) <input type="checkbox"/> AQMD TM 25.1	
<input type="checkbox"/> Manufacturing, Synthetic Organic Chemical Manufacturing Industry (SOCMI) Air Oxidation Unit Processes	<input type="checkbox"/> 40 CFR60 SUBPART III <input type="checkbox"/> 40 CFR60 SUBPART NNN	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Manufacturing, Synthetic Organic Chemical Manufacturing Industry (SOCMI) Reactor Processes	<input type="checkbox"/> 40 CFR60 SUBPART RRR	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Vinyl Chloride	<input type="checkbox"/> 40 CFR61 SUBPART F	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manufacturing, Water Heaters	<input type="checkbox"/> Rule 1121 (09/03/04)	N/A	N/A
<input type="checkbox"/> Manufacturing, Wool Fiberglass Insulation	<input type="checkbox"/> 40 CFR60 SUBPART PPP	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Manure Processing Operations	<input type="checkbox"/> Rule 1127 (08/06/04)	<input type="checkbox"/> Rule 1127(h)	<input type="checkbox"/> Rule 1127(g)
<input type="checkbox"/> Marine Tank Vessel Operations	<input type="checkbox"/> Rule 1142 (07/19/91) <input type="checkbox"/> Rule 1173 (02/06/09) <input type="checkbox"/> 40 CFR63 SUBPART Y	<input type="checkbox"/> Rule 1142(e) <input type="checkbox"/> Rule 1173(j) See Applicable Subpart	<input type="checkbox"/> Rule 1142(h) <input type="checkbox"/> Rule 1173(i) See Applicable Subpart
<input type="checkbox"/> Mercury Emissions	<input type="checkbox"/> 40 CFR61 SUBPART E <input type="checkbox"/> 40 CFR63 SUBPART IIII	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Motor Vehicle Air Conditioners with Ozone Depleting Substances (ODS): Repair, Service, Manufacturing, Maintenance, or Disposal	<input type="checkbox"/> 40 CFR82 SUBPART B <input type="checkbox"/> 40 CFR82 SUBPART F	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Municipal Waste Combustors	<input type="checkbox"/> 40 CFR60 SUBPART Cb <input type="checkbox"/> 40 CFR60 SUBPART Ea <input type="checkbox"/> 40 CFR60 SUBPART Eb	See Applicable Subpart See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Negative Air Machines/HEPA, Asbestos	<input type="checkbox"/> 40 CFR61 SUBPART M	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Nickel Electroplating Operation	<input type="checkbox"/> Rule 1426 (05/02/03)		<input type="checkbox"/> Rule 1426(e)
<input type="checkbox"/> Nonmetallic Mineral Processing Plants	<input type="checkbox"/> Rule 404 (02/07/86) <input type="checkbox"/> Rule 405 (02/07/86) <input type="checkbox"/> 40 CFR60 SUBPART OOO	<input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3 <input type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3 See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Off-site Waste and Recovery Operation	<input type="checkbox"/> 40 CFR63 SUBPART DD	See Applicable Subpart	See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
Rule = AQMD Rule

App. = Appendix  
AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Oil and Gas Well Operation	<input type="checkbox"/> Rule 1148 (11/05/82) <input type="checkbox"/> Rule 1148.1 (03/05/04)	<input type="checkbox"/> AQMD TM 25.1 <input type="checkbox"/> Rule 1148.1 (g)	<input type="checkbox"/> Rule 1148.1 (f)
<input type="checkbox"/> Onshore Natural Gas Processing, SO2 Emissions	<input type="checkbox"/> 40 CFR60 SUBPART LLL	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Open Fires	<input type="checkbox"/> Rule 444 (11/07/08)		
<input type="checkbox"/> Open Storage, Petroleum Coke	<input type="checkbox"/> Rule 403 (06/03/05) <input type="checkbox"/> Rule 403.1 (04/02/04) <input type="checkbox"/> Rule 1158 (06/11/99)	<input type="checkbox"/> Rule 403(d)(4) <input type="checkbox"/> Rule 1158(h)	<input type="checkbox"/> Rule 403(f) <input type="checkbox"/> Rule 403.1(h) <input type="checkbox"/> Rule 1158(j)
<input type="checkbox"/> Open Storage	<input type="checkbox"/> Rule 403 (06/03/05) <input type="checkbox"/> Rule 403.1 (04/02/04)	<input type="checkbox"/> Rule 403(d)(4)	<input type="checkbox"/> Rule 403(f) <input type="checkbox"/> Rule 403.1(h)
<input type="checkbox"/> Outer Continental Shelf Platform	<input type="checkbox"/> Rule 1183 (03/12/93) <input type="checkbox"/> 40 CFR55	<input type="checkbox"/> 40 CFR55 See Applicable Subpart	<input type="checkbox"/> 40 CFR55 See Applicable Subpart
<input type="checkbox"/> Oven, Commercial Bakery	<input type="checkbox"/> Rule 1153 (01/13/95)	<input type="checkbox"/> Rule 1153(h)	<input type="checkbox"/> Rule 1153(g)
<input type="checkbox"/> Oven, Petroleum Coke	<input type="checkbox"/> Rule 477 (04/03/81) <input type="checkbox"/> 40 CFR63 SUBPART L <input type="checkbox"/> 40 CFR63 SUBPART CCCCC	<input type="checkbox"/> AQMD Visible Emissions, AQMD TM 5.1, 5.2, or 5.3 See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Ozone Depleting Substances (ODS) or Alternative ODS, Use	<input type="checkbox"/> 40 CFR82 Subpart G	See Applicable Subpart	See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
Rule = AQMD Rule

App. = Appendix  
AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Petroleum Refineries	<input type="checkbox"/> Rule 218 (05/14/99) <input type="checkbox"/> Rule 465 (08/13/99) <input type="checkbox"/> Rule 468 (10/08/76) <input type="checkbox"/> Rule 469 (02/13/81) <input type="checkbox"/> Rule 1118 (11/04/05) <input type="checkbox"/> Rule 1123 (12/07/90) <input type="checkbox"/> Rule 1189 (01/21/00) <input type="checkbox"/> 40 CFR60 SUBPART J <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR63 SUBPART CC <input type="checkbox"/> 40 CFR63 SUBPART EEEE <input type="checkbox"/> 40 CFR63 SUBPART GGGG <input type="checkbox"/> Title 13 CCR 2250	<input type="checkbox"/> AQMD TM 100.1  <input type="checkbox"/> AQMD TM 6.1 or 6.2 <input type="checkbox"/> AQMD TM 6.1 or 6.2 <input type="checkbox"/> Rule 1118(j) N/A <input type="checkbox"/> Rule 1189(f) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 218(e) & (f)  <input type="checkbox"/> Rule 1118(f), (g), (h), & (i) <input type="checkbox"/> Rule 1123(c) <input type="checkbox"/> Rule 1189(e) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Petroleum Refineries, Fugitive Emissions	<input type="checkbox"/> Rule 1173 (02/06/09) <input type="checkbox"/> Rule 466 (10/07/83) <input type="checkbox"/> Rule 466.1 (03/16/84) <input type="checkbox"/> Rule 467 (03/05/82) <input type="checkbox"/> 40 CFR60 SUBPART GGG <input type="checkbox"/> 40 CFR61 SUBPART V <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 1173(j) <input type="checkbox"/> Rule 466(f) <input type="checkbox"/> Rule 466.1(g) <input type="checkbox"/> Rule 467(f) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1173(i) <input type="checkbox"/> Rule 466(e) <input type="checkbox"/> Rule 466.1(h) <input type="checkbox"/> Rule 467(e) See Applicable Subpart See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Petroleum Refineries, Storage Tanks	<input type="checkbox"/> Rule 463 (05/06/05) <input type="checkbox"/> Rule 1178 (04/07/06) <input type="checkbox"/> 40 CFR60 SUBPART K <input type="checkbox"/> 40 CFR60 SUBPART Ka <input type="checkbox"/> 40 CFR60 SUBPART Kb <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40 CFR63 SUBPART CC <input type="checkbox"/> 40 CFR63 SUBPART EEEE	<input type="checkbox"/> Rule 463(g) <input type="checkbox"/> Rule 1178(i) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 463(e)(5) <input type="checkbox"/> Rule 1178(f) & (h) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Petroleum Refineries, Wastewater Systems	<input type="checkbox"/> Rule 1176 (09/13/96) <input type="checkbox"/> Rule 464 (12/07/90) <input type="checkbox"/> 40 CFR60 SUBPART QQQ <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 1176(h) N/A See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Pharmaceuticals & Cosmetics Manufacturing	<input type="checkbox"/> Rule 1103 (03/12/99) <input type="checkbox"/> 40 CFR63 SUBPART GGG	<input type="checkbox"/> Rule 1103(f) See Applicable Subpart	<input type="checkbox"/> Rule 1103(e) See Applicable Subpart
<input type="checkbox"/> Polyester Resin Operation	<input type="checkbox"/> Rule 109 (05/02/03) <input type="checkbox"/> Rule 1162 (07/08/05) <input type="checkbox"/> Rule 1171 (05/01/09)	<input type="checkbox"/> Rule 109(g) <input type="checkbox"/> Rule 1162(f) <input type="checkbox"/> Rule 1171(e)	<input type="checkbox"/> Rule 109(c) <input type="checkbox"/> Rule 1162(e) <input type="checkbox"/> Rule 1171(c)(6)
<input type="checkbox"/> Primary Magnesium Refining	<input type="checkbox"/> 40 CFR63 SUBPART TTTT	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Printing Press	See Coating Operations		
<input type="checkbox"/> Publicly Owned Treatment Works Operations	<input type="checkbox"/> Rule 1179 (03/06/92) <input type="checkbox"/> 40 CFR60 SUBPART O	<input type="checkbox"/> Rule 1179(e) See Applicable Subpart	<input type="checkbox"/> Rule 1179(c) & (d) See Applicable Subpart
<input type="checkbox"/> Pumps	See Fugitive Emissions of Petroleum Refineries, Fugitive Emissions		

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Recycling & Recovery Equipment for Ozone Depleting Substances (ODS),	<input type="checkbox"/> 40 CFR82 SUBPART F	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Refrigerant Reclaimers for Ozone Depleting Substances (ODS)	<input type="checkbox"/> 40 CFR82 SUBPART F	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Rendering Plant	<input type="checkbox"/> Rule 472 (05/07/76)	N/A	<input type="checkbox"/> Rule 472(b)
<input type="checkbox"/> Rock Crushing	See Nonmetallic Mineral Processing Plants		
<input type="checkbox"/> Secondary Aluminum Production	<input type="checkbox"/> 40 CFR63 SUBPART LL	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Semiconductor Manufacturing	See Manufacturing, Semiconductors		
<input type="checkbox"/> Sewage Treatment Plants	See Publicly Owned Treatment Works Operation		
<input type="checkbox"/> Site Remediation	<input type="checkbox"/> 40 CFR63 SUBPART GGGGG	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Smelting, Primary Copper	<input type="checkbox"/> 40 CFR63 SUBPART QQQ	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Smelting, Secondary Lead	<input type="checkbox"/> 40 CFR60 SUBPART L <input type="checkbox"/> 40 CFR63 SUBPART X	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Soil Decontamination / Excavation	<input type="checkbox"/> Rule 1166 (05/11/01) <input type="checkbox"/> 40 CFR63 SUBPART GGGGG	<input type="checkbox"/> Rule 1166(e) See Applicable Subpart	<input type="checkbox"/> Rule 1166(c)(1)(C) See Applicable Subpart
<input type="checkbox"/> Spray Booth	See Coating Operations		
<input type="checkbox"/> Sterilizer, Ethylene Oxide	<input type="checkbox"/> 40 CFR63 SUBPART O	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Storage Tank, Degassing Operation	<input type="checkbox"/> Rule 1149 (07/14/95) <input type="checkbox"/> 40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
Rule = AQMD Rule

App. = Appendix  
AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Storage Tank, Greater Than 19,815 Gallon Capacity	<input type="checkbox"/> Rule 463 (05/06/05) <input type="checkbox"/> Rule 1178 (04/07/06) <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR60 SUBPART K <input type="checkbox"/> 40 CFR60 SUBPART Ka <input type="checkbox"/> 40 CFR60 SUBPART Kb <input type="checkbox"/> 40 CFR63 SUBPART R <input type="checkbox"/> 40CFR63 SUBPART BBBB <input type="checkbox"/> 40 CFR63 SUBPART CC	<input type="checkbox"/> Rule 463(g) <input type="checkbox"/> Rule 1178(i) See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 463(e)(5) <input type="checkbox"/> Rule 1178(h) See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Synthetic Fiber Production Facilities	<input type="checkbox"/> 40 CFR60 SUBPART HHH	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Taconite Iron Ore Processing Facilities	<input type="checkbox"/> 40 CFR63 SUBPART RRRRR	See Applicable Subpart	See Applicable Subpart
<input checked="" type="checkbox"/> Turbine, Stationary Gas-Fired	<input checked="" type="checkbox"/> Rule 1134 (08/08/97) <input checked="" type="checkbox"/> Rule 475 (08/07/78) <input type="checkbox"/> 40 CFR60 SUBPART GG <input checked="" type="checkbox"/> 40 CFR60 SUBPART KKKK <input type="checkbox"/> 40 CFR63 SUBPART YYYY	<input checked="" type="checkbox"/> Rule 1134(e) & (g) <input checked="" type="checkbox"/> AQMD TM 5.1, 5.2, or 5.3 See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input checked="" type="checkbox"/> Rule 1134(d) & (f)  See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Turbine, Stationary Oil-Fired	<input type="checkbox"/> 40 CFR63 SUBPART YYYY	See Applicable Subpart	See Applicable Subpart
<input type="checkbox"/> Valves	See Fugitive Emissions or Petroleum Refineries, Fugitive Emissions		
<input type="checkbox"/> Vessel, Refinery Process	<input type="checkbox"/> Rule 1123 (12/07/90)	N/A	<input type="checkbox"/> Rule 1123(c)
<input type="checkbox"/> Vessels	See Petroleum Refineries, Fugitive Emissions		

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations

**Section II - Applicable Requirements, Test Methods, & MRR Requirements**

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
<input type="checkbox"/> Wastewater, Chemical Plant	<input type="checkbox"/> Rule 464 (12/07/90) <input type="checkbox"/> Rule 1176 (09/13/96) <input type="checkbox"/> 40 CFR63 SUBPART F <input type="checkbox"/> 40 CFR63 SUBPART G <input type="checkbox"/> 40 CFR63 SUBPART H <input type="checkbox"/> 40 CFR63 SUBPART I <input type="checkbox"/> 40 CFR63 SUBPART CC	N/A <input type="checkbox"/> Rule 1176(h) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	<input type="checkbox"/> Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
<input type="checkbox"/> Wastewater Treatment, Other	<input type="checkbox"/> Rule 464 (12/07/90) <input type="checkbox"/> Rule 1176 (09/13/96)	N/A <input type="checkbox"/> Rule 1176(h)	<input type="checkbox"/> Rule 1176(f) & (g)
<input type="checkbox"/> Woodworking Operations	<input type="checkbox"/> Rule 1137 (02/01/02)	N/A	<input type="checkbox"/> Rule 1137(e)

**KEY ABBREVIATIONS:**

Reg. = AQMD Regulation  
 Rule = AQMD Rule

App. = Appendix  
 AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations  
 CCR = California Code of Regulations



**Section IV - SIP-Approved Rules That Are Not The Most Current AQMD Rules**

Check off each SIP-Approved Rule as it applies to the facility. Use the blanks at the end of this form to fill-in new items.

SIP - Approved Rule	Adoption/ Amendment Date	Check (✓) If Applies	SIP - Approved Rule	Adoption/ Amendment Date	Check (✓) If Applies
401	03/02/84	<input checked="" type="checkbox"/>			<input type="checkbox"/>
431.2	05/04/90	<input type="checkbox"/>			<input type="checkbox"/>
461	6/3/05	<input type="checkbox"/>			<input type="checkbox"/>
466.1	05/02/80	<input type="checkbox"/>			<input type="checkbox"/>
469	04/07/76	<input type="checkbox"/>			<input type="checkbox"/>
475	10/08/76	<input checked="" type="checkbox"/>			<input type="checkbox"/>
1112	01/06/84	<input type="checkbox"/>			<input type="checkbox"/>
1112.1	2/7/86	<input type="checkbox"/>			<input type="checkbox"/>
1113	11/08/96	<input checked="" type="checkbox"/>			<input type="checkbox"/>
1117	1/6/83	<input type="checkbox"/>			<input type="checkbox"/>
1122	07/11/97	<input type="checkbox"/>			<input type="checkbox"/>
1132	03/05/04	<input type="checkbox"/>			<input type="checkbox"/>
1140	02/01/80	<input type="checkbox"/>			<input type="checkbox"/>
1146	11/17/00	<input type="checkbox"/>			<input type="checkbox"/>
1146.1	5/13/94	<input type="checkbox"/>			<input type="checkbox"/>
1151	12/11/98	<input type="checkbox"/>			<input type="checkbox"/>
1158	6/11/99	<input type="checkbox"/>			<input type="checkbox"/>
1162	11/17/00	<input type="checkbox"/>			<input type="checkbox"/>
1166	07/14/95	<input type="checkbox"/>			<input type="checkbox"/>
1171	11/07/03	<input checked="" type="checkbox"/>			<input type="checkbox"/>
1175	05/13/94	<input type="checkbox"/>			<input type="checkbox"/>
1186	09/10/99	<input type="checkbox"/>			<input type="checkbox"/>

**Section V - AQMD Rules That Are Not SIP-Approved (Continued on Following Page)**

Check off each AQMD Rule as it applies to the facility. Use the blanks at the end of this form to fill-in new items.

Non SIP - Approved Rule	Adoption/ Amendment Date	Check (✓) If Applies	Non SIP - Approved Rule	Adoption/ Amendment Date	Check (✓) If Applies
53 Los Angeles Co.	N/A	<input type="checkbox"/>	1192	06/16/00	<input type="checkbox"/>
53 Orange Co.	N/A	<input type="checkbox"/>	1193	07/09/10	<input type="checkbox"/>
53 Riverside Co.	N/A	<input type="checkbox"/>	1194	10/20/00	<input type="checkbox"/>
53 San Bernardino Co.	N/A	<input type="checkbox"/>	1195	05/05/06	<input type="checkbox"/>
53A San Bernardino Co.	N/A	<input type="checkbox"/>	1196	06/06/08	<input type="checkbox"/>
402	05/07/76	<input type="checkbox"/>	1401	09/10/10	<input type="checkbox"/>
429	12/21/90	<input type="checkbox"/>	1401.1	11/04/05	<input type="checkbox"/>
430	07/12/96	<input type="checkbox"/>	1402	03/04/05	<input type="checkbox"/>
441	05/07/76	<input type="checkbox"/>	1403	10/05/07	<input type="checkbox"/>
473	05/07/76	<input type="checkbox"/>	1404	04/06/90	<input type="checkbox"/>
477	04/03/81	<input type="checkbox"/>	1405	01/04/91	<input type="checkbox"/>
480	10/07/77	<input type="checkbox"/>	1406	07/08/94	<input type="checkbox"/>
1109	08/05/88	<input type="checkbox"/>	1407	07/08/94	<input type="checkbox"/>
1110.2	07/09/10	<input type="checkbox"/>	1411	03/01/91	<input type="checkbox"/>
1116.1	10/20/78	<input type="checkbox"/>	1414	05/03/91	<input type="checkbox"/>
1127	08/06/04	<input type="checkbox"/>	1415	10/14/94	<input type="checkbox"/>
1143	07/09/10	<input type="checkbox"/>	1418	09/10/99	<input type="checkbox"/>
1147	12/05/08	<input type="checkbox"/>	1420	09/11/92	<input type="checkbox"/>
1148.1	03/05/04	<input type="checkbox"/>	1420.1	11/05/10	<input type="checkbox"/>
1150	10/15/82	<input type="checkbox"/>	1421	12/06/02	<input type="checkbox"/>
1155	12/04/09	<input type="checkbox"/>	1425	03/16/01	<input type="checkbox"/>
1156	03/06/09	<input type="checkbox"/>	1426	05/02/03	<input type="checkbox"/>
1157	09/08/06	<input type="checkbox"/>			<input type="checkbox"/>
1163	06/07/85	<input type="checkbox"/>			<input type="checkbox"/>
1170	05/06/88	<input type="checkbox"/>			<input type="checkbox"/>
1183	03/12/93	<input type="checkbox"/>			<input type="checkbox"/>
1186.1	01/09/09	<input type="checkbox"/>			<input type="checkbox"/>
1191	06/16/00	<input type="checkbox"/>			<input type="checkbox"/>

**Section V - AQMD Rules That Are Not SIP-Approved (Continued on Following Page)**

Check off each AQMD Rule as it applies to the facility. Use the blanks at the end of this form to fill-in new items.

Non SIP - Approved Rule	Adoption/ Amendment Date	Check (✓) If Applies	Non SIP - Approved Rule	Adoption/ Amendment Date	Check (✓) If Applies
1469	12/05/08	<input type="checkbox"/>	2009.1	05/11/01	<input type="checkbox"/>
1469.1	03/04/05	<input type="checkbox"/>	2501	05/09/97	<input type="checkbox"/>
1470	06/01/07	<input type="checkbox"/>	2506	12/10/99	<input type="checkbox"/>
1472	03/07/08	<input type="checkbox"/>			<input type="checkbox"/>
2009	01/07/05	<input type="checkbox"/>			<input type="checkbox"/>
		<input type="checkbox"/>			<input type="checkbox"/>
		<input type="checkbox"/>			<input type="checkbox"/>
		<input type="checkbox"/>			<input type="checkbox"/>
		<input type="checkbox"/>			<input type="checkbox"/>
		<input type="checkbox"/>			<input type="checkbox"/>



South Coast Air Quality Management District

**Form 500-F1 (Title V)**

**Title IV - Acid Rain Phase II Facility Information Summary**

Mail To:  
 SCAQMD  
 P.O. Box 4944  
 Diamond Bar, CA 91765-0944  
 Tel: (909) 396-3385  
 www.aqmd.gov

This form shall be completed by Acid Rain facilities ONLY and shall accompany all requests for Phase II permit actions unique to Acid Rain facilities. Also attach a completed Form 500-A2. In addition, if an initial Title V permit, permit renewal, or permit revision is requested, attach Form 500-A1 and any supplemental Acid Rain forms (Forms 500-F2, 500-F3, and 500-F4), as appropriate.

**Section I - General Information**

1. Facility Name (Business Name of Operator That Appears On Permit): Southern California Edison Company

2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 051475

3. ORIS Code (5-Digit): 56474

4. This is an application for a (Check all that apply to the facility):

- a.  Phase II Acid Rain Permit or Revision (Complete Section II of this form)
- b.  Repowering Extension Plan or Revision (Complete Form 500-F2)
- c.  New Unit Exemption or Revision (Complete Form 500-F3)
- d.  Retired Unit Exemption or Revision (Complete Form 500-F4)

5. The requested permit action involves a(n) (Check one):

- a.  Administrative Permit Revision
- b.  Significant Permit Revision
- c.  Fast Track Permit Revision
- d.  Automatic Permit Revision
- e.  Other (specify): Renewal of Title V permit.

6. For all applications requesting a permit revision, provide a general description of the proposed changes (Attach additional sheets as necessary):

No changes requested.

**Section II - Phase II Acid Rain Device Summary**

1. The following information is (Check one): a.  New b.  Revised

AQMD Device #	EPA Unit #	Will device need a Repowering Extension Plan?	Has device started operations on or after 11/15/90?	Device Operations Start Date (mo/day/yr)	For devices starting-up after 11/15/90, provide date when Monitoring Certification will begin (mo/day/yr)
D1	CT1	<input type="radio"/> Yes <input checked="" type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	07/20/2007	09/05/2007
		<input type="radio"/> Yes <input type="radio"/> No	<input type="radio"/> Yes <input type="radio"/> No		
		<input type="radio"/> Yes <input type="radio"/> No	<input type="radio"/> Yes <input type="radio"/> No		
		<input type="radio"/> Yes <input type="radio"/> No	<input type="radio"/> Yes <input type="radio"/> No		
		<input type="radio"/> Yes <input type="radio"/> No	<input type="radio"/> Yes <input type="radio"/> No		

To complete this application, type or print the information in the appropriate blanks.

**Section I - General Information**

1. **Facility Name:** Provide the name of the legal entity that operates the facility.

**AQMD Facility ID:** Complete only if the facility has been issued a 6-digit identification or ID number by AQMD. If not, leave these boxes blank. An ID number will be assigned when the application is submitted.

**ORIS Code:** Provide the 5-digit code that has been assigned to facility by Department of Energy.

2. Check all applicable boxes to indicate the type of Acid Rain application filed. If box 1a. is checked, complete Section II of this form. If box 1b. is checked, complete and attach Form 500-F2 - Title IV Phase II Acid Rain Repowering Extension Plan. If box 1c. is checked, complete and attach Form 500-F3 - Title IV Phase II Acid Rain New Unit Exemption Request. If box 1d. is checked, complete and attach Form 500-F4 - Title IV Phase II Acid Rain Retired Unit Exemption Request.
3. Check one box that best represents the type of permit action requested. If box 1e. is checked, in the space provided identify any additional elements regarding the application or the facility that need to be considered during the processing of this application (i.e., Initial Title V Permit Application).
4. If the application is a revision request, describe in general terms the changes that are proposed in the application revision request. Attach additional sheets as necessary.

**Section II - Phase II Acid Rain Device Summary**

1. Before completing this section, check one box to indicate whether this is a new application or a revision.

<b>AQMD Device #:</b>	Provide the identification number for each AQMD-assigned device subject to Phase II requirements.
<b>EPA Unit #:</b>	Provide the identification number for each EPA-assigned device subject to Phase II requirements.
<b>Will device need a Repowering Extension Plan?:</b>	Indicate with a "yes" or "no" if the device is or will be participating under a Repowering Extension Plan.
<b>Has device started operations on or after 11/15/90?:</b>	Indicate with a "yes" or "no" if the device was source tested or started operating on or after November 15, 1990.
<b>Device Operations Start Date:</b>	Complete this column <u>only</u> if the device was source tested or started operating on or after November 15, 1990. Provide the date (mo/day/yr) when the device started or will start operating. Note: If the date of beginning operations changes, an administrative permit revision application will be required.
<b>For Devices starting-up after 11/15/90, provide date when Monitoring Certification will begin:</b>	Complete this column <u>only</u> if the device was source tested or started operating on or after November 15, 1990. Provide the date (mo/day/yr) when compliance with the monitoring procedures for the device will begin. Refer to 40 CFR Part 75.4 to determine this date. Note: If the monitoring certification date changes, an administrative permit revision application will be required.



South Coast Air Quality Management District

**Form 500-H**

**Title V - Compliance Assurance Monitoring (CAM) Applicability Determination for Initial, Renewal, & Significant Permit Revision**

This form is required as part of an initial, significant permit revision, or renewal Title V application. If your Title V facility has control devices in use, the CAM rule may apply. Follow the instructions on the reverse side of this form to determine whether your facility is subject to CAM requirements.

Mail To:  
SCAQMD  
P.O. Box 4944  
Diamond Bar, CA 91765-0944

Tel: (909) 396-3385  
www.aqmd.gov

**Section I - Operator Information**

1. Facility Name (Business Name of Operator That Appears On Permit):

2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD):

Southern California Edison Company

051475

**Section II - CAM Status Summary for Emission Units**

3. Based on the criteria in the instructions (check one and attach additional pages as necessary):

a.  The emission units identified below are subject to the CAM rule<sup>1</sup> and a CAM plan<sup>2</sup> is attached for each affected emissions unit:

b.  There are no emission units with control devices at this Title V facility that are subject to the CAM rule.

Emission Unit <sup>3</sup> (Application, Permit or Device No.)	Equipment Description <sup>4</sup>	Uncontrolled Emissions		Connected to Control Unit <sup>3</sup> (Application, Permit or Device No.)	Equipment Description <sup>4</sup>	Controlled Emissions	
		Pollutant	PTE <sup>5</sup> (tons/year)			Pollutant	PTE <sup>5</sup> (tons/year)

<sup>1</sup> For more detailed information regarding the CAM rule applicability, refer to Title 40, Chapter I, Part 64, Section 64.1 of the Code of Federal Regulations (40 CFR Part 64, Section 64.1). This also can be accessed via the internet at: [http://www.access.gpo.gov/nara/cfr/waisidx\\_99/40cfr64\\_99.html](http://www.access.gpo.gov/nara/cfr/waisidx_99/40cfr64_99.html).

<sup>2</sup> Only one CAM plan is required for a control device that is common to more than one emissions unit, or if an emissions unit is controlled by more than one control device similar in design and operation. If the control devices are not similar in design and operation, one plan is required for each control device.

<sup>3</sup> List all new and existing emission units and the connected control devices either by AQMD application, permit or device number. When the emission unit is new and has not yet been assigned an application number, leave this column blank.

<sup>4</sup> Provide a brief equipment description of the emission units and control devices by indicating equipment type, make, and model and serial numbers as appropriate.

<sup>5</sup> Potential to Emit

## Instructions for Determining Applicability to the CAM Rule

With the exception of emission units that are municipally-owned backup utility power units as described by 40 CFR Part 64, Section 64.2(b)(2)<sup>1</sup>, the CAM rule is applicable to each emission unit (existing and new construction) at a Title V facility that meets ALL of the following criteria<sup>2</sup>:

1. The emission unit is subject to an emission limitation or standard<sup>3</sup> (often found in permit conditions);
2. The emission unit uses a control device to achieve compliance with the emission limitation or standard; and,
3. The emission unit has a potential to emit (PTE)<sup>4</sup>, either pre-control or post-control depending on the type of Title V application<sup>5</sup>, that exceeds or is equivalent to any of Title V major source thresholds shown in the following table:

<b>CAM Potential to Emit (PTE) Emission Threshold<sup>6</sup> For Individual Emission Units at a Title V Facility</b> (tons per year)			
<b>Pollutant</b>	<b>South Coast Air Basin (SOCAB)</b>	<b>Riverside County Portion of Salton Sea Air Basin (SSAB) and Los Angeles County Portion of Mojave Desert Air Basin (MDAB)</b>	<b>Riverside County Portion of Mojave Desert Air Basin (MDAB)</b>
VOC	10	25	100
NO <sub>x</sub>	10	25	100
SO <sub>x</sub>	100	100	100
CO	50	100	100
PM-10	70	70	100
1 HAP <sup>7</sup>	10	10	10
2+ HAPs	25	25	25

1 The facility must attach the documentation required by 40 CFR Part 64, Section 64.2 (b)(2) to demonstrate that the backup utility power unit only operates during periods of peak demand or emergency situations; and has actual emissions, averaged over the last three calendar years of operation, less than 50% of the major source emission thresholds.

2 Additional information about the CAM rule can be found on EPA's website at <http://www.epa.gov/tncmc01/cam.html>

3 Only emission limitations and standards from an "applicable requirement" for emission units with control devices are subject to the CAM rule. Applicable requirements are federally-enforceable requirements that are rules adopted by AQMD or the State that are approved by EPA into the State Implementation Plan (SIP) (i.e. "SIP-approved rules"). Refer to Form 500-C1 for the latest versions of SIP-approved and non-SIP approved rules.

For emissions units with control devices that are subject to following federally enforceable requirements, the CAM rule does NOT apply: 1) NSPS (40 CFR Part 60); 2) NESHAP (40 CFR Parts 61 and 63); 3) Title VI of the Federal Clean Air Act (CAA) for Stratospheric Ozone Protection; 4) Title IV of the CAA and SCAQMD Regulation XXXI for Acid Rain facilities; 5) SCAQMD Regulation XX - RECLAIM; 6) Any emission cap that is federally enforceable, quantifiable, and meets the requirements in 40 CFR Part 70, Section 70.4 (b)(12); and 6) Emission limitation or standards for which a continuous compliance determination method is required.

4 To calculate the pre-control device and post-control device PTE for emission units at the facility, refer to the Title V Technical Guidance Document Version 4 .0, Appendix A (pages A-12 through A-23). The calculations are used to determine the CAM applicability according to 40 CFR Part 64, Section 64.5 of the CAM rule.

5 For initial Title V or significant permit revision applications submitted after April 20, 1998, use the post-control device PTE emissions to determine CAM applicability. For Title V permit renewal applications (submittals will begin in 2002), the CAM applicability will be based on the pre-control device PTE.

6 The following table is based on Rule 3001 (Amended November 14, 1997) and Rule 3008 (Amended March 16, 2001). Please be advised that the threshold values are subject to change based on rule amendments.

7 Hazardous Air Pollutant