

South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 8, 2010

Mr. Gerardo Rios
Chief – Permits Office
U.S. EPA - Region IX
75 Hawthorne Street, Air 3
San Francisco, CA 94105

Subject: Transmittal of Final Title V Renewal Permit (ID 13990)

Dear Mr. Rios:

Enclosed is the final Title V renewal permit issued by the South Coast Air Quality Management District (AQMD) for U.S. Govt., Veterans Affairs Medical Center, Long Beach located at 5901 East 7th Street, Long Beach, CA 90822. The copy of the proposed permit for this facility has been submitted to EPA Region IX for 45-day review and made available for a 30-day public comment period. The AQMD did not receive any public comments on the proposed permit.

If there are specific questions on this Title V renewal permit, please contact Roy Olivares at (909) 396-2208.

Sincerely

A handwritten signature in black ink, appearing to read 'Brian L. Yeh', is written over a horizontal line.

Brian L. Yeh
Senior Air Quality Manager
General Commercial and Energy Team
Engineering and Compliance

BLY:AYL:ABS:RDO
Attachment



FACILITY PERMIT TO OPERATE


**US GOVT, VETERANS AFFAIRS MEDICAL CENTER
5901 E 7TH ST
LONG BEACH, CA 90822**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By 
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	0	09/08/2010
B	RECLAIM Annual Emission Allocation	0	09/08/2010
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	0	09/08/2010
E	Administrative Conditions	0	09/08/2010
F	RECLAIM Monitoring and Source Testing Requirements	0	09/08/2010
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	09/08/2010
H	Permit To Construct and Temporary Permit to Operate	0	09/08/2010
I	Compliance Plans & Schedules	0	09/08/2010
J	Air Toxics	0	09/08/2010
K	Title V Administration	0	09/08/2010
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	09/08/2010
B	Rule Emission Limits	0	09/08/2010



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: US GOVT, VETERANS AFFAIRS MEDICAL CENTER

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 5901 E 7TH ST
LONG BEACH, CA 90822-5299

MAILING ADDRESS: 5901 E 7TH ST
LONG BEACH, CA 90822-5299

RESPONSIBLE OFFICIAL: LAWRENCE STEWART

TITLE: MEDICAL CENTER DIRECTOR

TELEPHONE NUMBER: (562) 494-5402

CONTACT PERSON: ADRIENNE FLYNN

TITLE: BUSINESS MANAGER, ENGR& FAC OPER SERVICE

TELEPHONE NUMBER: (562) 826-5365

TITLE V PERMIT ISSUED: September 08, 2010

TITLE V PERMIT EXPIRATION DATE: September 07, 2015

TITLE V		RECLAIM	
YES	NOx:	NO	
	SOx:	NO	
	CYCLE:	0	
	ZONE:	COASTAL	



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section B	Page: 1
Facility ID:	013990
Revision #:	0
Date:	September 08, 2010

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

NOT APPLICABLE



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section C	Page: 1
Facility ID:	013990
Revision #:	0
Date:	September 08, 2010

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

**Facility Equipment and Requirements
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit to Operate number	Equipment description	Page no.
213797	D35143	I C E (>500 HP) EM ELEC GEN DIESEL	4
213798	D22276	I C E (50-500 HP) EM ELEC GEN-DIESEL	6
213800	D28791	I C E (>500 HP) EM ELEC GEN DIESEL	8
213804	D22281	I C E (50-500 HP) EM ELEC GEN-DIESEL	10
213805	D22282	I C E (50-500 HP) EM ELEC GEN-DIESEL	12
242917	D67572	BOILER (>20-50 MMBTU/HR) COMB GAS-DISTIL	14
242918	D67574	BOILER (>20-50 MMBTU/HR) COMB GAS-DISTIL	17
242919	D67573	BOILER (>20-50 MMBTU/HR) COMB GAS-DISTIL	20
452849	N18921	GASOLINE STORAGE AND DISPENSING SYSTEM	23
301007	D91873	I C E (>500 HP) EM ELEC GEN DIESEL	27
301008	D91874	I C E (>500 HP) EM ELEC GEN DIESEL	29
321084	F6238	BOILER/HOTWATER HEATER,SINGLE FACILITY,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED	31
321085	F6237	BOILER/HOTWATER HEATER,SINGLE FACILITY,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED	33
387099	F49031	I C E (>500 HP) EM ELEC GEN DIESEL	35
387100	F49032	I C E (50-500 HP) EM ELEC GEN DIESEL	37
401098	F52909	I C E (>500 HP) EM ELEC GEN DIESEL	39
431729	F83385	SPRAY BOOTH	41

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGLEMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]

2. THE OPERATOR SHALL USE PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPMV BY WEIGHT AS SUPPLIED BY THE SUPPLIER
[RULE 431.2]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D35143
A/N 213797**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL KTA-19-GI, S/N 37120235, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, 560 BHP.

Conditions

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1304 (a)(4)-MODELING AND OFFSETS, RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1110.2, RULE 1470, RULE 1303 (a)(1)-BACT]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D22276
A/N 213798**

Equipment Description:

INTERNAL COMBUSTION ENGINE GENERAC DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 88A01051-S, SERIAL NO. 8609Z8, 4 CYLINDERS. FOUR CYCLE, NATURALLY ASPIRATED, 130 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
4. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303 (a)-BACT]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1110.2, RULE 1470]
6. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

7. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
9. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Periodic Monitoring:

10. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D28791
A/N 213800**

Equipment Description:

INTERNAL COMBUSTION ENGINE. CUMMINS DIESEL-FUELED. EMERGENCY ELECTRICAL GENERATION. MODEL NTA-855-G. SERIAL NO. 10794305, TURBOCHARGED. AFTERCOOLED, 6 CYLINDERS,. 655 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1304 (a)(4), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304 (a)-MODELING AND OFFSETS, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D22281
A/N 213804**

Equipment Description:

INTERNAL COMBUSTION ENGINE GENERAL MOTORS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6150. SERIAL NO. 6A-86830, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED, 250 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
{RULE 1303 (a)(1)-BACT}
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1470, RULE 1110.2]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Periodic Monitoring:

9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D22282
A/N 213805**

Equipment Description:

INTERNAL COMBUSTION ENGINE ALLIS-CHALMERS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 25000, SERIAL NO. 2503562, 6 CYLINDERS, FOUR CYCLE, TURBOCHARGED, 445 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.
[RULE 1303 (a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Periodic Monitoring:

9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004 (a)(4)]
10. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.
[RULE 3004 (a)(4)]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D67572
A/N 242917

Equipment Description:

BOILER NO. 3, TRANE MURRAY, WATERTUBE TYPE, BOILER TYPE NO. 3-50, SERIAL NO. 10415, WITH A 45,000,000 BTU PER HOUR, NATURAL GAS OR OIL FIRED, FABER BURNER, MODEL NO. WBH-1-20, WITH A 30 H.P. COMBUSTION AIR BLOWER AND AN INDUCED FLUE GAS, RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION EXCEPT DURING MAINTENANCE OR TESTING.
[RULE 1146]
4. FUEL OIL SUPPLIED AT THE BURNER SHALL BE NO.2 OR A LIGHTER GRADE AS DESCRIBED BY THE LATEST ASTM SPECIFICATIONS AND SHALL CONTAIN LESS THAN 0.015 PERCENT SULFUR BY WEIGHT.
[RULE 431.2]
5. THIS BOILER SHALL BE EQUIPPED WITH A NON- RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL TO BE BURNED.
[RULE 1146]
6. THE BOILER OPERATOR SHALL RECORD THE ANNUAL FUEL USE IN A MANNER APPROVED IN WRITING BY THE DIRECTOR OF COMPLIANCE. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF FIVE YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
7. IF THIS BOILER BURNS MORE THAN 98,550,000,000 BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER SHALL MEET THE 30 PPM OXIDES OF NITROGEN LIMIT OF RULE 1146 FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR.
[RULE 1146]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

8. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AND OPERATE FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(B).
[RULE 1146]
9. THIS EQUIPMENT SHALL COMPLY WITH THE NOX EMISSIONS LIMITS OF 9 PPMV. THE COMPLIANCE DATE FOR THE NOX CONCENTRATION LIMIT IS SPECIFIED IN RULE 11146, TABLE 1146-1.
[RULE 1146]
10. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.
[RULE 1146]
11. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).
[RULE 1146]

Periodic Monitoring:

12. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
13. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
14. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
- B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

- 15. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

- 16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
CO: 400 PPMV, RULE 1146
NOX 40 PPMV, RULE 1146, FUEL OIL
NOX 30 PPMV, RULE 1146, NATURAL GAS
NOX 9 PPMV, RULE 1146, EFFECTIVE 1/12/2012 AND 1/12/2014

PERMIT TO OPERATE



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

**Permit No. D67574
A/N 242918**

Equipment Description:

BOILER NO. 2, TRANE MURRAY, WATERTUBE TYPE, BOILER TYPE NO. 3-50, SERIAL NO. 10416, WITH A 45,000,000 BTU PER HOUR, NATURAL GAS OR OIL FIRED, FABER BURNER, MODEL NO. WBH-1-20, WITH A 30 H.P. COMBUSTION AIR BLOWER AND AN INDUCED FLUE GAS, RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION EXCEPT DURING MAINTENANCE OR TESTING.
[RULE 1146]
4. FUEL OIL SUPPLIED AT THE BURNER SHALL BE NO.2 OR A LIGHTER GRADE AS DESCRIBED BY THE LATEST ASTM SPECIFICATIONS AND SHALL CONTAIN LESS THAN 0.015 PERCENT SULFUR BY WEIGHT.
[RULE 431.2]
5. THIS BOILER SHALL BE EQUIPPED WITH A NON- RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL TO BE BURNED.
[RULE 1146]
6. THE BOILER OPERATOR SHALL RECORD THE ANNUAL FUEL USE IN A MANNER APPROVED IN WRITING BY THE DIRECTOR OF COMPLIANCE. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
7. IF THIS BOILER BURNS MORE THAN 98,550,000,000 BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER SHALL MEET THE 30 PPM OXIDES OF NITROGEN LIMIT OF RULE 1146 FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR.
[RULE 1146]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

8. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR. THE BOILER OPERATOR SHALL INSTALL AND OPERATE FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(B).
[RULE 1146]
9. THIS EQUIPMENT SHALL COMPLY WITH THE NOX EMISSIONS LIMITS OF 9 PPMV. THE COMPLIANCE DATE FOR THE NOX CONCENTRATION LIMIT IS SPECIFIED IN RULE 1146, TABLE 1146-1.
[RULE 1146]
10. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.
[RULE 1146]
11. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).
[RULE 1146]

Periodic Monitoring:

12. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
13. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
14. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

- C. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;
OR
- D. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- E. STACK OR EMISSION POINT IDENTIFICATION;
- F. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- G. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- H. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

- 15. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

- 16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- CO: 2000 PPMV, RULE 407
- SOX: 500 PPMV, RULE 407
- PM: 0.1 GR/SCF, RULE 409
- CO: 400 PPMV, RULE 1146
- NOX 40 PPMV, RULE 1146, FUEL OIL
- NOX: 30 PPMV, RULE 1146, NATURAL GAS
- NOX 9 PPMV, RULE 1146, EFFECTIVE 1/12/2012 AND 1/12/2014

PERMIT TO OPERATE



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

Permit No. D67573
A/N 242919

Equipment Description:

BOILER NO. 1, TRANE MURRAY, WATERTUBE TYPE, BOILER TYPE NO. 3-50, SERIAL NO. 10417, WITH A 45,000,000 BTU PER HOUR, NATURAL GAS OR OIL FIRED, FABER BURNER, MODEL NO. WBH-1-20, WITH A 30 H.P. COMBUSTION AIR BLOWER AND AN INDUCED FLUE GAS, RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION EXCEPT DURING MAINTENANCE OR TESTING.
[RULE 1146]
4. FUEL OIL SUPPLIED AT THE BURNER SHALL BE NO.2 OR A LIGHTER GRADE AS DESCRIBED BY THE LATEST ASTM SPECIFICATIONS AND SHALL CONTAIN LESS THAN 0.015 PERCENT SULFUR BY WEIGHT.
[RULE 431.2]
5. THIS BOILER SHALL BE EQUIPPED WITH A NON- RESETTABLE, TOTALIZING FLOW METER FOR EACH FUEL TO BE BURNED.
[RULE 1146]
6. THE BOILER OPERATOR SHALL RECORD THE ANNUAL FUEL USE IN A MANNER APPROVED IN WRITING BY THE DIRECTOR OF COMPLIANCE. ALL RECORDS SHALL BE RETAINED FOR A PERIOD OF TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
7. IF THIS BOILER BURNS MORE THAN 98,550,000,000 BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER SHALL MEET THE 30 PPM OXIDES OF NITROGEN LIMIT OF RULE 1146 FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR.
[RULE 1146]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

8. IF THIS BOILER BURNS MORE THAN 200 BILLION BTUS OF FUEL IN ANY ONE CALENDAR YEAR. THE BOILER OPERATOR SHALL INSTALL AND OPERATE FOR THE LIFE OF THE UNIT BEGINNING MARCH 1 OF THE FOLLOWING YEAR AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(B).
[RULE 1146]
9. THIS EQUIPMENT SHALL COMPLY WITH THE NOX EMISSIONS LIMITS OF 9 PPMV. THE COMPLIANCE DATE FOR THE NOX CONCENTRATION LIMIT IS SPECIFIED IN RULE 11146, TABLE 1146-1.
[RULE 1146]
10. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.
[RULE 1146]
11. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).
[RULE 1146]

Periodic Monitoring:

12. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
13. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
14. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

- E. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;
OR
- F. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- I. STACK OR EMISSION POINT IDENTIFICATION;
- J. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- K. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- L. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

- 15. UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS OR GREATER THAN 336 HOURS OF OPERATION, BUT DOES NOT EXCEED 2,000,000 GALLONS IN ANY ONE YEAR. THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

- 16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- CO: 2000 PPMV, RULE 407
- SOX: 500 PPMV, RULE 407
- PM: 0.1 GR/SCF, RULE 409
- CO: 400 PPMV, RULE 1146
- NOX: 40 PPMV, RULE 1146, FUEL OIL
- NOX: 30 PPMV, RULE 1146, NATURAL GAS
- NOX: 9 PPMV, RULE 1146, EFFECTIVE 1/12/2012 AND 1/12/2014



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. N18921
A/N 452849**

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY CONSISTING OF:

1. 1- GASOLINE UNDERGROUND STORAGE TANK, 10,000-GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM (VR-102-E), NOT METHANOL COMPATIBLE.
2. 1- METHANOL UNDERGROUND STORAGE TANK, 6,000-GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM (VR-102-E), 1 METHANOL COMPATIBLE.
3. 2- GASOLINE NOZZLES DISPENSING 2 PRODUCTS, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-A).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO CONSTRUCT/OPERATE N16871 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT, A WRITTEN REQUEST SHALL BE SUBMITTED TO THE AQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR AQMD.
[RULE 461]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.
[RULE 461]



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

5. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.
[RULE 461]
6. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.
[RULE 461]
7. NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED, SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE. COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT. PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER.
[RULE 461]
8. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO BACK-FILLING ANY UNDERGROUND STORAGE TANK OR PIPING, THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461BACKFILL@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTORS; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE BACK-FILLING PROCEDURE. THE BACK-FILLING PROCEDURE SHALL NOT COMMENCE UNTIL INSPECTED BY A DISTRICT REPRESENTATIVE.
[RULE 461]
9. DEPENDING ON THE SYSTEM CONFIGURATION, A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE. EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP-201.1C OR TP-201.1D, RESPECTIVELY. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
10. A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN THIRTY DAYS (30) AFTER THE START OF OPERATION OF THE OPW PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201.1E. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

REQUEST.
[RULE 461]

11. A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201.1B AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]

12. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE RISER, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURE DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

NITROGEN FLOWRATES
(CFH)
60

DYNAMIC BACK PRESSURE
(INCHES OF WATER)
0.50

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4, METHODOLOGY 4; AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS.
[RULE 461]

13. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3 AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]

14. A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201-A AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]

15. A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

VR-201-A AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.

[RULE 461]

16. A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR-201-A. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
17. THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED.
[RULE 461]

Periodic Monitoring:

18. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(C)(6) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT D, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.
[RULE 3004 (a)(4)]

Emissions And Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 461
VOC: RULE 1170



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D91873
A/N 301007**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL NO. VTS-1710-GI, EMERGENCY ELECTRICAL GENERATION, DIESEL-FUELED, 12 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 760 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIME METER SHALL BE MAINTAINED TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1304 (a)(4), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304 (a)(4), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. D91874
A/N 301008**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL NO. VTA-28-G2, EMERGENCY ELECTRICAL GENERATION, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 900 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIME METER SHALL BE MAINTAINED TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1304 (a)(4), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304 (a)(4), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. F6238
A/N 321084**

Equipment Description:

BOILER, ALLIED MANUFACTURING INC., PORTABLE, STEAM CLEANING, MODEL NO. 2500-3JGT, SERIAL NO. 1809-183104, 280,000 BTU/HR, FUEL OIL OR KEROSENE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL COMPLY WITH RULE 1147.
[RULE 1147]
4. THIS BOILER SHALL EMIT NO MORE THAN 40 PPM FOR OXIDES OF NITROGEN (NOX) MEASURED BY VOLUME ON A DRY BASIS AT 3% OXYGEN. THIS EQUIPMENT SHALL COMPLY WITH THE 40 PPMV NO_x CONCENTRATION LIMIT BY 7/1/2011.
[RULE 1147]

Periodic Monitoring:

5. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1147 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section D Page 32
Facility I.D.#: 013990
Revision #: 0
Date: September 8, 2010

**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409
NOx 40 PPMV, RULE 1147,



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. F6237
A/N 321085**

Equipment Description:

BOILER, DAYTON ELECTRIC MANUFACTURING INC., PORTABLE, STEAM CLEANING, MODEL NO. 5Z022, SERIAL NO. C-41785, 224,000 BTU/HR, FUEL OIL OR KEROSENE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL COMPLY WITH RULE 1147.
[RULE 1147]
5. THIS BOILER SHALL EMIT NO MORE THAN 40 PPM FOR OXIDES OF NITROGEN (NOX) MEASURED BY VOLUME ON A DRY BASIS AT 3% OXYGEN. THIS EQUIPMENT SHALL COMPLY WITH THE 40 PPMV CONCENTRATION LIMIT BY 7/1/2011
[RULE 1147]

Periodic Monitoring:

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1147 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
SOX: 500 PPMV, RULE 407



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

PM: 0.1 GR/SCF, RULE 409
NOx 40 PPMV, RULE 1147



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. F49031
A/N 387099**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL KTA-38G1, SERIAL NO. 33124481, DIESEL FUEL, TWELVE CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 1135 B.H.P, DRIVING AN EMERGENCY STAND-BY ELECTRICAL GENERATOR

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIME METER SHALL BE MAINTAINED TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1304 (a)(4), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[[RULE 1304 (a)(4), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**


[RULE 1304(b)(2), RULE 1110.2, RULE 1470]

6. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. F49032
A/N 387100**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL LTA10-GI, SERIAL NO. 34984574, DIESEL FUEL, SIX CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 380 B.H.P, DRIVING AN EMERGENCY STAND-BY ELECTRICAL GENERATOR

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIME METER SHALL BE MAINTAINED TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1304 (a)(4), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[RULE 1304 (a)(4), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

6. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. F52909
A/N 401098**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL QST30-G5, SERIAL NO. 37199012, DIESEL FUEL, 12 CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 1490 B.H.P, DRIVING AN EMERGENCY STAND-BY ELECTRICAL GENERATOR

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A NON-RESETTABLE TIME METER SHALL BE MAINTAINED TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 1304 (a)(4), RULE 1110.2]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
[[RULE 1304 (a)(4), RULE 1110.2, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(b)(2), RULE 1110.2, RULE 1470]



FACILITY PERMIT TO OPERATE US GOVT, VETERANS AFFAIRS MEDICAL CENTER

6. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1304(a)(1)-BACT, RULE 1470]
7. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304(a)(1)-BACT, RULE 1470]
8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

PERMIT TO OPERATE

**Permit No. F83385
A/N 431729**

Equipment Description:

SPRAY BOOTH, GREENHECK, MODEL PF-6-7-8, FLOOR TYPE, 6'-0" W.x 8'-0" L.x 7'-0" H., WITH TWELVE FILTERS, EACH 20" X 20" X 2" , AND ONE EXHAUST BLOWER, RATED AT ONE H.P.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA AT LEAST TWO INCHES THICK.
[RULE 1303 (a), RULE 212(a)]
4. A GAUGE SHALL BE INSTALLED TO INDICATE THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS. IN OPERATION, THE PRESSURE DIFFERENTIAL SHALL NOT EXCEED 0.25 INCH OF WATER.
[RULE 1303 (a), RULE 212(a)]
5. MATERIAL SAFETY DATA SHEETS FOR ALL COATINGS, SOLVENTS USED IN THIS EQUIPMENT SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1136, 1171, RULE 1401, RULE 1303 (b)(2)]
6. COATINGS, ADHESIVE, REDUCERS, CLEAN-UP SOLVENTS AND ANY OTHER MATERIALS USED IN THIS EQUIPMENT AT THIS FACILITY SHALL NOT CONTAIN ANY COMPOUND IDENTIFIED AS CARCINOGENIC CONTAMINANTS IN RULE 1401, AS AMENDED ON MAY 3, 2003.
[RULE 1401]
7. THIS EQUIPMENT SHALL COMPLY WITH RULES 1136 AND 1171.
[RULE 1136 AND 1171]
8. THE OPERATOR SHALL COMPLY WITH RULE 109 (RECORDKEEPING FOR VOLATILE ORGANIC COMPOUND EMISSIONS).
[RULE 109]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**


9. THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT EXCEED ONE GALLON IN ANY ONE DAY.
[RULE 1136, RULE 1303 (a)-BACT, RULE 1303 (b)(2)-OFFSETS]
10. THE OPEATOR SHALL KEEP ADEQUATE RECORDS FOR THIS FACILITY TO VERIFY CALENDAR MONTHLY VOLATILE ORGANIC COMPOUND (VOC) EMISSIONS AND VOC CONTENT OF EACH COATING AS APPLIED (INCLUDING WATER AND EXEMPT COMPOUNDS). ALL RECORDS SHALL BE PREPARED IN A FORMAT WHICH IS ACCEPTABLE TO THE DISTRICT DURING THE PRECEDING 12 MONTHS.
[RULE 109, RULE 1303 (b)(2)]

Periodic Monitoring:

11. THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER MEDIA ONCE EVERY WEEK.
[RULE 3004 (a)(4)]
12. THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.
- [RULE 3004 (a)(4)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 109
 - VOC: RULE 1136, SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC: RULE 1171, SEE APPENDIX B FOR EMISSIONS LIMITS
 - PM: RULE 481
 - PM: RULE 404, SEE APPENDIX B FOR EMISSIONS LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS, WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CR⁺⁶: RULE 1404



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**


RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT/RECOVERY

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
REFRIGERANT: RULE 1415
REFRIGERANT: 40 CFR82 SUBPART F



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, SOLVENT CLEANING

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1171



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statues of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO₂) and be averaged over 15 consecutive minutes; [407]
 - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO₂) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]



FACILITY PERMIT TO OPERATE
~~US GOVT, VETERANS AFFAIRS MEDICAL CENTER~~

SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O₂) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
 - a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
 - a. The results of the source test.



AQMD

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief description of the equipment tested.
 - c. Operating conditions under which the test was performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
 11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

NOT APPLICABLE



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section G	Page:	1
Facility ID:		013990
Revision #:		0
Date:	September 08, 2010	

~~FACILITY PERMIT TO OPERATE~~
~~US GOVT, VETERANS AFFAIRS MEDICAL CENTER~~

**SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR
RECLAIM SOURCES**

NOT APPLICABLE



~~FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER~~

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

NONE



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

Section J	Page: 1
Facility ID:	013990
Revision #:	0
Date:	September 08, 2010

**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

SECTION J: AIR TOXICS

NOT APPLICABLE



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]

15. Nothing in this permit or in any permit shield can alter or affect:
 - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]

16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

**SECTION K: TITLE V Administration
EMERGENCY PROVISIONS**

17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

**SECTION K: TITLE V Administration
RECORDKEEPING PROVISIONS**

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;



**FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER**

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]



FACILITY PERMIT TO OPERATE
~~US GOVT, VETERANS AFFAIRS MEDICAL CENTER~~

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1138	11-14-1997	Federally enforceable
RULE 1146	5-13-1994	Federally enforceable
RULE 1147	12-5-2008	Non federally enforceable
RULE 1170	5-6-1988	Non federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	3-17-2000	Non federally enforceable
RULE 1404	4-6-1990	Non federally enforceable
RULE 1405	1-4-1991	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 2202	11-8-1996	Non federally enforceable



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	1-14-1982	Non federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	4-21-2000	Federally enforceable
RULE 701	6-13-1997	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable



FACILITY PERMIT TO OPERATE
US GOVT, VETERANS AFFAIRS MEDICAL CENTER

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

NONE



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 01-06-2006]**

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:


VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 01-06-2006]**

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 01-06-2006]**

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-09-2001]**

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-09-2001]**

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-09-2001]**

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 05-14-1999]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6) of Rule 1113, the operator shall not supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6) of Rule 1113, the operator shall not supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings for residential use; or of any rust-preventative coating for industrial use.



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 05-14-1999]
TABLE OF STANDARDS
VOC LIMITS**

**Grams of VOC Per Liter of Coating,
Less Water And Less Exempt Compounds**

COATING	Limit*	Effective 1/1/1998	Effective 1/1/1999	Effective 5/14/99	Effective 7/1/2001	Effective 7/1/2002	Effective 1/1/2005	Effective 7/1/2006	Effective 7/1/2008
Bond Breakers	350								
Chemical Storage Tank Coatings	420							100	
Clear Wood Finishes									
Varnish	350								
Sanding Sealers	350								
Lacquer	680	550					275		
Concrete-Curing Compounds	350								
Dry-Fog Coatings	400								
Essential Public Service Coating	420					340		100	
Fire-proofing Exterior Coatings	450		350						
Fire-Retardant Coatings									
Clear	650								
Pigmented	350								
Flats	250				100				50
Floor Coatings	420					100		50	
Graphic Arts (Sign) Coatings	500								
High Temperature Industrial Maintenance Coatings						550		420	
Industrial Maintenance Coatings	420					250		100	
Japans/Faux Finishing Coatings	700		350						
Magnesite Cement Coatings	600		450						
Mastic Coatings	300								
Metallic Pigmented Coatings	500								
Multi-Color Coatings	420	250							
Non-Flat Coatings	250					150		50	
Pigmented Lacquer	680	550					275		
Pre-Treatment Wash Primers	780								
Primers, Sealers, and Undercoaters	350					200		100	
Quick-Dry Enamels	400					250		50	



**FACILITY PERMIT TO OPERATE
 US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 1113 05-14-1999]**

Quick-Dry Primers, Sealers, and Undercoaters	350**					200		100	
Recycled Coatings				250		250		100	
Roof Coatings	300			250					
Bituminous Roof Coatings	300					250			
Rust Preventative Coatings	420			400				100	
Shellac									
Clear	730								
Pigmented	550								
Specialty Primers	350							100	
Stains	350					250			
Swimming Pool Coatings									
Repair	650								
Other	340								
Traffic Coatings	250	150							
Waterproofing Sealers									
Wood	400					250			
Concrete/Masonry	400								
Wood Preservatives									
Below-Ground	350								
Other	350								

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

** The specified limit applies unless the manufacturer submits a report pursuant to Rule 1113(g)(2).

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 07-13-2007]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.



FACILITY PERMIT TO OPERATE US GOVT. VETERANS AFFAIRS MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007] TABLE OF STANDARDS VOC LIMITS

**Grams of VOC Per Liter of Coating,
Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 07-13-2007]**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing Concrete/Masonry Sealers	400					100		
Wood Preservatives								
Below-Ground	350							
Other	350							

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

** Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

*** The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 07-13-2007]**

**TABLE OF STANDARDS (cont.)
VOC LIMITS**

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 06-14-1996]**

Except as otherwise provided in Rule 1136

- (a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

(1)

VOC LIMITS

Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>		<u>On and After</u>
	<u>I</u>	<u>or</u>	<u>7/1/2005</u>
	<u>II</u>		
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

- (2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 06-14-1996]**

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

COATING

Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]

(3)

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>	<u>On and After 7/1/2005</u>
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

VOC LIMITS

Grams Per Liter (lb/gal) of Material

<u>COATING</u>	<u>Current Limit</u>	<u>On and After 7/1/2005</u>
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 06-14-1996]**

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

- (4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.
- (b) A person shall not use a stripper on wood products unless:
 - (1) it contains less than 350 grams of VOC per liter of material; or
 - (2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]**

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]**

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

* The specified limits remain in effect unless revised limits are listed in subsequent columns.



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 06-13-1997]**

Except as otherwise provided in Rule 1171, the operator shall not use a solvent to perform solvent cleaning unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS		Effective 1/1/1999	
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application				
(i) General	70 (0.58)			
(ii) Electronic Components or Medical Devices	900 (7.5)	33		
(B) Repair and Maintenance Cleaning				
(i) General	900 (7.5)	20	50 (0.42)	
(ii) Electrical Apparatus Components	900 (7.5)	20		
(iii) Medical Devices	900 (7.5)	33		



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 06-13-1997]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS		Effective 1/1/1999	
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)
(C) Cleaning of Coatings, or Adhesives Application Equipment	950 (7.9)	35		
(D) Cleaning of Ink Application Equipment				
(i) General	100 (0.83)	3		
(ii) Flexographic or Gravure Printing	100 (0.83)	3		
(iii) Lithographic or Letter Press Printing	900 (7.5)	25		10
(iv) Screen Printing	1070 (8.9)	5		
(v) Ultraviolet Inks (except screen printing)	800 (6.7)	33		
(vi) Specialty Flexographic Printing	810 (6.8)	21		
(E) Cleaning of Polyester Resin Application Equipment	50 (0.42)			
or		1		



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]**

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a).

Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter ² Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter ² Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148



**FACILITY PERMIT TO OPERATE
US GOVT. VETERANS AFFAIRS MEDICAL CENTER**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100