South Coast
Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 · www.aqmd.gov

March 13, 2012

Mr. Richard Corrette
Facilities Manager
ARLON, Materials for Electronics Division
9433 Hyssop Drive
Rancho Cucamonga, CA 91730

SUBJECT: Title V Facility Permit Revision (Facility ID: 046646)

Dear Mr. Corrette:

Please find attached the revised Title Page, Table of Contents, and Section D of your Title V Facility Permit. The revised sections reflect the approval of the permit revision requested in your Application No. 530201. The proposed permit revision was submitted to EPA for 45-day review on January 25, 2012. This permit revision includes the modification of two boilers with low NOx burners to comply with the requirements of Rule 1146 – Emissions of Oxides Nitrogen from Industrial, Institutional, and Commercial Boilers, Steam Generators and Process Heaters.

Equipment	Application No.	Permit Type
Boiler	530199	P/C
Boiler	530200	P/C

Please review the attached sections carefully. Insert the enclosed sections into your Facility Permit and discard the earlier versions. Questions concerning changes to your permit should be directed to Mr. Shailesh Patel at (909) 396-2681.

Sincerely,

Brian L. Yeh
Senior Manager
Coating, Printing, Plating, Military &
Entertainment Operations

BLY:EMM:approval
Attachment

cc: Gerardo Rios, EPA Region IX