



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 9, 2011

Mr. Gerardo Rios
U.S. EPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105

**SUBJECT: Transmittal of Proposed Title V Renewal Permit
LONG BEACH MEMORIAL MEDICAL CENTER
2801 Atlantic Ave
Long Beach, CA 90806
Facility ID 14213**

Dear Mr. Rios:

Enclosed is the above-referenced proposed renewal of a Title V permit along with the facility permit application, a Statement of Basis and public notice. With your receipt of this proposed Title V permit, we will note that the EPA 45-day review period has begun on September 9, 2011.

Questions on the proposed permit should be directed to Mr. Chris Perri, Air Quality Engineer, at (909) 396-2696 or cperri@aqmd.gov.

Sincerely,

Brian L. Yeh.
Senior Manager
Mechanical, Chemical, and Public Services Team
Engineering and Compliance

BLY:AYL:JTY:CGP

Enclosures:

Facility Permit (Proposed Renewal)
Public Notice
Statement of Basis
Facility Permit Application

FACILITY PERMIT TO OPERATE

**LONG BEACH MEMORIAL MEDICAL CENTER
2801 ATLANTIC AVE
LONG BEACH, CA 90806**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By _____
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	09/08/2011
B	RECLAIM Annual Emission Allocation	DRAFT	09/08/2011
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	09/08/2011
E	Administrative Conditions	DRAFT	09/08/2011
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	09/08/2011
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	09/08/2011
H	Permit To Construct and Temporary Permit to Operate	DRAFT	09/08/2011
I	Compliance Plans & Schedules	DRAFT	09/08/2011
J	Air Toxics	DRAFT	09/08/2011
K	Title V Administration	DRAFT	09/08/2011
 Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	09/08/2011
B	Rule Emission Limits	DRAFT	09/08/2011

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: LONG BEACH MEMORIAL MEDICAL CENTER

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 2801 ATLANTIC AVE
LONG BEACH, CA 90806-1737

MAILING ADDRESS: P O BOX 1428 N: ENGINEERING
LONG BEACH, CA 90801-1428

RESPONSIBLE OFFICIAL: GLENN CRABTREE

TITLE: VICE PRESIDENT OF FACILITIES

TELEPHONE NUMBER: (562) 933-0448

CONTACT PERSON: DOUG BUDD

TITLE: OPERATION MANAGER

TELEPHONE NUMBER: (562) 933-0565

INITIAL TITLE V PERMIT ISSUED: May 25, 2005

TITLE V PERMIT EXPIRATION DATE: May 24, 2010

TITLE V	RECLAIM
YES	NOx: NO SOx: NO CYCLE: 0 ZONE: COASTAL

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit to Operate number	Equipment description
189297	D10829	ICE (50-500 BHP), EM ELECTRICAL GEN, DIESEL
222052	D61318	BOILER, NAT GAS & OIL, > 5=20 MM BTU/HR
222053	D61319	BOILER, NAT GAS & OIL, > 5=20 MM BTU/HR
222054	D61321	BOILER, NAT GAS & OIL, > 5=20 MM BTU/HR
287673	D78999	ICE (>500 BHP), EM ELECTRICAL GEN, DIESEL
287674	D79000	ICE (>500 BHP), EM ELECTRICAL GEN, DIESEL
287675	D79001	ICE (>500 BHP), EM ELECTRICAL GEN, DIESEL
287677	D79002	ICE (>500 BHP), EM ELECTRICAL GEN, DIESEL
287678	D79003	ICE (>500 BHP), EM ELECTRICAL GEN, DIESEL
305182	D92304	ETHYLENE OXIDE STERILIZER
305183	D92305	ETHYLENE OXIDE STERILIZER
305184	D92306	ETHYLENE OXIDE STERILIZER
305185	D92307	ETHYLENE OXIDE STERILIZER
305186	D92308	AIR POLLUTION CONTROL SYSTEM-CATALYTIC OXIDIZER
305187	D92309	AIR POLLUTION CONTROL SYSTEM-CATALYTIC OXIDIZER
322832	F10118	STEAM CLEANER, DIESEL
349892	F19420	ICE (>500 BHP), EM ELECTRICAL, GEN, DIESEL
349893	F19419	ICE (>500 BHP), EM ELECTRICAL, GEN, DIESEL
349894	F19421	ICE (>500 BHP), EM ELECTRICAL, GEN, DIESEL
482039	F98634	ICE (>500 BHP), EM ELECTRICAL, GEN, DIESEL
483304	F98635	ICE (50-500 BHP), EM ELECTRICAL, GEN, DIESEL
494126	G4482	ICE (>500 BHP), EM ELECTRICAL, GEN, DIESEL
494131	G4483	ICE (>500 BHP), EM ELECTRICAL, GEN, DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS

**FACILITY PERMIT TO OPERATE
LONG BEACH MEMORIAL MEDICAL CENTER**

SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGLEMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]

2. THE OPERATOR SHALL ONLY USE DIESEL FUEL WITH A SULFUR CONTENT THAT DOES NOT EXCEED 15 PPM BY WEIGHT, UNLESS THE OPERATOR DEMONSTRATES IN WRITING TO THE EXECUTIVE OFFICER THAT SPECIFIC ADDITIONAL TIME IS NECESSARY.
[RULE 431.2]

3. THIS FACILITY SHALL SUBMIT A RULE 1472 COMPLIANCE PLAN ON OR BEFORE JANUARY 1, 2011.
[RULE 1472]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D10829
A/N 189297

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3412TA, DIESEL-FUELED, 12 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 895 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]
6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]
8. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES
RETARDED RELATIVE TO STANDARD TIMING.
[RULE 1110.2]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D61318
A/N 222052

Equipment Description:

BOILER, NO. 1, BABCOCK AND WILCOX, WATER TUBE TYPE, NATURAL GAS OR FUEL OIL FIRED, COEN, MODEL SDAF-14 LOW NO_x BURNER, 19,860,000 BTU PER HOUR WITH A 7-1/2 H.P. COMBUSTION AIR BLOWER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL BE OPERATED IN FULL COMPLIANCE WITH THE APPLICABLE PROVISIONS OF RULE 1146.
[RULE 1146]
5. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING AN EMERGENCY AND REQUIRED TESTING AT WHICH FUEL OIL MAY BE USED.
[RULE 1146]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR, FUEL, AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.
[RULE 1146]
7. THE OWNER OR OPERATOR OF THIS BOILER SHALL MAINTAIN ALL BOILER TUNE-UP RECORDS, AS SPECIFIED IN CONDITION NO. 6 ABOVE FOR A PERIOD OF AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

8. THE EMISSIONS FROM THIS BOILER SHALL NOT EXCEED BY VOLUME ON A DRY BASIS AT 3% O₂, AVERAGED OVER 15 CONSECUTIVE MINUTES:
- A. 400 PPM OF CARBON MONOXIDE.
 - B. 30 PPM OF OXIDES OF NITROGEN WHEN FIRING NATURAL GAS.
 - C. 40 PPM OF OXIDES OF NITROGEN WHEN FIRING FUEL OIL.
[RULE 1146]

Periodic Monitoring:

9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a) (4)]
10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a) (4)]
11. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;
OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a) (4)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146, WHEN FIRING NATURAL GAS
NOx: 40 PPMV, RULE 1146, WHEN FIRING FUEL OIL
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D61319
A/N 222053

Equipment Description:

BOILER, NO. 2, BABCOCK AND WILCOX, WATER TUBE TYPE, NATURAL GAS OR FUEL OIL FIRED, COEN, MODEL SDAF-14 LOW NO_x BURNER, 19,860,000 BTU PER HOUR WITH A 7-1/2 H.P. COMBUSTION AIR BLOWER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL BE OPERATED IN FULL COMPLIANCE WITH THE APPLICABLE PROVISIONS OF RULE 1146.
[RULE 1146]
5. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING AN EMERGENCY AND REQUIRED TESTING AT WHICH FUEL OIL MAY BE USED.
[RULE 1146]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR, FUEL, AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.
[RULE 1146]
7. THE OWNER OR OPERATOR OF THIS BOILER SHALL MAINTAIN ALL BOILER TUNE-UP RECORDS, AS SPECIFIED IN CONDITION NO. 6 ABOVE FOR A PERIOD OF AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

8. THE EMISSIONS FROM THIS BOILER SHALL NOT EXCEED BY VOLUME ON A DRY BASIS AT 3% O₂, AVERAGED OVER 15 CONSECUTIVE MINUTES:
- A. 400 PPM OF CARBON MONOXIDE.
 - B. 30 PPM OF OXIDES OF NITROGEN WHEN FIRING NATURAL GAS.
 - C. 40 PPM OF OXIDES OF NITROGEN WHEN FIRING FUEL OIL.
- [RULE 1146]

Periodic Monitoring:

9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
- [RULE 3004 (a) (4)]
10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
- [RULE 3004 (a) (4)]
11. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A.. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a) (4)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146, WHEN FIRING NATURAL GAS
NOx: 40 PPMV, RULE 1146, WHEN FIRING FUEL OIL.
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D61321
A/N 222054

Equipment Description:

BOILER NO. 3, BABCOCK AND WILCOX, WATER TUBE TYPE, NATURAL GAS OR FUEL OIL FIRED, COEN, MODEL SDAF-18 LOW NO_x BURNER, 25,700,000 BTU PER HOUR WITH A 7-1/2 H.P. COMBUSTION AIR BLOWER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
[RULE 1146]
4. THIS BOILER SHALL BE OPERATED IN FULL COMPLIANCE WITH THE APPLICABLE PROVISIONS OF RULE 1146.
[RULE 1146]
5. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING AN EMERGENCY AND REQUIRED TESTING AT WHICH FUEL OIL MAY BE USED.
[RULE 1146]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR, FUEL, AND RECIRCULATED FLUE GAS AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.
[RULE 1146]
7. THE OWNER OR OPERATOR OF THIS BOILER SHALL MAINTAIN ALL BOILER TUNE-UP RECORDS, AS SPECIFIED IN CONDITION NO. 6 ABOVE FOR A PERIOD OF AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

8. THE EMISSIONS FROM THIS BOILER SHALL NOT EXCEED BY VOLUME ON A DRY BASIS AT 3% O₂, AVERAGED OVER 15 CONSECUTIVE MINUTES:
- A. 400 PPM OF CARBON MONOXIDE.
 - B. 30 PPM OF OXIDES OF NITROGEN WHEN FIRING NATURAL GAS.
 - C. 40 PPM OF OXIDES OF NITROGEN WHEN FIRING FUEL OIL.
[RULE 1146]

Periodic Monitoring:

9. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a) (4)]
10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a) (4)]
11. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A.. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
 - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a) (4)]

Emissions And Requirements:

12. IF THIS BOILER BURNS MORE THAN 200,000,000,000 (200 BILLION) BTUS OF FUEL IN ANY ONE CALENDAR YEAR, THE BOILER OPERATOR SHALL INSTALL AND OPERATE BY MARCH 1 OF THE FOLLOWING YEAR, AN OXIDES OF NITROGEN CONTINUOUS EMISSION MONITORING SYSTEM THAT IS APPROVED BY THE EXECUTIVE OFFICER IN ACCORDANCE WITH RULE 218(b) AND SHALL CONTINUE TO OPERATE IT FOR THE LIFE OF THE BOILER.
[RULE 1146, 218(b)]

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146, WHEN FIRING NATURAL GAS
NOx: 40 PPMV, RULE 1146, WHEN FIRING FUEL OIL.
CO: 400 PPMV, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D78999
A/N 287673

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. KTA19-G3, SERIAL NO. D930505842, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 685 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D79000
A/N 287674

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. NTA855-G3, SERIAL NO. D930504735, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 535 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]
7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D79001
A/N 287675

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. NTA855-G3, SERIAL NO. D930504736, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 535 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D79002
A/N 287677

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. NTA855-G3, SERIAL NO. D930504733, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 535 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D79003
A/N 287678

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. NTA855-G3, SERIAL NO. D930504734, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 535 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92304
A/N 305182

Equipment Description:

STERILIZER/AERATOR, ETHYLENE OXIDE, AMSCO, MODEL NO. 3017, 1'-3" W. X 2'-8' L. X 1'-5" H. INTERNAL DIMENSION, WITH A COMPRESSED-AIR VENTURI EVACUATION SYSTEM.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 1 LOAD IN ANY ONE DAY.
[RULE 1401]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT AND/OR OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. THIS EQUIPMENT SHALL BE LEAKED CHECKED PER AQMD RULE 1405 (d)(5).
[RULE 1405]
6. ALL RECORDS, SUCH AS OPERATING SCHEDULES AND NUMBER OF BATCHES PROCESSED, SHALL BE MAINTAINED, KEPT ON FILE FOR A MINIMUM OF FIVE YEARS, AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

7. ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92305
A/N 305183

Equipment Description:

STERILIZER/AERATOR, ETHYLENE OXIDE, AMSCO, MODEL NO. 3017, 1'-3" W. X 2'-8' L. X 1'-5" H. INTERNAL DIMENSION, WITH A COMPRESSED-AIR VENTURI EVACUATION SYSTEM.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 1 LOAD IN ANY ONE DAY.
[RULE 1401]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT AND/OR OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. THIS EQUIPMENT SHALL BE LEAKED CHECKED PER AQMD RULE 1405 (d) (5).
[RULE 1405]
6. ALL RECORDS, SUCH AS OPERATING SCHEDULES AND NUMBER OF BATCHES PROCESSED, SHALL BE MAINTAINED, KEPT ON FILE FOR A MINIMUM OF FIVE YEARS, AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

7. ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92306
A/N 305184

Equipment Description:

STERILIZER/AERATOR, ETHYLENE OXIDE, AMSCO, MODEL NO. 3017, 1'-3" W. X 2'-8" L. X 1'-5" H. INTERNAL DIMENSION, WITH A COMPRESSED-AIR VENTURI EVACUATION SYSTEM.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 1 LOAD IN ANY ONE DAY.
[RULE 1401]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT AND/OR OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. THIS EQUIPMENT SHALL BE LEAKED CHECKED PER AQMD RULE 1405 (d) (5).
[RULE 1405]
6. ALL RECORDS, SUCH AS OPERATING SCHEDULES AND NUMBER OF BATCHES PROCESSED, SHALL BE MAINTAINED, KEPT ON FILE FOR A MINIMUM OF FIVE YEARS, AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

7. ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92307
A/N 305185

Equipment Description:

STERILIZER/AERATOR, ETHYLENE OXIDE, AMSCO, MODEL NO. 3017, 1'-3" W. X 2'-8" L. X 1'-5" H. INTERNAL DIMENSION, WITH A COMPRESSED-AIR VENTURI EVACUATION SYSTEM.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 1 LOAD IN ANY ONE DAY.
[RULE 1401]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO CONSTRUCT AND/OR OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1405]
5. THIS EQUIPMENT SHALL BE LEAKED CHECKED PER AQMD RULE 1405 (d) (5).
[RULE 1405]
6. ALL RECORDS, SUCH AS OPERATING SCHEDULES AND NUMBER OF BATCHES PROCESSED, SHALL BE MAINTAINED, KEPT ON FILE FOR A MINIMUM OF FIVE YEARS, AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

7. ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92308
A/N 305186

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER (ETO ABATOR), DONALDSON, 2'-0" W. X 3'-2" L. X 2'-4" H. INTERNAL DIMENSIONS, WITH A PREFILTER, AN ELECTRIC HEATER, AND A HOPCALITE CATALYST BED.
2. EXHAUST SYSTEM WITH A BLOWER, 50 SCFM, VENTING TWO ETHYLENE OXIDE STERILIZERS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OWNER OR OPERATOR OF THE EQUIPMENT SHALL CONDUCT ANNUAL SOURCE TESTS PER AQMD RULE 1405(d) (6).
[RULE 1405]
4. RECORDS SHALL BE MAINTAINED TO SHOW COMPLIANCE WITH THE ABOVE IN A FORMAT APPROVED BY THE AQMD. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

5. ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. D92309
A/N 305187

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER (ETO ABATOR), DONALDSON, 2'-0" W. X 3'-2" L. X 2'-4" H. INTERNAL DIMENSIONS, WITH A PREFILTER, AN ELECTRIC HEATER, AND A HOPCALITE CATALYST BED.
2. EXHAUST SYSTEM WITH A BLOWER, 50 SCFM, VENTING TWO ETHYLENE OXIDE STERILIZERS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OWNER OR OPERATOR OF THE EQUIPMENT SHALL CONDUCT ANNUAL SOURCE TESTS PER AQMD RULE 1405(d) (6).
[RULE 1405]
4. RECORDS SHALL BE MAINTAINED TO SHOW COMPLIANCE WITH THE ABOVE IN A FORMAT APPROVED BY THE AQMD. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 1405]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

5. ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR REQUIREMENTS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

**Permit No. F10118
A/N 322832**

Equipment Description:

STEAM CLEANING UNIT CONSISTING OF:

1. BOILER, HOTSY EQUIPMENT COMPANY, PORTABLE, STEAM CLEANING, MODEL NO. 1240, 420,000 BTU/HR, FUEL OIL.
2. INTERNAL COMBUSTION ENGINE, VANGUARD, 9 HP, DRIVING A 4 GPM PUMP, GASOLINE.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 4 HOURS IN ANY ONE CALENDAR DAY.
[RULE 1303(a) (1)-BACT]
4. AN EQUIPMENT OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME (IN HOURS), AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a) (1)-BACT]

Emissions And Requirements:

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

**Permit No. F19420
A/N 349892**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. KTA19-G3, SERIAL NO. I980801991, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 685 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]
7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F19419
A/N 349893

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. KTA19-G3, SERIAL NO. I980801990, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 685 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F19421
A/N 349894

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. KTA19-G3, SERIAL NO. I980801992, DIESEL-FUELED, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 685 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F98634
A/N 482039

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3412 C DITA, SERIAL NO. 81Z09207, DIESEL-FUELED, 12 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 890 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]

7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. F98635
A/N 483304

Equipment Description:

INTERNAL COMBUSTION ENGINE, ISUZU, EMERGENCY ELECTRICAL GENERATION, MODEL NO. BB-4JG1T, DIESEL-FUELED, 4 CYLINDERS, TURBOCHARGED, 65 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF TWO CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

6. OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304 (a)]
7. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 1470, RULE 431.2]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. G4482
A/N 494126

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QST30-G5, DIESEL-FUELED, 12 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 1,490 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR IN CASE OF AN EMERGENCY.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. THE ENGINES OPERATING UNDER APPLICATION NUMBERS 494126 AND 494131 SHALL NOT BE OPERATED MORE THAN COMBINED 31 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES AND NO MORE THAN 2.58 HOURS IN ANY ONE CALENDAR MONTH FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
6. A CHART RECORDER SHALL BE INSTALLED AND MAINTAINED TO RECORD THE DATE AND TIME THE ENGINES OPERATING UNDER APPLICATION NUMBERS 494126 AND 494131 ARE OPERATED FOR MAINTENANCE AND TESTING IN A CALENDAR MONTH. THE RECORDS SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.

[RULE 1110.2, RULE 1304 (a)]

8. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
- A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1110.2, RULE 1304 (a)]

9. OPERATION OF THE ENGINES OPERATING UNDER APPLICATION NUMBERS 494126 & 494131 BEYOND THE 31 HOURS PER YEAR COMBINED ALLOTTED FOR ENGINES MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1304 (a)]

10. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.

[RULE 1470, RULE 431.2]

11. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

PERMIT TO OPERATE

Permit No. G4483
A/N 494131

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QST30-G5, DIESEL-FUELED, 12 CYLINDERS, TURBOCHARGED, AFTERCOOLED, 1,490 BHP.

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR IN CASE OF AN EMERGENCY.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
4. THE ENGINES OPERATING UNDER APPLICATION NUMBERS 494126 AND 494131 SHALL NOT BE OPERATED MORE THAN COMBINED 31 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES AND NO MORE THAN 2.58 HOURS IN ANY ONE CALENDAR MONTH FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1110.2, RULE 1304 (a), RULE 1470]
5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1304 (a)]
6. A CHART RECORDER SHALL BE INSTALLED AND MAINTAINED TO RECORD THE DATE AND TIME THE ENGINES OPERATING UNDER APPLICATION NUMBERS 494126 AND 494131 ARE OPERATED FOR MAINTENANCE AND TESTING IN A CALENDAR MONTH. THE RECORDS SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1110.2, RULE 1304 (a), RULE 1470]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.

[RULE 1110.2, RULE 1304 (a)]

8. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
- A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1110.2, RULE 1304 (a)]

9. OPERATION OF THE ENGINES OPERATING UNDER APPLICATION NUMBERS 494126 & 494131 BEYOND THE 31 HOURS PER YEAR COMBINED ALLOTTED FOR ENGINES MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1304 (a)]

10. THE ENGINE SHALL MEET ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.

[RULE 1470, RULE 431.2]

11. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

[RULE 1110.2, RULE 1304 (a)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR THE EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statues of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO₂) and be averaged over 15 consecutive minutes; [407]
 - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO₂) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O₂) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
 - a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
 - a. The results of the source test.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief description of the equipment tested.
 - c. Operating conditions under which the test was performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
- (B) The date(s) analyses were performed;
- (C) The company or entity that performed the analyses;
- (D) The analytical techniques or methods used;
- (E) The results of such analyses; and
- (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:

- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 109	5-2-2003	Federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1146	5-13-1994	Federally enforceable
RULE 1303(a)-BACT	5-10-1996	Federally enforceable
RULE 1401	12-7-1990	Non federally enforceable
RULE 1405	1-4-1991	Non federally enforceable
RULE 1470	4-2-2004	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 405	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable

**FACILITY PERMIT TO OPERATE
LONG BEACH MEMORIAL MEDICAL CENTER**

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN
PERMIT PURSUANT TO RULE 219**

NONE

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550		275	
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 06-13-1997]

Except as otherwise provided in Rule 1171, the operator shall not use a solvent to perform solvent cleaning unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS		Effective 1/1/1999	
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application				
(i) General	70 (0.58)			
(ii) Electronic Components or Medical Devices	900 (7.5)	33		
(B) Repair and Maintenance Cleaning				
(i) General	900 (7.5)	20	50 (0.42)	
(ii) Electrical Apparatus Components	900 (7.5)	20		
(iii) Medical Devices	900 (7.5)	33		

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 06-13-1997]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS		Effective 1/1/1999	
	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)
(C) Cleaning of Coatings, or Adhesives Application Equipment	950 (7.9)	35		
(D) Cleaning of Ink Application Equipment				
(i) General	100 (0.83)	3		
(ii) Flexographic or Gravure Printing	100 (0.83)	3		
(iii) Lithographic or Letter Press Printing	900 (7.5)	25		10
(iv) Screen Printing	1070 (8.9)	5		
(v) Ultraviolet Inks (except screen printing)	800 (6.7)	33		
(vi) Specialty Flexographic Printing	810 (6.8)	21		
(E) Cleaning of Polyester Resin Application Equipment	50 (0.42)			
or		1		

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

FACILITY PERMIT TO OPERATE LONG BEACH MEMORIAL MEDICAL CENTER

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

NOTICE OF PROPOSED RENEWAL TITLE V PERMIT

The South Coast Air Quality Management District (AQMD) is proposing to renew the existing Title V permit previously issued to the facility listed below:

Facility Location and Contact Person

LONG BEACH MEMORIAL MEDICAL CENTER
2801 Atlantic Ave
Long Beach, CA 90806
Facility ID 14213

Contact Person:

Doug Budd
Operations Manager
PO Box 1428 N: Engineering
Long Beach, CA 90801-1428

The facility operates 3 steam boilers, 13 emergency diesel generators, and ethylene oxide sterilization equipment, used in the operation of the hospital.

Pursuant to Title V of the federal Clean Air Act and the AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, this facility has submitted a Title V renewal application and requested the AQMD to renew their Title V permits. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to this facility.

The proposed permit is available for public review at the AQMD, 21865 Copley Dr., Diamond Bar, CA, and at the Long Beach Public Library, 101

Pacific Ave, Long Beach, CA 90822. Information regarding the facility owner's compliance history submitted to the AQMD pursuant to California Health & Safety Code Section 42336, or otherwise known to the AQMD based on credible information, is also available from the AQMD for public review. For more information or to review additional supporting documents, call the AQMD's Title V hotline at (909) 396-3013. Written comments should be submitted to Mr. Chris Perri, Air Quality Engineer, 21865 Copley Drive, Diamond Bar, CA 91765-4178. Comments must be received by October 15, 2011. The AQMD will consider all public comments and may revise the Title V permit in accordance with AQMD rules and regulations.

The public may request the AQMD to conduct a public hearing on the proposed permit by submitting a Hearing Request Form (Form 500-G) to Chris Perri at the above AQMD address. The AQMD will hold a public hearing if there is evidence that the proposed permit is not correct or is not adequate to ensure compliance with regulatory requirements, and a hearing will likely provide additional information that will affect the drafting and/or issuance of the permit. Public hearing request forms and the schedule of public hearings may be obtained from the AQMD by calling the Title V hotline at (909) 396-3013, or from the Internet at <http://www.aqmd.gov/titlev>. Requests for public hearings are due by September 30, 2011. A copy of the hearing request must also be sent by first class mail to the appropriate facility contact person listed above.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Title V Permit Summary

AQMD Facility ID:	14213	Company Name:	LONG BEACH MEMORIAL MEDICAL CENTER		
Equipment Location:	2801 ATLANTIC AVE, LONG BEACH, CALIFORNIA 90806			SIC Code: 8060	
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected:			
Application #(s):	525605	Application Submittal Date(s):	07/15/11		
AQMD Contact Person:	CHRIS PERRI	Phone #:	(909) 396-2696	E-Mail Address: cperri@aqmd.gov	
Project Description: This is an existing facility applying for a renewal to their Title V permit. The facility is a hospital providing medical care services. This facility operates 3 natural gas fired boilers, 13 emergency diesel generators, and ethylene oxide sterilizing equipment.					
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal					
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other _____ <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance					
Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for Reporting Year: 2010		<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> The Following TACs Were Reported:		<u>Emissions (lbs/yr):</u>	
		AMMONIA		358.703	
		BENZENE		1.924	
		FORMALDEHYDE		457.007	
		NAPHTHALENE		0.131	
		PAH		0.182	
		1,3 BUTADIENE		0.923	
		CADMIUM		0.006	
		LEAD		0.037	
		ARSENIC		0.007	
		ETHYLENE OXIDE		0.08	
		FLUOROCARBONS		1000	
Health Risk From Toxic Air Contaminants: <input type="checkbox"/> Health Risk Reduction Plan in Force (AQMD Rule 1402) (date): _____ <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input checked="" type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input type="checkbox"/> Final Facility Health Risk Approved Cancer Risk = _____ Acute Hazard Index = _____ Chronic Hazard Index = _____					
Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2010		<input checked="" type="checkbox"/> NOx	2.468	<input checked="" type="checkbox"/> PM	3.901
		<input checked="" type="checkbox"/> CO	1.372	<input checked="" type="checkbox"/> SOx	0.049
		<input checked="" type="checkbox"/> VOC	2.301	<input type="checkbox"/> Other:	_____
Compliance History: <input checked="" type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years (0) <input checked="" type="checkbox"/> Notices to Comply Issued in Last Two Calendar Years (0) <input checked="" type="checkbox"/> Notices of Violation Issued in Last Two Calendar Years (0)					
Comments: None					

South Coast Air Quality Management District

Statement of Basis

Proposed Title V Renewal Permit

Facility Name:	Long Beach Memorial Medical Center
Facility ID:	14213
SIC Code:	8060
Equipment Location:	2801 Atlantic Ave Long Beach, CA 90806
Application #(s):	525605
Application Submittal Date(s):	07/15/11
AQMD Contact Person:	Chris Perri, Air Quality Engineer
Phone Number:	(909) 396-2696
E-Mail Address:	cperri@aqmd.gov

1. Introduction and Scope of Permit

Title V is a national operating permit program for air pollution sources. Facilities subject to Title V must obtain a Title V permit and comply with specific Title V procedures to modify the permit. This permit replaces the facility's other existing permits. Title V does not necessarily include any new requirements for reducing emissions. It does, however, include new permitting, noticing, record keeping, and reporting requirements.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years after the date of issuance, unless such permit has been renewed. Accordingly, each facility is required to submit a Title V renewal application and request that the AQMD renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The AQMD implements Title V through Regulation XXX – Title V Permits, adopted by the AQMD Governing Board in order to comply with EPA's requirement that local air permitting authorities develop a Title V program. Regulation XXX was developed with the participation of the public and affected facilities through a series of public workshops, working group meetings, public hearings and other meetings.

The Title V major source threshold for a particular pollutant depends on the attainment status of the pollutant. NO₂, SO₂, CO, and lead are in attainment with federal standards. The status for

PM-10 is serious nonattainment. The status for ozone is currently extreme nonattainment. For the South Coast Air Basin (SOCAB) the threshold levels are as follows:

Pollutant	SOCAB Major Source Thresholds
VOC	10
NOx	10
SOx	100
CO	50
PM-10	70
Single HAP	10
Combination of HAPS	25

A Title V permit is proposed to be issued to cover the operations of the Long Beach Memorial Medical Center, located at 2801 Atlantic Ave in Long Beach. This facility is subject to Title V requirements because it is a major source of one of more criteria pollutants.

2. Facility Description

This is an existing hospital and medical care services facility. The facility operates 3 boilers to provide heating and cooling for the buildings, 13 emergency back up diesel generators, and ethylene oxide sterilizing equipment. All the boilers are natural gas-fired (with oil back-up). The 2 smaller units are scheduled to meet a 9 ppm NOx limit by 2013 in accordance with Rule 1146. The facility has an approved Rule 1146 plan for these units under A/N 519073. The facility has recently submitted a revised Rule 1146 plan for the larger unit (A/N 525727), and is proposing to replace the burner in the unit to reduce the rating and meet a 9 ppm NOx level. The diesel generators are of various sizes. The facility has NOT submitted a Rule 1470 plan for the engines.

3. Construction and Permitting History

The Long Beach Memorial Medical Center has been in Southern California for over 100 years. The facility has had permits from AQMD since the early 1970's. As the facility has grown, it's added heating and cooling capacity in the form of boilers, and emergency backup power in the form of diesel generators. The initial Title V permit was issued on 5/25/05. Since the permit was issued, there have been 2 permit revisions, both minor revisions to add emergency generators.

4. Regulatory Applicability Determinations

Applicable legal requirements for this facility are required to be identified in the Title V permit (for example, Section D, E, and H of the proposed Title V permit). Applicability determinations (i.e., determinations made by the District with respect to what legal requirements apply to a specific piece of equipment, process, or operation) can be found in the Engineering Evaluations.

The following summarizes the key rules that apply to the major equipment at this site:

Boilers

- 401 – Visible Emissions
- 402 – Nuisance
- 407 – Liquid and Gaseous Air Contaminants (CO and SO_x)
- 409 – Combustion Contaminants (PM)
- 431.1 – Sulfur Content of Gaseous Fuel (SO_x)
- 1146 – NO_x from Boilers

Emergency Engines

- 401 – Visible Emissions
- 402 - Nuisance
- 404 – Particulate Matter
- 431.2 – Sulfur Content of Liquid Fuels
- Rule 1470 – Air Toxic Control Measure

Sterilizers

- 1405 – Control of Ethylene Oxide from Sterilizers

The facility is not a major source of HAPs and therefore is not subject to any MACT standards. There are no area source MACT standards which apply to this facility. Compliance Assurance Monitoring (CAM) requirements of 40 CFR Part 64 do not apply to any of the equipment at this site.

The permit terms and conditions may be found in Section D of the Title V permit.

5. Monitoring and Operational Requirements

Applicable monitoring and operational requirements for which the facility is required to comply are identified in the Title V permit (for example, Section D, F, and J, and Appendix B). Discussion of any applicable monitoring and operational requirements can be found in the Engineering Evaluations. All periodic monitoring requirements were developed using strict adherence to the following applicable guidance documents: SCAQMD Periodic Monitoring Guidelines for Title V Facilities (November 1997), CAPCOA/CARB/EPA region IX Periodic Monitoring Recommendations for Generally Applicable Requirements in SIP (June 1999), and CAPCOA/CARB/EPA Region IX Recommended Periodic Monitoring for Generally Applicable Grain Loading Standards in the SIP: Combustion Sources (July 2001).

Under Rule 1146, a stack test for NO_x and CO on the boilers is required once every 5 years, and periodic testing with portable analyzers is required every 2000 operating hours.

Detailed discussion of any applicable monitoring and operational requirements can be found in the Engineering Evaluations.

6. Permit Features

Permit Shield

A permit shield is an optional part of a Title V permit that gives the facility explicit protection from requirements that may be incorrectly specified in the permit. A permit shield is a provision in a permit that states that compliance with the conditions contained in the permit shall be deemed compliance with all identified regulatory requirements. To incorporate a permit shield into the Title V permit involves submission of applications for change of conditions for each equipment affected by the permit shield. Permit shields are addressed in Rule 3004 (c). This facility has not applied for a permit shield.

Streamlining Requirements

Some emission units may be subject to multiple requirements which are closely related or redundant. The conditions may be streamlined to simplify the permit conditions and compliance. Emission limits, work practice standards, and monitoring, recordkeeping, and reporting requirements may be streamlined. Compliance with a streamlined condition will be deemed compliance with the underlying requirements whether or not the emission unit is actually in compliance with the specific underlying requirement. This facility has not applied for any streamlined conditions.

7. Summary of Emissions and Health Risks

Criteria Pollutant Emissions (tons/year) Annual Reported Emissions for Reporting Period 2010

Pollutant	Emissions (tons/year)
NOx	2.468
CO	1.372
VOC	2.301
PM	3.901
SOx	0.049

Toxic Air Contaminants Emissions (TAC) Annual Reported Emissions for Reporting Period 2010

The Following TACs Were Reported	Emissions (lbs/yr)
1,3 Butadiene	0.923
Ammonia	358.703
Benzene	1.924
Formaldehyde	457.007
Cadmium	0.006
Lead	0.037
Naphthalene	0.131
Nickel	0.018

Polynuclear aromatic hydrocarbons (PAHs)	0.182
Arsenic	0.007
Ethylene Oxide	0.08
Fluorocarbons	1000

Health Risk from Toxic Air Contaminants

The facility is subject to review by the Air Toxics Information and Assessment Act (AB2588). However, the toxic emissions from this facility are low, and it is categorized as a facility that is being tracked, therefore, no risk assessment has been performed at this time.

8. Compliance History

As noted, the facility has been in constant operation for over 100 years. The facility has been subject to both self-reporting requirements and AQMD inspections. The facility has had 0 citizen complaints filed, 0 Notices to Comply issued, and 0 Notices of Violation issued in the last two calendar years.

9. Compliance Certification

By virtue of the Title V permit application and renewal of this permit, the reporting frequency for compliance certification for the facility shall be annual.



South Coast Air Quality Management District
Form 400-A
Application Form for Permit or Plan Approval
 List only one piece of equipment or process per form.

Mail To:
 SCAQMD
 P.O. Box 4944
 Diamond Bar, CA 91765-0944
 Tel: (909) 396-3385
 www.aqmd.gov

Section A - Operator Information

1. Facility Name (Business Name of Operator to Appear on the Permit): LONG BEACH MEMORIAL MEDICAL CENTER	2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 014213
3. Owner's Business Name (If different from Business Name of Operator):	

Section B - Equipment Location Address

4. Equipment Location Is: Fixed Location Various Location
 (For equipment operated at various locations, provide address of initial site.)

2801 ATLANTIC AVENUE
 Street Address
LONG BEACH, CA 90806
 City Zip
DOUG BUDD OPERATION MANAGER
 Contact Name Title
(562) 933-0565 (562) 933-0569
 Phone # Ext. Fax #
 E-Mail: **DBudd@MemorialCare.org**

Section C - Permit Mailing Address

5. Permit and Correspondence Information:
 Check here if same as equipment location address

PO BOX 1428 N: ENGINEERING
 Address
LONG BEACH, CA 90801-1428
 City State Zip
DOUG BUDD OPERATION MANAGER
 Contact Name Title
(562) 933-0565 (562) 933-0569
 Phone # Ext. Fax #
 E-Mail: **DBudd@MemorialCare.org**

Section D - Application Type

6. The Facility Is: Not In RECLAIM or Title V In RECLAIM In Title V In RECLAIM & Title V Programs

7. Reason for Submitting Application (Select only ONE):

<p>7a. New Equipment or Process Application:</p> <input type="radio"/> New Construction (Permit to Construct) <input type="radio"/> Equipment On-Site But Not Constructed or Operational <input type="radio"/> Equipment Operating Without A Permit * <input type="radio"/> Compliance Plan <input type="radio"/> Registration/Certification <input type="radio"/> Streamlined Standard Permit	<p>7c. Equipment or Process with an Existing/Previous Application or Permit:</p> <input type="radio"/> Administrative Change <input type="radio"/> Alteration/Modification <input type="radio"/> Alteration/Modification without Prior Approval * <input type="radio"/> Change of Condition <input type="radio"/> Change of Condition without Prior Approval * <input type="radio"/> Change of Location <input type="radio"/> Change of Location without Prior Approval * <input type="radio"/> Equipment Operating with an Expired/Inactive Permit *	<p>Existing or Previous Permit/Application If you checked any of the items in 7c., you MUST provide an existing Permit or Application Number: _____</p>
<p>7b. Facility Permits:</p> <input checked="" type="radio"/> Title V Application or Amendment (Also submit Form 500-A1) <input type="radio"/> RECLAIM Facility Permit Amendment	<p>* A Higher Permit Processing Fee and additional Annual Operating Fees (up to 3 full years) may apply (Rule 301(c)(1)(D)(i)).</p>	

8a. Estimated Start Date of Construction (mm/dd/yyyy): _____ 8b. Estimated End Date of Construction (mm/dd/yyyy): _____ 8c. Estimated Start Date of Operation (mm/dd/yyyy): _____

9. Description of Equipment or Reason for Compliance Plan (list applicable rule):
TITLE V RENEWAL

10. For identical equipment, how many additional applications are being submitted with this application? (Form 400-A required for each equipment / process) **0**

11. Are you a Small Business as per AQMD's Rule 102 definition? (10 employees or less and total gross receipts are \$500,000 or less OR a not-for-profit training center) No Yes

12. Has a Notice of Violation (NOV) or a Notice to Comply (NC) been issued for this equipment? No Yes
 If Yes, provide NOV/NC#: _____

Section E - Facility Business Information

13. What type of business is being conducted at this equipment location?
HOSPITAL

14. What is your business primary NAICS Code? (North American Industrial Classification System) **622110**

15. Are there other facilities in the SCAQMD jurisdiction operated by the same operator? No Yes

16. Are there any schools (K-12) within 1000 feet of the facility property line? No Yes

Section F - Authorization/Signature I hereby certify that all information contained herein and information submitted with this application are true and correct.

17. Signature of Responsible Official: _____ 18. Title of Responsible Official: **VICE PRESIDENT, FACILITIE**

19. I wish to review the permit prior to issuance. (This may cause a delay in the application process.) No Yes

20. Print Name: **GLENN CRABTREE** 21. Date: _____ 22. Do you claim confidentiality of data? (If Yes, see instructions.) No Yes

23. Check List: Authorized Signature/Date Form 400-CEQA Supplemental Form(s) (ie., Form 400-E-xx) Fees Enclosed

AQMD USE ONLY	APPLICATION TRACKING # 585605	CHECK # 856169	AMOUNT RECEIVED \$ 6462.90	PAYMENT TRACKING #	VALIDATION 7/15/10			
DATE 8-16-10	APP. DATE REJ	APP. REJ	CLASS I III	BASIC CONTROL	EQUIPMENT CATEGORY CODE 555002	TEAM EV	ENGINEER	REASON/ACTION TAKEN

© South Coast Air Quality Management District, Form 400-A (2009.04)

1984.24

07 95877

6/06