

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING AND COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES	PAGE
	3	1
	APPL. NO.	DATE
	503109	6/11/2010
	PROCESSED BY	CHECKED BY
	MV02	

EVALUATION REPORT FOR TITLE V FACILITY PERMIT REVISION
Revision No. 11

APPLICANT'S NAME: University of California, Los Angeles (Facility ID No. 18452)

MAILING ADDRESS: 501 Westwood Plaza P O Box 951605
Los Angeles, CA 90095-1605

EQUIPMENT LOCATION: Refer to Individual Applications

EQUIPMENT DESCRIPTION:

TITLE V FACILITY PERMIT REVISION (Minor)

HISTORY/PROCESS DESCRIPTION:

University of California, Los Angeles (facility id # 18452) is requesting to modify its Title V facility permit by adding two emergency internal combustion engines (A/N's 503209 and 503210) to the facility permit and removing two existing engines (A/N's 293497 and 378961). UCLA bought the 100 Medical Plaza building which used to be owned and operated by a group of doctors (Fac. ID 084485). The Medical Plaza building is located in the UCLA campus. The change of ownership of the two engines will be incorporated in the university's Title V facility permit under application 503109 which was submitted on Oct. 16, 2009. The removal of the two engines will also be included in this revision.

Attached are the drafts of Sections D and K and Appendix B in the facility permit which are affected by the changes. The following is a summary of the changes in the facility permit that will be completed in relation to this application:

ITEM	CHANGES
A/N's 503209 and 503210	Added to the facility permit.
A/N's 293497 and 378961	Deleted from the facility permit.
Section K	Updated with the most recent rule amendments.
Appendix B	Updated with the most recent rule amendments.

The modification is classified as a "minor permit revision" to the Title V permit because the proposed change of ownership of the engines and removal of two engines do not result in any emission increase. The proposed transfer of ownership complies with all air pollution requirements and permits to operate are recommended to be issued. The permit evaluations are attached.

Compliance staff last inspected the UCLA campus in August, 2009 (see equipment list report). Notice of Violation P55181 was issued during this inspection. The university has achieved compliance with the violation notice.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING AND COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES	PAGE
	3	2
	APPL. NO.	DATE
	503109	6/11/2010
	PROCESSED BY	CHECKED BY
	MV02	

EMISSION CALCULATIONS :

Refer to the attached evaluation reports for A/N's 503209 and 503210. There are no emission increases because the proposed revisions are for change of operator only. The operating parameters for the two engines remain the same as in the previous applications.

RULES EVALUATION:

Refer to the evaluation files for A/N's 503209 and 503210.

RULE 2001 (Regional Clean Air Incentives Market) :

The facility is exempt from the requirements per Rule 2001(i)(2)(H), which is the exemption from the Regional Clean Air Incentives Market program for schools or universities.

Regulation XXX (Title V Permits) :

University of California, Los Angeles is included in Phase I of the Title V universe. The initial Title V permit, A/N 339402 was issued on 09/28/2001. The Title V facility permit has undergone ten revisions since. These permit revisions are as follows :

Application No. (Revision No.)	Issue Date
409787 (1)	04/11/2003
415230 (2)	08/13/2003
429612 (3)	09/20/2005
447309 (4)	01/18/2006
448153 (5)	04/07/2006
455049 (6)	01/10/2007
455619 (7, Permit Renewal 1)	12/12/2007
474127 (8)	05/16/2008
482480 (9)	09/19/2008
498785 (10)	07/29/2009

This proposed modification to the Title V facility permit complies with the following:

Rule 3000:

The subject application qualifies as a minor permit revision since it meets the criteria set forth in section (b)(12).

Rule 3003:

The "minor permit revision" is expected to comply with all applicable requirements of this rule as follows :

Rule 3003(i)(4) – The permit revision will be issued only after the permit revision application has been found to comply with all requirements of this section.

Rule 3003(j) – The proposed permit revision is expected to comply with all requirements of this section.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT <i>ENGINEERING AND COMPLIANCE</i> APPLICATION PROCESSING AND CALCULATIONS	PAGES	PAGE
	3	3
	APPL. NO.	DATE
	503109	6/11/2010
	PROCESSED BY	CHECKED BY
	MV02	

Rule 3005(c)(1) :

This proposed Title V permit revision brought about by the change of ownership of two emergency internal combustion engines with A/N's 503209 and 503210 and removal of the engines under A/N's 293497 and 378961 satisfies all the applicable requirements of this section. This modification constitutes a "minor permit revision" because there are no emission increases associated with the proposed changes.

Rule 3006(a):

This proposed "minor permit revision" is exempt from the requirements of this section per Rule 3006(b).

CONCLUSIONS & RECOMMENDATIONS:

The application is expected to comply with all applicable District Rules and Regulations. The issuance of a revised Title V facility permit incorporating the change of ownership of two emergency internal combustion (A/N's 503209 and 503210) and removal of engine A/N's 293497 and 378961, is recommended. The attached draft permit includes the updates in sections D and K and appendix B resulting from these changes.