

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. TBD
A/N 512830

Equipment Description:

STORAGE TANK, FIXED ROOF, ID NO. 10ITNK037 (P1 HEADWORKS), HYDROCHLORIC ACID, 12' - 0" DIA. X 10' - 0" H., 8,000-GALLON CAPACITY AND VENTING THROUGH A 55-GALLON DRUM CONTAINING (50% SULPHASORB XL AND 50% SAFETYSORB BLEND OR EQUAL) ACTIVATED CARBON.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL STORE HYDROCHLORIC ACID WITH CONCENTRATION OF 38 WEIGHT PERCENT OR LESS ONLY.
[RULE 204]
4. THE MAXIMUM AMOUNT OF HYDROCHLORIC ACID FILLED INTO THIS STORAGE TANK SHALL NOT EXCEED 2,000 GALLONS PER MONTH.
[RULE 1303 (b) (1) - OFFSET]
5. THIS EQUIPMENT SHALL NOT BE FILLED UNLESS THE VENT GASES PASS THROUGH A 55-GALLON DRUM CONTAINING ACTIVATED CARBON.
[RULE 1303 (a) (1)-BACT]
6. THE OPERATOR SHALL REPLACE THE CARBON PER MANUFACTURER'S RECOMMENDATION.
[RULE 204]
7. RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. TBD
A/N 512831

Equipment Description:

STORAGE TANK, FIXED ROOF, ID NO. 11ITNK100 (P1 PRIMARY), HYDROCHLORIC ACID, 6' - 0" DIA. X 11' - 0" H., 2,000-GALLON CAPACITY AND VENTING THROUGH A 55-GALLON DRUM CONTAINING (50% SULPHASORB XL AND 50% SAFETYSORB BLEND OR EQUAL) ACTIVATED CARBON.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL STORE HYDROCHLORIC ACID WITH CONCENTRATION OF 38 WEIGHT PERCENT OR LESS ONLY.
[RULE 204]
4. THE MAXIMUM AMOUNT OF HYDROCHLORIC ACID FILLED INTO THIS STORAGE TANK SHALL NOT EXCEED 2,000 GALLONS PER MONTH.
[RULE 1303 (b) (1) - OFFSET]
5. THIS EQUIPMENT SHALL NOT BE FILLED UNLESS THE VENT GASES PASS THROUGH A 55-GALLON DRUM CONTAINING ACTIVATED CARBON.
[RULE 1303 (a) (1)-BACT]
6. THE OPERATOR SHALL REPLACE THE CARBON PER MANUFACTURER'S RECOMMENDATION.
[RULE 204]
7. RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]