

DATE

09-E CAB
File No. 0030

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
(XXX)

Mr. Michael P. Ribao
Manager, Power Supply
Maui Electric Company, Ltd.
P.O. Box 398
Kahului, Hawaii 96732

Dear Mr. Ribao:

Subject: Amendment to Covered Source Permit (CSP) No. 0030-06-C
Minor Modification Application No. 0030-09
Maui Electric Company, Ltd. (MECO)
Miki Basin Generating Station
Eight (8) Diesel Engine Generators
Located at: Miki Basin, Lanai
Date of Expiration: October 7, 2013

In accordance with Hawaii Administrative Rules, Chapter 11-60.1, and pursuant to your November 3, 2008 minor modification application, the Department of Health hereby amends Covered Source Permit (CSP) No. 0030-06-C, issued to Maui Electric Company, Ltd. on October 8, 2008. The amendment adds an alternate operating scenario to allow the use of EMD 645 series components as replacement parts in the existing EMD 567 series diesel engine generators.

The following permit condition shall be added to Attachment IIA, Section B.6.a of CSP No. 0030-06-C issued on October 8, 2008:

- 3) The permittee may overhaul the existing EMD 567 series DEG's with EMD 645 series components provided the following conditions are met:
 - a) Written notification shall be provided to the Department of Health prior to any overhaul identifying the unit to be overhauled and the estimated time for the overhaul to be completed. A notification of completion shall also be submitted within fifteen (15) days after the startup of the overhauled engine.

PROPOSED

Mr. Michael P. Ribao
DATE
Page 2

- b) The overhauled DEG complies with all applicable permit conditions, including all air pollution control equipment requirements, operating restrictions, emission limits, and emission rates.
- c) A performance test on the overhauled diesel engine generator shall be conducted within 180 days after the startup of the overhauled DEG to verify compliance with the emission limits in Attachment IIA, Section B.3. Testing shall be performed in accordance with Attachment IIA, Section E, Testing Requirements.

All other permit conditions of CSP No. 0030-06-C, issued on October 8, 2008 shall not be affected and shall remain valid.

If you have any questions regarding this matter, please contact Mr. Kevin Kihara of the Clean Air Branch at (808) 586-4200.

Sincerely,

THOMAS E. ARIZUMI, P.E., CHIEF
Environmental Management Division

KK:nn

c: CAB Monitoring Section
Blake Shiigi, EHS-Maui