

**FACILITY PERMIT TO OPERATE
LOS ANGELES COUNTY SHERIFF'S DEPARTMENT**

**Facility Equipment and Requirements
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

**FACILITY PERMIT TO OPERATE
LOS ANGELES COUNTY SHERIFF'S DEPARTMENT**

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

| Application number | Permit to Operate number | Equipment description |
|---------------------------|---------------------------------|--|
| 256694 | D72328 | BOILER (>20-50 MMBTU/HR) COMB GAS-DISTIL |
| 256695 | D72329 | BOILER (>20-50 MMBTU/HR) COMB GAS-DISTIL |
| 385186 | F39236 | ICE (>500 BHP) EM ELEC GEN, DIESEL |
| 385187 | F39230 | ICE (>500 BHP) EM ELEC GEN, DIESEL |
| 469550 | N19540 | SERV STAT STORAGE & DISPENSING GASOLINE |
| 513816 | TBD | ICE (>500 BHP) EM ELEC GEN, DIESEL |

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGLEMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]
2. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT.
[RULE 431.2]
3. THE OPERATOR SHALL NOT USE OR SELL GASEOUS FUEL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPM CALCULATED AS HYDROGEN SULFIDE AVERAGED OVER FOUR HOURS.
[RULE 431.1]

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

PERMIT TO OPERATE

Permit No. D72328
A/N 256694

Equipment Description:

BOILER, MURRAY IRON WORKS, WATER TUBE TYPE, WITH A COEN DAF MODEL D 1920, LOW NOX, 39,500,000 BTU/HR, NATURAL GAS OR FUEL OIL BURNER, A 40 HP COMBUSTION AIR BLOWER, AND A FORCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL- BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, DURING MAINTENANCE TESTING WITH THE STAND BY FUEL NOT TO EXCEED 1/2 HOUR PER MONTH, AND DURING COMPLIANCE TESTING.
[RULE 1303(a)(1)-BACT, RULE 1146, RULE 431.1]
4. THIS BOILER SHALL BE OPERATED IN FULL COMPLIANCE WITH THE APPLICABLE PROVISIONS OF RULE 1146.
[RULE 1146]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE AMOUNT OF FLUE GAS RECIRCULATED FROM THE EXHAUST STACK TO THE BURNER.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
6. THE FLUE GAS RECIRCULATION SYSTEM (FGR) SHALL RECIRCULATE AT LEAST 12% OF THE FLUE GAS FROM THE EXHAUST STACK TO THE BURNER OF THE BOILER, WHENEVER THE BOILER IS OPERATING BETWEEN 10% THROUGH 100% LOAD.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
7. THE FGR SHALL BE IN USE WHENEVER THE BOILER LOAD IS 10% OR GREATER.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
8. THE LOW NOX BOILER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR, ACCORDING TO THE MANUFACTURERS SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]

9. THE OWNER OR OPERATOR OF THIS BOILER SHALL MAINTAIN ALL BOILER TUNE-UP RECORDS, AS SPECIFIED IN CONDITION 9 ABOVE FOR A PERIOD OF AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
10. THE OWNER OR OPERATOR OF THIS BOILER SHALL ARRANGE FOR A CERTIFIED BOILER TECHNICIAN TO PERFORM TWICE YEARLY BOILER TUNE-UPS IN ACCORDANCE WITH "ATTACHMENT 1" OF RULE 1146. THE BOILER TUNE-UP RECORDS SHALL BE MAINTAINED FOR A PERIOD OF AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1146]

Periodic Monitoring:

11. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
 - A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT OR
 - B. HAVE A CARD-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
 - D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004(a)(4)]
12. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 5.2. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTION E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTES TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

- 13 FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions and Requirements

- 14 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS.

NOX: 30 PPMV, RULE 1146 [FOR NATURAL GAS]
NOX: 40 PPM, RULE 1146 [FOR FUEL OIL]
CO: 400 PPM, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

PERMIT TO OPERATE

Permit No. D72329
A/N 256695

Equipment Description:

BOILER, MURRAY IRON WORKS, WATER TUBE TYPE, WITH A COEN DAF MODEL D 1920, LOW NOX, 39,500,000 BTU/HR, NATURAL GAS OR FUEL OIL BURNER, A 40 HP COMBUSTION AIR BLOWER, AND A FORCED FLUE GAS RECIRCULATION SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL- BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY, EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, DURING MAINTENANCE TESTING WITH THE STAND BY FUEL NOT TO EXCEED 1/2 HOUR PER MONTH, AND DURING COMPLIANCE TESTING.
[RULE 1303(a)(1)-BACT, RULE 1146, RULE 431.1]
4. THIS BOILER SHALL BE OPERATED IN FULL COMPLIANCE WITH THE APPLICABLE PROVISIONS OF RULE 1146.
[RULE 1146]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE AMOUNT OF FLUE GAS RECIRCULATED FROM THE EXHAUST STACK TO THE BURNER.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
6. THE FLUE GAS RECIRCULATION SYSTEM (FGR) SHALL RECIRCULATE AT LEAST 12% OF THE FLUE GAS FROM THE EXHAUST STACK TO THE BURNER OF THE BOILER, WHENEVER THE BOILER IS OPERATING BETWEEN 10% THROUGH 100% LOAD.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
7. THE FGR SHALL BE IN USE WHENEVER THE BOILER LOAD IS 10% OR GREATER.
[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]
8. THE LOW NOX BOILER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR, ACCORDING TO THE MANUFACTURERS SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]

9. THE OWNER OR OPERATOR OF THIS BOILER SHALL MAINTAIN ALL BOILER TUNE-UP RECORDS, AS SPECIFIED IN CONDITION 9 ABOVE FOR A PERIOD OF AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

[RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT, RULE 1146]

10. THE OWNER OR OPERATOR OF THIS BOILER SHALL ARRANGE FOR A CERTIFIED BOILER TECHNICIAN TO PERFORM TWICE YEARLY BOILER TUNE-UPS IN ACCORDANCE WITH "ATTACHMENT 1" OF RULE 1146. THE BOILER TUNE-UP RECORDS SHALL BE MAINTAINED FOR A PERIOD OF AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1146]

Periodic Monitoring:

11. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF DIESEL FUEL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:

- C. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT OR
- D. HAVE A CARD-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- E. STACK OR EMISSION POINT IDENTIFICATION;
- F. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- G. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- H. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004(a)(4)]

12. IF ANNUAL FUEL OIL USAGE EXCEEDS 2,000,000 GALLONS IN ANY ONE YEAR, THEN OPERATOR SHALL DETERMINE COMPLIANCE WITH THE PARTICULATE MATTER (PM) EMISSION LIMIT(S) BY CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 5.2. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 409 LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTION E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 409 LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTES TIME PERIOD.

THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

B. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

- 13 FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

B. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

Emissions and Requirements

- 14 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS.

NOX: 30 PPMV, RULE 1146 [FOR NATURAL GAS]
NOX: 40 PPM, RULE 1146 [FOR FUEL OIL]
CO: 400 PPM, RULE 1146
CO: 2000 PPMV, RULE 407
PM: 0.1 GR/SCF, RULE 409

**FACILITY PERMIT TO OPERATE
LOS ANGELES COUNTY SHERIFF'S DEPARTMENT**

PERMIT TO OPERATE

**Permit No. F39236
A/N 385186**

Equipment Description:

INTERNAL COMBUSTION ENGINE, WAUKESHA, MODEL NO. VLRDU, SERIAL NO. RU-12535, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, 12 CYLINDERS, TURBOCHARGED, 680 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATOR SHALL ONLY USE DIESEL FUEL WITH A SULFUR CONTENT THAT DOES NOT EXCEED 15 PPM BY WEIGHT.
[RULE 431.2, RULE 1470]
4. THIS ENGINE SHALL NOT OPERATE FOR MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1304(a)(1)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THEN TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304(a)(1)-MODELING AND OFFSET, RULE 1470]

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

7. THE ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

8. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004(A)(4)]

Emissions and Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

PERMIT TO OPERATE

Permit No. F39230
A/N 385187

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL NO. 9123-7305, SERIAL NO. 12E-2183, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, 12 CYLINDERS, TURBOCHARGED, 1020 BHP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATOR SHALL ONLY USE DIESEL FUEL WITH A SULFUR CONTENT THAT DOES NOT EXCEED 15 PPM BY WEIGHT.
[RULE 431.2, RULE 1470]
4. THIS ENGINE SHALL NOT OPERATE FOR MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.
[RULE 1304(a)(1)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THEN TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
[RULE 1304(a)(1)-MODELING AND OFFSET, RULE 1470]

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

7. THE ENGINE SHALL COMPLY WITH APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

Periodic Monitoring:

8. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.
[RULE 3004(A)(4)]

Emissions and Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

PERMIT TO OPERATE

Permit No. N19540
A/N 469550

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY CONSISTING OF

1. 2 - GASOLINE BELLOWS-LESS NOZZLES DISPENSING 2 PRODUCTS EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM. HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-A/C).
2. 1 - GASOLINE UNDERGROUND STORAGE TANK, 12,000 GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM OPW (VR-102-E/H), 1 METHANOL COMPATIBLE

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS
[RULE 461]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.1.
[RULE 461]
5. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS
[RULE 461, RULE 1303(a)(1) - BACT]
6. NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED, SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE. COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS EQUIPMENT. PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER.
[RULE 461]

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

7. DEPENDING ON THE SYSTEM CONFIGURATION, A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL, OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE. EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP-201 IC OR TP-201 ID, RESPECTIVELY. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
8. A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN THIRTY DAYS (30) AFTER THE START OF OPERATION OF THE OPW PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TO-201 1E. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 461]
9. A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201 1B AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.
[RULE 461]
10. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE RISER, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURE DESCRIBED BY THE CALIFORNIA AIR RESOURCE BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED.

NITROGEN FLOWRATES
(CFH)
60

DYNAMIC BACK PRESSURE
(INCHES OF WATER)
0.50

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201 4, METHODOLOGY 4 AND 6, AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY TWO (72) HOURS OF TESTS.
[RULE 461]

**FACILITY PERMIT TO OPERATE
LOS ANGELES COUNTY SHERIFF'S DEPARTMENT**

11. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201 3 AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY TWO (72) HOURS OF TESTS.
[RULE 461]

12. A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201-C. AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY TWO (72) HOURS OF TESTS.
[RULE 461]

13. A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER VR-201-C. AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY TWO (72) HOURS OF TESTS.
[RULE 461]

14. A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR-201-C. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY TWO (72) HOURS OF TESTS.
[RULE 461]

15. THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR, THE NAME OF THE CONTRACTOR, THE LOCATION OF THE FACILITY, AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED.
[RULE 461]

16. THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT
[RULE 461]

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

17. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FOUR YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 461]
18. FOR ISD REQUIREMENTS ONLY, THIS FACILITY SHALL NOT DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE PER CALENDAR YEAR. SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE PER CALENDAR YEAR, THE OPERATOR SHALL IMMEDIATELY CEASE ALL GASOLINE DISPENSING OPERATIONS AND FILE AN APPLICATION FOR A PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. GASOLINE DISPENSING OPERATIONS SHALL NOT RESUME UNTIL THE ISD SYSTEM HAS BEEN GRANTED A PERMIT TO CONSTRUCT/OPERATE AND FULLY INSTALLED.
[RULE 461]
19. THE MAXIMUM QUANTITY OF GASOLINE DISPENSED FROM THE STORAGE TANKS AT THE FACILITY SHALL NOT EXCEED 27,375 GALLONS IN ANY ONE CALENDAR MONTH OR 328,500 GALLONS IN ANY CALENDAR YEAR.
[RULE 461]

Periodic Monitoring:

20. RECORDS OF MONTHLY AND ANNUAL FUEL DISPENSED SHALL BE PREPARED, SHALL BE RETAINED ON SITE FOR TWO YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 3004(A)(4)]

Emissions and Requirements:

21. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 461

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

PERMIT TO OPERATE

Permit No.
A/N 513816

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, ENGINE MODEL NO. QSK23-G7NR2, SERIAL NO. 00322291, SIX CYLINDERS, TURBOCHARGED/AFTERCOOLED, RATED AT 1220 B.H.P., DRIVING AN EMERGENCY ELECTRICAL GENERATOR RATED AT 750KW, WITH A JOHNSON MATTHEY PARTICULATE FILTER SYSTEM, PART NUMBER CRT(+)-4-C-BITO-CS-12-LP.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING AND NO MORE.
[RULE 1304, RULE 1470]
4. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]
5. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1470]
6. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
- B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1470]

- 7. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE
 - B. MAINTENANCE AND TESTING
 - C. OTHER (BE SPECIFIC).

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.
[RULE 1470]

- 8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470. THE SULFUR CONTENT OF DIESEL FUEL SUPPLIED TO THE ENGINE SHALL NOT EXCEED 15 PPM BY WEIGHT.
[RULE 431.2, RULE 1470]
- 9. THIS ENGINE SHALL NOT BE OPERATED UNLESS ITS EXHAUST IS VENTED TO THE DIESEL PARTICULATE FILTER WHICH SHALL BE IN FULL OPERATION AND IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 1303-BACT]
- 10. THIS ENGINE SHALL OPERATE AT THE LOAD LEVEL REQUIRED TO ACHIEVE A MINIMUM EXHAUST TEMPERATURE (FOR FILTER REGENERATION) OF 240 DEGREES CELSIUS (464 DEGREES FAHRENHEIT) FOR A MINIMUM OF 40% OF THE ENGINE'S OPERATING TIME.
[RULE 1303-BACT]
- 11. REGENERATION OF THE CATALYST SHALL BE PERFORMED AFTER 24 CONSECUTIVE COLD START-UPS AND 30-MINUTE IDLE SESSIONS.
[RULE 1303-BACT]
- 12. AFTER 6 MONTHS NORMAL ENGINE OPERATION, THE OPERATOR SHALL INSPECT THE INTEGRITY OF THE FILTER AND, IF NECESSARY, REPLACE IT.
[RULE 1303-BACT]

Periodic Monitoring:

- 13. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

[RULE 3004(A)(4)]

14. THE OPERATOR SHALL KEEP RECORDS OF PARTICULATE FILTER INSPECTIONS, REPLACEMENTS, AND MANUAL REGENERATIONS. THE OPERATOR SHALL MAINTAIN THESE RECORDS FOR A MINIMUM OF TWO YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER UPON REQUEST.

[RULE 3004(A)(4)]

Emissions and Requirements:

15. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN (g/l) OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN (g/l) OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a)(4)]

Emissions and Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE LOS ANGELES COUNTY SHERIFF'S DEPARTMENT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS.

Emissions and Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- VOC: RULE 1107, SEE APPENDIX B FOR EMISSION LIMITS
- VOC: RULE 1136, SEE APPENDIX B FOR EMISSION LIMITS
- VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

**FACILITY PERMIT TO OPERATE
LOS ANGELES COUNTY SHERIFF'S DEPARTMENT**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, CLEANING EQUIPMENT, SMALL UNHEATED, NON-CONVEYORIZED.

Emissions and Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1122
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS