



DEC 12 2011

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-883
Project # S-1110988**

Dear Mr. Rios:

The Air Pollution Control Officer has modified the Title V permit for Rio Bravo Poso by incorporating S-883-31-4. This modification authorizes the storing of biomass in an existing storage silo and revises the dust collector emissions factor.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on November 10, 2011. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

David Warner
Director of Permit Services

DW:KTR

Enclosures

Seyad Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1980 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



DEC 12 2011

William Rossiter
Rio Bravo Poso
P.O. Box 81027
Bakersfield, CA 93380-1027

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-883
Project # S-1110988**

Dear Mr. Rossiter:

The Air Pollution Control Officer has modified the Title V permit for Rio Bravo Poso by incorporating S-883-31-4. This modification authorizes the storing of biomass in an existing storage silo and revises the dust collector emissions factor.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on November 10, 2011. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



David Warner
Director of Permit Services

DW:KTR

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1980 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-883-31-5

EXPIRATION DATE: 01/31/2015

EQUIPMENT DESCRIPTION:

450 TON (15,000 FT³) CAPACITY REFINERY COKE AND/OR BIOMASS STORAGE SILO EQUIPPED WITH BHA MODEL SPJ-24-X4B8BV VENT FILTER BAGHOUSE, AND ENCLOSED PNEUMATIC SILO LOADING AND UNLOADING SYSTEMS

PERMIT UNIT REQUIREMENTS

1. Concentration of PM10 in coke and/or biomass storage silo baghouse exhaust shall not exceed 0.006 gr/scf. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
2. Bin vent shall operate with a volumetric air rate not to exceed 1,400 scfm. [District Rule 2201] Federally Enforceable Through Title V Permit
3. There shall be no visible emissions during unloading of coke and/or biomass from silo to boiler. [District Rule 2201] Federally Enforceable Through Title V Permit
4. No air contaminant shall be discharged into the atmosphere from coke and/or biomass storage silo baghouse exhaust for a period or periods aggregating more than 3 minutes in any one hour which is dark or darker than Ringelmann 1/4 or equivalent to 5% opacity. [District Rules 2201 and 4101] Federally Enforceable Through Title V Permit
5. The bin vent filter located on top of the coke and/or biomass silo shall be inspected weekly during silo loading for any visible emissions. If visible emissions are observed, corrective action shall be taken to eliminate visible emissions prior to further loading. Corrective action shall eliminate visible emissions before next loading event. The result of inspection shall be kept in a record and shall be made available to the District upon request. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. Permittee shall perform a complete vent filter inspection during each calendar quarter. Vent filters shall be inspected thoroughly for tears, scuffs, abrasions, holes, or any evidence of particulate matter leaks and shall be replaced as needed. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. Records of vent filter maintenance, inspections, and repair shall be maintained. The records shall include identification of the equipment, date of inspection, corrective action taken, and identification of the individual performing the inspection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. The permittee shall maintain, and make available for District inspection, all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.