



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

October 28, 2011

Mr. Gerardo Rios
Chief – Permits Office
U. S. EPA, Region IX
75 Hawthorne Street, Air 3
San Francisco, CA 94105

Subject: Transmittal of Final Title V Renewal Permit

Dear Mr. Rios:

Enclosed is the final Title V renewal permit issued by the South Coast Air Quality Management District (AQMD) under Application No. 495103 for Access Business Group LLC, Nutrilite (ID 12362) located at 19600 Sixth St., Lakeview, CA 92567. The proposed renewal permit for this facility was submitted to EPA Region IX for 45-day review on September 8, 2011 and made available for 30-day public comment on September 14, 2011. The AQMD did not receive any public comments on the proposed renewal permit.

If there are specific questions on this Title V renewal permit, please contact Mr. Manuel Quizon, Air Quality Engineer II at (909) 396-2639.

Sincerely,

A handwritten signature in black ink, appearing to read 'Brian L. Yeh', is written over a diagonal line.

Brian L. Yeh
Senior Engineering Manager
Mechanical, Chemical, and Public Services

Enclosure

FACILITY PERMIT TO OPERATE


**ACCESS BUSINESS GROUP LLC, NUTRILITE
19600 6TH ST
LAKEVIEW, CA 92567**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By 
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

TABLE OF CONTENTS

| Section | Description | Revision # | Date Issued |
|----------|--|-----------------|-------------|
| A | Facility Information | 2 | 10/28/2011 |
| B | RECLAIM Annual Emission Allocation | 0 | 07/23/2004 |
| C | Facility Plot Plan | TO BE DEVELOPED | |
| D | Facility Description and Equipment Specific Conditions | 7 | 10/28/2011 |
| E | Administrative Conditions | 3 | 09/27/2007 |
| F | RECLAIM Monitoring and Source Testing Requirements | 0 | 07/23/2004 |
| G | Recordkeeping and Reporting Requirements for RECLAIM Sources | 0 | 07/23/2004 |
| H | Permit To Construct and Temporary Permit to Operate | 3 | 12/16/2010 |
| I | Compliance Plans & Schedules | 0 | 07/23/2004 |
| J | Air Toxics | 1 | 10/28/2011 |
| K | Title V Administration | 1 | 10/28/2011 |
| Appendix | | | |
| A | NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219 | 0 | 07/23/2004 |
| B | Rule Emission Limits | 1 | 10/28/2011 |

FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: ACCESS BUSINESS GROUP LLC, NUTRILITE

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 19600 6TH ST
LAKEVIEW, CA 92567-8401

MAILING ADDRESS: 5600 BEACH BLVD
BUENA PARK, CA 90621-5941

RESPONSIBLE OFFICIAL: JIM SIEWERTSEN

TITLE: VICE PRESIDENT - NUTRILITE OPERATIONS

TELEPHONE NUMBER: (714) 562-6484

CONTACT PERSON: KATHRYN HUBBARD

TITLE: SUPERVISOR, ENVIRONMENTAL HEALTH & SAFETY

TELEPHONE NUMBER: (714) 562-1829

TITLE V PERMIT ISSUED: October 28, 2011

TITLE V PERMIT EXPIRATION DATE: October 27, 2016

| TITLE V | RECLAIM |
|----------------|---------------------|
| YES | NOx: NO |
| | SOx: NO |
| | CYCLE: 0 |
| | ZONE: INLAND |

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

NOT APPLICABLE



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

**Facility Equipment and Requirements
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.




**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

| Application number | Permit to Operate number | Equipment description |
|---------------------------|---------------------------------|---|
| 00951E | E04278 | STORAGE TANK |
| 104058 | M47300 | AIR POLLUTION CONTROL SYSTEM |
| 259155 | D63829 | BOILER |
| 301855 | D89406 | BOILER |
| 320476 | F4150 | AIR POLLUTION CONTROL SYSTEM |
| 324483 | R-F46946 | BOILER (5-20 MMBTU/HR) NAT GAS ONLY |
| 324836 | R-F46947 | BOILER (5-20 MMBTU/HR) NAT GAS ONLY |
| 329550 | F7968 | ICE |
| 364875 | F66687 | STORAGE TANK FX RF W/CTL ALCOHOLS |
| 364879 | F66688 | STORAGE TANK FX RF W/CTL ALCOHOLS |
| 414552 | N13374 | SERV STAT STORAGE & DISPENSING GASOLINE |
| 414553 | F92351 | TOTE LOADING/TUMBLING SYSTEM |
| 414555 | F66536 | PLASMA ARC CUTTING |
| 415393 | F92352 | AIR POLLUTION CONTROL SYSTEM |
| 417811 | F66689 | ADSORBER DRUM VENT M.S. |
| 419825 | F94224 | FLUIDIZED BED DRYING, SEPARATION, AND PACKAGING SYSTEM (T7) |
| 419827 | F94225 | FLUIDIZED BED DRYING, SEPARATION, AND PACKAGING SYSTEM (T8) |
| 419828 | F94226 | AIR POLLUTION CONTROL SYSTEM |
| 419830 | F92353 | WEIGH STATION SYSTEM |
| 419831 | F92354 | AIR POLLUTION CONTROL SYSTEM |
| 424259 | F66537 | BAGHOUSE, AMBIENT TEMP (>100-500 SQ FT) |
| 420863 | F78775 | PHARMACEUTICALS MFG.-TABLETING, COATING, VITAMINS |
| 422029 | F78772 | ALCOHOLS, EVAPORATION |
| 422030 | F78773 | FEED AND FOOD MISC EVAPORATION |
| 430218 | F89677 | EXTRUSION SYSTEM |
| 430219 | F89678 | AIR POLLUTION CONTROL SYSTEM |
| 432127 | F94227 | AIR POLLUTION CONTROL SYSTEM |
| 432128 | F94228 | AIR POLLUTION CONTROL SYSTEM |
| 434780 | F89679 | AIR POLLUTION CONTROL SYSTEM |
| 435311 | F89681 | AIR POLLUTION CONTROL SYSTEM |
| 435313 | F89682 | BOILER |
| 441899 | F94229 | BLENDING/MILLNG SYSTEM |
| 441902 | F94230 | AIR POLLUTION CONTROL SYSTEM |
| 442846 | F92355 | BLENDING SYSTEM |
| 449766 | F92357 | FLUIDIZED BED DRYER SYSTEM (GLATT A) |
| 449767 | F92358 | FLUIDIZED BED DRYER SYSTEM (GLATT B) |



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

| | | |
|--------|--------|---|
| 449768 | F92359 | AIR POLLUTION CONTROL SYSTEM |
| 449769 | F92360 | AIR POLLUTION CONTROL SYSTEM |
| 475444 | F96162 | PHYTONUTRIENT EXTRACTION, FILTERING AND RECOVERY SYSTEM |
| 475445 | F96163 | FOOD SUPPLEMENT SPRAY DRYING SYSTEM |
| 475446 | F96164 | AIR POLLUTION CONTROL SYSTEM |
| 475447 | F96165 | AIR POLLUTION CONTROL SYSTEM |
| 478498 | G1099 | AIR POLLUTION CONTROL SYSTEM |
| 511248 | | GRANULATED PRODUCTS MANUFACTURING SYSTEM |
| 484341 | G8008 | AIR POLLUTION CONTROL SYSTEM |
| 484344 | G8009 | AIR POLLUTION CONTROL SYSTEM |
| 484345 | G1100 | AIR POLLUTION CONTROL SYSTEM |
| 484346 | G8010 | AIR POLLUTION CONTROL SYSTEM |
| 484347 | G8011 | AIR POLLUTION CONTROL SYSTEM |
| 502182 | G8800 | PASTEURIZED PRODUCTS MANUFACTURING SYSTEM |
| 504117 | | CENTRITHERM (CT1-09RM) EVAPORATOR SYSTEM |
| 504118 | | AIR POLLUTION CONTROL SYSTEM |
| 514695 | | AIR POLLUTION CONTROL SYSTEM |
| 514696 | | STORAGE TANK FX RF W/CTL ALCOHOLS |
| 514697 | | STORAGE TANK FX RF W/CTL ALCOHOLS |

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.
[RULE 401]

2. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. E04278
A/N 00951E**

Equipment Description:

SOLVENT MIXING TANK, 2000 GALLONS CAPACITY.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

Emissions And Requirements:

3. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. M47300
A/N 104058**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. SCRUBBER, NIRO ATOMIZER INC., MODEL 1120 SFP, VENTURI TYPE.
2. RECIRCULATION TANK, WATER, 225 GALLON CAPACITY, WITH A 1 H.P PUMP.
3. EXHAUST SYSTEM WITH A 50 HP BLOWER VENTING ONE CYCLONE TO A DEMISTER.
4. DEMISTER/SETTLING CHAMBER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. NOT LESS THAN 11 GALLONS PER MINUTE OF WATER MUST BE SUPPLIED TO THE SCRUBBER WHEN THE EQUIPMENT IT SERVES IS IN OPERATION.
[RULE 1303(a)(1)-BACT; RULE 1303(b)(2)-OFFSET; RULE 3004(a)(4)-PERIODIC MONITORING]
4. A FLOWMETER, INDICATING IN GPM MUST BE INSTALLED IN WATER SUPPLY LINE TO SCRUBBER.
[RULE 1303(a)(1)-BACT; RULE 1303(b)(2)-OFFSET; RULE 3004(a)(4)-PERIODIC MONITORING]
5. THE SCRUBBING WATER MUST BE CHANGED AFTER EACH DAY'S OPERATION.
[RULE 1303(a)(1)-BACT; RULE 1303(b)(2)-OFFSET; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL USE THIS EQUIPMENT IN SUCH A MANNER THAT THE FLOW RATE OF THE SCRUBBING SOLUTION IS NOT LESS THAN 11 GPM. TO COMPLY WITH THIS CONDITION THE OPERATOR SHALL INSTALL AND MAINTAIN A FLOW METER TO ACCURATELY INDICATE THE FLOW RATE OF THE SCRUBBING SOLUTION. THE OPERATOR SHALL DETERMINE AND RECORD THE PARAMETER BEING MONITORED ONCE EVERY DAY.
[RULE 3004 (a)(4)]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
 - B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
 - C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. D63829
A/N 259155**

Equipment Description:

BOILER, SELLERS IMMERSION LOW NOX TYPE, MODEL SH-LN390, NATURAL GAS FIRED, RATED AT 5,200,000 BTU PER HOUR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL USE ONLY NATURAL GAS OR PROPANE AS A FUEL.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL COMPLY WITH RULE 1146.
[RULE 1146]

Periodic Monitoring:

5. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.
[RULE 3004(a)(4)]

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
 - B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
 - C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
CO: 400 PPMV, RULE 1146
PM: 0.1 GR/SCF, RULE 409
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
NOX: 30 PPMV, RULE 1146



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. D89406
A/N 301855**

Equipment Description:

BOILER, SELLERS ENGINEERING CO. MODEL LN390, NATURAL GAS FIRED, 8.4 MMBTU BTU PER HOUR, WITH A SELLERS LOW NOX BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT]
4. THE BURNER AND ITS ASSOCIATED AIR-FUEL SYSTEM SHALL BE ADJUSTED AT LEAST TWICE A YEAR IN THE FOLLOWING MANNER:
 - A. ACCORDING TO THE MANUFACTURER'S SPECIFICATION TO ENSURE COMPLIANCE WITH CONDITION NO. 5.
 - B. THE ADJUSTMENTS SHALL INCLUDE AT LEAST MEASUREMENTS OF EFFLUENT CO, NOX, AND O2 CONCENTRATIONS BY USING A PORTABLE CHEMICAL CELL TYPE OR EQUIVALENT ANALYZER.
 - C. WRITTEN RECORDS OF THE MEASUREMENTS SHALL BE KEPT AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]
5. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NOX) CALCULATED AS NITROGEN DIOXIDE, AND 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3 PERCENT OXYGEN.
[RULE 1146]

Periodic Monitoring:

6. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE



FACILITY PERMIT TO OPERATE ACCESS BUSINESS GROUP LLC, NUTRILITE

ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.
[RULE 3004(a)(4)]

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
 - B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
 - C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

[RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
CO: 400 PPMV, RULE 1146
PM: 0.1 GR/SCF, RULE 409
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
NOX: 30 PPMV, RULE 1146



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F4150
A/N 320476**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. BAGHOUSE, FARR MARK III, TENKAY 20 L, PULSE JET CLEANING, CARTRIDGE TYPE, WITH 4,800 SQUARE FEET OF FILTER AREA.
2. EXHAUST SYSTEM WITH A 20 HP BLOWER VENTING A MAXIMUM OF THREE PRODUCT CYCLONES AND A BAG FILLING/PACKAGING SYSTEM.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE CARTRIDGE FILTERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. THE PRESSURE DROP ACROSS THE CARTRIDGE FILTERS SHALL NOT EXCEED 4.0 INCHES WATER COLUMN AT ANY TIME DURING THE OPERATION.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO CLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL USE THIS EQUIPMENT IN SUCH A MANNER THAT THE DIFFERENTIAL PRESSURE ACROSS THE BAGS DOES NOT EXCEED 4.0 INCHES WATER COLUMN. TO COMPLY WITH THIS CONDITION THE OPERATOR SHALL INSTALL AND MAINTAIN A PRESSURE GAUGE TO ACCURATELY INDICATE THE DIFFERENTIAL PRESSURE ACROSS THE BAGS. THE OPERATOR SHALL DETERMINE AND RECORD THE PARAMETER BEING MONITORED ONCE EVERY WEEK.
[RULE 3004 (a)(4)]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

7. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.
- [RULE 3004 (a)(4)]
8. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.
- [RULE 3004 (a)(4)]
9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A QUARTERLY BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE QUARTERLY PERIOD. THE ROUTINE QUARTERLY INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
- THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
- A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED.
- [RULE 3004 (a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. R-F46946
A/N 324483**

Equipment Description:

BOILER, SELLERS, MODEL LN-390, FIRE TUBE TYPE, 19.9 MMBTU/HR, NATURAL GAS FIRED, WITH A LOW NOX BURNER, SELLERS, MODEL LN-390.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT]
4. SOURCE TESTS SHALL BE CONDUCTED ON OR BEFORE JULY 1, 2002, AND EVERY YEAR THEREAFTER, TO DEMONSTRATE COMPLIANCE WITH THE EMISSIONS LEVELS IN CONDITION NO. 5, AS REQUIRED BY AQMD RULE 1146(d)(4) AND (d)(6). RECORDS OF ALL SOURCE TESTS SHALL BE MAINTAINED FOR A PERIOD OF TWO YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
5. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NOX) CALCULATED AS NO₂ AND 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3 PERCENT OXYGEN.
[RULE 1146]
6. TOTAL AMOUNT OF NATURAL GAS USED AT THIS FACILITY SHALL NOT EXCEED 1,638,000 THERMS IN ANY ONE YEAR.
[RULE 1303(b)(2)-OFFSETS]
7. TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6, RECORDS OF THE GAS COMPANY BILLS SHALL BE KEPT ON FILE FOR AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]
8. TOTAL AMOUNT OF NATURAL GAS USED IN THE ABOVE DESCRIBED BOILER SHALL NOT EXCEED 8.64 MILLION CUBIC FEET IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

9. TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 8, A TOTALIZING GAS METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE CUBIC FEET OF NATURAL GAS USED BY THIS BOILER. MONTHLY NATURAL GAS USAGE RECORDS SHALL BE MAINTAINED ON FILE FOR AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. [RULE 1303(b)(2)-OFFSETS]

Periodic Monitoring:

10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD. [RULE 3004(a)(4)]

11. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT. [RULE 3004 (a)(4)]

12. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
 - B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN



FACILITY PERMIT TO OPERATE ACCESS BUSINESS GROUP LLC, NUTRILITE

- ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
- C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- CO: 2000 PPMV, RULE 407
CO: 400 PPMV, RULE 1146
PM: 0.1 GR/SCF, RULE 409
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
NOX: 30 PPMV, RULE 1146



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

+

PERMIT TO OPERATE

**Permit No. R-F46947
A/N 324836**

Equipment Description:

BOILER, SELLERS, MODEL SH-LN-390, FIRE TUBE TYPE, 8.4 MMBTU/HR, NATURAL GAS FIRED, WITH A LOW NOX BURNER, SELLERS, MODEL LN-390

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT]
4. SOURCE TESTS SHALL BE CONDUCTED ON OR BEFORE JULY 1, 2002, AND EVERY YEAR THEREAFTER, TO DEMONSTRATE COMPLIANCE WITH THE EMISSIONS LEVELS IN CONDITION NO. 5, AS REQUIRED BY AQMD RULE 1146(d)(4) AND (d)(6). RECORDS OF ALL SOURCE TESTS SHALL BE MAINTAINED FOR A PERIOD OF TWO YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]
5. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF NITROGEN OXIDES (NOX), CALCULATED AS NO₂, AND 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3 PERCENT OXYGEN.
[RULE 1146]
6. TOTAL AMOUNT OF NATURAL GAS USED AT THIS FACILITY SHALL NOT EXCEED 1,638,000 THERMS IN ANY ONE YEAR.
[RULE 1303(b)(2)-OFFSETS]
7. TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6, RECORDS OF THE GAS COMPANY BILLS SHALL BE KEPT ON FILE FOR AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

8. NATURAL GAS CONSUMPTION FOR THIS BOILER AND THE OTHER 8.4 MMBTU/HR BOILER OPERATING UNDER PERMIT D89406 SHALL NOT EXCEED 5.76 MILLION CUBIC FEET IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]
9. TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 8, A TOTALIZING GAS METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE CUBIC FEET OF NATURAL GAS USED BY THIS BOILER AND THE OTHER 8.4 MMBTU/HR BOILER OPERATING UNDER PERMIT D89406. MONTHLY NATURAL GAS USAGE RECORDS SHALL BE MAINTAINED ON FILE FOR AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Periodic Monitoring:

10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.
[RULE 3004(a)(4)]

11. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]

12. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
 - A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;

- B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
- C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

Emissions And Requirements:

- 13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
CO: 400 PPMV, RULE 1146
PM: 0.1 GR/SCF, RULE 409
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
NOX: 30 PPMV, RULE 1146



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F7968
A/N 329550**

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, 6 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL NO. 6CTAA8.3-G1, 317 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.1 & 1110.2]
4. THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 199 HOURS IN ANY ONE YEAR.
[RULE 1110.1 & 1110.2]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1110.1 & 1110.2]
6. SULFUR CONTENT OF FUEL SUPPLIED TO THE ENGINE SHALL NOT EXCEED 0.05 % BY WEIGHT.
[RULE 1303(a)(1)-BACT]

Periodic Monitoring:

7. A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 3004 (a)(4)]
8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:

- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
- B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
- C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
 - D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]
9. A DAILY LOG LISTING THE ENGINE OPERATING TIME, IN HOURS, SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF TWO YEARS. THE LOG SHALL BE MADE AVAILABLE UPON REQUEST TO SCAQMD PERSONNEL.
[RULE 3004(a)(4)]
10. THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 199 HOURS IN ANY ONE YEAR
[RULE 3004(a)(4)]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F66687
A/N 364875**

Equipment Description:

STORAGE TANK, ETHANOL, NO. AT-1, FIXED ROOF, 7'-7.5" DIA. X 15'-1" H., 5,000 GALLON CAPACITY WITH A VAPOR RETURN SYSTEM AND A 0.03 PSIG COMBINATION PRESSURE/VACUUM RELIEF VALVE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
3. THIS TANK SHALL ONLY BE USED TO STORE FRESH AND RECLAIM (RECYCLE) AQUEOUS ETHYL ALCOHOL. [RULE 1303(b)(2)-OFFSETS]
4. THIS TANK SHALL NOT BE FILLED WITH FRESH ALCOHOL UNLESS THE DISPLACED VAPORS ARE RETURNED TO THE UNLOADING TANKER THROUGH A GAS TIGHT VAPOR LINE. [RULE 1303(a)(1)-BACT]
5. THE VAPOR RETURN SYSTEM SHALL BE IN FULL USE DURING THE FRESH ALCOHOL LOADING OPERATION TO ENSURE COMPLETE RETURN OF THE DISPLACED VAPOR FROM THE TANK TO THE DELIVERY VEHICLE. [RULE 1303(a)(1)-BACT]
6. THE OPERATOR SHALL DEMONSTRATE THAT DELIVERING TRUCKS OR TRUCKING COMPANIES HAVE VENTED THE DISPLACED VAPOR COLLECTED BY THE TANK TRUCKS DURING THE FRESH ALCOHOL FILLING OPERATION TO AIR POLLUTION CONTROL SYSTEMS OPERATING WITH A VALID AQMD PERMIT. [RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6 BY KEEPING RECORDS OF THE TRUCKING COMPANIES, THEIR LOCATIONS AND AQMD PERMIT NO(S). OF THE AIR POLLUTION CONTROL SYSTEM. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST 2 YEARS AND BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST. [RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

8. THE MAXIMUM QUANTITY OF FRESH AND RECLAIM ALCOHOL LOADED INTO THIS STORAGE TANK SHALL NOT EXCEED 205,480 GALLONS IN ANY 30-DAY PERIOD. [RULE 1303(b)(2)-OFFSETS]
9. THE OPERATOR SHALL MAINTAIN RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 8. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. [RULE 1303(b)(2)-OFFSETS]
10. THIS TANK SHALL NOT BE FILLED WITH RECLAIM ALCOHOL UNLESS THE DISPLACED VAPORS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER. [RULE 1303(a)(1)-BACT]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F66688
A/N 364879**

Equipment Description:

STORAGE TANK, ETHANOL, NO. AT-2, FIXED ROOF, 7'-7.5" DIA. X 15'-1" H., 5,000 GALLON CAPACITY WITH A VAPOR RETURN SYSTEM AND A 0.03 PSIG COMBINATION PRESSURE/VACUUM RELIEF VALVE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
3. THIS TANK SHALL ONLY BE USED TO STORE FRESH AND RECLAIM (RECYCLE) AQUEOUS ETHYL ALCOHOL. [RULE 1303(b)(2)-OFFSETS]
4. THIS TANK SHALL NOT BE FILLED WITH FRESH ALCOHOL UNLESS THE DISPLACED VAPORS ARE RETURNED TO THE UNLOADING TANKER THROUGH A GAS TIGHT VAPOR LINE. [RULE 1303(a)(1)-BACT]
5. THE VAPOR RETURN SYSTEM SHALL BE IN FULL USE DURING THE FRESH ALCOHOL LOADING OPERATION TO ENSURE COMPLETE RETURN OF THE DISPLACED VAPOR FROM THE TANK TO THE DELIVERY VEHICLE. [RULE 1303(a)(1)-BACT]
6. THE OPERATOR SHALL DEMONSTRATE THAT DELIVERING TRUCKS OR TRUCKING COMPANIES HAVE VENTED THE DISPLACED VAPOR COLLECTED BY THE TANK TRUCKS DURING THE FRESH ALCOHOL FILLING OPERATION TO AIR POLLUTION CONTROL SYSTEMS OPERATING WITH A VALID AQMD PERMIT. [RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6 BY KEEPING RECORDS OF THE TRUCKING COMPANIES, THEIR LOCATIONS AND AQMD PERMIT NO(S). OF THE AIR POLLUTION CONTROL SYSTEM. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST 2 YEARS AND BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST. [RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

8. THE MAXIMUM QUANTITY OF FRESH AND RECLAIM ALCOHOL LOADED INTO THIS STORAGE TANK SHALL NOT EXCEED 205,480 GALLONS IN ANY 30-DAY PERIOD. [RULE 1303(b)(2)-OFFSETS]
9. THE OPERATOR SHALL MAINTAIN RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 8. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. [RULE 1303(b)(2)-OFFSETS]
10. THIS TANK SHALL NOT BE FILLED WITH RECLAIM ALCOHOL UNLESS THE DISPLACED VAPORS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER. [RULE 1303(a)(1)-BACT]

Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. N13374
A/N 414552**

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY CONSISTING OF:

1. 1-DUAL COMPARTMENT ABOVEGROUND GASOLINE/DIESEL STORAGE TANK, STEEL TANK INSTITUTE FIREGUARD (G-70-162-A), 5'-1.75" DIA. X 11'-6" L., 1,750- GALLON CAPACITY, CONCRETE INSULATION, EQUIPPED WITH A PRESSURE/VACUUM RELIEF VALVE, AND A SUBMERGED FILL TUBE, CONSISTING OF:
 - A. ONE 750-GALLON GASOLINE COMPARTMENT, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM.
 - B. ONE -1000 GALLON DIESEL COMPARTMENT, NOT EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM.
2. 1-GASOLINE NOZZLE DISPENSING 1 PRODUCT ON A TANK TOP MOUNTED DISPENSER, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, BALANCE RETRACTOR (G-70-52-AM).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.
[RULE 461]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.
[RULE 461]
5. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.
[RULE 461]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

6. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE SYSTEM INCLUDING NOZZLE, VAPOR HOSE, SWIVELS, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURES DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

| NITROGEN FLOW RATES (CFH) | DYNAMIC BACK PRESSURE (INCHES OF WATER) |
|------------------------------|--|
| 60 | 0.35 |
| 80 | 0.62 |

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4, METHODOLOGY 1. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN FORTY-EIGHT (48) HOURS OF TESTS.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE DYNAMIC BACK PRESSURE TESTS.
[RULE 461]

7. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN FORTY-EIGHT (48) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE STATIC PRESSURE LEAK DECAY TEST.
[RULE 461]

8. IF THE CARB EXECUTIVE ORDER REQUIRES THE INSTALLATION OF A LIQUID REMOVAL DEVICE, A LIQUID REMOVAL RATE TEST SHALL BE CONDUCTED TO DEMONSTRATE THE REMOVAL OF GASOLINE FROM THE VAPOR PASSAGE OF THE COAXIAL HOSE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.6. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN FORTY-EIGHT (48) HOURS OF TEST.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO TESTING. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR;



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE LIQUID REMOVAL RATE TEST.
[RULE 461]

9. THE TESTING FREQUENCY FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.
[RULE 461]
10. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 461]
11. THE MAXIMUM QUANTITY OF GASOLINE DISPENSED FROM THE STORAGE TANKS AT THIS FACILITY SHALL NOT EXCEED 3,000 GALLONS IN ANY ONE CALENDAR MONTH NOR 36,000 GALLONS IN ANY ONE CALENDAR YEAR.
[RULE 1303(b)(2)-OFFSETS]
12. RECORDS OF MONTHLY AND ANNUAL FUEL DISPENSED SHALL BE PREPARED, SHALL BE RETAINED ON SITE FOR TWO YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Periodic Monitoring:

13. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(d)(5) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT B, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.
[RULE 300(a)(4)]

Emissions And Requirements:

14. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

ROG: RULE 461



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92351
A/N 414553**

Equipment Description:

TOTE LOADING/TUMBLING SYSTEM CONSISTING OF:

1. SWECO SCREEN, 4'-0" DIA. X 2'-6" H., 5 H.P.
2. TOTE LOADING TABLE, 9'-0" W. X 9'-9" W. X 7'-4" H.
3. TOTE TUMBLER, 10'-0" W. X 5'-0" D. X 10'-0" H., 15 H.P.
4. TOTE UNLOADING TABLE (DRUMS), 3'-6" W. X 4'-0" L. X 6'-11" H.
5. TOTE UNLOADING TABLE (SUPER SACKS), 5'-6" W. X 2'-10" H. X 5'-10" D.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 360 TONS OF MATERIAL IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST TWO YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F66536
A/N 414555**

Equipment Description:

METAL CUTTING TORCH, HYPERTHERM, PLASMA ARC TYPE, MODEL POWERMAX 900, 11.4 KW,
ELECTRICALLY POWERED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
3. THIS PLASMA ARC CUTTER SHALL NOT BE OPERATED UNLESS IT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER. [RULE 401]
4. THIS EQUIPMENT SHALL NOT CUT MORE THAN 125 LINEAR FEET OF STAINLESS STEEL IN ANY ONE DAY. [RULE 1303(b)(2)-OFFSETS, RULE 1401]
5. THIS EQUIPMENT SHALL NOT CUT MORE THAN 2100 LINEAR FEET OF STAINLESS STEEL IN ANY ONE YEAR. [RULE 1303(b)(2)-OFFSETS, RULE 1401]
6. THE OPERATOR SHALL MAINTAIN RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 3, 4, AND 5. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. [RULE 1303(b)(2)-OFFSETS, RULE 1401]

Periodic Monitoring:

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING
REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.
[RULE 3004 (a)(4)]

Emissions And Requirements:

- 8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92352
A/N 415393**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. BAGHOUSE, FARR, MODEL MARK III TENKAY 20L, WITH TWENTY BAGS, EACH 1'-1" DIA. X 2'-3" H., TOTAL FILTER AREA OF 4,800 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 20 H.P. BLOWER VENTING A SWECO SCREEN, A TOTE TUMBLER, TWO UNLOADING TABLES, AND A SUPER SACK DUMP HOPPER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER BAGS SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE FILTER BAGS SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER BAGS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F66689
A/N 417811**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. ADSORBER, PRIMARY, CAMERON ENVIRONMENTAL, ZEOLITE WITH 6% POTASSIUM PERMANGANATE, MODEL KLEEN AIR 2000S, 3'-10" DIA. X 7'-4" H., 4000 LBS ZEOLITE.
2. ADSORBER, SECONDARY, CAMERON ENVIRONMENTAL, ZEOLITE WITH 6% POTASSIUM PERMANGANATE, MODEL KLEEN AIR 55, 2'-0" DIA. X 3'-0" H., 400 LBS ZEOLITE.
3. EXHAUST SYSTEM VENTING TWO ETHANOL TANKS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE PRIMARY AND SECONDARY ADSORBERS SHALL BE CONNECTED IN SERIES. [RULE 1303(a)(1)-BACT]
4. THE OPERATOR SHALL MEASURE THE VOC CONCENTRATION AT THE INLET AND OUTLET OF THE PRIMARY CARBON ADSORBER AT LEAST ONCE A DAY BY USING A FLAME IONIZATION DETECTOR OR A DISTRICT APPROVED ORGANIC VAPOR ANALYZER CALIBRATED IN PPMV OF HEXANE TO DETERMINE THE CONTROL EFFICIENCY OF THE PRIMARY CARBON ADSORBER.
$$\text{CONTROL EFFICIENCY} = (1 - \text{OUTLET CONCENTRATION} / \text{INLET CONCENTRATION}) * 100$$

[RULE 1303(a)(1)-BACT, RULE 3004(a)(4)-PERIODIC MONITORING]
5. WHEN THE CONTROL EFFICIENCY OF THE PRIMARY ADSORBER, AS DETERMINED BY CONDITION NO. 4, DROPS BELOW 95%, THE ADSORBENT IN THE PRIMARY AND SECONDARY ADSORBERS SHALL BE REPLACED WITH FRESH ADSORBENT WITHIN FOUR DAYS.
[RULE 1303(a)(1)-BACT, RULE 3004(a)(4)-PERIODIC MONITORING]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

Periodic Monitoring:

6. THE OPERATOR SHALL MEASURE THE VOC CONCENTRATION AT THE INLET AND OUTLET OF THE PRIMARY CARBON ADSORBER AT LEAST ONCE A DAY BY USING A FLAME IONIZATION DETECTOR OR A DISTRICT APPROVED ORGANIC VAPOR ANALYZER CALIBRATED IN PPMV OF HEXANE TO DETERMINE THE CONTROL EFFICIENCY OF THE PRIMARY CARBON ADSORBER.

CONTROL EFFICIENCY = $(1 - \text{OUTLET CONCENTRATION} / \text{INLET CONCENTRATION}) * 100$

[RULE 3004(a)(4)]

7. WHEN THE CONTROL EFFICIENCY OF THE PRIMARY ADSORBER, AS DETERMINED BY CONDITION NO. 4, DROPS BELOW 95%, THE ADSORBENT IN THE PRIMARY AND SECONDARY ADSORBERS SHALL BE REPLACED WITH FRESH ADSORBENT WITHIN FOUR DAYS. [RULE 3004(a)(4)]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94224
A/N 419825**

Equipment Description:

FLUIDIZED BED DRYING, SEPARATION, AND PACKAGING SYSTEM (T7) CONSISTING OF:

1. BOWL BIN, 4'-10" DIA. X 1'-11" H.
2. FLUIDIZED BED DRYER, T7, HOT AIR, 5'-0" DIA. X 11'-0" H.
3. MIXING TANK, 4'-6" DIA. X 3'-6" H., 250 GALLON CAPACITY, 0.25 H.P.
4. PRESSURE POT.
5. PNEUMATIC TRANSFER BLOWER, VAC-U-MAX, 10 H.P.
6. SWECO SCREEN, 4'-0" DIA. X 2'-3" H., 1.5 H.P.
7. MILL, 7.5 H.P.
8. PACKAGING STATION. 45dd

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 245 TONS OF MATERIAL IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94225
A/N 419827**

Equipment Description:

FLUIDIZED BED DRYING, SEPARATION, AND PACKAGING SYSTEM (T8) CONSISTING OF:

1. BOWL BIN, 5'-6" DIA. X 2'-0" H.
2. FLUIDIZED BED DRYER, T8, HOT AIR, 6'-9" DIA. X 11'-0" H.
3. MIXING TANK, 4'-6" DIA. X 3'-6" H., 250 GALLON CAPACITY, 0.25 H.P.
4. PRESSURE POT.
5. PNEUMATIC TRANSFER BLOWER, VAC-U-MAX, 10 H.P.
6. SWECO SCREEN, 4'-0" DIA. X 2'-3" H., 1.5 H.P.
7. MILL, 7.5 H.P.
8. PACKAGING STATION.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 245 TONS OF MATERIAL IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94226
A/N 419828**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL 10D, WITH TEN CARTRIDGES, EACH 1'-1" DIA. X 2'-11" H., TOTAL FILTER AREA OF 2,820 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 15 H.P. BLOWER VENTING A SWECO SCREEN, BLENDER, LOADING STATION, AND TWO MILLS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92353
A/N 419830**

Equipment Description:

WEIGH STATION SYSTEM CONSISTING OF:

1. THREE WEIGH ROOMS WITH A DRUM WEIGHING POINT.
2. ONE WEIGH ROOM WITH A DRUM WEIGHING POINT AND A PALLET WEIGHING POINT.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 3,750 TONS OF MATERIAL IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST TWO YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92354
A/N 419831**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL 16D, WITH SIXTEEN CARTRIDGES, EACH 1'-1" DIA. X 2'-11" H., TOTAL FILTER AREA OF 4,512 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 25 H.P. BLOWER VENTING FOUR WEIGH ROOMS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F66537
A/N 424259**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. BAGHOUSE, DONALDSON TORIT, MODEL DFO2-2, WITH 2 TORIT, ULTRA-WEB, CARTRIDGES, 380 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING, AND 10 FT COLLECTION ARM.
2. EXHAUST SYSTEM WITH A 3 H.P. BLOWER VENTING A PLASMA ARC CUTTER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS. [RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. A GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN INCHES OF WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES. THE PRESSURE DIFFERENTIAL SHALL NOT EXCEED 5 INCHES OF WATER. [RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

5. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

[RULE 3004 (a)(4)]

6. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F78775
A/N 420863**

Equipment Description:

PHYTONUTRIENT EXTRACTION, FILTERING AND RECOVERY SYSTEM CONSISTING OF:

1. RECEIVING HOPPER, 10 HP
2. PUMP, WATER
3. BELT CONVEYORS, TWO
4. MILL, 40 HP
5. PUMP, 10 HP
6. SURGE TANKS/MIXERS, FOUR, 8 HP TOTAL
7. PUMPS, FOUR, 12 HP TOTAL
8. VIBRATING SCREENS, FOUR, 8 HP TOTAL
9. SURGE TANKS HOPPER
10. SCREW CONVEYOR, 2 HP TOTAL
11. EXTRACTION TANKS, TWO, ALCOHOL, EACH 6'-3" DIA. X 9'-11" H., 2000 GALLONS CAPACITY, STEAM HEATED
12. PILOT EXTRACTION TANKS, TWO, NOS. PET1 AND PET2, ALCOHOL, EACH, 3'-6" DIA. X 6'-0" H., 200 GALLONS CAPACITY, STEAM HEATED
13. SCREW PRESS, 20 HP
14. MIXING TANKS, TWO, 2 HP TOTAL
15. PUMPS, TWO, 1 HP TOTAL
16. FILTER SYSTEM
17. FEED CONVEYOR, 5 HP
18. TWIN SCREW FEEDER, 1 HP
19. TURBO DRYER, WYSSMONT, MODEL N-25 WITH A 2 HP INTERNAL CIRCULATION FAN, A TRAY AND A DISCHARGE AIR LOCK
20. DRYER PRESSURE BALANCING VALVE
21. PRODUCT RECOVERY COLLECTOR, SLY, MODEL SBR-1011-R, WITH 1320 SQ. FT. OF FILTER AREA, AND ONE 10 HP EXHAUST FAN
22. AIR CONVEYOR, VAC-U-MAX, 5 HP, PNEUMATIC CONVEYOR
23. CONDENSER, 1635 SQ. FT. OF HEAT TRANSFER AREA
24. SOLVENT RECEIVER, 425 GALLONS CAPACITY
25. PARALLEL FLOW FILTERS, TWO
26. SOLVENT RECIRCULATION FAN, 5 HP
27. SOLVENT RECOVERY PUMP, 5 HP
28. RECIRCULATION PUMP, 5 HP
29. HEAT EXCHANGER, 2200 SQ. FT. OF HEAT TRANSFER AREA
30. TANK, NITROGEN, 3000 GALLONS
31. AIR LOCK DISCHARGE, ¾ HP
32. SYSTEM FAN, 10 HP



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
3. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 1,781,220 POUNDS OF VOC-CONTAINING SOLVENTS IN ANY 30 DAY PERIOD. [RULE 1303(b)(2)-OFFSETS]
4. THIS EQUIPMENT SHALL COMPLY WITH THE EMISSIONS STANDARDS OF RULE 1103(d). [RULE 1103]
5. THE TOTAL AMOUNT OF DRY MATERIALS ADDED TO THE SURGE TANKS HOPPER (ITEM 9), TWO EXTRACTION TANKS (ITEM 11), AND ONE SURGE TANK (ECHINACEA TANK, 1 OF 4 TANKS IN ITEM 6) SHALL NOT EXCEED 902,880 POUNDS IN ANY 30 DAY PERIOD. [RULE 1303(b)(2)—OFFSETS]
6. DURING EXTRACTION, EACH EXTRACTION TANK SHALL VENT ONLY THROUGH A PRESSURE RELIEF VALVE SET AT 0.5 OZ PRESSURE OR HIGHER. [RULE 1303(a)(1)-BACT]
7. THE TEMPERATURE OF THE NITROGEN GAS STREAM EXITING THE CONDENSER SHALL NOT EXCEED 90 DEGREES FAHRENHEIT. [RULE 1103, RULE 1303(a)(1)-BACT]
8. THE TEMPERATURE OF THE COOLING WATER SUPPLIED TO THE CONDENSER SHALL NOT EXCEED 80 DEGREES FAHRENHEIT WHEN ALCOHOL IS USED FOR EXTRACTION. [RULE 1103, RULE 1303(a)(1)-BACT]
9. NOT LESS THAN 250 GALLONS OF COOLING WATER SHALL BE SUPPLIED TO THE CONDENSER WHEN ALCOHOL IS USED FOR EXTRACTION. [RULE 1103, RULE 1303(a)(1)-BACT]
10. A TEMPERATURE GAUGE AND RECORDER SHALL BE INSTALLED AND MAINTAINED TO MEASURE THE TEMPERATURE OF THE GAS EXITING THE CONDENSER, AND A TEMPERATURE GAUGE AND RECORDER SHALL BE INSTALLED AND MAINTAINED TO MEASURE THE TEMPERATURE OF THE WATER ENTERING THE CONDENSER. [RULE 1103, RULE 1303(a)(1)-BACT]
11. A FLOW METER INDICATING GPM SHALL BE INSTALLED AND MAINTAINED IN THE COOLING WATER SUPPLY LINE TO THE CONDENSER. [RULE 1103, RULE 1303(a)(1)-BACT]
12. THE DUST COLLECTED IN THE PRODUCT RECOVERY COLLECTOR SHALL BE DISCHARGED ONLY INTO CLOSED CONTAINERS. [RULE 1303(a)(1)-BACT]
13. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE SURGE TANKS HOPPER (ITEM 9), TWO EXTRACTION TANKS (ITEM 11), AND ONE SURGE TANK (ECHINACEA TANK, 1 OF 4 TANKS IN ITEM 6) ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL



FACILITY PERMIT TO OPERATE ACCESS BUSINESS GROUP LLC, NUTRILITE

USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]

14. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE TWO EXTRACTION TANKS (ITEM 11), TWO PILOT EXTRACTION TANKS (ITEM 12), ONE SURGE TANK (ECHINACEA TANK, 1 OF 4 TANKS IN ITEM 6), VIBRATING SCREEN (1 OF 4 SCREENS IN ITEM 8), SCREW PRESS (ITEM 13), FEED CONVEYOR (ITEM 17), AND DRYER PRESSURE BALANCING VALVE (ITEM 20) ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER. [RULE 1103, RULE 1303(a)(1)-BACT]
15. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS TO VERIFY COMPLIANCE WITH CONDITIONS NOS. 3, 4, 5, 7, 8, AND 9 ABOVE. SUCH RECORDS SHALL BE KEPT ON THE PREMISES FOR AT LEAST TWO YEARS AND BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST. [RULE 1103, RULE 1303(a)(1)-BACT]

Periodic Monitoring:

16. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.
[RULE 3004 (a)(4)]
17. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
 - A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED.[RULE 3004 (a)(4)]
18. THE OPERATOR SHALL USE THIS EQUIPMENT IN SUCH A MANNER THAT THE FLOW RATE OF THE CONDENSER WATER IS NOT LESS THAN 250 GPM. TO COMPLY WITH THIS CONDITION THE OPERATOR SHALL INSTALL AND MAINTAIN A FLOW METER TO ACCURATELY INDICATE THE FLOW RATE OF THE COOLING WATER. THE OPERATOR SHALL DETERMINE AND RECORD THE PARAMETER BEING MONITORED ONCE EVERY DAY.
[RULE 3004 (a)(4)]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

Emissions And Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F78772
A/N 422029**

Equipment Description:

THIN FILM EVAPORATOR —TF1 CONSISTING OF:

1. TURBO-FILM PROCESSOR, VOTATOR, MODEL NO. 26-120, WITH A 2 HP PRODUCT PUMP AND A CONDENSER, BASCO, MODEL NO. 5, SIZE 22156, WITH 1,250 SQUARE FEET OF HEAT TRANSFER AREA
2. PRODUCT RECEIVER, 25 GALLON CAPACITY
3. CONDENSATE PUMP, 5 HP
4. VACUUM PUMP, NASH ENGINEERING CO., MODEL CL-203, 30 HP
5. LIQUID SEAL PUMP, 1 HP
6. SOLVENT COOLER, BASCO TYPE 500, WITH 56 SQ. FT. OF COOLING AREA
7. EXHAUST COOLER, BASCO TYPE 500, WITH 15.7 SQ. FT. OF COOLING AREA
8. LIQUID SEAL COOLER, BASCO TYPE 500, MODEL PU2768
9. THREE EXTRACT HOLDING TANKS, NOS. EHT1, EHT2 AND EHT3, EACH 9'-6" DIA. X 6'-0" H., EACH 2000 GALLONS CAPACITY, EACH WITH A 3 HP FEED PUMP (COMMON TO A/N 422029 AND 422030)
10. CHILL TANK, NO. CT1, 7'-6" DIA. X 4'-0" H., 1,300 GALLONS CAPACITY (COMMON TO A/N 422029 AND 422030)

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

3. THE MAXIMUM EMISSIONS OF VOLATILE ORGANIC COMPOUNDS FROM THE OPERATION OF THIS EQUIPMENT SHALL NOT EXCEED 87 POUNDS IN ANY ONE MONTH. [RULE 1103, RULE 1303(b)(2)—OFFSETS]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 4,234,000 POUNDS OF VOC CONTAINING FEED EXTRACT IN ANY ONE MONTH. [RULE 1303(b)(2)—OFFSETS]
5. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS TO VERIFY COMPLIANCE WITH CONDITION NO. 4 ABOVE. SUCH RECORDS SHALL BE KEPT ON THE PREMISES FOR AT LEAST TWO YEARS AND BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST. [RULE 1303(b)(2)—OFFSETS]
6. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE TURBO-FILM PROCESSOR AND THE THREE EXTRACT HOLDING TANKS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER. [RULE 1103]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F78773
A/N 422030**

Equipment Description:

THIN FILM EVAPORATOR—TF2 CONSISTING OF:

1. VACUUM EVAPORATOR, NO. TF2, STEAM-HEATED, WITH 86 SQ. FT. OF HEAT TRANSFER AREA AND A 25 HP AGITATOR
2. ONE PRODUCT RECEIVER, 25 GALLONS CAPACITY, WITH A PRODUCT DISCHARGE PUMP
3. VACUUM PUMP, 40 HP
4. CONDENSER, NO. CON2, WATER-COOLED, WITH 1640 SQ. FT. OF HEAT TRANSFER AREA AND A 5 HP DISCHARGE PUMP
5. ONE CONDENSATE RECEIVER, 25 GALLON CAPACITY
6. LIQUID SEAL COOLER, BASCO TYPE 500, MODEL PU2768
7. THREE EXTRACT HOLDING TANKS, NOS. EHT1, EHT2, AND EHT3, EACH 9'-6" DIA. X 6'-0" H., EACH 2,000 GALLONS CAPACITY, EACH WITH A 3 HP FEED PUMP (COMMON TO A/N 422029 AND 422030)
8. CHILL TANK, NO. CT1, 7'-6" DIA. X 4'-0" H., 1,300 GALLONS CAPACITY (COMMON TO A/N 422029 AND 422030)

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE MAXIMUM EMISSIONS OF VOLATILE ORGANIC COMPOUNDS FROM THE OPERATION OF THIS EQUIPMENT SHALL NOT EXCEED 10 POUNDS IN ANY ONE MONTH. [RULE 1103, RULE 1303(b)(2)—OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 4,500,000 POUNDS OF VOC CONTAINING FEED EXTRACT IN ANY ONE MONTH. [RULE 1303(b)(2)—OFFSETS]
5. THE OPERATOR SHALL MAINTAIN RECORDS TO VERIFY COMPLIANCE WITH CONDITION NO. 4 ABOVE. SUCH RECORDS SHALL BE KEPT ON THE PREMISES FOR AT LEAST TWO YEARS AND BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST. [RULE 1303(b)(2)—OFFSETS]
6. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE VACUUM EVAPORATOR AND THREE EXTRACT HOLDING TANKS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER. [RULE 1103]

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F89677
A/N 430218**

Equipment Description:

EXTRUSION SYSTEM CONSISTING OF:

1. FEED HOPPER, ACCURATE, 10 CU. FT. CAPACITY.
2. TWO SCREW FEEDERS, 0.78 H.P. AND 3 H.P.
3. EXTRUDER, 30 H.P.
4. CONVEYOR, 1'-6" W. X 16'-0" L., 0.5 H.P.
5. MILL, 7.5 H.P.
6. SCREEN, SWECO, 2'-6" DIA. X 2'-6" H., 0.5 H.P.
7. PACKAGING AREA.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 320 TONS OF MATERIAL IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF THE LAST TWO YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F89678
A/N 430219**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL 4D, WITH FOUR CARTRIDGES, EACH 1'-1" DIA. X 2'-11" H., TOTAL FILTER AREA OF 1,128 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 5 H.P. BLOWER VENTING THE FEED HOPPER, SWECO SCREEN AND THE PACKAGING AREA.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER. [RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS. [RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES. [RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

A. STACK OR EMISSION POINT IDENTIFICATION;

B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND

C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94227
A/N 432127**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL GS-12, WITH TWELVE FILTER CARTRIDGES, TOTAL FILTER AREA OF 2,400 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 40 H.P. BLOWER VENTING A FLUIDIZED BED DRYER (T8).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94228
A/N 432128**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL GS-12, WITH TWELVE FILTER CARTRIDGES, TOTAL FILTER AREA OF 2,400 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 40 H.P. BLOWER VENTING A FLUIDIZED BED DRYER (T7).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDEGS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F89679
A/N 434780**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL GS-16, WITH SIXTEEN BAGS, EACH 6'-9" DIA. X 14'-4" L., TOTAL FILTER AREA OF 3,200 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 25 H.P. BLOWER VENTING THE SUPER SACK UNLOADING STATION, BELT CONVEYOR, VACUUM MIXER/DRYER, THREE LOADING STATIONS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F89681
A/N 435311**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. THERMAL OXIDIZER, RELIABLE THERMAL TECHNOLOGIES, MODEL RTT-3.3M-125WHB, 6'-0" W. X 10'-6" L. X 5'-6" H., WITH A 6.0 MMBTU/HR HIRT, MODEL MJG-24, DIRECT NATURAL GAS FIRED BURNER.
2. EXHAUST SYSTEM WITH A 10-HP BLOWER VENTING TWO EXTRACTION TANKS, TWO PILOT EXTRACTION TANKS, SURGE TANK, VIBRATING SCREEN, SCREW PRESS, FEED CONVEYOR, DRYER PRESSURE BALANCING VALVE FOR THE PHYTONUTRIENT EXTRACTION, FILTERING, AND RECOVERY SYSTEM (A/N 420863), TURBO-FILM PROCESSOR FOR THE THIN FILM EVAPORATOR-TF1 (A/N 422029), VACUUM EVAPORATOR FOR THE THIN FILM EVAPORATOR-TF2 (A/N 422030), AND THREE EXTRACT HOLDING TANKS (COMMON TO BOTH THIN FILM EVAPORATORS - A/N 422029 AND 422030).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE THERMAL OXIDIZER SHALL BE IN FULL USE WHENEVER THE PHYTONUTRIENT EXTRACTION, FILTERING, AND RECOVERY SYSTEM (A/N 420863), THE THIN FILM EVAPORATOR—TF1 (A/N 422029), OR THE THIN FILM EVAPORATOR—TF2 (A/N 422030) IS IN OPERATION AND PROCESSING ALCOHOL-BASED EXTRACTIONS OR EVAPORATIONS. [RULE 1103, RULE 1303(b)(2)-OFFSETS]
4. THE OPERATOR SHALL OPERATE AND MAINTAIN THIS AIR POLLUTION CONTROL SYSTEM TO ACHIEVE A MINIMUM DESTRUCTION EFFICIENCY OF 98% VOC BY WEIGHT IN THE EXHAUST GASES.
[RULE 1103, RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

Periodic Monitoring:

5. THE OPERATOR SHALL USE THIS EQUIPMENT IN SUCH A MANNER THAT THE TEMPERATURE OF THE AFTERBURNER IS NOT LESS THAN 1425 DEG F. TO COMPLY WITH THIS CONDITION, THE OPERATOR SHALL INSTALL AND MAINTAIN A TEMPERATURE READING DEVICE TO ACCURATELY INDICATE THE TEMPERATURE OF THE AFTERBURNER. THE OPERATOR SHALL ALSO INSTALL AND MAINTAIN A DEVICE TO CONTINUOUSLY RECORD THE PARAMETER BEING MEASURED. [RULE 1103, RULE 1303(b)(2)-OFFSETS, RULE 3004(a)(4)]

6. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
 - A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED.[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT SOURCE TEST(S) IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:
 - A. THE TEST SHALL BE CONDUCTED AT LEAST ONCE DURING THE LIFE OF THE PERMIT.
 - B. THE TEST SHALL BE CONDUCTED TO DETERMINE THE VOC EMISSIONS USING EPA METHOD 25 OR 25A MEASURED OVER A 60 MINUTE AVERAGING TIME PERIOD.
 - C. THE TEST SHALL BE CONDUCTED TO DEMONSTRATE COMPLIANCE WITH RULE 1103 AND 1303(b)(2).[RULE 1103, RULE 1303(b)(2)-OFFSETS, RULE 3004(a)(4)]

8. THE OPERATOR SHALL OPERATE AND MAINTAIN THE THERMAL OXIDIZERS ACCORDING TO THE FOLLOWING REQUIREMENTS:
 - A. THE COMBUSTION CHAMBER TEMPERATURE SHALL BE MAINTAINED AT A MINIMUM OF 1,425 DEGREES FAHRENHEIT WHENEVER THE EQUIPMENT IT SERVES IS IN OPERATION.
 - B. THE OPERATOR SHALL OPERATE AND MAINTAIN A TEMPERATURE MEASURING AND RECORDING SYSTEM TO CONTINUOUSLY MEASURE AND RECORD THE COMBUSTION CHAMBER TEMPERATURE PURSUANT TO THE OPERATION AND MAINTENANCE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.7. SUCH A SYSTEM SHALL HAVE AN ACCURACY OF WITHIN 1% OF THE TEMPERATURE BEING MONITORED AND SHALL BE INSPECTED, MAINTAINED, AND CALIBRATED ON AN ANNUAL BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- C. FOR THE PURPOSE OF THIS CONDITION, A DEVIATION SHALL BE DEFINED AS WHEN A COMBUSTION CHAMBER TEMPERATURE OF LESS THAN 1,425 DEGREES FAHRENHEIT OCCURS DURING NORMAL OPERATION OF THE EQUIPMENT IT SERVES. THE OPERATOR SHALL REVIEW THE RECORDS OF THE COMBUSTION CHAMBER TEMPERATURE ON A DAILY BASIS TO DETERMINE IF A DEVIATION OCCURS OR SHALL INSTALL AN ALARM SYSTEM TO ALERT THE OPERATOR WHEN A DEVIATION OCCURS.
- D. WHENEVER A DEVIATION OCCURS, THE OPERATOR SHALL INSPECT THIS EQUIPMENT TO IDENTIFY THE CAUSE OF SUCH A DEVIATION, TAKE IMMEDIATE CORRECTIVE ACTION TO MAINTAIN THE COMBUSTION CHAMBER TEMPERATURE AT OR ABOVE 1,425 DEGREES FAHRENHEIT, AND KEEP RECORDS OF THE DURATION AND CAUSE (INCLUDING UNKNOWN CAUSE, IF APPLICABLE) OF THE DEVIATION AND THE CORRECTIVE ACTION TAKEN.
- E. ALL DEVIATIONS SHALL BE REPORTED TO THE AQMD PURSUANT TO THE REQUIREMENTS SPECIFIED IN 40 CFR PART 64.9 AND CONDITION NOS. 22 AND 23 IN SECTION K OF THIS PERMIT. THE REPORT SHALL INCLUDE THE TOTAL OPERATING TIME OF THIS EQUIPMENT AND THE TOTAL ACCUMULATED DURATION OF ALL DEVIATIONS FOR EACH SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K OF THIS PERMIT.
- F. THE OPERATOR SHALL SUBMIT AN APPLICATION WITH A QUALITY IMPROVEMENT PLAN (QIP) IN ACCORDANCE WITH 40 CFR PART 64.8 TO THE AQMD IF AN ACCUMULATION OF DEVIATIONS EXCEEDS 5 PERCENT DURATION OF THIS EQUIPMENT'S TOTAL OPERATING TIME FOR ANY SEMI-ANNUAL REPORTING PERIOD SPECIFIED IN CONDITION NO. 23 IN SECTION K OF THIS PERMIT. THE REQUIRED QIP SHALL BE SUBMITTED TO THE AQMD WITHIN 90 CALENDAR DAYS AFTER THE DUE DATE FOR THE SEMI-ANNUAL MONITORING REPORT.
- G. THE OPERATOR SHALL INSPECT AND MAINTAIN ALL COMPONENTS OF THIS EQUIPMENT ON AN ANNUAL BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.
- H. THE OPERATOR SHALL KEEP ADEQUATE RECORDS IN A FORMAT THAT IS ACCEPTABLE TO THE AQMD TO DEMONSTRATE COMPLIANCE WITH ALL APPLICABLE REQUIREMENTS SPECIFIED IN THIS CONDITION AND 40 CFR PART 64.9 FOR A MINIMUM OF FIVE YEARS. [RULE 1303(a)(1)-BACT, 3004(a)(4)-PERIODIC MONITORING, 40CFR PART 64]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F89682
A/N 435313**

Equipment Description:

BOILER, SELLERS, MODEL SH-LN390, WITH ONE 5,200,000 BTU PER HOUR, NATURAL GAS FIRED LOW NO_x BURNER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.
[RULE 1303(a)(1)-BACT]
4. THE BOILER SHALL EMIT NO MORE THAN 40 PPM OF OXIDES OF NITROGEN (NO_x), CALCULATED AS NO₂, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS, AT 3% O₂.
[RULE 1146]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR AND FUEL AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE.
[RULE 1146]
6. AN EQUIPMENT OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS, ADJUSTMENTS TUNE-UP, AND CALIBRATION AS STATED IN CONDITION NO. 5 SHALL BE MAINTAINED AND KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1146]

Periodic Monitoring:

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO_x EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE



FACILITY PERMIT TO OPERATE ACCESS BUSINESS GROUP LLC, NUTRILITE

ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

FOR THE PURPOSE OF DETERMINING COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT, THE EMISSIONS SHALL BE MEASURED AND AVERAGED OVER A 60 MINUTE TIME PERIOD.
[RULE 3004(a)(4)]

8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 3004 (a)(4)]
9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- D. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
 - E. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
 - F. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- E. STACK OR EMISSION POINT IDENTIFICATION;
- F. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- G. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- H. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

[RULE 3004 (a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
CO: 400 PPMV, RULE 1146
PM: 0.1 GR/SCF, RULE 409
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
NOX: 40 PPMV, RULE 1146



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94229
A/N 441899**

Equipment Description:

BLENDING/MILLING SYSTEM CONSISTING OF:

1. SWECO SCREEN, 2'-6" DIA. X 1'-3" H., WITH TWO 0.38 H.P. MOTORS.
2. PNEUMATIC TRANSFER BLOWER, VAC-U-MAX, 10 H.P.
3. BLENDER, 4'-0" DIA. X 9'-8" L., 125 H.P.
4. PACKAGING STATION.
5. TWO MILLS, 7.5 H.P. AND 15 H.P.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 490 TONS OF MATERIAL IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
- PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F94230
A/N 441902**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL 20L, WITH TWENTY FILTER CARTRIDGES, TOTAL FILTER AREA OF 4,400 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 10 H.P. BLOWER VENTING A FLUIDIZED BED DRYER (T7), FLUIDIZED BED DRYER (T8), TWO SWECO SCREENS, TWO MILLS, AND TWO PACKAGING STATIONS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDEGS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

Permit No. F92355
A/N 442846

Equipment Description:

BLENDING SYSTEM CONSISTING OF:

1. SWECO SCREEN, 2'-6" DIA. X 0'-1" H., 0.5 H.P.
2. BLENDER, LITTLEFORD, MODEL FKM-600, 3'-0" DIA. X 4'-3" L., 13 CU. FT. CAPACITY, 35 H.P., WITH TWO CHOPPERS, 10 H.P. EACH.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 320 TONS IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST TWO YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

Permit No. F92357
A/N 449766

Equipment Description:

FLUIDIZED BED DRYING, SEPARATION, AND PACKAGING SYSTEM (GLATT A) CONSISTING OF:

1. SWECO SCREEN, 2'-6" DIA. X 3'-5" H., 1/2 H.P.
2. SURGE BIN, 25 CU. FT. CAPACITY.
3. PNEUMATIC TRANSFER BLOWER, VAC-U-MAX, 10 H.P.
4. MIXING TANK, 3'-3" DIA. X 4'-0" H., 250 GALLON CAPACITY, 2 H.P.
5. PRESSURE POT.
6. FLUIDIZED BED DRYER, HOT AIR, GLATT, 5'-11" DIA. X 31'-0" H., 50 H.P.
7. RECEIVING HOPPER, 25 CU. FT. CAPACITY.
8. AUGER, 0'-6" DIA. X 4'-0" L., 3 H.P.
9. SWECO SCREEN, 5'-0" DIA. X 4'-8" H., 2.5 H.P.
10. CO-MILL, 5 H.P.
11. RECEIVING HOPPER, 75 CU. FT. CAPACITY.
12. AUGER, 0'-6" DIA. X 15'-0" L., 3 H.P.
13. SWECO SCREEN, 2'-0" DIA. X 2'-6" H., 1/3 H.P.
14. POUCH PACKAGING STATION.
15. AUGER, 0'-6" DIA. X 15'-0" L., 3 H.P.
16. SUPERSACK PACKAGING STATION.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]



AQMD

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 260 TONS IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92358
A/N 449767**

Equipment Description:

FLUIDIZED BED DRYING, SEPARATION, AND PACKAGING SYSTEM (GLATT B) CONSISTING OF:

1. SWECO SCREEN, 2'-6" DIA. X 3'-5" H., 1/2 H.P.
2. SURGE BIN, 25 CU. FT. CAPACITY.
3. PNEUMATIC TRANSFER BLOWER, VAC-U-MAX, 10 H.P.
4. MIXING TANK, 3'-3" DIA. X 4'-0" H., 250 GALLON CAPACITY, 2 H.P.
5. PRESSURE POT.
6. FLUIDIZED BED DRYER, HOT AIR, GLATT, 5'-11" DIA. X 31'-0" H., 50 H.P.
7. RECEIVING HOPPER, 25 CU. FT. CAPACITY.
8. AUGER, 0'-6" DIA. X 4'-0" L., 3 H.P.
9. SWECO SCREEN, 5'-0" DIA. X 4'-8" H., 2.5 H.P.
10. CO-MILL, 5 H.P.
11. RECEIVING HOPPER, 75 CU. FT. CAPACITY.
12. AUGER, 0'-6" DIA. X 15'-0" L., 3 H.P.
13. SWECO SCREEN, 2'-0" DIA. X 2'-6" H., 1/3 H.P.
14. POUCH PACKAGING STATION.
15. AUGER, 0'-6" DIA. X 15'-0" L., 3 H.P.
16. SUPERSACK PACKAGING STATION.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

ISSUED UNLESS OTHERWISE NOTED BELOW.

[RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE EQUIPMENT IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 260 TONS IN ANY ONE CALENDAR MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED FOR AT LEAST THE LAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92359
A/N 449768**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. BAGHOUSE, FARR, MODEL GS-10, WITH TEN FILTER BAGS, TOTAL FILTER AREA OF 2,000 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 20 H.P. BLOWER VENTING A FLUIDIZED BED DRYER (GLATT A).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER BAGS SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER BAGS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F92360
A/N 449769**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. BAGHOUSE, FARR, MODEL GS-10, WITH TEN FILTER BAGS, TOTAL FILTER AREA OF 2,000 SQ. FT., PULSE JET CLEANED.
2. EXHAUST SYSTEM WITH A 20 H.P. BLOWER VENTING A FLUIDIZED BED DRYER (GLATT B).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER BAGS SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER BAGS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F96162
A/N 475444**

Equipment Description:

PHYTONUTRIENT EXTRACTION, FILTERING AND RECOVERY SYSTEM CONSISTING OF:

1. INCLINED FEED CONVEYOR, 1'-3" W. X 47'-0" L., 5 H.P.
2. MILL, URSHELL LABORATORIES, WITH AN AGITATOR, FEED SCREW, AND IMPELLOR, 45 H.P. TOTAL.
3. PUMP, 10 H.P.
4. TWO EXTRACTION TANKS, C.E. HOWARD, ALCOHOL, STEAM HEATED, EACH 6'-3" DIA. X 9'-11" H., EACH 2,000 GALLON CAPACITY, EACH WITH A 5 H.P. PUMP AND A 2 H.P. MIXER.
5. SURGE TANK HOPPER, WITH A 2 H.P. SCREW CONVEYOR (FLOVEYOR).
6. EXTRACTION TANK, C.E. HOWARD, ALCOHOL, STEAM HEATED, 4'-5" DIA. X 5'-6" H., 400 GALLON CAPACITY, WITH A 3 H.P. PUMP AND A 2 H.P. MIXER.
7. EXTRACTION TANK, C.E. HOWARD, ALCOHOL, STEAM HEATED, 6'-0" DIA. X 5'-0" H., 1,000 GALLON CAPACITY, WITH A 3 H.P. PUMP AND TWO 2 H.P. MIXERS.
8. SEPARATOR, LIQUITEX, 2 H.P.
9. ACCUMULATION TANK, PPT INC., 1'-6" DIA. X 2'-0" H., 15 GALLON CAPACITY, WITH TWO PUMPS.
10. SCREW PRESS, REHNBERG, 20 H.P.
11. ENCLOSED CONVEYOR, 1'-1" W. X 65'-0" L., 5 H.P.
12. TWIN SCREW FEEDER WITH HOPPER, 3 H.P.
13. TURBO DRYER, WYSSMONT, STEAM HEATED, MODEL N-25, WITH A 2 H.P. CIRCULATION FAN, ROTARY TRAY, DISCHARGE AIRLOCK AND A 1/2 H.P. ROTARY VALVE.
14. PNEUMATIC TRANSFER SYSTEM, VAC-U-MAX, 7-1/2 H.P.
17. BELT CONVEYOR, 1'-0" W. X 40'-0" L., 1 H.P.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

18. PRODUCT RECOVERY SYSTEM, SLY, MODEL SBR-1011-R, WITH 1,320 SQ. FT. HEAT TRANSFER AREA, A 20 H.P. EXHAUST FAN AND A ½ H.P. ROTARY VALVE.
19. CONDENSER, 1635 SQ. FT. HEAT TRANSFER AREA.
20. SOLVENT RECEIVER, 425 GALLON CAPACITY.
21. TWO PARALLEL FLOW FILTERS.
22. RECIRCULATION PUMP, GOULD PUMP, 3 H.P.
23. SOLVENT RECOVERY PUMP, GOULD PUMP, 3 H.P.
24. SOLVENT RECOVERY RECIRCULATION FAN, 40 H.P.
25. DRYER PRESSURE BALANCING VALVE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 1,781,220 POUNDS OF VOC-CONTAINING SOLVENTS IN ANY 30 DAY PERIOD.
[RULE 1303(b)(2)-OFFSETS]
4. THIS EQUIPMENT SHALL COMPLY WITH THE EMISSIONS STANDARDS OF RULE 1103(d).
[RULE 1103]
5. THE TOTAL AMOUNT OF DRY MATERIALS ADDED TO THE SURGE TANKS HOPPER (ITEM NO. 5) SHALL NOT EXCEED 902,880 POUNDS IN ANY 30 DAY PERIOD.
[RULE 1303(b)(2)-OFFSETS]
6. DURING EXTRACTION, EACH EXTRACTION TANK SHALL VENT ONLY THROUGH A PRESSURE RELIEF VALVE SET AT 0.5 OZ PRESSURE OR HIGHER.
[RULE 1303(a)(1)-BACT]
7. THE TEMPERATURE OF THE NITROGEN GAS STREAM EXITING THE CONDENSER SHALL NOT EXCEED 90 DEGREES FAHRENHEIT.
[RULE 1103, RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

8. THE TEMPERATURE OF THE COOLING WATER SUPPLIED TO THE CONDENSER SHALL NOT EXCEED 90 DEGREES FAHRENHEIT.
[RULE 1103, RULE 1303(a)(1)-BACT]
9. NOT LESS THAN 250 GALLONS OF COOLING WATER SHALL BE SUPPLIED TO THE CONDENSER WHEN ALCOHOL IS USED FOR EXTRACTION.
[RULE 1103, RULE 1303(a)(1)-BACT]
10. A TEMPERATURE GAUGE AND RECORDER SHALL BE INSTALLED AND MAINTAINED TO MEASURE THE TEMPERATURE OF THE GAS EXITING THE CONDENSER, AND A TEMPERATURE GAUGE AND RECORDER SHALL BE INSTALLED AND MAINTAINED TO MEASURE THE TEMPERATURE OF THE WATER ENTERING THE CONDENSER.
[RULE 1103, RULE 1303(a)(1)-BACT]
11. A FLOW METER INDICATING GPM SHALL BE INSTALLED AND MAINTAINED IN THE COOLING WATER SUPPLY LINE TO THE CONDENSER.
[RULE 1103, RULE 1303(a)(1)-BACT]
12. THE DUST COLLECTED IN THE PRODUCT RECOVERY SYSTEM SHALL BE DISCHARGED ONLY INTO CLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT]
13. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE SURGE TANK HOPPER (ITEM NO. 5), FOUR EXTRACTION TANKS (ITEM NO. 4, 6 AND 7), SEPARATOR (ITEM NO. 8), SCREW PRESS (ITEM NO. 10), TWIN SCREW FEEDER (ITEM NO. 23) AND DRYER PRESSURE BALANCING VALVE (ITEM NO. 25) ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATED BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
14. THE OPERATOR SHALL MAINTAIN ADEQUATE RECORDS TO VERIFY COMPLIANCE WITH CONDITIONS NOS. 3, 4, 5, 7, 8, AND 9. SUCH RECORDS SHALL BE KEPT ON THE PREMISES FOR AT LEAST THE LAST TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1103, RULE 1303(a)(1)-BACT]

Periodic Monitoring:

15. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.
[RULE 3004(a)(4)]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

16. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.
[RULE 3004(a)(4)]
17. THE OPERATOR SHALL USE THIS EQUIPMENT IN SUCH A MANNER THAT THE FLOW RATE OF THE CONDENSER WATER IS NOT LESS THAN 250 GPM. TO COMPLY WITH THIS CONDITION THE OPERATOR SHALL INSTALL AND MAINTAIN A FLOW METER TO ACCURATELY INDICATE THE FLOW RATE OF THE COOLING WATER. THE OPERATOR SHALL DETERMINE AND RECORD THE PARAMETER BEING MONITORED ONCE EVERY DAY.
[RULE 3004(a)(4)]

Emissions And Requirements:

18. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F96163
A/N 475445**

Equipment Description:

FOOD SUPPLEMENT SPRAY DRYING SYSTEM CONSISTING OF:

1. BULK-SACK UNLOADING STATION WITH A ½ H.P. ROTARY AIRLOCK.
2. PNEUMATIC TRANSFER SYSTEM, REIMELT, 40 H.P.
3. GUMP SIFTER.
4. PRODUCT RECEIVER, REIMELT, 3'-0" DIA. X 8'-6" H., 25 CU. FT. CAPACITY, WITH A ½ H.P. ROTARY AIRLOCK.
5. GRAVIMETRIC FEED SYSTEM, K-TRON, WITH A 3 CU. FT. HOPPER, A ¾ H.P. TWIN-SCREW FEEDER, AND A ¾ H.P. BELT FEEDER.
6. BREDDO TANK SYSTEM, 4'-8" DIA. X 4'-2" H., WITH A 3 H.P. AGITATOR AND A 1-1/2 H.P. TRANSFER PUMP.
7. HEATER, MAXON, DIRECT GAS FIRED, WITH A MAXON MODEL NP-III-18 BURNER AND A 7.5 H.P. SUPPLY FAN.
8. TOTE UNLOADING SYSTEM.
9. MIX TANK, 4'-8" DIA. X 4'-2" H., WITH TWO 3 H.P. AGITATORS AND A 3 H.P. TRANSFER PUMP.
10. FEED TANK, 4'-8" DIA. X 4'-2" H., WITH A 3 H.P. AGITATOR AND A 1-1/2 H.P. TRANSFER PUMP.
11. PASTEURIZATION SYSTEMS, HEAT EXCHANGERS, ALFA-LAVA, MODEL 15389, 1'-8" W. X 3'-7" L. X 4'-0" H., PLATE AND FRAME TYPE, 644 SQ. FT. OF HEAT TRANSFER AREA.
12. SCHUGI NOZZLE, 7.5 H.P.
13. ATOMIZER NOZZLE, 5 H.P.
14. SPRAY DRYER, NIRO, MODEL 8-80R, WITH A ½ H.P. COOLING FAN AND A 5 H.P. SWEEP FAN.
15. CYCLONE SEPARATOR, CARMAN, MODEL CS-195, 1'-8" DIA. X 6'-10" H.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

16. FLUID BED COOLER, CARMAN, MODEL FBP-140, 1'-10" W. X 9'-2" L. X 4'-3" H., 2 H.P.
17. CYCLONE SEPARATOR, 1'-6" DIA. X 2'-4" H.
18. INCLINE AUGER, 0'-8" DIA. X 10'-0" L., 1-1/2 H.P.
19. SEPARATOR, SWECO, 3'-0" DIA. X 2'-6" H., 5 H.P.
20. RECEIVING POT, WITH A 10 H.P. VACUUM TRANSFER SYSTEM.
21. PRODUCT RECEIVER, VAC-U-MAX, 10 CU. FT. CAPACITY.
22. SUPER SACK PRODUCT HOPPER, 14.5 CU. FT. CAPACITY.
23. SUPER SACK LOADING STATION, MATERIAL MASTER, WITH A 1-1/2 H.P. LIFT AND A 1/2 H.P. DISCHARGE CONVEYOR.
24. BULK BAG PRODUCT HOPPER, 40 CU. FT. CAPACITY.
25. BULK BAG LOADING STATION.
26. BAG SEALER WITH CONVEYOR.
27. BAG FLATTENER CONVEYOR.
28. METAL DETECTOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE MAXIMUM EMISSIONS OF SOLID PARTICULATE MATTER FROM THE OPERATION OF THIS EQUIPMENT SHALL NOT EXCEED 21 POUNDS IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]
4. THE MAXIMUM QUANTITY OF MATERIALS PROCESS IN THIS EQUIPMENT SHALL NOT EXCEED 1,050 TONS IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

5. NO ORGANIC SOLVENTS SHALL BE USED IN THE SPRAY DRYER SYSTEM.
[RULE 1303(b)(2)-OFFSETS]

6. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE PRODUCT CYCLONE, TWO CYCLONE SEPARATORS, AND SACK DUMP HOPER ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]

7. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE MAINTAINED AND KEPT ON FILE FOR A MINIMUM OF THE LAST TWO YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(a)(1)-BACT]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F96164
A/N 475446**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL GS-4, REVERSE AIR TYPE, WITH FOUR FILTER CARTRIDGES, EACH 1'-3" DIA. X 3'-3" L., TOTAL FILTER AREA OF 900 SQ. FT.
2. EXHAUST SYSTEM WITH A 10 H.P. BLOWER VENTING FOUR EXTRACTION TANKS IN APPLICATION NO. 475444 AND ONE MIX TANK IN APPLICATION NO. 475445.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT. THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. F96165
A/N 475447**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL GS-10, REVERSE AIR TYPE, WITH TEN FILTER CARTRIDGES, EACH 1'-3" DIA. X 3'-3" L., TOTAL FILTER AREA OF 2,225 SQ. FT.
2. EXHAUST SYSTEM WITH A 20 H.P. BLOWER VENTING A PRODUCT RECEIVER, CYCLONE SEPARATOR, SUPER SACK PRODUCT HOPPER AND A BULK BAG PRODUCT HOPPER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE DUST COLLECTOR SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 7. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

[RULE 3004 (a)(4)]

- 8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

- 9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. G1099
A/N 478498**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, FARR, MODEL GS-16, WITH SIXTEEN CARTRIDGES, SPUN BONDED POLYESTER, EACH 1'- 3" DIA. X 3'- 3" L., 3,600 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING TYPE.
2. EXHAUST SYSTEM WITH A 25 H.P. BLOWER VENTING A VACUUM PUMP, TWO PACKAGING STATIONS, TWO BAG DUMP STATIONS, THREE BIN VENTS AND FOUR SCREENS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS OR RETURNED TO PROCESS AND SHALL NOT BE HANDLED IN A MANNER THAT MAY RESULT IN THE RE-RELEASE OF COLLECTED MATERIALS TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT,



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO CONSTRUCT

**Permit No.
A/N 511248**

Equipment Description:

GRANULATED PRODUCTS MANUFACTURING SYSTEM (FULLY ENCLOSED) CONSISTING OF:

1. SCREEN, SWECO, 5'-0" DIA. X 2'-6" H., 2.5 H.P.
2. PADDLE MIXER, LITTEFORD DAY, 3,000 LITER CAPACITY, WITH A 150 H.P. MAIN MOTOR AND 10 H.P. CHOPPER MOTOR.
3. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 10 H.P.
4. GRAVIMETRIC FEEDER WITH A 19 CU. FT. CONICAL HOPPER, SCHENCK ACCURATE.
5. SUPER SACK UNLOADING STATION WITH AUGER.
6. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 25 H.P.
7. GRAVIMETRIC FEEDER WITH A 19 CU. FT. CONICAL HOPPER, SCHENCK ACCURATE.
8. MIXING TANK, 300 GALLONS CAPACITY, BREDDO, WITH A 40 H.P. MIXER.
9. MIXING TANK, 500 GALLONS CAPACITY, WALKER STAINLESS, WITH A 2 H.P. MIXER.
10. SCHUGI MIXER, BEPEX INTERNATIONAL, MODEL FXD-160, 10 H.P.
11. FLUID BED DRYER, VENTILEX USA, 1.5 MMBTU/HR, NATURAL GAS, WITH AN ULTRA LOW NOX BURNER, MAXON, MODEL EB-3 M PAKT.
12. AUGER, 10" DIA. X 16'-8" H., 3 H.P.
13. MILL, FITZ, MODEL G, 7.5 H.P.
14. SCREEN, SWECO, 1.5 H.P.
15. HOPPER, 24" W. X 33" L. X 23" H.
16. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 2 H.P.
17. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 10 H.P.
18. SCREEN, SWECO, 2'-6" DIA., 0.5 H.P.
19. MILL, FITZ MILL, MODEL 6, 7.5 H.P.
20. STORAGE HOPPER, REIMELT, 4'-2" DIA. X 7'-0" H.
21. BULK PACKAGING STATION, CONTROL AND METERING BULK FILLING.
22. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 25 H.P.
23. SCREEN, SWECO, 5'-0" DIA. X 2'-6" H., 2.5 H.P.
24. MILL, FITZ MILL, MODEL 6, 7.5 H.P.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

25. STORAGE HOPPER, REIMELT, 4'- 2" DIA. X 7'- 0" H.
26. BULK PACKAGING STATION, DRUM, SUPER SACK, OR OTHER BULK FILLING.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE SUPER SACK UNLOADING STATION, SCREENS, PADDLE MIXER, FLUID BED DRYER, CYCLONE, MILLS AND PACKAGING STATIONS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 2,970 TONS OF MATERIAL IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF THE LAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]
6. THE FLUID BED DRYER SHALL EMIT NO MORE THAN 30 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO₂, AND NO MORE THAN 300 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS, AT 3% O₂.
[RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL CONDUCT SOURCE TEST(S) IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:
 - A. THE TEST SHALL BE CONDUCTED WITHIN 90 DAYS AFTER ACHIEVING MAXIMUM PRODUCTION RATE, BUT NO LATER THAN 120 AFTER INITIAL START-UP.
 - B. SOURCE TEST SHALL BE CONDUCTED WHEN THIS EQUIPMENT IS OPERATING AT MAXIMUM LOAD.
 - C. THE TEST SHALL BE CONDUCTED TO DETERMINE THE NOX AND CO EMISSIONS AT THE OUTLET.
 - D. THE TEST SHALL BE CONDUCTED TO DEMONSTRATE COMPLIANCE WITH BACT.[RULE 1303(a)(1)-BACT]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

8. THE OPERATOR SHALL PROVIDE TO THE DISTRICT A SOURCE TEST REPORT IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:
- A. SOURCE TEST RESULTS SHALL BE SUBMITTED TO THE DISTRICT NO LATER THAN 60 DAYS AFTER THE SOURCE TEST WAS CONDUCTED.
 - B. EMISSION DATA SHALL BE EXPRESSED IN TERMS OF CONCENTRATION (PPMV), CORRECTED TO 3 PERCENT OXYGEN, DRY BASIS.
- [RULE 1303(a)(1)-BACT]

Periodic Monitoring:

9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST; OR
 - B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
 - C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
 - D. VISIBLE EMISSION OBSERVATIONS RECORDED BY A CERTIFIED SMOKE READER.
- [RULE 3004 (a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. G8008
A/N 484341**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, NO. LVB22DUSTCOL03, TORIT, MODEL SDF-6, WITH SIX CARTRIDGES, ULTRA WEB, EACH 9.2" DIA. X 1'- 10.3" L., 618 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING TYPE.
- 2.
3. EXHAUST SYSTEM WITH A 10 H.P. BLOWER VENTING A SCREEN AND A PADDLE MIXER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS OR RETURNED TO PROCESS AND SHALL NOT BE HANDLED IN A MANNER THAT MAY RESULT IN THE RE-RELEASE OF COLLECTED MATERIALS TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. G8009
A/N 484344**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, NO. LVB22DUSTCOL04, TORIT, MODEL SDF-6, WITH SIX CARTRIDGES, ULTRA WEB, EACH 9.2" DIA. X 1'- 10.3" L., 618 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING TYPE.
2. EXHAUST SYSTEM WITH A 10 H.P. BLOWER VENTING A SCREEN.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS OR RETURNED TO PROCESS AND SHALL NOT BE HANDLED IN A MANNER THAT MAY RESULT IN THE RE-RELEASE OF COLLECTED MATERIALS TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT. THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

Permit No. G1100
A/N 484345

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, NO. LVB22DUSTCOL05, TORIT, MODEL SDF-6, WITH SIX CARTRIDGES, ULTRA WEB, EACH 9.2" DIA. X 1'- 10.3" L., 618 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING TYPE.
2. EXHAUST SYSTEM WITH A 10 H.P. BLOWER VENTING A SCREEN.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS OR RETURNED TO PROCESS AND SHALL NOT BE HANDLED IN A MANNER THAT MAY RESULT IN THE RE-RELEASE OF COLLECTED MATERIALS TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. G8010
A/N 484346**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, NO. LVB22DUSTCOL02, FARR, MODEL GS-16-OS, WITH SIXTEEN CARTRIDGES, SPUN BONDED POLYESTER, EACH 1'- 3" DIA. X 3'- 3" L., 3,600 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING TYPE.
2. CYCLONE, VENTILEX USA, 3'- 7" DIA. X 18'- 0" H.
3. EXHAUST SYSTEM WITH A 40 H.P. BLOWER VENTING THE FLUID BED DRYER.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS OR RETURNED TO PROCESS AND SHALL NOT BE HANDLED IN A MANNER THAT MAY RESULT IN THE RE-RELEASE OF COLLECTED MATERIALS TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT. THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. G8011
A/N 484347**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. DUST COLLECTOR, NO. LVB22DUSTCOL01, FARR, MODEL GS-16-EX, WITH SIXTEEN BAGS, SPUN BONDED POLYESTER, EACH 1'- 3" DIA. X 3'- 3" L., 3,600 SQ. FT. TOTAL FILTER AREA, PULSE JET CLEANING TYPE.
2. EXHAUST SYSTEM WITH A 25 H.P. BLOWER VENTING THREE SCREENS, A PASTEURIZER, TWO MILLS AND THREE PACKAGING STATIONS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE FILTER CARTRIDGES SHALL BE CLEANED AT A FREQUENCY SPECIFIED BY THE MANUFACTURER.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
4. DUST COLLECTED IN THE BAGHOUSE SHALL BE DISCHARGED ONLY INTO ENCLOSED CONTAINERS OR RETURNED TO PROCESS AND SHALL NOT BE HANDLED IN A MANNER THAT MAY RESULT IN THE RE-RELEASE OF COLLECTED MATERIALS TO THE ATMOSPHERE.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]
5. A MECHANICAL GAUGE SHALL BE INSTALLED AND MAINTAINED SO AS TO INDICATE, IN INCHES WATER COLUMN, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE FILTER CARTRIDGES.
[RULE 1303(a)(1)-BACT; RULE 3004(a)(4)-PERIODIC MONITORING]

Periodic Monitoring:

6. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT,



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

- A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
- B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
- C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

7. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A SEMI-ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE SEMI-ANNUAL PERIOD. THE ROUTINE SEMI-ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED.

[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO OPERATE

**Permit No. G8800
A/N 502182**

Equipment Description:

PASTEURIZED PRODUCTS MANUFACTURING SYSTEM (FULLY ENCLOSED) CONSISTING OF:

1. SUPER SACK UNLOADING STATION WITH AUGER AND HOPPER.
2. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 25 H.P.
3. PASTEURIZER, LITTLEFORD DAY INC., MODEL VT-4200-D, 148 CU. FT. CAPACITY.
4. MILL, BAUERMIESTER MILL, 50 H.P.
5. BULK HOPPER
6. PNEUMATIC CONVEYING SYSTEM WITH FILTER, VAC-U-MAX, 30 H.P.
7. RECEIVING HOPPER, REIMELT, 5'- 4" DIA. X 17'- 4" H.
8. SCREEN, SWECO, 5'- 0" DIA. X 2'-6" H., 2.5 H.P.
9. STORAGE HOPPER, REIMELT, 4'- 2" DIA. X 7'- 0" H.
10. BULK PACKAGING STATION, DRUM, SUPER SACK, OR OTHER BULK FILLING.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE BULK UNLOADING STATION, PASTEURIZER, SCREEN AND PACKAGING STATION ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO CONSTRUCT BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]
4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 792 TONS OF MATERIAL IN ANY ONE MONTH.
[RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 4. THE RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF THE LAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]

Periodic Monitoring:

6. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- D. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST; OR
 - E. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
 - F. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- E. STACK OR EMISSION POINT IDENTIFICATION;
- F. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- G. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- H. VISIBLE EMISSION OBSERVATIONS RECORDED BY A CERTIFIED SMOKE READER.
[RULE 3004 (a)(4)]

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO CONSTRUCT

**Permit No.
A/N 504117**

Equipment Description:

EVAPORATOR SYSTEM CONSISTING OF:

1. SHAKER SCREEN, WET
2. SCREW PRESS, 2 H.P.
3. FEED TANK, 50 GALLONS CAPACITY
4. FEED PUMP, 0.5 H.P.
5. EVAPORATOR, THIN FILM, CENTRIFUGAL TYPE, FT INDUSTRIAL, MODEL CT1-09RM, ONE STEAM HEATED.
6. CONCENTRATE PUMP, 0.5 H.P.
7. CONCENTRATE COOLER, TUBE IN SHELL HEAT EXCHANGER
8. CONDENSER, VAPOR, TUBE IN SHELL HEAT EXCHANGER
9. CYCLONE SEPARATOR
10. PRODUCT CONDENSATE PUMP, 0.74 H.P.
11. VACUUM PUMP, 2 H.P.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
3. THE MAXIMUM EMISSIONS OF VOLATILE ORGANIC COMPOUNDS FROM THE OPERATION OF THIS EQUIPMENT SHALL NOT EXCEED 37 POUNDS IN ANY ONE MONTH. [RULE 1103, RULE 1303(b)(2)—OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

4. THIS EQUIPMENT SHALL NOT PROCESS MORE THAN 92,400 POUNDS OF VOC CONTAINING SOLVENT IN ANY ONE MONTH. [RULE 1303(b)(2)—OFFSETS]
5. THE OPERATOR SHALL MAINTAIN RECORDS TO VERIFY COMPLIANCE WITH CONDITION NO. 4 ABOVE. SUCH RECORDS SHALL BE KEPT ON THE PREMISES FOR AT LEAST TWO YEARS AND BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST. [RULE 1303(b)(2)—OFFSETS]
6. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE FEED TANK AND EVAPORATOR ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER. [RULE 1103]
7. THE OPERATOR OF THIS EQUIPMENT SHALL CONDUCT A SOURCE TEST IN ACCORDANCE WITH THE FOLLOWING CONDITIONS:
 - A. THE SOURCE TEST SHALL BE CONDUCTED WITHIN 180 DAYS AFTER ACHIEVING MAXIMUM PRODUCTION BUT NO LATER THAN 60 DAYS AFTER INITIAL START UP.
 - B. THE SOURCE TEST SHALL BE CONDUCTED TO DETERMINE THE ROG EMISSIONS FROM THE FEED TANK AND EVAPORATOR.
 - C. THE TEST SHALL BE CONDUCTED WHILE THIS EQUIPMENT IS OPERATING AT MAXIMUM CAPACITY. [RULE 1303(b)(2)—OFFSETS]
8. THE SOURCE TEST SHALL BE CONDUCTED ACCORDING TO A DISTRICT APPROVED PROTOCOL. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED FOR APPROVAL TO THE DISTRICT AT LEAST 60 DAYS PRIOR TO TESTING AND SHALL BE APPROVED BY THE DISTRICT BEFORE THE TESTING COMMENCES. THE PROTOCOL SHALL INCLUDE SAMPLING AND TEST METHODS AND A LIST OF OPERATING CONDITIONS TO BE MONITORED DURING THE SOURCE TEST. [RULE 1303(b)(2)—OFFSETS]
9. SOURCE TEST NOTIFICATION SHALL BE SUBMITTED IN WRITING TO THE DISTRICT AT LEAST 14 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. [RULE 1303(b)(2)—OFFSETS]
10. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT WITHIN 60 DAYS AFTER THE SOURCE TESTING DATE. [RULE 1303(b)(2)—OFFSETS]
11. EMISSION DATA SHALL BE EXPRESSED IN TERMS OF MASS RATE (LBS/HR). [RULE 1303(b)(2)—OFFSETS]
12. THE TEST SHALL BE CONDUCTED BY A TESTING LABORATORY APPROVED BY THE DISTRICT IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST). [RULE 1303(b)(2)—OFFSETS]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO CONSTRUCT

**Permit No.
A/N 504118**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. THERMAL OXIDIZER, RELIABLE THERMAL TECHNOLOGIES, MODEL RTT-3.3M-125WHB, 6'-0" W. X 10'-6" L. X 5'-6" H., WITH A 6.0 MMBTU/HR HIRT, MODEL MJG-24, DIRECT NATURAL GAS FIRED BURNER.
2. EXHAUST SYSTEM WITH A 10-HP BLOWER VENTING A FEED TANK, AN EVAPORATOR (A/N 504117), THREE EXTRACTION TANKS, SURGE TANK, VIBRATING SCREEN, SCREW PRESS, FEED CONVEYOR, DRYER PRESSURE BALANCING VALVE FOR THE PHYTONUTRIENT EXTRACTION, FILTERING, AND RECOVERY SYSTEM (A/N 475444/F96162), TURBO-FILM PROCESSOR FOR THE THIN FILM EVAPORATOR-TF1 (A/N 422029/F78772), VACUUM EVAPORATOR FOR THE THIN FILM EVAPORATOR-TF2 (A/N 422030/F78773), AND THREE EXTRACT HOLDING TANKS (COMMON TO BOTH THIN FILM EVAPORATORS – A/N 422029/F78772 AND A/N 422030/F78773).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TEMPERATURE OF NOT LESS THAN 1425 DEGREES FAHRENHEIT SHALL BE MAINTAINED IN THE THERMAL OXIDIZER WHENEVER THE EQUIPMENT IT SERVES IS IN OPERATION. [RULE 1103, RULE 1303(b)(2)-OFFSETS]
4. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUSLY INDICATING AND RECORDING DEVICE TO ACCURATELY RECORD THE OPERATING TEMPERATURE OF THE THERMAL OXIDIZER.
[RULE 1103, RULE 1303(b)(2)-OFFSETS, RULE 3004(a)(4)]
5. THE THERMAL OXIDIZER SHALL BE IN FULL USE WHENEVER THE EVAPORATOR SYSTEM (A/N 504118), THE PHYTONUTRIENT EXTRACTION, FILTERING, AND RECOVERY SYSTEM (A/N 475444), THE THIN FILM EVAPORATOR—TF1 (A/N 422029), OR THE THIN FILM EVAPORATOR—TF2 (A/N 422030) ARE IN OPERATION AND PROCESSING ALCOHOL-BASED EXTRACTIONS OR EVAPORATIONS. [RULE 1103, RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

6. THE OPERATOR SHALL OPERATE AND MAINTAIN THIS AIR POLLUTION CONTROL SYSTEM TO ACHIEVE A MINIMUM DESTRUCTION EFFICIENCY OF 98% VOC BY WEIGHT IN THE EXHAUST GASES. [RULE 1103, RULE 1303(b)(2)-OFFSETS]

Periodic Monitoring:

7. THE OPERATOR SHALL USE THIS EQUIPMENT IN SUCH A MANNER THAT THE TEMPERATURE OF THE AFTERBURNER IS NOT LESS THAN 1425 DEG F. TO COMPLY WITH THIS CONDITION, THE OPERATOR SHALL INSTALL AND MAINTAIN A TEMPERATURE READING DEVICE TO ACCURATELY INDICATE THE TEMPERATURE OF THE AFTERBURNER. THE OPERATOR SHALL ALSO INSTALL AND MAINTAIN A DEVICE TO CONTINUOUSLY RECORD THE PARAMETER BEING MEASURED. [RULE 3004(a)(4)]
8. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
- A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED.
- [RULE 3004 (a)(4)]
9. THE OPERATOR SHALL CONDUCT SOURCE TEST(S) IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:
- A. THE TEST SHALL BE CONDUCTED AT LEAST ONCE DURING THE LIFE OF THE PERMIT.
 - B. THE TEST SHALL BE CONDUCTED TO DETERMINE THE VOC EMISSIONS USING EPA METHOD 25 OR 25A MEASURED OVER A 60 MINUTE AVERAGING TIME PERIOD.
 - C. THE TEST SHALL BE CONDUCTED TO DEMONSTRATE COMPLIANCE WITH RULE 1103 AND 1303(b)(2).
- [RULE 3004(a)(4)]

Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO CONSTRUCT

**Permit No.
A/N 514696**

Equipment Description:

STORAGE TANK, ETHANOL, NO. AT-1, FIXED ROOF, 7'-7.5" DIA. X 15'-1" H., 5,000 GALLON CAPACITY WITH A VAPOR RETURN SYSTEM AND A 0.03 PSIG COMBINATION PRESSURE/VACUUM RELIEF VALVE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS TANK SHALL ONLY BE USED TO STORE FRESH AND RECLAIM (RECYCLE) AQUEOUS ETHYL ALCOHOL.
[RULE 1303(b)(2)-OFFSETS]
4. THIS TANK SHALL NOT BE FILLED WITH FRESH ALCOHOL UNLESS THE DISPLACED VAPORS ARE RETURNED TO THE UNLOADING TANKER THROUGH A GAS TIGHT VAPOR LINE.
[RULE 1303(a)(1)-BACT]
5. THE VAPOR RETURN SYSTEM SHALL BE IN FULL USE DURING THE FRESH ALCOHOL LOADING OPERATION TO ENSURE COMPLETE RETURN OF THE DISPLACED VAPOR FROM THE TANK TO THE DELIVERY VEHICLE.
[RULE 1303(a)(1)-BACT]
6. THE MAXIMUM QUANTITY OF FRESH AND RECLAIM ALCOHOL LOADED INTO THIS STORAGE TANK SHALL NOT EXCEED 205,480 GALLONS IN ANY 30-DAY PERIOD.
[RULE 1303(b)(2)-OFFSETS]
7. THE OPERATOR SHALL MAINTAIN RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]
8. THIS TANK SHALL NOT BE FILLED WITH RECLAIM ALCOHOL UNLESS THE DISPLACED VAPORS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO CONSTRUCT

**Permit No.
A/N 514697**

Equipment Description:

STORAGE TANK, ETHANOL, NO. AT-2, FIXED ROOF, 7'-7.5" DIA. X 15'-1" H., 5,000 GALLON CAPACITY WITH A VAPOR RETURN SYSTEM AND A 0.03 PSIG COMBINATION PRESSURE/VACUUM RELIEF VALVE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS TANK SHALL ONLY BE USED TO STORE FRESH AND RECLAIM (RECYCLE) AQUEOUS ETHYL ALCOHOL.
[RULE 1303(b)(2)-OFFSETS]
4. THIS TANK SHALL NOT BE FILLED WITH FRESH ALCOHOL UNLESS THE DISPLACED VAPORS ARE RETURNED TO THE UNLOADING TANKER THROUGH A GAS TIGHT VAPOR LINE.
[RULE 1303(a)(1)-BACT]
5. THE VAPOR RETURN SYSTEM SHALL BE IN FULL USE DURING THE FRESH ALCOHOL LOADING OPERATION TO ENSURE COMPLETE RETURN OF THE DISPLACED VAPOR FROM THE TANK TO THE DELIVERY VEHICLE.
[RULE 1303(a)(1)-BACT]
6. THE MAXIMUM QUANTITY OF FRESH AND RECLAIM ALCOHOL LOADED INTO THIS STORAGE TANK SHALL NOT EXCEED 205,480 GALLONS IN ANY 30-DAY PERIOD.
[RULE 1303(b)(2)-OFFSETS]
7. THE OPERATOR SHALL MAINTAIN RECORDS TO DEMONSTRATE COMPLIANCE WITH CONDITION NO. 6. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF AT LEAST TWO YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1303(b)(2)-OFFSETS]
8. THIS TANK SHALL NOT BE FILLED WITH RECLAIM ALCOHOL UNLESS THE DISPLACED VAPORS ARE VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

WHICH HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1)-BACT]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

PERMIT TO CONSTRUCT

**Permit No.
A/N 514695**

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER, FALMOUTH PRODUCTS, MODEL FALCO 600, 3'-4" W. X 6'-6" L. X 7'-3" H., 36 KW ELECTRICALLY HEATED, WITH 5 CUBIC FEET OF CATALYST.
2. EXHAUST SYSTEM WITH A 15-HP BLOWER VENTING TWO ETHANOL TANKS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. A TEMPERATURE OF NOT LESS THAN 625 DEGREES FAHRENHEIT SHALL BE MAINTAINED IN THE CATALYTIC OXIDIZER'S CATALYST WHENEVER THE EQUIPMENT IT SERVES IS IN OPERATION.
[RULE 1103, RULE 1303(b)(2)-OFFSETS]
4. A TEMPERATURE INDICATING AND RECORDING SYSTEM SHALL BE INSTALLED AND MAINTAINED TO CONTINUOUSLY MEASURE AND RECORD THE TEMPERATURE OF THE CATALYTIC OXIDIZER'S CATALYST. SUCH A SYSTEM SHALL HAVE AN ACCURACY OF WITHIN 1% OF THE TEMPERATURE BEING MONITORED AND SHALL BE INSPECTED, MAINTAINED, AND CALIBRATED ON AN ANNUAL BASIS IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS. THE TEMPERATURE INDICATING AND RECORDING SYSTEM SHALL BE IN OPERATION WHENEVER THE EQUIPMENT IT SERVES IS IN OPERATION.
[RULE 1103, RULE 1303(b)(2)-OFFSETS, RULE 3004(a)(4)]
5. THE CATALYTIC OXIDIZER SHALL BE MAINTAINED AND OPERATED AT A MINIMUM VOC DESTRUCTION EFFICIENCY OF 95% WHENEVER THE EQUIPMENT IT SERVES IS IN OPERATION.
[RULE 1103, RULE 1303(b)(2)-OFFSETS]
6. THE CATALYST SHALL BE MAINTAINED ACCORDING TO THE MANUFACTURER'S RECOMMENDATIONS.
[RULE 1103, RULE 1303(b)(2)-OFFSETS]



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

7. THE CATALYST IN THE OXIDIZER SHALL BE TESTED FOR ACTIVITY EFFICIENCY ACCORDING TO THE MANUFACTURER'S RECOMMENDED METHOD AT LEAST ONCE EACH CALENDAR YEAR.
[RULE 1103, RULE 1303(b)(2)-OFFSETS]
8. RECORDS SHALL BE MAINTAINED TO DEMONSTRATE COMPLIANCE WITH CONDITION NOS. 3, 4, 5 AND 6. THE RECORDS SHALL BE KEPT FOR AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.
[RULE 1103, RULE 1303(b)(2)-OFFSETS]

Periodic Monitoring:

9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
 - A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED.[RULE 3004 (a)(4)]
10. THE OPERATOR SHALL CONDUCT SOURCE TEST(S) NO LATER THAN 180 DAYS AFTER COMPLETION OF CONSTRUCTION OF THE CATALYTIC OXIDIZER UNLESS OTHERWISE APPROVED IN WRITING BY THE DISTRICT.
[RULE 3004(a)(4)]
11. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED TO THE DISTRICT ENGINEER NO LATER THAN 60 DAYS AFTER THE INITIAL START-UP OF THE CATALYTIC OXIDIZER UNLESS OTHERWISE APPROVED IN WRITING BY THE DISTRICT. THE TEST PROTOCOL SHALL BE APPROVED IN WRITING BY THE DISTRICT BEFORE THE TEST COMMENCES. THE TEST PROTOCOL SHALL INCLUDE THE COMPLETED DISTRICT FORMS ST-1 AND ST-2 SPECIFYING THE PROPOSED OPERATING CONDITIONS OF THE EQUIPMENT DURING THE TEST, THE IDENTITY OF THE TESTING LABORATORY, A STATEMENT FROM THE TESTING LABORATORY CERTIFYING IT MEETS THE CRITERIA IN DISTRICT RULE 304(k), AND A DESCRIPTION OF THE SAMPLING AND ANALYTICAL PROCEDURES TO BE USED.
[RULE 3004(a)(4)]
12. THE OPERATOR SHALL CONDUCT SOURCE TEST(S) IN ACCORDANCE WITH THE FOLLOWING SPECIFICATIONS:
 - A. THE TEST SHALL BE CONDUCTED AT MAXIMUM OPERATING CONDITIONS WHILE USING ALCOHOL FOR EXTRACTATIONS OR EVAPORATIONS.



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

- B. THE TEST SHALL BE CONDUCTED TO DETERMINE THE DESTRUCTION EFFICIENCY OF THE CATALYTIC OXIDIZER AND THE VOC EMISSIONS USING APPROVED DISTRICT METHOD.
 - C. THE TEST SHALL BE CONDUCTED TO DEMONSTRATE COMPLIANCE WITH RULE 1103 AND 1303(b)(2).
[RULE 3004(a)(4)]
13. A WRITTEN NOTICE OF THE SOURCE TEST(S) SHALL BE SUBMITTED TO THE DISTRICT ENGINEER AT LEAST 7 DAYS PRIOR TO THE SOURCE TESTING DATE SO THAT AN OBSERVER FROM THE DISTRICT MAY BE PRESENT.
[RULE 3004(a)(4)]
14. TWO COMPLETE COPIES OF THE SOURCE(S) TEST REPORT SHALL BE SUBMITTED TO THE DISTRICT ENGINEER WITHIN 45 DAYS AFTER THE SOURCE TESTING DATE. THE SOURCE TEST REPORT SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, ALL TESTING DATA REQUIRED BY THIS CONDITION.
[RULE 3004(a)(4)]
15. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANTS TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TESTS.
[RULE 3004(a)(4)]
16. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217.
[RULE 3004(a)(4)]

Emissions And Requirements:

17. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1103



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

[RULE 3004 (a) (4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, > 400,000 BTU/HR BUT < 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409
NOx: 30 PPMV, RULE 1146.2
CO: 400 PPMV, RULE 1146.2
CO: 2000 PPMV, RULE 407



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
REFRIGERANT: RULE 1415
REFRIGERANT: 40 CFR 82 SUBPART F



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT: RULE 1411
REFRIGERANT: 40 CFR 82 SUBPART B



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, ABRASIVE BLASTING EQUIPMENT, GLOVE-BOX, < 53 FT³, WITH DUST FILTER.

Periodic Monitoring:

1. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.[RULE 3004 (a)(4)]

2. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.
[RULE 3004 (a)(4)]

3. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:
 - A. STACK OR EMISSION POINT IDENTIFICATION;
 - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
 - C. DATE AND TIME VISIBLE EMISSION WAS ABATED.[RULE 3004 (a)(4)]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS
 - PM: RULE 1140, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CR¹⁶: RULE 1404



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE ACCESS BUSINESS GROUP LLC, NUTRILITE

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statues of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

FACILITY PERMIT TO OPERATE ACCESS BUSINESS GROUP LLC, NUTRILITE

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO₂) and be averaged over 15 consecutive minutes; [407]
 - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO₂) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O₂) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
- a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
- a. The results of the source test.

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief description of the equipment tested.
 - c. Operating conditions under which the test was performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE

**SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR
RECLAIM SOURCES**

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

See Section D of this permit for any Permit to Construct issued to this facility.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765



**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION J: AIR TOXICS

NOT APPLICABLE

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
- (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

**SECTION K: TITLE V Administration
RECORDKEEPING PROVISIONS**

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

| RULE SOURCE | Adopted/Amended Date | FEDERAL Enforceability |
|--|-----------------------------|-------------------------------|
| RULE 1103 | 3-12-1999 | Federally enforceable |
| RULE 1113 | 11-8-1996 | Federally enforceable |
| RULE 1113 | 7-13-2007 | Non federally enforceable |
| RULE 1140 | 2-1-1980 | Federally enforceable |
| RULE 1140 | 8-2-1985 | Non federally enforceable |
| RULE 1146 | 11-17-2000 | Federally enforceable |
| RULE 1146 | 9-5-2008 | Non federally enforceable |
| RULE 1171 | 11-7-2003 | Federally enforceable |
| RULE 1171 | 5-1-2009 | Non federally enforceable |
| RULE 1303(a)(1)-BACT | 12-6-2002 | Non federally enforceable |
| RULE 1303(a)(1)-BACT | 5-10-1996 | Federally enforceable |
| RULE 1303(b)(2)-Offset | 12-6-2002 | Non federally enforceable |
| RULE 1303(b)(2)-Offset | 5-10-1996 | Federally enforceable |
| RULE 1304(c)-Offset Exemption | 6-14-1996 | Federally enforceable |
| RULE 1404 | 4-6-1990 | Non federally enforceable |
| RULE 1415 | 12-3-2010 | Non federally enforceable |
| RULE 3004(a)(4)-Periodic Monitoring | 12-12-1997 | Federally enforceable |
| RULE 401 | 11-9-2001 | Non federally enforceable |
| RULE 401 | 3-2-1984 | Federally enforceable |
| RULE 402 | 5-7-1976 | Non federally enforceable |

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

SECTION K: TITLE V Administration

| RULE SOURCE | Adopted/Amended Date | FEDERAL Enforceability |
|--------------------|-----------------------------|-------------------------------|
| RULE 404 | 2-7-1986 | Federally enforceable |
| RULE 405 | 2-7-1986 | Federally enforceable |
| RULE 407 | 4-2-1982 | Federally enforceable |
| RULE 409 | 8-7-1981 | Federally enforceable |
| RULE 461 | 3-7-2008 | Non federally enforceable |
| RULE 461 | 6-3-2005 | Federally enforceable |
| 40CFR 82 Subpart B | 7-14-1992 | Federally enforceable |
| 40CFR 82 Subpart F | 5-14-1993 | Federally enforceable |

FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN
PERMIT PURSUANT TO RULE 219**

NONE

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 1113 11-08-1996]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

**Grams of VOC Per Liter of Coating,
 Less Water And Less Exempt Compounds**

| COATING | Limit* | Effective Date of Adoption | Effective 1/1/1998 | Effective 1/1/1999 | Effective 7/1/2001 | Effective 1/1/2005 | Effective 7/1/2008 |
|---------------------------------|--------|----------------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| Bond Breakers | 350 | | | | | | |
| Clear Wood Finishes | | | | | | | |
| Varnish | 350 | | | | | | |
| Sanding Sealers | 350 | | | | | | |
| Lacquer | 680 | | 550 | | | 275 | |
| Concrete-Curing Compounds | 350 | | | | | | |
| Dry-Fog Coatings | 400 | | | | | | |
| Fire-proofing Exterior Coatings | 350 | 450 | | 350 | | | |
| Fire-Retardant Coatings | | | | | | | |
| Clear | 650 | | | | | | |
| Pigmented | 350 | | | | | | |
| Flats | 250 | | | | | | |
| Graphic Arts (Sign) Coatings | 500 | | | | 100 | | 50 |

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC, NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 1113 11-08-1996]**

| | | | | | | |
|-----------------------------|-----|-----|-----|-----|-----|--|
| Industrial Maintenance | | | | | | |
| Primers and Topcoats | | | | | | |
| Alkyds | 420 | | | | | |
| Catalyzed Epoxy | 420 | | | | | |
| Bituminous Coatings | 420 | | | | | |
| Materials | | | | | | |
| Inorganic Polymers | 420 | | | | | |
| Vinyl Chloride Polymers | 420 | | | | | |
| Chlorinated Rubber | 420 | | | | | |
| Acrylic Polymers | 420 | | | | | |
| Urethane Polymers | 420 | | | | | |
| Silicones | 420 | | | | | |
| Unique Vehicles | 420 | | | | | |
| Japans/Faux Finishing | 350 | 700 | | 350 | | |
| Coatings | | | | | | |
| Magnesite Cement Coatings | 600 | | | 450 | | |
| Mastic Coatings | 300 | | | | | |
| Metallic Pigmented Coatings | 500 | | | | | |
| Multi-Color Coatings | 420 | | 250 | | | |
| Pigmented Lacquer | 680 | | 550 | | 275 | |
| Pre-Treatment Wash Primers | 780 | | | | | |
| Primers, Sealers, and | 350 | | | | | |
| Undercoaters | | | | | | |
| Quick-Dry Enamels | 400 | | | | | |
| Roof Coatings | 300 | | | | | |
| Shellac | | | | | | |
| Clear | 730 | | | | | |
| Pigmented | 550 | | | | | |
| Stains | 350 | | | | | |
| Swimming Pool Coatings | | | | | | |
| Repair | 650 | | | | | |
| Other | 340 | | | | | |
| Traffic Coatings | 250 | | 150 | | | |
| Waterproofing Sealers | 400 | | | | | |
| Wood Preservatives | | | | | | |
| Below-Ground | 350 | | | | | |
| Other | 350 | | | | | |

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

| COATING | Limit |
|--------------------|-------|
| Low-Solids Coating | 120 |

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 12-06-2002]**

File Not Found

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC, NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

| SOLVENT CLEANING ACTIVITY | CURRENT LIMITS |
|--|------------------------|
| | VOC g/l (lb/gal) |
| (A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application | |
| (i) General | 25 (0.21) |
| (ii) Electrical Apparatus Components & Electronic Components | 500 (4.2) |
| (iii) Medical Devices & Pharmaceuticals | 800 (6.7) |
| (B) Repair and Maintenance Cleaning | |
| (i) General | 25 (0.21) |
| (ii) Electrical Apparatus Components & Electronic Components | 900 (7.5) |

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC, NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 1171 11-07-2003]**

| SOLVENT CLEANING ACTIVITY | CURRENT LIMITS |
|---|------------------------|
| | VOC g/l (lb/gal) |
| (iii) Medical Devices & Pharmaceuticals | |
| (A) Tools, Equipment, & Machinery | 800 (6.7) |
| (B) General Work Surfaces | 600 (5.0) |
| (C) Cleaning of Coatings or Adhesives Application Equipment | 550 (4.6) |
| (D) Cleaning of Ink Application Equipment | |
| (i) General | 25 (0.21) |
| (ii) Flexographic Printing | 25 (0.21) |
| (iii) Gravure Printing | |
| (A) Publication | 750 (6.3) |
| (B) Packaging | 25 (0.21) |
| (iv) Lithographic or Letter Press Printing | |

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]**

| SOLVENT CLEANING ACTIVITY | CURRENT LIMITS |
|---|------------------------|
| | VOC g/l (lb/gal) |
| (A) Roller Wash – Step 1 | 600 (5.0) |
| (B) Roller Wash-Step 2, Blanket Wash, & On-Press Components | 800 (6.7) |
| (C) Removable Press Components | 25 (0.21) |
| (v) Screen Printing | 750 (6.3) |
| (vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing) | 800 (6.7) |
| (vii) Specialty Flexographic Printing | 600 (5.0) |
| (E) Cleaning of Polyester Resin Application Equipment | 25 (0.21) |

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC, NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 1171 08-02-2002]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

| SOLVENT CLEANING ACTIVITY | CURRENT LIMITS* | Effective 1/1/2003 | Effective 7/1/2005 |
|---|------------------------|------------------------|------------------------|
| | VOC g/l (lb/gal) | VOC g/l (lb/gal) | VOC g/l (lb/gal) |
| (A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application | | | |
| (i) General | 50 (0.42) | 25 (0.21) | |
| (ii) Electrical Apparatus Components & Electronic Components | 500 (4.2) | | 100 (0.83) |
| (iii) Medical Devices & Pharmaceuticals | 800 (6.7) | | |
| (B) Repair and Maintenance Cleaning | | | |
| (i) General | 50 (0.42) | 25 (0.21) | |
| (ii) Electrical Apparatus Components & Electronic Components | 900 (7.5) | | 100 (0.83) |
| (iii) Medical Devices & Pharmaceuticals | | | |
| (A) Tools, Equipment, & Machinery | 800 (6.7) | | |
| (B) General Work Surfaces | 600 (5.0) | | |
| (C) Cleaning of Coatings, or Adhesives Application Equipment | 550 (4.6) | | 25 (0.21) |
| (D) Cleaning of Ink Application Equipment | | | |
| (i) General | 50 (0.42) | 25 (0.21) | |

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 08-02-2002]**

| SOLVENT CLEANING ACTIVITY | CURRENT LIMITS* | Effective 1/1/2003 | Effective 7/1/2005 |
|--|------------------------|------------------------|------------------------|
| | VOC g/l (lb/gal) | VOC g/l (lb/gal) | VOC g/l (lb/gal) |
| (ii) Flexographic Printing | 50 (0.42) | 25 (0.21) | |
| (iii) Gravure Printing | | | |
| (A) Publication | 750 (6.3) | | 100 (0.83) |
| (B) Packaging | 50 (0.42) | 25 (0.21) | |
| (iv) Lithographic or Letter Press Printing | | | |
| (A) Roller Wash – Step 1 | 600 (5.0) | | 100 (0.83) |
| (B) Roller Wash-Step 2, Blanket Wash, & On-Press Components | 800 (6.7) | | 100 (0.83) |
| (C) Removable Press Components | 50 (0.42) | 25 (0.21) | |
| (v) Screen Printing | 750 (6.3) | | 100 (0.83) |
| (vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing) | 800 (6.7) | | 100 (0.83) |
| (vii) Specialty Flexographic Printing | 600 (5.0) | | 100 (0.83) |
| (E) Cleaning of Polyester Resin Application Equipment | 50 (0.42) | 25 (0.21) | |

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 404 02-07-1986]**

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

| Volume Discharged Calculated as Dry Gas At Standard Conditions | | Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions | | Volume Discharged Calculated as Dry Gas At Standard Conditions | | Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions | |
|--|-----------------------|--|-----------------------|--|-----------------------|--|-----------------------|
| Cubic meters Per Minute | Cubic feet Per Minute | Milligrams per Cubic Meter | Grains per Cubic Foot | Cubic meters Per Minute | Cubic feet Per Minute | Milligrams per Cubic Meter | Grains per Cubic Foot |
| 25 or less | 883 or less | 450 | 0.196 | 900 | 31780 | 118 | 0.0515 |
| 30 | 1059 | 420 | .183 | 1000 | 35310 | 113 | .0493 |
| 35 | 1236 | 397 | .173 | 1100 | 38850 | 109 | .0476 |
| 40 | 1413 | 377 | .165 | 1200 | 42380 | 106 | .0463 |
| 45 | 1589 | 361 | .158 | 1300 | 45910 | 102 | .0445 |

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 404 02-07-1986]**

| Volume Discharged Calculated as Dry Gas At Standard Conditions | | Maximum Concentration of Particulate Matter" Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions | | Volume Discharged Calculated as Dry Gas At Standard Conditions | | Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions | |
|--|--------------------------------|---|--------------------------|--|--------------------------------|---|-----------------------------|
| Cubic meters Per Minute | Cubic feet Per Minute | Milligrams per Cubic Meter | Grains per Cubic Foot | Cubic meters Per Minute | Cubic feet Per Minute | Milligrams per Cubic Meter | Grains per Cubic Foot |
| 50 | 1766 | 347 | .152 | 1400 | 49440 | 100 | .0437 |
| 60 | 2119 | 324 | .141 | 1500 | 52970 | 97 | .0424 |
| 70 | 2472 | 306 | .134 | 1750 | 61800 | 92 | .0402 |
| 80 | 2825 | 291 | .127 | 2000 | 70630 | 87 | .0380 |
| 90 | 3178 | 279 | .122 | 2250 | 79460 | 83 | .0362 |
| 100 | 3531 | 267 | .117 | 2500 | 88290 | 80 | .0349 |
| 125 | 4414 | 246 | .107 | 3000 | 105900 | 75 | .0327 |
| 150 | 5297 | 230 | .100 | 4000 | 141300 | 67 | .0293 |
| 175 | 6180 | 217 | .0947 | 5000 | 176600 | 62 | .0271 |
| 200 | 7063 | 206 | .0900 | 6000 | 211900 | 58 | .0253 |
| 250 | 8829 | 190 | .0830 | 8000 | 282500 | 52 | .0227 |
| 300 | 10590 | 177 | .0773 | 10000 | 353100 | 48 | .0210 |
| 350 | 12360 | 167 | .0730 | 15000 | 529700 | 41 | .0179 |
| 400 | 14130 | 159 | .0694 | 20000 | 706300 | 37 | .0162 |
| 450 | 15890 | 152 | .0664 | 25000 | 882900 | 34 | .0148 |

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 404 02-07-1986]**

| Volume Discharged Calculated as Dry Gas At Standard Conditions | | Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions | | Volume Discharged Calculated as Dry Gas At Standard Conditions | | Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions | |
|--|--------------------------------|--|--------------------------|--|--------------------------------|---|-----------------------------|
| | | Milligrams per Cubic Meter | Grains per Cubic Foot | | | Milligrams per Cubic Meter | Grains per Cubic Foot |
| Cubic meters Per Minute | Cubic feet Per Minute | | | Cubic meters Per Minute | Cubic feet Per Minute | | |
| 500 | 17660 | 146 | .0637 | 30000 | 1059000 | 32 | .0140 |
| 600 | 21190 | 137 | .0598 | 40000 | 1413000 | 28 | .0122 |
| 700 | 24720 | 129 | .0563 | 50000 | 1766000 | 26 | .0114 |
| 800 | 28250 | 123 | .0537 | 70000 or more | 2472000 or more | 23 | .0100 |

**FACILITY PERMIT TO OPERATE
ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
[RULE 405 02-07-1986]**

The operator shall not discharge into the atmosphere from this equipment, solid particulate matter including lead and lead compounds in excess of the rate shown in Table 405(a).

Where the process weight per hour is between figures listed in the table, the exact weight of permitted discharge shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 405(a)

| Process Weight Per Hour | | Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process) | | Process Weight Per Hour | | Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process) | |
|-------------------------|-----------------|---|-----------------|-------------------------|-----------------|---|-----------------|
| Kilograms Per Hour | Pounds Per Hour | Kilograms Per Hour | Pounds Per Hour | Kilograms Per Hour | Pounds Per Hour | Kilograms Per Hour | Pounds Per Hour |
| 100 or less | 220 or less | 0.450 | 0.99 | 9000 | 19840 | 5.308 | 11.7 |
| 150 | 331 | 0.585 | 1.29 | 10000 | 22050 | 5.440 | 12.0 |
| 200 | 441 | 0.703 | 1.55 | 12500 | 27560 | 5.732 | 12.6 |
| 250 | 551 | 0.804 | 1.77 | 15000 | 33070 | 5.982 | 13.2 |
| 300 | 661 | 0.897 | 1.98 | 17500 | 38580 | 6.202 | 13.7 |
| 350 | 772 | 0.983 | 2.17 | 20000 | 44090 | 6.399 | 14.1 |
| 400 | 882 | 1.063 | 2.34 | 25000 | 55120 | 6.743 | 14.9 |
| 450 | 992 | 1.138 | 2.51 | 30000 | 66140 | 7.037 | 15.5 |
| 500 | 1102 | 1.209 | 2.67 | 35000 | 77160 | 7.296 | 16.1 |
| 600 | 1323 | 1.340 | 2.95 | 40000 | 88180 | 7.527 | 16.6 |

**FACILITY PERMIT TO OPERATE
 ACCESS BUSINESS GROUP LLC. NUTRILITE**

**APPENDIX B: RULE EMISSION LIMITS
 [RULE 405 02-07-1986]**

| Process Weight Per Hour | | Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process) | | Process Weight Per Hour | | Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process) | |
|-------------------------|-----------------|---|-----------------|-------------------------|--------------------|---|-----------------|
| Kilograms Per Hour | Pounds Per Hour | Kilograms Per Hour | Pounds Per Hour | Kilograms Per Hour | Pounds Per Hour | Kilograms Per Hour | Pounds Per Hour |
| 700 | 1543 | 1.461 | 3.22 | 45000 | 99210 | 7.738 | 17.1 |
| 800 | 1764 | 1.573 | 3.47 | 50000 | 110200 | 7.931 | 17.5 |
| 900 | 1984 | 1.678 | 3.70 | 60000 | 132300 | 8.277 | 18.2 |
| 1000 | 2205 | 1.777 | 3.92 | 70000 | 154300 | 8.582 | 18.9 |
| 1250 | 2756 | 2.003 | 4.42 | 80000 | 176400 | 8.854 | 19.5 |
| 1500 | 3307 | 2.206 | 4.86 | 90000 | 198400 | 9.102 | 20.1 |
| 1750 | 3858 | 2.392 | 5.27 | 100000 | 220500 | 9.329 | 20.6 |
| 2000 | 4409 | 2.563 | 5.65 | 125000 | 275600 | 9.830 | 21.7 |
| 2250 | 4960 | 2.723 | 6.00 | 150000 | 330700 | 10.26 | 22.6 |
| 2500 | 5512 | 2.874 | 6.34 | 175000 | 385800 | 10.64 | 23.5 |
| 2750 | 6063 | 3.016 | 6.65 | 200000 | 440900 | 10.97 | 24.2 |
| 3000 | 6614 | 3.151 | 6.95 | 225000 | 496000 | 11.28 | 24.9 |
| 3250 | 7165 | 3.280 | 7.23 | 250000 | 551200 | 11.56 | 25.5 |
| 3600 | 7716 | 3.404 | 7.50 | 275000 | 606300 | 11.82 | 26.1 |
| 4000 | 8818 | 3.637 | 8.02 | 300000 | 661400 | 12.07 | 26.6 |
| 4500 | 9921 | 3.855 | 8.50 | 325000 | 716500 | 12.30 | 27.1 |
| 5000 | 11020 | 4.059 | 8.95 | 350000 | 771600 | 12.51 | 27.6 |
| 6000 | 13230 | 4.434 | 9.78 | 400000 | 881800 | 12.91 | 28.5 |
| 7000 | 15430 | 4.775 | 10.5 | 450000 | 992100 | 13.27 | 29.3 |
| 8000 | 17640 | 5.089 | 11.2 | 500000 or more | 1102000 or more | 13.60 | 30.0 |