

Amended Date

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
(xxxx xxxx xxxx xxxx xxxx)

13-xxxE CAB
File No. 0087-06

Mr. Jeff Walsh
President and General Manager
AES Hawaii, Inc.
91-086 Kaomi Loop
Kapolei, Hawaii 96707-1883

Dear Mr. Walsh:

**Subject: Amendment of Covered Source Permit (CSP) No. 0087-02-C
 Minor Modification Application No. 0087-06
 CFB Boilers
 AES Hawaii, Inc.
 203 MW Coal-Fired Cogeneration Plant
 Located at: 91-086 Kaomi Loop, Campbell Industrial Park, Kapolei, Oahu
 Date of Expiration: July 19, 2014**

In accordance with Hawaii Administrative Rules, Chapter 11-60.1, and pursuant to your application for a Minor Modification dated March 12, 2013, the Department of Health hereby amends Covered Source Permit (CSP) No. 0087-02-C issued to AES Hawaii, Inc. The amendment removes the fuel sulfur content restriction in coal and revises Attachment IIA, Special Condition No. C.1 as follows:

The CFB boilers (boilers) shall be fired primarily on coal. In the event that the emissions of sulfur dioxide (SO₂) exceed 645.0 lb/hr, 1.2 lb/MMBtu, or 48 ppmvd @ 15% O₂ while firing coal with a sulfur content in excess of 1.5 percent by weight, the permittee shall immediately take steps to limit the feed rate of coal until such time as the process returns to compliance with the SO₂ permit limits in Attachment IIA, Special Condition No. C.10. During hot or cold startups, the boilers may be fired on fuel oil no. 2 with a maximum sulfur content not to exceed 0.5 percent by weight.

All other permit conditions issued with CSP No. 0087-02-C on July 20, 2009 and amended on April 3, 2012, shall not be affected and shall remain valid. A receipt for the application filing fee of \$200.00 is enclosed.

PROPOSED

Mr. Jeff Walsh
Issue Date
Page 2

If there are any questions regarding these matters, please contact Mr. Darin Lum of the Clean Air Branch at (808) 586-4200.

Sincerely,

STUART YAMADA, P.E., CHIEF
Environmental Management Division

DL:smk
Enclosure

c: CAB Monitoring Section