

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **Facility Equipment and Requirements (Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



**FACILITY PERMIT TO OPERATE  
ALLERGAN INC.**

**FACILITY WIDE CONDITION(S)**

**Condition(s):**

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
  - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
  - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.  
[RULE 401]
  
2. ON JUNE 1, 2004, AND THEREAFTER, THE OPERATOR SHALL ONLY USE DIESEL FUEL WITH A SULFUR CONTENT THAT DOES NOT EXCEED 15 PPM BY WEIGHT.  
[RULE 431.2]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. D38381  
A/N 210357

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL KTTA-19-G1, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, 685 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 162.5 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 20 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:
- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
  - B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
- [RULE 1470(c)(3)(C), RULE 3004(a)(4)]
8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
- [RULE 1470(d)(9)(A), RULE 3004(a)(4)]
9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: GREATER THAN 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. D31546  
A/N 229382

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL KTA 38, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, 1135 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 88 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 20 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:
- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
  - B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
- [RULE 1470(c)(3)(C), RULE 3004(a)(4)]

8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
- [RULE 1470(d)(9)(A), RULE 3004(a)(4)]

9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: GREATER THAN 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. D31549  
A/N 229383

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL KTA 38, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, 1135 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 88 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 20 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:

- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
- B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1470(c)(3)(C), RULE 3004(a)(4)]

8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:

- A. EMERGENCY USE HOURS OF OPERATION;
- B. MAINTENANCE AND TESTING HOURS OF OPERATION;
- C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
- D. INITIAL START-UP HOURS;
- E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
- F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
- G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1470(d)(9)(A), RULE 3004(a)(4)]

9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
- PM: GREATER THAN 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. D60073  
A/N 263600

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLER, MODEL NO. 3412 DT, SERIAL NO. 38506732, DIESEL FUELED, EMERGENCY, ELECTRICAL GENERATOR DRIVER, 12 CYLINDERS, 545 BHP., TURBOCHARGED AND AFTERCOOLED.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 199 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 30 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:
- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
  - B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
- [RULE 1470(c)(3)(C), RULE 3004(a)(4)]
8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
- [RULE 1470(d)(9)(A), RULE 3004(a)(4)]
9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.
- LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.
- LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.
- [RULE 1470(d)(9)(B), RULE 3004 (a)(4)]
10. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
- [RULE 1303(a)(1)-BACT]

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
  - PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: LESS THAN OR EQUAL TO 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. D60074  
A/N 263601

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL NO. 12V92T, SERIAL NO. 12VF002698, DIESEL FUELED, EMERGENCY, ELECTRICAL GENERATOR DRIVER, 8 CYLINDERS, 741 BHP., TURBOCHARGED AND AFTERCOOLED.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 70 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 30 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:
- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
  - B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
- [RULE 1470(c)(3)(C), RULE 3004(a)(4)]
8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
- [RULE 1470(d)(9)(A), RULE 3004(a)(4)]
9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.
- LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.
- LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.
- [RULE 1470(d)(9)(B), RULE 3004 (a)(4)]
10. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.
- [RULE 1303(a)(1)-BACT]

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
  - PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: LESS THAN OR EQUAL TO 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. F40294  
A/N 386871

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL NO. R163-7K36 (1115 KW), SERIAL NO. 0701738, DIESEL FUELLED, EMERGENCY, ELECTRICAL GENERATOR DRIVER, 16 CYLINDERS, 1495 BHP., TURBOCHARGED AND AFTERCOOLED.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 199 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 30 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:
- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
  - B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
- [RULE 1470(c)(3)(C), RULE 3004(a)(4)]
8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
- [RULE 1470(d)(9)(A), RULE 3004(a)(4)]
9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: LESS THAN OR EQUAL TO 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. F49257  
A/N 397563

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL NO. T163-7K36 (2190 KW), DIESEL FUELLED, EMERGENCY, ELECTRICAL GENERATOR DRIVER, 16 CYLINDERS, 2935 BHP., TURBOCHARGED AND AFTERCOOLED.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 199 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 30 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:

A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND

B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.

[RULE 1470(c)(3)(C), RULE 3004(a)(4)]

8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION;

B. MAINTENANCE AND TESTING HOURS OF OPERATION;

C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;

D. INITIAL START-UP HOURS;

E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;

F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND

G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1470(d)(9)(A), RULE 3004(a)(4)]

9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: LESS THAN OR EQUAL TO 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. F71153  
A/N 434558

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL NO. KTA50-G9, SERIAL NO. H040685554, 2220 BHP, 16-CYLINDERS, TURBOCHARGED, AFTERCOOLED, DIESEL FIRED, DRIVING AN ELECTRICAL GENERATOR.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED WITHOUT THE USE OF AN AUTOMATIC CONTROL SYSTEM THAT REGULATES EXHAUST OXYGEN CONTENT.  
[RULE 1303(a)(1)-BACT]

#### Periodic Monitoring:

4. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE HOUR METER WITH A MINIMUM DISPLAY CAPABILITY OF 9,999 HOURS, TO INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 1470(d)(7)(A), RULE 3004 (a)(4)]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]
6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.  
[RULE 1470(c)(3)(C), RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

7. OPERATION BEYOND 20 HOURS PER YEAR FOR MAINTENANCE AND TESTING IS ALLOWED ONLY IN THE EVENT OF LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT:
- A. THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED OR EXPECTS TO ORDER, ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME; AND
  - B. THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.
- [RULE 1470(c)(3)(C), RULE 3004(a)(4)]
8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
- [RULE 1470(d)(9)(A), RULE 3004(a)(4)]
9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 5, 6 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: GREATER THAN 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. F69364  
A/N 430184

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 16 CYLINDERS, TURBOCHARGED, AFTERCOOLED, MODEL 3516B DITA, SERIAL NO. 6HN01649, 2847 BHP, DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS EQUIPMENT SHALL COMPLY WITH RULE 431.2 AND 1470.  
[RULE 431.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS PER YEAR FOR MAINTENANCE AND TESTING AS REQUIRED IN RULE 1470(C)(3).  
[RULE 1470(c)(3)(C), 1304(a)(4)]
5. OPERATION BEYOND THE ALLOTTED TIME FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1470(c)(3)(C)]
6. THIS ENGINE SHALL NOT BE USED AS PART OF AN INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ELECTRIC LOAD ON THE GRID WHEN REQUESTED BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1304(a)(4)]

#### Periodic Monitoring:

7. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

[RULE 1470(d)(7)(A), RULE 1304(a)(4)]

8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
- A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1470(d)(9)(A), RULE 1304(a)(4), RULE 3004(a)(4)]

9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 4, 5 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004(a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: GREATER THAN 0.4 GRAM/BHP-HR, RULE 1470(c)(3)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO CONSTRUCT/OPERATE

Permit No.  
A/N 484615

**Equipment Description:**

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL NO. QSX15-G9, DIESEL FUELED, 6 CYLINDERS, 755 BHP, TURBOCHARGED AND AFTERCOOLED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS EQUIPMENT SHALL COMPLY WITH RULE 431.2 AND 1470.  
[RULE 431.2, RULE 1470]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS PER YEAR FOR MAINTENANCE AND TESTING AS REQUIRED IN RULE 1470(C)(3).  
[RULE 1470(c)(2)(C), RULE 1304(a)(4)]
5. OPERATION BEYOND THE ALLOTTED TIME FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1470(c)(2)(C)]
6. THIS ENGINE SHALL NOT BE PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1304(a)(4)]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### Periodic Monitoring:

7. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
RULE 1470(d)(7)(A), RULE 1304(a)(4), RULE 3004(a)(4)]
  
8. THE OPERATOR SHALL KEEP A MONTHLY LOG OF USAGE THAT SHALL LIST AND DOCUMENT THE NATURE OF USE IN EACH OF THE FOLLOWING AREAS:
  - A. EMERGENCY USE HOURS OF OPERATION;
  - B. MAINTENANCE AND TESTING HOURS OF OPERATION;
  - C. OPERATION ASSOCIATED WITH NOTICE OF AN IMPENDING OR AN ACTUAL ROTATING OUTAGE;
  - D. INITIAL START-UP HOURS;
  - E. ALL OTHER HOURS OF OPERATION NOT SPECIFIED ABOVE;
  - F. HOURS OF OPERATION TO DEMONSTRATE COMPLIANCE WITH DISTRICT RULES; AND
  - G. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.  
[RULE 1470(d)(9)(A), RULE 1304(a)(4), RULE 3004(a)(4)]
  
9. THE OPERATOR SHALL MAINTAIN ADEQUATE OPERATION LOGS FOR THIS EQUIPMENT TO VERIFY COMPLIANCE WITH CONDITIONS 4, 5 AND 8 ABOVE. LOG ENTRIES SHALL BE RETAINED FOR A MINIMUM OF 5 YEARS FROM THE DATE OF ENTRY.

LOG ENTRIES MADE WITHIN 24 MONTHS OF THE MOST RECENT ENTRY SHALL BE RETAINED ON SITE, EITHER AT A CENTRAL LOCATION OR AT THE ENGINE'S LOCATION AND MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

LOG ENTRIES MADE FROM 25 TO 60 MONTHS FROM THE MOST RECENT ENTRY SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE WITHIN 5 WORKING DAYS FROM THE DATE REQUESTED.

[RULE 1470(d)(9)(B), RULE 3004 (a)(4)]

### Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
  - PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: LESS THAN OR EQUAL TO 0.15 GRAM/BHP-HR, RULE 1470(c)(2)(C)

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### PERMIT TO OPERATE

Permit No. F56598  
A/N 408568

#### Equipment Description:

BOILER NO.B1, CLEAVER BROOKS, FIRETUBE TYPE, MODEL NO. CB700-500, SERIAL NO. L90246, 21.0 MM BTU/HR., WITH ONE LOW NO<sub>x</sub> BURNER, ALZETA, MODEL NO. CSB22-2SO-30/15, AND A 25 HP. COMBUSTION AIR BLOWER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1303(a)(1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>, MEASURED AS NO<sub>2</sub>), AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT, RULE 1146]
5. THE OPERATOR SHALL FOLLOW THE PROCEDURES SPECIFIED BY THE MANUFACTURER TO TUNE-UP AND MAINTAIN THE COMBUSTION SYSTEM (INCLUDING BUT NOT LIMITED TO BURNERS AND AIR/FUEL CONTROL DEVICES) OF THIS BOILER IN ORDER TO ASSURE COMPLIANCE WITH THE EMISSION LIMITS IN CONDITION NO. 4.  
[RULE 1303(a)(1)-BACT, RULE 1146]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(a)(1)-BACT, RULE 1146]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### Periodic Monitoring:

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO<sub>x</sub> EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.  
[RULE 3004(a)(4)]
8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.  
[RULE 3004(a)(4)]
9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD.

THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:

- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
- B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
- C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NOx: 30 PPMV, RULE 1146  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: 0.1 GR/SCF, RULE 409

**FACILITY PERMIT TO OPERATE  
ALLERGAN INC.**

**PERMIT TO OPERATE**

**Permit No. F56600  
A/N 408569**

**Equipment Description:**

BOILER NO.B2, CLEAVER BROOKS, FIRETUBE TYPE, MODEL NO. CB700-500, SERIAL NO. L90247, 21.0 MM BTU/HR., WITH ONE LOW NO<sub>x</sub> BURNER, ALZETA, MODEL NO. CSB22-2SO-30/15, AND A 25 HP. COMBUSTION AIR BLOWER.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1303(a)(1)-BACT]
4. THIS BOILER SHALL EMIT NO MORE THAN 9 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>, MEASURED AS NO<sub>2</sub>), AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT, RULE 1146]
5. THE OPERATOR SHALL FOLLOW THE PROCEDURES SPECIFIED BY THE MANUFACTURER TO TUNE-UP AND MAINTAIN THE COMBUSTION SYSTEM (INCLUDING BUT NOT LIMITED TO BURNERS AND AIR/FUEL CONTROL DEVICES) OF THIS BOILER IN ORDER TO ASSURE COMPLIANCE WITH THE EMISSION LIMITS IN CONDITION NO. 4.  
[RULE 1303(a)(1)-BACT, RULE 1146]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(a)(1)-BACT, RULE 1146]

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### Periodic Monitoring:

7. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE NO<sub>x</sub> EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 7.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.  
[RULE 3004(a)(4)]
8. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1; OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATION LIMIT. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.  
[RULE 3004(a)(4)]
9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD.

THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:

A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;

B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR

C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NOx: 30 PPMV, RULE 1146  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: 0.1 GR/SCF, RULE 409

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **RULE 219 EQUIPMENT**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **RULE 219 EQUIPMENT**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

REFRIGERANT: RULE 1415  
REFRIGERANT: 40CFR 82 SUBPART F

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **RULE 219 EQUIPMENT**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, LABORATORY FUME HOODS.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1103

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **RULE 219 EQUIPMENT**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, R & D BUILDING EXHAUST.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1103

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **RULE 219 EQUIPMENT**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

CR\*6: RULE 1404

## FACILITY PERMIT TO OPERATE ALLERGAN INC.

### RULE 219 EQUIPMENT

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, BOILER, > 1 MMBTU/HR BUT < 2 MMBTU/HR.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409  
NOx: 30 PPMV, RULE 1146.2  
CO: 400 PPMV, RULE 1146.2  
CO: 2000 PPMV, RULE 407

## **FACILITY PERMIT TO OPERATE ALLERGAN INC.**

### **RULE 219 EQUIPMENT**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, MICRO GAS TURBINE, > 1 MMBTU/HR BUT < 2.975 MMBTU/HR.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409  
NOx: 30 PPMV, RULE 1146.2  
CO: 400 PPMV, RULE 1146.2  
CO: 2000 PPMV, RULE 407