



SEP 20 2012

Mr. Tim Durham  
Ingomar Packing  
PO Box 1448  
Los Banos, CA 93635

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)  
Project # N-1113286**

Dear Mr. Durham:

The Air Pollution Control Officer has issued Authorities to Construct (N-1276-3-14, N-1276-19-0 and N-1276-20-0) with Certificates of Conformity to Ingomar Packing. The proposal is to install a cooling tower and an emergency fire pump powered by a compression ignition IC engine and to lower the PM10 emission limit of a boiler.

Enclosed are the Authorities to Construct and invoice. The application and proposal were sent to US EPA Region IX on August 29, 2012. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authorities to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400.

Sincerely,

David Warner  
Director of Permit Services

DW:MJS/st

Enclosures

Seyed Sadredin  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



SEP 20 2012

Gerardo C. Rios, Chief  
Permits Office  
Air Division  
U.S. EPA - Region IX  
75 Hawthorne St  
San Francisco, CA 94105

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)  
Project # N-1113286**

Dear Mr. Rios:

The Air Pollution Control Officer has issued Authorities to Construct (N-1276-3-14, N-1276-19-0 and N-1276-20-0) with Certificates of Conformity to Ingomar Packing. The proposal is to install a cooling tower and an emergency fire pump powered by a compression ignition IC engine and to lower the PM10 emission limit of a boiler.

Enclosed are copies of the Authorities to Construct. The application and proposal were sent to US EPA Region IX on August 29, 2012. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400.

Sincerely,

David Warner  
Director of Permit Services

DW:MJS/st

Enclosures

Seyed Sadredin  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** N-1276-3-14

**ISSUANCE DATE:** 09/14/2012

**LEGAL OWNER OR OPERATOR:** INGOMAR PACKING COMPANY

**MAILING ADDRESS:** P O BOX 1448  
LOS BANOS, CA 93635

**LOCATION:** 9950 S INGOMAR GRADE  
LOS BANOS, CA 93635

**EQUIPMENT DESCRIPTION:**

156 MMBTU/HR NEBRASKA MODEL N25-T-84 BOILER WITH A TODD RMB ULTRA-LOW NOX BURNER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM. MODIFICATION TO REDUCE PM10 LIMIT TO 0.0024 LB/MMBTU.

### CONDITIONS

1. Authorities to Construct N-1276-3-14, N-1276-19-0 and N-1276-20-0 shall be implemented simultaneously. [District Rule 2201]
2. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
3. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
6. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

  
\_\_\_\_\_  
DAVID WARNER, Director of Permit Services

N-1276-3-14, Sep 14 2012 10:52AM - ECHONHOM : Joint Inspection NOT Required

7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
8. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
9. This unit shall be fired only on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
10. The facility-wide fuel usage shall not exceed 19,600 MMBtu in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The fuel usage of this unit shall not exceed 1,063,560 MMBtu during any rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
12. NO<sub>x</sub> emissions shall not exceed 7 ppmvd @ 3% O<sub>2</sub> (referenced as NO<sub>2</sub>) or 0.008 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
13. CO emissions shall not exceed 100 ppmvd @ 3% O<sub>2</sub> or 0.074 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
14. VOC emissions shall not exceed 0.0055 lb/MMBtu (referenced as methane). [District Rule 2201] Federally Enforceable Through Title V Permit
15. SO<sub>x</sub> emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. PM<sub>10</sub> emissions shall not exceed 0.0024 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Source testing to determine compliance with the NO<sub>x</sub> and CO emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Source testing to measure NO<sub>x</sub> emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

25. Stack gas oxygen (O<sub>2</sub>) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NO<sub>x</sub> and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. During the 36-month source-testing interval, the owner/operator shall have unit tuned at least twice during each calendar year it operates. The tune-ups shall be four to eight months apart and shall be conducted by a technician that is qualified, to the satisfaction of the APCO. All tune-ups shall be conducted in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
33. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
34. The records necessary to show the required tune-ups were conducted shall be kept. [District Rule 4320] Federally Enforceable Through Title V Permit
35. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
36. A record of the daily facility-wide fuel usage, in Btu, shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
37. A record of the annual fuel usage of this unit, on a rolling 12-month basis, shall be kept. The record shall be in MMBtu and shall be updated at least once during each calendar month that the unit operates. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

38. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
39. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
40. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
42. This unit is subject to the requirements of 40 CFR Part 60, Subpart Db: Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units. [District Rule 4001] Federally Enforceable Through Title V Permit
43. The permittee shall comply with the emission monitoring requirements for nitrogen oxides given in 40 CFR Part 60.48b. [District Rule 4001] Federally Enforceable Through Title V Permit
44. The permittee shall comply with the reporting requirements of 40 CFR Part 60.48b. [District Rule 4001] Federally Enforceable Through Title V Permit
45. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR part 64] Federally Enforceable Through Title V Permit
46. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR part 64] Federally Enforceable Through Title V Permit
47. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** N-1276-19-0

**ISSUANCE DATE:** 09/14/2012

**LEGAL OWNER OR OPERATOR:** INGOMAR PACKING COMPANY

**MAILING ADDRESS:** P O BOX 1448  
LOS BANOS, CA 93635

**LOCATION:** 9950 S INGOMAR GRADE  
LOS BANOS, CA 93635

**EQUIPMENT DESCRIPTION:**  
20,000 GPM COOLING TOWER SERVED BY A DRIFT ELIMINATOR

### CONDITIONS

1. Authorities to Construct N-1276-3-14, N-1276-19-0 and N-1276-20-0 shall be implemented simultaneously. [District Rule 2201]
2. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
3. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
6. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadreidin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

N-1276-19-0 : 9/14/2012 10:52AM -- 5CH101H10M : Joint Inspection NOT Required

7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
8. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012] Federally Enforceable Through Title V Permit
9. Drift eliminator drift rate shall not exceed 0.001%. [District Rule 2201] Federally Enforceable Through Title V Permit
10. PM10 emission rate from the cooling tower shall not exceed 1.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Compliance with the PM10 emission limit shall be demonstrated as follows:  $PM10 \text{ lb/day} = \text{Circulating Water Recirculation rate (gal/day)} \times 8.34 \text{ lb/gal} \times \text{Total Dissolved Solids Concentration in the blowdown water (ppm)} \times \text{Design Drift Rate (\%)}$ . [District Rule 2201] Federally Enforceable Through Title V Permit
12. Compliance with the PM10 emission limit shall be determined by blowdown water sample analysis by independent laboratory at once each calendar year. [District Rule 1081] Federally Enforceable Through Title V Permit
13. Records of the annual water sample analyses shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
14. All records shall be retained on site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** N-1276-20-0

**ISSUANCE DATE:** 09/14/2012

**LEGAL OWNER OR OPERATOR:** INGOMAR PACKING COMPANY

**MAILING ADDRESS:** P O BOX 1448  
LOS BANOS, CA 93635

**LOCATION:** 9950 S INGOMAR GRADE  
LOS BANOS, CA 93635

**EQUIPMENT DESCRIPTION:**

182 BHP CUMMINS MODEL 6 BTA 5.9 F1 DIESEL FIRED (TIER 1 CERTIFIED) EMERGENCY ENGINE POWERING A FIRE PUMP.

### CONDITIONS

1. Authorities to Construct N-1276-3-14, N-1276-19-0 and N-1276-20-0 shall be implemented simultaneously. [District Rule 2201]
2. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
3. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST** NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director (A100)

DAVID WARNER, Director of Permit Services

N-1276-20-0: Sep 14 2012 10:52AM - SCHONHOM : Joint Inspection NOT Required

7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
8. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 4701 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed any of the following limits: 6.9 g-NO<sub>x</sub>/bhp-hr, 8.5 g-CO/bhp-hr, or 1.0 g-VOC/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Emissions from this IC engine shall not exceed 0.4 g-PM<sub>10</sub>/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
12. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
13. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
14. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the type of fuel used, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702] Federally Enforceable Through Title V Permit
16. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit