

**Covered Source Permit Review Summary (Renewal)**

**Application File No.:** 0216-12

**Permit No.:** 0216-06-C

**Applicant:** City and County of Honolulu  
Department of Environmental Services

**Facility Title:** Sand Island Wastewater Treatment Plant  
Located at 1350 Sand Island Parkway, Honolulu, Oahu  
UTM: 615,900 m E; 2,356,500 m N / NAD 83

**Mailing Address:** Department of Environmental Services  
City and County of Honolulu  
1000 Uluohia Street  
Kapolei, HI 96707

**Responsible Official:** Mr. Timothy E. Steinberger, P.E.  
Director  
City and County of Honolulu  
Department of Environmental Services  
Ph. (808) 768-3486

**Plant Manager:** Mr. Kenny Huy  
Plant Superintendent  
Ph. (808) 847-0800

**Application Dates:** March 10, 2009

**Proposed Project:**

SICC 4952 (Sewerage Systems)

This is an application for the renewal of Covered Source Permit No. 0216-06-C which expires on September 15, 2009.

The In-Vessel Bioconversion Facility's purpose is to recycle Sand Island Wastewater Treatment Plant municipal sludge into a marketable fertilizer product. The facility is designed to process 10,000 dry tons per year of the Sand Island WWTP raw sludge. To do this, the facility will be using an anaerobic digester, dewatering centrifuges, and a sludge dryer capable of handling all of Sand Island WWTP's sludge. The anaerobic digester will reduce the volume of the sludge while producing digester gas that will provide fuel energy to the sludge dryer. The digested sludge will be dewatered and then dried into pellet form. The pellets will be marketed locally as fertilizer.

An application fee of \$500 for the renewal of a covered source permit was submitted and processed.

**Equipment Description:**

The In-Vessel Bioconversion Facility consists of the following major equipment:

1. Andritz DDS-40 Drying System
  - a. Combustion Furnace
  - b. Rotary Drum Dryer
  - c. Regenerative Thermal Oxidizer (RTO)
  - d. Wet Venturi Scrubber
2. Building Air Chemical Odor Control Scrubber
3. Two (2) Fugitive Dust Control Systems
4. Hot Water Boiler
5. Waste Gas Burner (Flare)
6. Gas Purifiers
7. Two (2) Pellet Storage Silos

Parameter	Combustion Furnace	Regenerative Thermal Oxidizer (RTO)	Hot Water Boiler	Waste Gas Burner (Flare)
<b>Max Design Capacity</b>	17.8 MMBtu/hr	2.0 MMBtu/hr	2.5 MMBtu/hr	8,000 scfh
<b>Fuel Type</b>	digester gas (diesel fuel no. 2 backup)	diesel fuel no. 2	digester gas (diesel fuel no. 2 backup)	unscrubbed digester gas
<b>Max Fuel Use</b>	32,364 scf/hr (127 gph)	14.3 gph	4,545 scf/hr (17.9 gph)	8,000 scfh
<b>Raw Materials</b>	scrubbed digester gas, diesel fuel no. 2	diesel fuel no. 2	scrubbed digester gas, diesel fuel no. 2	unscrubbed digester gas

**Process Description:**

Raw sludge undergoes anaerobic digestion in the 2.3 million gallon Egg-Shaped Digester (ESD). Gas generated during this digestion process is used for combustion. Digested sludge is transferred to a 0.53 million gallon sludge storage tank. From this tank the sludge is moved to centrifuges for dewatering and then to a wet cake bin. From this bin the digested, dewatered biosolids cake is transferred to a mixer where it is combined with material recycled from the pelletizing process. From the mixer, the material is conveyed to a rotary drum dryer where it is dried by direct heating. The heat is provided by a combustion furnace rated at 17.8 MMBtu/hr and is fired on scrubbed digester gas. Diesel fuel no. 2 is the backup fuel for the combustion furnace.

When drying is complete, the material is conveyed to a pre-separator, a poly-cyclone and then to a vibrating screen for further classification. The largest particles on the screen are transferred to a crusher and then to a mixer cited above where they are mixed with the incoming dewatered biosolids cake. The smallest particles passing the screen bypass the crusher and are also conveyed to the mixer. Particles, i.e., pellets, of acceptable size are transferred to a

pellet cooler and then pneumatically conveyed to a storage silo. From this silo they are transferred to a pellet oiling mixer prior to truck loading.

Gas generated during the digestion process is stored within the ESD, the sludge storage tank, and a dry seal gasholder. The gasholder is an enclosed vessel with an internal piston necessary to stabilize pressure in the gas delivery system. Gas from the gasholder passes through gas purifiers to remove H<sub>2</sub>S prior to being piped to the combustion furnace or the hot water boiler. Excess unscrubbed digester gas that cannot be used by the combustion furnace or the hot water boiler is disposed of by burning in a separate 7.0 meter high waste gas burner (flare).

A 2.5 MMBtu/hr hot water boiler is used if necessary to maintain the proper operating temperature (approximately 95 deg F). The hot water boiler is served by its own 12.5 meter high stack.

Exhaust air from the combustion furnace is ducted to a water-supplied sub-cooler where a portion of it is returned to the combustion furnace as combustion air. The remainder of the cooled exhaust air passes through a wet venturi scrubber and then to a 2.0 MMBtu/hr regenerative thermal oxidizer (RTO) for final cleanup prior to exhausting through a 22.25 meter stack.

The drying and pelletizing systems are housed within a building maintained at a slight negative pressure and served by a building air chemical odor control scrubber which removes all odors prior to exhausting through the RTO stack cited above. A fugitive dust control system is also provided for the mixer, crusher-to-mixer and screen-to-silo bucket elevators, pellet cooler, and pneumatic conveyor. Outlet air from this dust collector moves to the RTO described above for final cleanup. A second fugitive dust control system treats air from the pellet silo, pellet oiling and truck load. The exhaust air from this system moves to the building air chemical odor control scrubber before exhausting through the RTO stack. The pellet oiling mixer also inhibits fugitive dust production.

### Air Emissions from the Anaerobic Digestion System

The Egg-Shaped Digester (ESD) has two support systems that affect air emissions from the facility, 1) the hot water boiler and 2) the waste gas burner. The ESD will use the hot water boiler when needed to maintain proper operating temperature (approximately 95 deg F). The hot water boiler will be fired on either scrubbed digester gas or diesel fuel no. 2. No air emission controls are incorporated in the operation of the hot water boiler. The hot water boiler input rating is 2.5 MMBtu/hr. When required, the waste gas burner will burn excess unscrubbed digester gas. No emission controls are incorporated in the operation of the waste gas burner.

### Air Emissions from the Heat Drying System

The heat drying process has two systems that affect air emissions from the facility, 1) the Andritz DDS-40 Drying System and 2) the building air chemical odor control scrubber.

### Andritz DDS-40 Drying System

The Andritz direct heat drying and pelletizing process dries the digested dewatered biosolids (cake) and converts them into dried, pelletized organic fertilizer. The process is essentially an evaporation of water from the cake. Hot air generated in the combustion furnace is mixed with the cake in the rotating triple pass drum to dry and pelletize the input material. The exhaust gas laden with dry pellets of various sizes undergoes several steps of treatment: i.e., separation of dried pellets and fine particulate matter from gas using air/solid separator and polycyclones;

condensing evaporated water; recirculating a certain portion of exhaust gas back to combustion chamber; agglomerating remaining fine particulate in the venturi and removing them in the wet packed scrubber; and finally treating the cooled and clean gas in the Regenerative Thermal Oxidizer (RTO) for thermal destruction, oxidation and deodorization of noncondensable gaseous components. The combustion furnace and the RTO have 17.8 MMBtu/hr and 2 MMBtu/hr capacity, respectively.

Building Air Chemical Odor Control Scrubber

The facility building will be kept at slightly negative pressure. The building will be ventilated, and the exhaust will be treated by a dedicated chemical scrubbing system. There will be one chemical scrubber with two fans (one primary and one as backup). The scrubber system will be capable of providing 25,000 acfm. The scrubbing system will remove ammonia and hydrogen sulfide with high removal efficiency. The scrubber exhaust will be vented to the atmosphere along with the Andritz DDS-40 Drying System exhaust through a combined exhaust stack (ES#1).

Adequate air changes will be provided for various parts of the facility operational areas. The facility personnel area will be served by a separate HVAC system.

Air Emission Sources

The facility has three potential emission point sources: 1) Andritz DDS-40 Drying System and Building Air Chemical Odor Control Scrubber exhaust stack, 2) Hot Water Boiler, and 3) Waste Gas Burner.

Air Emission Source No. 1 (ES#1)

A single exhaust stack will be provided to release the combined flows and the controlled air emission from the Andritz DDS-40 Drying System and the chemical odor control scrubbing system for the facility building. The two fugitive dust control systems are also routed through this exhaust stack.

Air Emission Source No. 2 (ES#2)

A single exhaust stack will be provided to release exhaust from the facility's hot water boiler. The hot water generated by the boiler will be used to heat the facility's Egg-Shaped Digester (ESD). The hot water boiler operates intermittently as required for the anaerobic digestion controls. The hot water boiler will utilize a dual fuel burner. Its sources of fuel are scrubbed digester gas or diesel fuel no. 2.

Air Emission Source No. 3 (ES#3)

A waste digester gas burner (flare) will be used to burn the excess unscrubbed digester gas. The waste gas burner will operate intermittently as required.

Facility Fuels

The facility will utilize three different fuels for operation.

Digester Gas

Digester gas will be generated by the on-site anaerobic digestion system. Prior to being used as a fuel for drying or heating, the gas shall be scrubbed to remove hydrogen sulfide (H<sub>2</sub>S). If the digester gas is not used as a fuel, excess gas will be flared prior to the hydrogen sulfide removal scrubber via the waste gas burner.

The scrubbed digester gas will be the primary fuel for use in the Andritz DDS-40 combustion

## PROPOSED

furnace and the hot water boiler. The Andritz DDS-40 combustion furnace and hot water boiler will utilize dual fuel burners, and have the option to use digester gas and/or diesel fuel no. 2.

### Diesel Fuel No. 2

Diesel fuel no. 2 is to be used only in the following equipment:

- a) Andritz DDS-40 Combustion Furnace (secondary fuel)
- b) Andritz DDS-40 RTO
- c) Hot water boiler (secondary fuel)

### Propane

A small amount of propane will be used to operate the pilot lights of the following burners:

- a) Andritz DDS-40 Combustion Furnace
- b) Hot water boiler
- c) Waste gas burner

### Quantity and Composition of Fuels

#### Digester Gas

Digester gas is produced by the on-site anaerobic digestion system. Values indicated are estimates.

Gas Production, ft <sup>3</sup> /day	190,000
High heat value, Btu/ft <sup>3</sup>	550
Methane, ppmv	58-62
Carbon Dioxide, CO <sub>2</sub> , ppmv	36-42
Moisture	Saturated
Hydrogen Sulfide, ppmv	3500-5000

Digester gas will be scrubbed prior to use as fuel for the combustion furnace and the hot water boiler. H<sub>2</sub>S concentrations at the discharge of the scrubber will be no more than 500 ppmv.

### Diesel Fuel No. 2

Diesel fuel no. 2 for use in the combustion furnace, RTO and the hot water boiler will be stored at the facility in an aboveground storage tank. The diesel fuel no. 2 used will meet the following specification:

Maximum sulfur content - 0.33% by weight

### Hours of operation:

The anaerobic digester will be in operation continuously (24 hours/day, 365 days/year). The associated hot water boiler and waste gas burner will be operated automatically when required by the system.

The Andritz DDS-40 rotary drum dryer will be in operation for the time required to dry the Sand Island WWTP sludge. It is expected that the dryer will operate approximately three to five days per week. During dryer operation the combustion furnace and regenerative thermal oxidizer (RTO) will be in continuous operation.

The Dryer Facility Building will have a chemical odor scrubber treating building air continuously (24 hours/day, 365 days/year).

**Air Pollution Control Equipment:**

SO<sub>2</sub>

The primary fuel for the Andritz DDS-40 Drying System and the hot water boiler is the digester gas which has been scrubbed to remove H<sub>2</sub>S generated by anaerobic digestion thereby effectively eliminating SO<sub>2</sub> generation in the subsequent combustion process. In the event it becomes necessary to use the backup fuel, low sulfur diesel fuel no. 2 is used (sulfur content not to exceed 0.33% by weight). The regenerative thermal oxidizer (RTO) also fires low sulfur diesel fuel no. 2 as its primary fuel.

NO<sub>x</sub>

Since the three emission sources all involve external combustion, NO<sub>x</sub> generation is relatively low (as compared to internal compression ignition) and will be controlled by assuring proper maintenance and operation of the respective burners to minimize NO<sub>x</sub> production. In the case of the largest source, i.e., the Andritz DDS-40 Drying System, exhaust gas cooling and recirculation will further inhibit NO<sub>x</sub> production.

CO

All three external combustion sources firing gaseous or liquid hydrocarbon fuels (digester gas or diesel fuel no. 2) will be maintained and operated as designed in order to assure complete combustion and complete conversion of carbon to CO<sub>2</sub>.

PM/PM<sub>10</sub>

Two fugitive dust control systems will be provided for the pelletizing facility which itself is enclosed in a negative pressure building with all exhaust air being processed through a chemical scrubber. One fugitive dust control system is provided for the mixer, crusher-to-mixer and screen-to-silo bucket elevators, pellet cooler, and pneumatic conveyor. A second fugitive dust control system treats air from the pellet silo, pellet oiling and truck load. The exhaust air from one fugitive dust control system is polished by passage through the RTO, while the exhaust from the second fugitive dust control system is polished by passage through the Building Air Chemical Odor Control Scrubber.

Exhaust air from the Andritz DDS-40 drum dryer passes through a wet venturi scrubber and then the RTO before being released through a stack to the ambient air. A portion of the drum dryer exhaust is also cooled and recirculated to the Andritz DDS-40 combustion furnace. The hot water boiler firing either digester gas or diesel fuel no. 2 will control PM through proper maintenance and operation to assure complete combustion of all hydrocarbons to CO<sub>2</sub> and H<sub>2</sub>O. PM control for the waste gas burner is accomplished by providing sufficient air to assure complete combustion of the hydrocarbons present in the unscrubbed digester gas.

VOC

All three external combustion sources firing gaseous or liquid hydrocarbon fuels (digester gas or diesel fuel no. 2) will be maintained and operated as designed in order to assure complete combustion and maximum conversion of carbon to CO<sub>2</sub> and hydrogen to H<sub>2</sub>O.

H<sub>2</sub>S

Since digester gas containing H<sub>2</sub>S will be scrubbed in the gas purifiers prior to burning in the

Andritz DDS-40 Drying System and hot water boiler, negligible emissions are expected. Smaller quantities of excess unscrubbed digester gas containing H<sub>2</sub>S will be oxidized to SO<sub>2</sub> in the waste gas burner. Any hydrogen sulfide (H<sub>2</sub>S) within the facility's building will be controlled by the Building Air Chemical Odor Control Scrubber. Removal efficiency was estimated to be 95%.

NH<sub>3</sub>

Any ammonia (NH<sub>3</sub>) within the facility's building will be controlled by the Building Air Chemical Odor Control Scrubber. Removal efficiency was estimated to be 99%.

**Insignificant Activities:**

None proposed.

**Alternate Operating Scenarios:**

1. The foul air from the Wet Sludge Storage Tanks (WSST) shall be routed to the Building Air Chemical Odor Control Scrubber until the new Solids Odor Control System specified in Noncovered Source Permit No. 0216-05-N is constructed.
2. During this period when the foul air from the Wet Sludge Storage Tanks (WSST) is routed to the Building Air Chemical Odor Control Scrubber, the maximum outlet concentration of H<sub>2</sub>S from the exhaust stack of the Andritz DDS-40 Drying System (Exhaust Stack No. 1) shall be 2.93 ppmv.
3. After the new Solids Odor Control System is constructed and the foul air from the Wet Sludge Storage Tanks (WSST) is rerouted to it, the maximum outlet concentration of H<sub>2</sub>S from the exhaust stack of the Andritz DDS-40 Drying System shall be as specified in Attachment II, Special Condition No. C.5.

**Applicable Requirements:**

Hawaii Administrative Rules (HAR)

Title 11, Chapter 59	Ambient Air Quality Standards
Title 11, Chapter 60.1	Air Pollution Control
Subchapter 1	General Requirements
Subchapter 2	General Prohibitions
HAR 11-60.1-31	Applicability
HAR 11-60.1-32	Visible Emissions
HAR 11-60.1-38	Sulfur Oxides from Fuel Combustion
Subchapter 5	Covered Sources
Subchapter 6	Fees for Covered Sources, Noncovered Sources, and Agricultural Burning
HAR 11-60.1-111	Definitions
HAR 11-60.1-112	General Fee Provisions for Covered Sources
HAR 11-60.1-113	Application Fees for Covered Sources
HAR 11-60.1-114	Annual Fees for Covered Sources
HAR 11-60.1-115	Basis of Annual Fees for Covered Sources
Subchapter 9	Hazardous Air Pollution Sources

Federal Requirements

40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants (NESHAPS)  
 Subpart A - General Provisions  
 Subpart E - National Emission Standards for Mercury

**Non-applicable Requirements:**

Hawaii Administrative Rules

Title 11, Chapter 60.1      Air Pollution Control  
 Subchapter 7              Prevention of Significant Deterioration  
 Subchapter 8              Standards of Performance for Stationary Sources

Federal Requirements

40 CFR Part 52.21 - Prevention of Significant Deterioration of Air Quality  
 40 CFR Part 60 - New Source Performance Standards (NSPS)  
 40 CFR Part 63 - National Emission Standards for Hazardous Air Pollutants for Source Categories (Maximum Achievable Control Technologies (MACT) Standards)

**Prevention of Significant Deterioration (PSD):**

This source is not a major stationary source nor are there modifications proposed that constitute a major stationary source that is subject to PSD review, as defined in HAR §11-60.1-131, definition of a major stationary source. Therefore, PSD is not applicable.

**Best Available Control Technology (BACT):**

A Best Available Control Technology (BACT) analysis is required for new covered sources or significant modifications to covered sources that have the potential to cause a net increase in air pollutant emissions above significant levels as defined in HAR §11-60.1-1. There are no proposed modifications, and therefore a BACT analysis is not required for this permit renewal.

**Consolidated Emissions Reporting Rule (CERR):**

40 CFR Part 51, Subpart A - Emission Inventory Reporting Requirements, determines CER based on the emissions of criteria air pollutants from Type B point sources (as defined in 40 CFR Part 51, Subpart A), that emit at the CER triggering levels as shown in the table below.

Pollutant	Type B CER Triggering Levels <sup>1</sup> (tpy)	Pollutant	In-house Total Facility Triggering Levels <sup>2</sup> (tpy)	Total Facility Emissions (tpy)
NO <sub>x</sub>	≥100	NO <sub>x</sub>	≥25	52.52
SO <sub>2</sub>	≥100	SO <sub>2</sub>	≥25	71.29
CO	≥1000	CO	≥250	27.13
PM <sub>10</sub> /PM <sub>2.5</sub>	≥100/100	PM/PM <sub>10</sub>	≥25/25	3.50
VOC	≥100	VOC	≥25	8.57
		HAPS	≥5	0.35

<sup>1</sup> Based on actual emissions

<sup>2</sup> Based on potential emissions

This facility does not emit at the CER triggering levels. Therefore, CER requirements are not applicable.

Although CER for the facility is not triggered, the Clean Air Branch requests annual emissions reporting from those facilities that have facility-wide emissions of a single air pollutant exceeding in-house triggering levels. Since the total emissions of NO<sub>x</sub> and SO<sub>2</sub> within the facility are greater than 25 tons per year, annual emissions reporting for the facility will be required for in-house recordkeeping purposes.

**Compliance Data System (CDS):**

Applicable since this is a covered source.

**Compliance Assurance Monitoring (CAM):**

40 CFR Part 64

Applicability of the CAM rule is determined on a pollutant specific basis for each affected emission unit. Each determination is based upon a series of evaluation criteria. In order for a source to be subject to CAM, each source must:

- Be located at a major source per Title V of the Clean Air Act Amendments of 1990;
- Be subject to federally enforceable applicable requirements;
- Be fitted with an “active” air pollution control device;
- Have pre-control device potential emissions that exceed applicable major source thresholds; and
- Not be subject to certain regulations that specifically exempt it from CAM.

Emission units are any part or activity of a stationary source that emits or has the potential to emit any air pollutant.

This source is not subject to CAM because it is not considered a major source after the sludge incinerators are removed from the permit.

**Synthetic Minor Source:**

This source is a synthetic minor source as NO<sub>x</sub> emissions are above major source levels without the operating restrictions on the 2,000 hp diesel engine effluent pumps (application no. 0216-05) and adding the emissions from the In-Vessel Bioconversion Facility (application no. 0216-07).

Pollutant	2000 hp Effluent Diesel Engine Pumps (NSP No. 0216-05-N) (tpy)	In-Vessel Bioconversion Facility (CSP No. 0216-06-C) (tpy)	Total Emissions (tpy)
NO <sub>x</sub>	158.84	25.32	184.16

Project Emissions:

In-Vessel Bioconversion Facility Emissions

Pollutant	Combustion Furnace, RTO, Chemical Scrubber <sup>1</sup> (tpy)	Hot Water Boiler <sup>1</sup> (tpy)	Waste Gas Burner <sup>1</sup> (Flare) (tpy)	Total (tpy)
NO <sub>x</sub>	21.5	2.4	1.42	25.32
CO	17.4	0.48	7.75	25.63
SO <sub>2</sub>	32.5	4.07	31.4	67.97
PM/PM <sub>10</sub>	2.37 <sup>2</sup>	0.17	0.66	3.20
VOC	5.04	0.05	2.93	8.02
H <sub>2</sub> S	0.45	0	0.35	0.80
Formaldehyde	3.78E-02	4.77E-03		4.26E-02
Arsenic	1.29E-04	4.82E-05		1.77E-04
Beryllium	2.86E-04	3.61E-05		3.22E-04
Cadmium	1.15E-04	3.61E-05		1.51E-04
Chromium	2.86E-04	3.61E-05		3.22E-04
Lead	7.52E-04	1.09E-04		8.61E-04
Mercury	2.88E-01	3.61E-05		2.88E-01
Manganese	2.86E-04	3.61E-05		3.22E-04
Nickel	9.60E-04	3.61E-05		9.96E-04
Selenium	3.66E-04	1.81E-04		5.47E-04
Total HAPS	0.329	5.32E-03		3.34E-01

<sup>1</sup> Based on annual operations of 8760 hrs/yr

<sup>2</sup> Negligible amounts of PM/PM<sub>10</sub> from the two fugitive dust control systems are also emitted at the RTO and Chemical Scrubber

**Sand Island Wastewater Treatment Plant - Total Emissions**

Pollutant	In-Vessel Bioconversion Facility (CSP No. 0216-06-C) (tpy)	2000 hp Effluent Diesel Engine Pumps (NSP No. 0216-05-N) (tpy)	New Odor Control Systems <sup>1</sup> (NSP No 0216-05-N) (tpy)	Total Emissions (tpy)
NO <sub>x</sub>	25.32	27.2		52.52
CO	25.63	1.5		27.13
SO <sub>2</sub>	67.97	3.32		71.29
PM/PM <sub>10</sub>	3.20	0.3		3.50
VOC	8.02	0.55		8.57
Lead	8.61E-04			8.61E-04
H <sub>2</sub> S	0.80		8.89	9.69
Total HAPS	3.34E-01	1.57E-02		0.35

<sup>1</sup> The new odor control systems consist of a new Headworks, Solids, and Primary Odor Control Systems and a revised Lo-Cat Odor Control System.

**Ambient Air Quality Assessment:**

An ambient air quality impact analysis (AAQIA) for the In-Vessel Bioconversion Facility was not required to be performed as there are no proposed modifications to the facility.

**Significant Permit Conditions:**

Significant permit conditions for the In-Vessel Bioconversion Facility included the following:

- The Andritz DDS-40 Drying System is subject to NESHAP, Subpart E - National Emission Standard for Mercury. Emissions are not to exceed 3200 grams of mercury per 24-hour period. An initial source performance test is required for mercury emissions.
- The diesel fuel no.2 fired in the combustion furnace, hot water boiler and regenerative thermal oxidizer (RTO) shall have a maximum sulfur content of 0.33% by weight.
- The scrubbed digester gas shall have a maximum H<sub>2</sub>S concentration of 500 ppmv.
- The unscrubbed digester gas shall have a maximum H<sub>2</sub>S concentration of 5000 ppmv.
- The maximum outlet concentration of H<sub>2</sub>S and NH<sub>3</sub> from the Andritz DDS-40 Drying System shall be 0.61 ppmv and 50.3 ppmv, respectively.
- The Building Air Chemical Odor Control Scrubber and the Fugitive Dust Control Systems shall operate continuously when the Andritz DDS-40 Drying System is in operation.
- Visible emission requirements for the Andritz DDS-40 Drying System, hot water boiler and waste gas burner.
- Baghouse maintenance requirements for the Fugitive Dust Control System.
- The finished product shall not be stored outside of the two (2) pellet storage silos.

**Conclusion and Recommendations:**

Recommend issuing the renewal for Covered Source Permit No. No. 0216-06-C, since there are no modifications proposed to the In-Vessel Bioconversion Facility. A 30-day public comment period and 45-day EPA review period are also required.

Reviewer: Darin Lum

Date: 8/09