



AUG 31 2015

Mr. Robert Beebout
Aera Energy LLC
P O Box 11164
Bakersfield, CA 93389-1164

**Re: Notice of Minor Title V Permit Modification
District Facility # S-1547
Project # 1153536**

Dear Mr. Beebout:


Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued S-1547-168-25, '174-28, '175-28, '683-6 and '684-6' (under project S-1153385) into the Title V operating permit. The ATCs are to designate five steam generators as compliant dormant emissions units (DEUs).

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued S-1547-168-25, '174-28, '175-28, '683-6 and '684-6', emission increases, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

TITLE V APPLICATION REVIEW

Minor Modification
Project #: 1153536

Engineer: David Torii
Reviewing Engineer: Steve Leonard

SL 3/26/15

Facility Number: S-1547
Facility Name: Aera Energy LLC
Mailing Address: P O Box 11164
Bakersfield, CA 93389-1164
Contact Name: Robert Beebout
Phone: 661-665-3212

Responsible Official: E.E. (Ed) Patterson
Title: Process Supervisor

I. PROPOSAL

Aera Energy LLC (Aera) is proposing a Title V minor permit modification to incorporate the recently issued ATCs S-1547-168-25, '174-28, '175-28, '683-6 and '684-6 into the Title V operating permit. The ATCs are to designate five steam generators as compliant dormant emissions units (DEUs).

II. FACILITY LOCATION

The equipment is located at various specified locations in Aera's Heavy Oil Western stationary source.

III. EQUIPMENT DESCRIPTION

Proposed Title V Operating Permit:

- S-1547-168-25: 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-1, DIS# 27461-71) AND FLUE GAS RECIRCULATION (WIER)
- S-1547-174-28: 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN LOW NOX BURNER AND FLUE GAS RECIRCULATION (WIER J-8, DIS# 27223-74)
- S-1547-175-28: 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-11, DIS# 27457-81) AND FLUE GAS RECIRCULATION (WIER)
- S-1547-683-6: 62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (W-10, DIS# 34142-93, S.N. 51106-01) (WIER #10)

S-1547-684-6: 62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (DIS# 34141-93, S.N. 51106-02) (WIER #9)

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

The Changes to the original Permits to Operate consist of adding the follows six conditions:

- While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Y
- Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Y
- While dormant, normal source testing shall not be required. [District Rule 2080] Y
- Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Y
- Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Y
- Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Y

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;

3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

ATTACHMENT A

Proposed Modified Title V Operating Permits

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-168-26

EXPIRATION DATE: 08/31/2016

SECTION: 22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-1, DIS# 27461-71) AND FLUE GAS RECIRCULATION (WIER)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201; 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
19. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
20. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
22. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. If either the NOx or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
24. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NOx and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
27. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
29. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
32. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-174-29

EXPIRATION DATE: 05/31/2016

SECTION: SW22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN LOW NOX BURNER AND FLUE GAS RECIRCULATION (WIER J-8, DIS# 27223-74)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.070 lb/MMBtu, SOx (as SO2): 0.092 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
18. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
19. Emission rates shall not exceed any of the following: PM10: 105.0 lb/day, SOx (as SO2): 138.0 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
26. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
28. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas h_hv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2, and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
31. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-175-29

EXPIRATION DATE: 05/31/2016

SECTION: 22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-11, DIS# 27457-81) AND FLUE GAS RECIRCULATION (WIER)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rule 2201; 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
19. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
20. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
22. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
24. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
27. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
29. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas h_hv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
32. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-683-7

EXPIRATION DATE: 03/31/2016

SECTION: SW22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (W-10, DIS# 34142-93, S.N. 51106-01) (WIER #10)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
14. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305 and 4306, 5.1] Federally Enforceable Through Title V Permit
15. Natural gas fuel sulfur content shall not exceed 2.8 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.008 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, or CO: 0.02 lb/MMBtu or 27 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
17. If FGR system on unit is used intermittently, monitoring shall consist of use of a portable analyzer. If FGR system on unit is continuously used, monitoring shall consist of either use of a portable analyzer or monitoring of FGR rate based on parameters established during initial compliance source testing. If FGR system on unit is not used, monitoring shall consist of either use of a portable analyzer or monitoring of stack O2 and burner mechanical adjustments. The alternate monitoring scheme selected for this unit shall be established prior to implementation of this Authority to Construct. [District Rule 4306, 5.7] Federally Enforceable Through Title V Permit
18. Permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
19. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
21. Permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. Whenever the unit is switched to operate with the flue gas recirculation (FGR) system in the closed position, compliance source testing for NO_x and CO shall be conducted within 60 days of cessation of FGR operation date unless source testing with FGR system in the closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit
24. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
26. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
29. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-684-7

EXPIRATION DATE: 05/31/2016

SECTION: SW22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (DIS# 34141-93, S.N. 51106-02) (WIER #9)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
14. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305 and 4306, 5.1] Federally Enforceable Through Title V Permit
15. Natural gas fuel sulfur content shall not exceed 2.8 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.008 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, or CO: 0.02 lb/MMBtu or 27 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 4405, 5.1] Federally Enforceable Through Title V Permit
17. If FGR system on unit is used intermittently, monitoring shall consist of use of a portable analyzer. If FGR system on unit is continuously used, monitoring shall consist of either use of a portable analyzer or monitoring of FGR rate based on parameters established during initial compliance source testing. If FGR system on unit is not used, monitoring shall consist of either use of a portable analyzer or monitoring of stack O2 and burner mechanical adjustments. The alternate monitoring scheme selected for this unit shall be established prior to implementation of this Authority to Construct. [District Rule 4306, 5.7] Federally Enforceable Through Title V Permit
18. Permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
19. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
21. Permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. Whenever the unit is switched to operate with the flue gas recirculation (FGR) system in the closed position, compliance source testing for NO_x and CO shall be conducted within 60 days of cessation of FGR operation date unless source testing with FGR system in the closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit
24. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
26. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
29. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

30. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Current Permits

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-168-20

EXPIRATION DATE: 05/31/2016

SECTION: 22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-1, DIS# 27461-71) AND FLUE GAS RECIRCULATION (WIER)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H₂S: ASTM D6228 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201; 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
13. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
14. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas h_hv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
26. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
27. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-174-22

EXPIRATION DATE: 05/31/2016

SECTION: SW22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN LOW NOX BURNER AND FLUE GAS RECIRCULATION (WIER J-8, DIS# 27223-74)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.070 lb/MMBtu, SOx (as SO2): 0.092 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
12. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
13. Emission rates shall not exceed any of the following: PM10: 105.0 lb/day, SOx (as SO2): 138.0 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit
16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
18. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
20. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
22. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2, and 4306, 6.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
25. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
26. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
27. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-175-23

EXPIRATION DATE: 05/31/2016

SECTION: 22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-11, DIS# 27457-81) AND FLUE GAS RECIRCULATION (WIER)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H₂S: ASTM D6228 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rule 2201; 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
13. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
14. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
26. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
27. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-683-5

EXPIRATION DATE: 05/31/2016

SECTION: SW22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (W-10, DIS# 34142-93, S.N. 51106-01) (WIER #10)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H₂S: ASTM D6228 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
8. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305 and 4306, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Natural gas fuel sulfur content shall not exceed 2.8 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.008 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, or CO: 0.02 lb/MMBtu or 27 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
11. If FGR system on unit is used intermittently, monitoring shall consist of use of a portable analyzer. If FGR system on unit is continuously used, monitoring shall consist of either use of a portable analyzer or monitoring of FGR rate based on parameters established during initial compliance source testing. If FGR system on unit is not used, monitoring shall consist of either use of a portable analyzer or monitoring of stack O2 and burner mechanical adjustments. The alternate monitoring scheme selected for this unit shall be established prior to implementation of this Authority to Construct. [District Rule 4306, 5.7] Federally Enforceable Through Title V Permit
12. Permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
13. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
16. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
17. Whenever the unit is switched to operate with the flue gas recirculation (FGR) system in the closed position, compliance source testing for NOx and CO shall be conducted within 60 days of cessation of FGR operation date unless source testing with FGR system in the closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

18. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
20. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
25. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-684-5

EXPIRATION DATE: 05/31/2016

SECTION: SW22 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (DIS# 34141-93, S.N. 51106-02) (WIER #9)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
8. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305 and 4306, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Natural gas fuel sulfur content shall not exceed 2.8 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SO_x (as SO₂): 0.008 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, or CO: 0.02 lb/MMBtu or 27 ppmv @ 3% O₂. [District Rules 2201, 4305, 5.1 and 4306, 4405, 5.1] Federally Enforceable Through Title V Permit
11. If FGR system on unit is used intermittently, monitoring shall consist of use of a portable analyzer. If FGR system on unit is continuously used, monitoring shall consist of either use of a portable analyzer or monitoring of FGR rate based on parameters established during initial compliance source testing. If FGR system on unit is not used, monitoring shall consist of either use of a portable analyzer or monitoring of stack O₂ and burner mechanical adjustments. The alternate monitoring scheme selected for this unit shall be established prior to implementation of this Authority to Construct. [District Rule 4306, 5.7] Federally Enforceable Through Title V Permit
12. Permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
13. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
16. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
17. Whenever the unit is switched to operate with the flue gas recirculation (FGR) system in the closed position, compliance source testing for NO_x and CO shall be conducted within 60 days of cessation of FGR operation date unless source testing with FGR system in the closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

18. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
20. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
25. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Authority to Construct Permits



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-168-25

ISSUANCE DATE: 08/12/2015

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: 22 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-1, DIS# 27461-71) AND FLUE GAS RECIRCULATION (WIER). DESIGNATE AS A COMPLIANT DORMANT EMISSIONS UNIT


CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Arnaud Marjollet, Director of Permit Services

S-1547-168-25 Aug 12 2015 4:26AM - TORID Job-1 Inspector NOT Reg. #14

7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H₂S: ASTM D6228 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM₁₀: 0.008 lb/MMBtu, SO_x (as SO₂): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 2201; 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
21. Emission rates shall not exceed any of the following: PM₁₀: 12.0 lb/day, SO_x (as SO₂): 4.5 lb/day, VOC: 4.5 lb/day, NO_x (as NO₂): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit
24. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
25. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

28. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
29. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
30. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit
32. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
33. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
35. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-174-28

ISSUANCE DATE: 08/12/2015

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: SW22 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN LOW NOX BURNER AND FLUE GAS RECIRCULATION (WIER J-8, DIS# 27223-74): DESIGNATE AS A COMPLIANT DORMANT EMISSIONS UNIT


CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5506 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment

Seyed Sadredin, Executive Director / APCO


Arnaud Marjollet, Director of Permit Services

S-1547-174-28 Aug 12 2015 7:42AM - TORID Joint Inspection NOT Required

7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.070 lb/MMBtu, SOx (as SO2): 0.092 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
19. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Emission rates shall not exceed any of the following: PM10: 105.0 lb/day, SOx (as SO2): 138.0 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
22. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.5] Federally Enforceable Through Title V Permit
23. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
24. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
27. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
29. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2, and 4306, 6.2] Federally Enforceable Through Title V Permit
31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
32. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-175-28

ISSUANCE DATE: 08/12/2015

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93399-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: 22 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH COEN QLN LOW NOX BURNER (#J-14, DIS# 27457-81) AND FLUE GAS RECIRCULATION (WIER): DESIGNATE AS A COMPLIANT DORMANT EMISSIONS UNIT

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Richard W. Kay
Arnaud Marjollet, Director of Permit Services

S-1547-175-28 Aug 12 2015 1:42PM - TGRID Job Inspection NOT Required

7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. No less than 1.65 miles of roadway shall be paved with asphalt concrete and maintained in good repair. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Natural gas fuel sulfur content shall not exceed 1.1 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rule 2201; 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
21. Emission rates shall not exceed any of the following: PM₁₀: 12.0 lb/day, SO_x (as SO₂): 4.5 lb/day, VOC: 4.5 lb/day, NO_x (as NO₂): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
24. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
25. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

28. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
29. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
30. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit
32. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
33. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
35. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-683-6

ISSUANCE DATE: 02/12/2015

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: SW22 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (W-10, DIS# 34142-93, S.N. 51106-01) (WIER #10): DESIGNATE AS A COMPLIANT DORMANT EMISSIONS UNIT

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (805) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Sayed Sadredin, Executive Director / AFCD

Richard W. Kauz
Richard W. Kauz, Director of Permit Services

S 1547-683-6 Aug 12 2015 1:12 AM - TORO - Joint Inspection RGT Register

7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
15. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305 and 4306, 5.1] Federally Enforceable Through Title V Permit
16. Natural gas fuel sulfur content shall not exceed 2.8 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.008 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, or CO: 0.02 lb/MMBtu or 27 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
18. If FGR system on unit is used intermittently, monitoring shall consist of use of a portable analyzer. If FGR system on unit is continuously used, monitoring shall consist of either use of a portable analyzer or monitoring of FGR rate based on parameters established during initial compliance source testing. If FGR system on unit is not used, monitoring shall consist of either use of a portable analyzer or monitoring of stack O2 and burner mechanical adjustments. The alternate monitoring scheme selected for this unit shall be established prior to implementation of this Authority to Construct. [District Rule 4306, 5.7] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. Permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
20. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
22. Permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
24. Whenever the unit is switched to operate with the flue gas recirculation (FGR) system in the closed position, compliance source testing for NO_x and CO shall be conducted within 60 days of cessation of FGR operation date unless source testing with FGR system in the closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit
25. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
27. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

28. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
30. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-684-6

ISSUANCE DATE: 08/12/2015

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93369-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

SECTION: SW22 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION (DIS# 34141-93, S.N. 51106-02) (WIER #9): DESIGNATE AS A COMPLIANT DORMANT EMISSIONS UNIT

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be canceled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadroodin, Executive Director / APCO

Arnaud Marjolle, Director of Permit Services

S-1547-684-R Aug 12 2015 7:42AM - To:RD J. Kim Inspection NOT Required

7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
15. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305 and 4306, 5.1] Federally Enforceable Through Title V Permit
16. Natural gas fuel sulfur content shall not exceed 2.8 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.008 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, or CO: 0.02 lb/MMBtu or 27 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 4405, 5.1] Federally Enforceable Through Title V Permit
18. If FGR system on unit is used intermittently, monitoring shall consist of use of a portable analyzer. If FGR system on unit is continuously used, monitoring shall consist of either use of a portable analyzer or monitoring of FGR rate based on parameters established during initial compliance source testing. If FGR system on unit is not used, monitoring shall consist of either use of a portable analyzer or monitoring of stack O2 and burner mechanical adjustments. The alternate monitoring scheme selected for this unit shall be established prior to implementation of this Authority to Construct. [District Rule 4306, 5.7] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. Permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
20. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
22. Permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
24. Whenever the unit is switched to operate with the flue gas recirculation (FGR) system in the closed position, compliance source testing for NO_x and CO shall be conducted within 60 days of cessation of FGR operation date unless source testing with FGR system in the closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit
25. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
27. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

28. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas h_hv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
30. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320, 6.1] Federally Enforceable Through Title V Permit
32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

ATTACHMENT D

Emissions Increases

SSIPE (lb/yr) = zero

ATTACHMENT E

Application



August 12, 2015

RECEIVED
AUG 18 2015
SJVAPCD
Southern Region

HAND DELIVERED TO BAKERSFIELD OFFICE

Mr. Leonard Scandura
San Joaquin Valley
Air Pollution Control District
Southern Region
34946 Flyover Court
Bakersfield, CA 93308

SUBJECT: APPLICATION FOR TITLE V MODIFICATION
FACILITY ID: S-1547
IMPLEMENT ATCs S-1547-168-25, '-174-28, '-175-28, '-683-6, and '-684-6

Dear Mr. Scandura:

Aera Energy LLC (Aera) requests that the Title V permit for Facility S-1547 be modified to implement Authority(s) to Construct (ATC) S-1547-168-25, '-174-28, '-175-28, '-683-6, and '-684-6 into the Title V permit. The ATCs for the Wier steam generators was originally evaluated as District project number S-1153385.

I have attached the appropriate application form, compliance certification form, and copy of the current Authority to Construct.

Thank you for your attention to this matter. Should you have any questions concerning this application or require additional information, please do not hesitate to contact me at (661) 665-3212 or via e-mail at rmbeebout@aeraenergy.com.


Sincerely,

A handwritten signature in black ink that reads "Robert M Beebout". The signature is written in a cursive, flowing style.

Robert M. Beebout
Environmental Advisor – Midway Sunset

Attachment

cc: Adean Valenzuela



San Joaquin Valley Unified Air Pollution Control District

APPLICATION FOR TITLE V MODIFICATION:

- ADMINISTRATIVE AMENDMENT
 MINOR MODIFICATION
 SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: Aera Energy LLC	
2. MAILING ADDRESS: STREET/P.O. BOX: P.O. Box 11164 CITY: Bakersfield STATE: CA 9-DIGIT ZIP CODE: 93389-1164	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: Heavy Oil Western Stationary Source CITY: Kern County, CA SW 1/4 SECTION 22 TOWNSHIP 31S RANGE 22E	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: Oil and Natural Gas Production	
5. EQUIPMENT FOR WHICH APPLICATION IS MADE (Include Permit Nos.): Implement ATC numbers S-1547-168-25, '-174-28, '-175-28, '-683-6, and '-684-6 into the Title V permit. <div style="text-align: right;">(Use additional sheets if necessary)</div>	
6. DO YOU REQUEST A CERTIFICATE OF CONFORMITY WITH THIS ACTION? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
7. IS THIS APPLICATION SUBMITTED AS A RESULT OF A NOV/NTC? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO NOV/NTC No.: _____	
8. SIGNATURE OF APPLICANT/CONTACT PERSON: <i>Robert M Beebout</i>	TYPE OR PRINT TITLE OF APPLICANT: Environmental Advisor
9. TYPE OR PRINT NAME OF APPLICANT/CONTACT: Robert M. Beebout	DATE: August 12, 2015
10. FAX NUMBER: (661) 665-3222	TELEPHONE NUMBER: (661) 665-3212

FOR APCD USE ONLY: *No Money Rcvd.*

RECEIVED DATE STAMP AUG 18 2015 SJVAPCD Southern Region	FILING FEE RECEIVED: \$ _____ / DATE PAID: _____ PROJECT NO.: S-115353b FACILITY REGION & ID: S-1547
--	--

San Joaquin Valley Unified Air Pollution Control District

TITLE V COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

COMPANY NAME: Aera Energy LLC	FACILITY ID: S-1547
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: Aera Energy LLC	
3. Agent to the Owner: N/A	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:



 Signature of Responsible Official

 8-12-2015
 Date

E.E. (Ed) Patterson

 Name of Responsible Official (please print)

Process Supervisor

 Title of Responsible Official (please print)