



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

May 7, 2013

Mr. Mike Burt  
General Manager  
Wheelabrator Norwalk Energy Company, Inc.  
11500 Balsam St.  
Norwalk, CA 90650

**SUBJECT:** RECLAIM/Title V Facility Permit Revision (Facility ID: 51620)

Dear Mr. Burt:

Please find attached the revised Title Page, Table of Contents, and Section D of your RECLAIM/Title V Facility Permit. The revised sections reflect the approval of the permit revision requested in your Application No. 539542. The proposed permit revision was submitted to EPA for 45-day review on October 26, 2012 and no comments were received. This permit revision reflects the addition of fuel oil readiness testing for Boiler No.2 as well as the inclusion of a 42 ppm NOx BACT and 112 lbs/hr NOx start up limit on the gas turbine. Following are the application numbers:

Equipment	Application No.	Device No.	Process/System	Permit Type
Gas Turbine	539543	D4	1/1	PO
Boiler No. 2	539544	D7	1/1	PO

In response to Wheelabrator's comments on the draft permit, the language of conditions B75.1, A99.1 and A195.1 were modified to reflect that the oil firing limits will be based on fuel usage and not time, that the start up NOx limit for the turbine is in lbs/hr, and to include up to eight excursions from the 42 ppm NOx limit for the turbine annually.

Please review the attached sections carefully. Insert the enclosed sections into your RECLAIM/Title V Facility Permit and discard the earlier versions. Questions concerning changes to your permit should be directed to Mr. Chris Perri at (909) 396-2696.

Sincerely,

Andrew Y. Lee, P.E.  
Senior Engineering Manager  
Engineering and Compliance

AYL:JTY:cgp  
Attachment

cc: Gerardo Rios, EPA Region IX