



MAY 07 2013

Mr. Jim Adams
Phillips 66 Pipeline LLC
1441 Wade Ave
Taft, CA 93268

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # S-1124497**

Dear Mr. Adams:


The Air Pollution Control Officer has issued an Authority to Construct (S-1525-4-5) with a Certificate of Conformity to Phillips 66 Pipeline LLC. The applicant proposes to designate the unit as dormant emissions unit.

Enclosed is the Authority to Construct and invoice. The application and proposal were sent to US EPA Region IX on April 9, 2013. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,


David Warner
Director of Permit Services

Enclosures
jag

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



MAY 07 2013

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # S-1124497**


Dear Mr. Rios:

The Air Pollution Control Officer has issued an Authority to Construct (S-1525-4-5) with a Certificate of Conformity to Phillips 66 Pipeline LLC. The applicant proposes to designate the unit as dormant emissions unit.

Enclosed is a copy of the Authority to Construct. The application and proposal were sent to US EPA Region IX on April 9, 2013. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Enclosures
jag

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1525-4-5

ISSUANCE DATE: 04/29/2013

LEGAL OWNER OR OPERATOR: PHILLIPS 66 PIPELINE LLC
MAILING ADDRESS: MIDWAY PUMP STATION
1441 WADE AVE
TAFT, CA 93268

LOCATION: MIDWAY PUMP STATION
1441 WADE AVE
TAFT, CA 93268

SECTION: 14 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 199 BHP WAUKESHA MODEL F1197G RICH BURN NATURAL GAS-FIRED PIPELINE PUMP ENGINE WITH NSCR AND AIR TO FUEL RATIO CONTROLLER: DESIGNATE AS A NON-COMPLIANT DORMANT EMISSIONS UNIT

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Operation of the unit is not authorized until modifications are made to comply with District Rules as authorized by an Authority to Construct. [District Rule 2010] Federally Enforceable Through Title V Permit
4. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
5. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

S-1525-4-5 : Apr 29 2013 6:37PM - GARCIAJ : Joint Inspection NOT Required

6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
7. This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Maintenance (I&M) plan submitted to the District. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
9. Emissions from this engine shall not exceed any of the following limits: 25 ppmvd NO_x @ 15% O₂ or equivalent to 0.303 g-NO_x/hp-hr, 0.009 g-SO_x/hp-hr, 0.063 g-PM₁₀/hp-hr, 2,000 ppmvd CO @ 15% O₂ or equivalent to 14.555 g-CO/hp-hr, or 250 ppmvd VOC @ 15% O₂ or equivalent to 1.040 g-VOC/hp-hr. [District Rules 2201, 4702, and 4801] Federally Enforceable Through Title V Permit
10. This engine shall be fired on PUC quality natural gas with a sulfur content of less than or equal to 0.017% by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
11. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
12. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246. [District Rule 2520] Federally Enforceable Through Title V Permit
13. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x, CO, and VOC emissions from this unit shall be measured not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
19. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25A or 25B, or ARB Method 100. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
22. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results and any other information necessary to demonstrate compliance. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
27. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the applicable requirements of Kern County Rule 407 and District Rule 4801. A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
29. On and after October 19, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. On and after October 19, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
31. On and after October 19, 2013, the engine's oil and filter shall be changed every 1,440 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
32. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
33. On and after October 19, 2013, the engine's spark plugs shall be inspected every 1,440 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
34. On and after October 19, 2013, the engine's hoses and belts shall be inspected every 1,440 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
35. On and after October 19, 2013, the permittee shall maintain monthly records that include any information necessary to demonstrate compliance with 40 CFR 63 Subpart ZZZZ. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
36. On and after October 19, 2013, the permittee shall maintain monthly records of all performance tests, opacity and visible emissions observations and required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
37. On and after October 19, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit