



SEP 14 2015

Brent Winn
Aera Energy Inc.
P.O. Box 11164
Bakersfield, CA 93389

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-1547
Project # S-1153555**

Dear Mr. Winn:

The Air Pollution Control Officer has modified the Title V permit for Aera Energy Inc. by incorporating S-1547-144-34. Aera Energy Inc. proposes to designate unit S-1547-144 as a compliant dormant emissions unit.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on 8/28/15. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



Arnaud Marjollet
Director of Permit Services

AM:wej

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-144-35

EXPIRATION DATE: 05/31/2016

SECTION: 26 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN-ULN LOW NOX BURNER, FLUE GAS RECIRCULATION, AND SHARED SO2 SCRUBBER LISTED ON S-1547-143, (#129 DIS# 28613-82) (A/F DEHY)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. (Adjust as necessary) [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Copies of all fuel invoices showing quantity and delivery points of supplier-certified gas delivered and copies of quality terms of supplier-certified gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Scrubber liquor pH shall be observed and recorded weekly during operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Records of scrubber liquor pH shall be maintained. The records shall include identification of the equipment, date of inspection, corrective action taken, and identification of the individual performing the inspection. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
15. No less than 3.0 miles of roads shall be paved and properly maintained with hot mix asphalt material at permittee's South Belridge field on Poleline Road - From the intersection of Main Camp Road to 1/2 mile north of Entrance 'D'. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Only asphalt concrete shall be used as road paving material. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Scrubber shall be located on site. Duct work to steam generators may be blinded off or removed. [District Rule 2080] Federally Enforceable Through Title V Permit
20. Scrubber shall be utilized whenever TEOR gas is incinerated in steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
22. This unit shall be fired exclusively on natural gas, which may consist of one or a mixture of fuels including vapor recovery gas, produced gas, and purchased gas. [District Rule 2201] Federally Enforceable Through Title V Permit
23. When utilizing scrubber, source testing to demonstrate compliance with SOx emission limit shall be conducted not less than once every 12 months. When not utilizing scrubber, fuel sulfur content shall be certified by a third party fuel supplier or compliance with sulfur compound emission limit shall be demonstrated not less than once every 12 months by fuel gas sulfur content analysis and higher heating value analysis of each fuel source. [District Rule 2201] Federally Enforceable Through Title V Permit
24. When scrubber is in operation, steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. Scrubber liquor pH shall be maintained above 6.15 and shall be continuously monitored. Compliance shall be determined on a three-hour rolling average. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Duration of startup and shutdown (as defined in Rule 4306) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
28. Emission rates, except during startup, shutdown, and refractory curing, shall not exceed any of the following PM10: 0.058 lb/MMBtu, SOx (as SO2): 0.063 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, or CO: 50 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
29. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
30. Emission rates shall not exceed any of the following: PM10: 87.0 lb/day, SOx (as SO2): 94.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 9855 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
32. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
34. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
36. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
38. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
39. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5 and 4306, 5.5] Federally Enforceable Through Title V Permit
40. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.4; 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
41. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and Rule 4320] Federally Enforceable Through Title V Permit
42. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320, 5.1 and 5.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.