



MAR 28 2012

Jim Giles  
SFPP, L.P.  
1100 Town and Country Road  
Orange, CA 92868

**Re: Notice of Final Action - Minor Title V Permit Modification  
District Facility # C-1077  
Project # C-1103479**


Dear Mr. Giles:

The Air Pollution Control Officer has modified the Title V permit for SFPP, L.P. by incorporating Authority to Construct C-1077-49-3. The applicant proposes to replace one lane pump sleeve denatured ethanol unloading station with two lane skid mounted denatured ethanol - unloading station and allow use of CARB Test Methods CP-204, TP-204.1, TP-204.2, and TP-204.3 for tanker truck vapor testing.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on February 7, 2011. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

  
David Warner  
Director of Permit Services

DW:st

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



**MAR 28 2012**

Gerardo C. Rios, Chief  
Permits Office (AIR-3)  
U.S. EPA - Region IX  
75 Hawthorne St  
San Francisco, CA 94105

**Re: Notice of Final Action - Minor Title V Permit Modification  
District Facility # C-1077  
Project # C-1103479**

Dear Mr. Rios:

The Air Pollution Control Officer has modified the Title V permit for SFPP, L.P. by incorporating Authority to Construct C-1077-49-3. The applicant proposes to replace one lane pump sleeve denatured ethanol unloading station with two lane skid mounted denatured ethanol - unloading station and allow use of CARB Test Methods CP-204, TP-204.1, TP-204.2, and TP-204.3 for tanker truck vapor testing.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on February 7, 2011. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner  
Director of Permit Services

DW:st

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** C-1077-49-4

**EXPIRATION DATE:** 05/31/2016

**EQUIPMENT DESCRIPTION:**

TWO-LANE DENATURED ETHANOL TRUCK UNLOADING STATION EACH LANE WITH TWO FLEXIBLE UNLOADING HOSES, TWO PUMPS, PRODUCT ACCUMULATOR, AIR ELIMINATOR, METER AND SUPPORT EQUIPMENT, AND ORGANIC VAPORS RETURNED TO DELIVERY TRUCKS FOR COLLECTION SERVING C-1077-5 AND C-1077-13

## PERMIT UNIT REQUIREMENTS

---

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Vapor return hose(s) shall connect displaced vapors to the delivery truck or to tanks C-1077-5 or '13 whenever tank truck, trailer, or car is unloading organic liquid. [District Rules 2201 and 4624] Federally Enforceable Through Title V Permit
4. All delivery trucks must be equipped with vapor collection equipment capable of undergoing a pressure change of no more than 1 inch of water within 5 minutes after it is pressured to 18 inches of water. This must be demonstrated annually for each truck using the procedures specified in EPA Method 27 of 40 CFR 60, Appendix A or CARB Test Methods CP-204, TP-204.1, TP204-2, and TP-204.3. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The vapor collection and control system shall operate such that the pressure in the delivery tank being unloaded does not exceed 18 inches water column pressure and six (6) inches water column vacuum. [District Rule 4624] Federally Enforceable Through Title V Permit
6. The transfer rack and vapor collection equipment shall be designed, installed, maintained and operated such that there are no leaks and no excess organic liquid drainage at disconnections. [District Rule 4624] Federally Enforceable Through Title V Permit
7. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of VOC greater than 1,000 ppmv as methane above a background when measured using a portable hydrocarbon detection instrument in accordance with EPA Method 21. [District Rule 4624] Federally Enforceable Through Title V Permit
8. Fugitive VOC emissions from the denatured ethanol unloading system shall not exceed 0.20 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall maintain accurate component count for tank according to EPA's "Protocol for Equipment Leak Emission Estimate," Table 2-3, Marketing Terminal Average Emission Factors. Permittee shall update such records when new components are approved and installed. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The maximum throughput of denatured ethanol unloaded shall not exceed 427,350 gallons per day. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The maximum volume of liquid spilled during disconnect shall not exceed 10 milliliters. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Daily records of amount of denatured ethanol unloaded at the denatured ethanol unloading system shall be maintained. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
14. Permittee shall maintain the following records for each truck: 1) the annual vapor collection equipment test result, 2) date the test was performed, and 3) truck identification. [District NSR Rule] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.