



APR 02 2013

Mr. Paul Franzia
Bronco Wine Company
PO Box 789
Ceres, CA 95307

**Re: Final - Authority to Construct / COC (Significant Mod)
District Facility # N-1665
Project # 1123083**

Dear Mr. Franzia:

The Air Pollution Control Officer has issued Authorities to Construct (N-1665-514-0) with Certificates of Conformity to Bronco Wine Company at 6342 Bystrum Rd, Ceres, CA. The project authorizes installation of a 15.75 MMBtu/hr natural gas-fired boiler. Enclosed are the Authorities to Construct and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the Authority to Construct permit was published on February 26, 2013. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on February 26, 2013. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Seyed Sadredin

Executive Director/Air Pollution Control Officer

Northern Region

4800 Enterprise Way
Modesto, CA 95356-8718

Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)

1990 E. Gettysburg Avenue
Fresno, CA 93726-0244

Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region

34946 Flyover Court
Bakersfield, CA 93308-9725

Tel: 661-392-5500 FAX: 661-392-5585

Mr. Paul Franzia
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

A handwritten signature in black ink, appearing to read "D. Warner", with a long horizontal flourish extending to the right.

David Warner
Director of Permit Services

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Modesto Bee

**NOTICE OF FINAL DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
THE PROPOSED SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue Authorities to Construct to Bronco Wine Company at 6342 Bystrum Rd, Ceres, CA, California. The project authorizes installation of a 15.75 MMBtu/hr natural gas-fired boiler.

No comments were received following the District's preliminary decision on this project.

The District's analysis of the legal and factual basis for this proposed action, project #1123083, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 34946 FLYOVER COURT, BAKERSFIELD, CA 93308, and at any other District office. For additional information, please contact the District at (661) 392-5500.



AUTHORITY TO CONSTRUCT

PERMIT NO: N-1665-514-0

ISSUANCE DATE: 03/26/2013

LEGAL OWNER OR OPERATOR: BRONCO WINE COMPANY
MAILING ADDRESS: ATTN: MAINTENANCE MANAGER
P O BOX 789
CERES, CA 95307

LOCATION: 6342 BYSTRUM RD
CERES, CA 95307

EQUIPMENT DESCRIPTION:
15.75 MMBTU/HR NATURAL GAS FIRED CLAYTON SSEG-404-FMB-1 BOILER

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. The economizer system shall be designed at maximum steam generator firing rate to either 1) reduce the temperature of the economizer flue gas outlet to a value no greater than 90 degrees F above the temperature of the boiler feed water or 2) heat the boiler feed water to a temperature which is no less than the saturation temperature of the steam at the pressure of the steam separator, or 3) reduce the final temperature of the boiler's flue gas to a temperature no greater than 300 degrees F. Feedwater temperature is defined as the temperature of the water stream delivered to the steam generator from the deaerator or feedwater tank. [CCR Title 14, Division 6, Chapter 3, § 15000-15387 (CEQA)]
4. Electric motors driving combustion air fans or induced draft fans shall have an efficiency meeting the standards of the National Electric Manufacturer's Association (NEMA) for "premium efficiency" motors and shall each be operated with a variable speed control or equivalent for control of flow through the fan. [CCR Title 14, Division 6, Chapter 3, § 15000-15387 (CEQA)]
5. The unit shall always operate at least 487 feet away from the nearest property boundary. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

APCS-514-0; Mar 26 2013 8:08AM - EDG:HLR ; Joint Inspection NOT Required

6. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
8. The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Emissions rates from the natural gas-fired unit shall not exceed any of the following limits: 7ppmv NO_x @ 3% O₂ or 0.008 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 50 ppmv CO @ 3% O₂ or 0.037 lb-CO/MMBtu, 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

18. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070]
27. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 285 lb, 2nd quarter - 285 lb, 3rd quarter - 285 lb, and fourth quarter - 285 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
28. ERC Certificate Number S-3442-1 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit