South Coast
Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 1, 2011

Mr. Gerardo Rios
Chief – Permit Office
US EPA, Region IX Air 3
75 Hawthorne Street
San Francisco, CA 94105

Dear Mr. Rios:

Subject: Transmittal of Proposed Title V Renewal Permit
US Gov't, Veterans Administration Medical Ctr. ID 5679

Enclosed are the proposed Title V renewal permit, permit summary, statement of basis, public notice, and the permit evaluation for the US Gov't Veterans Administration Medical Center, located at 16111 Plummer Street, North Hills, California 91343. With your receipt of the proposed Title V renewal permit, we will note that EPA's 45-day review period shall begin on September 1, 2011.

If you have any questions concerning the proposed Title V renewal permit, please contact Mr. Roy Olivares, Air Quality Engineer, at (909) 396-2208 or you may contact him by email at mrolivares@aqmd.gov.

Sincerely,

FOR

Brian L. Yeh
Senior Manager
Mechanical, Chemical, and Public Services

BLY:AYL:JTY:rdo

Enclosures:

Proposed Title V Renewal Permit
Permit Summary
Statement of Basis
Public Notice

South Coast
Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

NOTICE OF PROPOSED
TITLE V RENEWAL PERMIT

The South Coast Air Quality Management District (AQMD) is proposing to renew the existing Title V permit that was previously issued to the following facility:

US Govt., Verterans Adm. Med. Center
16111 Plummer Street
North Hills, CA 91343
Facility ID# 5679

Contact Person:
Joe Olson
Environmental Engr.
16111 Plummer St., Bldg 218, Room 310
Los Angeles, CA 90073

This is an existing facility applying for a Title V permit renewal that is engaged in operating a medical center. This facility operates boilers, emergency generators, LPG storage tanks, gasoline dispensing and storage and other supporting equipment.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, the above facility has submitted a Title V renewal application and requested the AQMD to renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The proposed permit is available for public review at AQMD, 21865 Copley Dr., Diamond Bar, CA 91765 and at the Mid-Valley Regional Brach Library, 16244 Nordhoff St., North Hills, CA 91343-3880.

Information regarding the facility owner's compliance history submitted to the AQMD pursuant to California Health & Safety Code Section 42336, or otherwise known to the AQMD based on credible information, is also available from the AQMD for public review. For more information or to review additional supporting documents, call the AQMD's Title V hotline at (909) 396-3013. Written comments should be submitted to:

South Coast Air Quality Management District
Mechanical, Chemical and roPublic Services Team
21865 Copley Drive
Diamond Bar, CA 91765-4178
Attention: Roy Olivares

Comments must be received by October 8, 2011. The AQMD will consider all public comments and may revise the Title V permit in accordance with AQMD rules and regulations.

The public may request AQMD to conduct a public hearing on the proposed permit by submitting a Hearing Request Form (Form 500-G) to Brian Yeh at the above AQMD address. The AQMD will hold a public hearing if there is evidence that the proposed permit is not correct or is not adequate to ensure compliance with regulatory requirements, and a hearing will likely provide additional information that will affect the drafting and/or issuance of the permit. A public hearing request form and the public hearing schedule may be obtained from the AQMD by calling the Title V hotline at (909) 396-3013, or from the internet at *http://www.aqmd.gov/titlev*. The request for a public hearing is due by September 23, 2011. A copy of the hearing request must also be sent by first class mail to the appropriate facility contact person listed above.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
Title V Permit Summary

AQMD Facility ID: 5679	Company Name: US GOVT. VA MEDICAL CENTER		
Equipment Location: 16111 PLUMMER STREET, NORTH HILLS, CA 91343			SIC Code: 611210
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected: ALL	
Application #(s): 519383		Application Submittal Date(s): 12/18/2008	
AQMD Contact Person: ROY OLIVARES		Phone #: (909) 396-2208	E-Mail Address: rolivares@aqmd.gov

Project Description: This is an existing facility applying for a Title V renewal that is in the business of medical center . The facility provides hospital care and other medical services to its members. This facility is operating 7 diesel fueled ICEs driving emergency electrical generators, 3 natural gas fueled boilers, 2 pressurized LPG storage tanks and one fuel dispensing facility.
.

Permit Type: ☐ Initial Title V Permit ☐ Significant Revision
☒ Permit Renewal

Permit Features:
☐ Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements
☐ Permit Shield Applies
☐ Permit Contains Conditions Allowing Emission Trading
☐ Alternative Operating Scenario
☐ Permit Streamlines Overlapping or Outdated Requirements
☐ Other: _____
☐ Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance

Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for
☐ No TACs Reported
☒ The Following TACs Were Reported: See attachment A
Emissions (lbs/yr):

Health Risk From Toxic Air Contaminants:
☐ Health Risk Assessment Required for this Permit Action (AQMD Rule 1401)
☐ Health Risk Reduction Plan Approved (AQMD Rule 1402) (Year): _____
☒ Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588)
- ☐ Facility Determined to be Exempt from AB2588 Requirements
- ☒ AQMD is Tracking Status of Facility under AB2588
- ☐ Health Risk Assessment Submittal Pending
- ☐ Health Risk Assessment Submitted to AQMD and Is Being Reviewed
- ☐ Final Facility Health Risk Approved (date) _____

Cancer Risk = _____ in one million
Acute Hazard Index = _____
Chronic Hazard Index = _____

Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2010				
☒ NOx	6.018	☒ PM	0.453	
☒ CO	4.589	☒ SOx	0.044	
☒ VOC	3.272	other		

Compliance History:
☐ Citizen Complaints Filed in Last Two Calendar Years (0)
☐ Notices to Comply Issued in Last Two Calendar Years (0)
☒ Notices of Violation Issued in Last Two Calendar Years (1)

Comments:

ATTACHMENT A

Toxic Air Contaminants Emissions (TAC)
Annual Reported Emissions for Reporting Period 2010

The Following TACs Were Reported	Emissions (lbs/yr)
Benzene	1.202
1,3 – Butadiene	0.689
Ammonia	1906.618
Asbestos	0.007
Arsenic	0.005
Cadmium	0.004
Formaldehyde	139.768
Naphthalene	0.094
Chromium (VI)	68.000
Lead	0.026
Nickel	0.012
Naphthalene	0.094
Fluorcarb (CL)	16.20
PAH, total with components not reported	0.125

South Coast Air Quality Management District

Statement of Basis

Proposed Title V Renewal Permit

Facility Name:	US Govt, Veterans Administration Medical Center
Facility ID:	5679
SIC Code:	3315
Equipment Location:	16111 Plummer Street North Hills, CA 91343
Application #(s):	519383
Application Submittal Date(s):	03/02/2011
AQMD Contact Person:	Roy Olivares
Phone Number:	(909) 396-2208
E-Mail Address:	rolivares@aqmd.gov

---

1. Introduction and Scope of Permit

Title V is a national operating permit program for air pollution sources. Facilities subject to Title V must obtain a Title V permit and comply with specific Title V procedures to modify the permit. This permit replaces the facility's other existing permits. Title V does not necessarily include any new requirements for reducing emissions. It does, however, include new permitting, noticing, recordkeeping, and reporting requirements.

Pursuant to Title V of the federal Clean Air Act and AQMD Rule 3004(f), a Title V permit shall expire five years from the date of issuance unless such permit has been renewed. Accordingly, each facility is required to submit a Title V renewal application and requested the AQMD to renew their Title V permit. The proposed permit incorporates updates to the facility information provided in the facility's Title V renewal application and all rules and regulations that are currently applicable to the facility.

The AQMD implements Title V through Regulation XXX – Title V Permits, adopted by the AQMD Governing Board in order to comply with EPA's requirement that local air permitting authorities develop a Title V program. Regulation XXX was developed with the participation of the public and affected facilities through a series of public workshops, working group meetings, public hearings and other meetings.

The Title V major source threshold for a particular pollutant depends on the attainment status of the pollutant. NO_2, SO_2, and lead are in attainment with federal standards. The status of CO is currently serious nonattainment, but AQMD has petitioned to EPA for redesignation to

attainment status. The status for PM-10 is serious nonattainment. The status for ozone is currently extreme nonattainment.

A Title V renewal permit is proposed to be issued to cover the hospital operations of US Govt., Veterans Administration Medical Center, 16111 Plummer Street, North Hills, CA 91343. This facility is subject to Title V requirements because it is a major source.

2. Facility Description

This is an existing facility that operates a medical center. The facility provides hospital care and other medical services to its members. This facility is operating 7 diesel fueled ICEs driving emergency electrical generators, 3 natural gas fueled boilers, 2 pressurized LPG storage tanks and one fuel dispensing facility.

3. Construction and Permitting History

The facility has been in constant operation at this location since 1948-50. Numerous permits to construct and or permits to operate have been issued to the facility since the first application permits were filed in 1983. An initial Title V permit was issued to the facility on 3/8/2001, renewal issued 09/12/200, and there has been no permit revisions issued to this facility in the last five years.

4. Regulatory Applicability Determinations

Applicable legal requirements for which this facility is required to comply are required to be identified in the Title V permit (for example, Section D, E, and H of the proposed Title V permit). Applicability determinations (i.e., determinations made by the District with respect to what legal requirements apply to a specific piece of equipment, process, or operation) can be found in the Engineering Evaluations. This facility is not subject to any NSPS or NESHAP requirements.

5. Monitoring and Operational Requirements

Applicable monitoring and operational requirements for which the facility is required to comply are identified in the Title V permit (for example, Section D, F, and J and Appendix B of the proposed Title V permit). Discussion of any applicable operational requirements can be found in the Engineering Evaluations. All periodic monitoring requirements were developed using strict adherence to the following applicable guidance documents: SCAQMD Periodic Monitoring Guidelines for Title V Facilities (November 1997); CAPCOA/CARB/EPA Region IX Periodic Monitoring Recommendations for Generally Applicable Requirements in SIP (June 1999); and CAPCOA/CARB/EPA Region IX Recommended Periodic Monitoring for Generally Applicable Grain Loading Standards in the SIP: Combustion Sources (July 2001).

The medical center does not operate any permitted equipment that is vented to Air Pollution Control equipment. Therefore , CAM requirements of 40 CFR Part 64 do not apply to any of the permitted emissions sources at this facility.

6. Permit Features

Permit Shield

A permit shield is an optional part of a Title V permit that gives the facility an explicit protection from requirements that do not apply to the facility. A permit shield is a provision in a permit that states that compliance with the conditions of the permit shall be deemed compliance with all identified regulatory requirements. To incorporate a permit shield into the Title V permit involves submission of applications for change of conditions for each equipment affected by the permit shield. Permit shields are addressed in Rule 3004 (c). This facility has not applied for a permit shield.

Streamlining Requirements

Some emission units may be subject to multiple requirements which are closely related or redundant. The conditions may be streamlined to simplify the permit conditions and compliance. Emission limits, work practice standards, and monitoring, recordkeeping, and reporting requirements may be streamlined. Compliance with a streamlined condition will be deemed compliance with the underlying requirements whether or not the emission unit is actually in compliance with the specific underlying requirement. This facility has not applied for any streamlined conditions.

7. Summary of Emissions and Health Risks

Criteria Pollutant Emissions (tons/year)
Annual Reported Emissions for Reporting Period 2010

Pollutant	Emissions (tons/year)
NOx	6.018
CO	4.589
VOC	3.272
PM	0.453
SOx .	0.044

Toxic Air Contaminants Emissions (TAC)
Annual Reported Emissions for Reporting Period 2010

The Following TACs Were Reported	Emissions (lbs/yr)
1,3 - BUTADIENE	0.689
AMMONIA	2445.47
ARSENIC (INORGANIC)	0.14
BENZENE	1.202
CADMIUM	0.004
ASBESTOS	0.007
ARSENIC (INORGANIC)	0.005
AMMONIA	1906.618
FORMALDEHYDE	139.768
LEAD	0.026
NICKEL	0.012
NAPHTHALENE	0.094
FLUORCARB (CL)	16.20
PAHS	0.125

Health Risk from Toxic Air Contaminants

The facility is not subject to review by the Air Toxics Information and Assessment Act (AB2588).

8. Compliance History

As noted, the facility has been in constant operation since 1948. The facility has been subject to both self-reporting requirements and AQMD inspections. The facility had no Notices to Comply and one Notice of Violation issued in the last two year. NOV was for not conducting required periodic monitoring monthly portable analyzer test. Issues were resolved, and the facility is now in compliance.

9. Compliance Certification

By virtue of the Title V permit application and issuance of this Title V renewal permit, the reporting frequency for compliance certification for the facility shall be annual.

FACILITY PERMIT TO OPERATE

US GOVT, VETERANS ADMINISTRATION MED CTR
16111 PLUMMER ST
NORTH HILLS, CA 91343

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By_____
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	07/13/2011
B	RECLAIM Annual Emission Allocation	DRAFT	07/13/2011
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	07/13/2011
E	Administrative Conditions	DRAFT	07/13/2011
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	07/13/2011
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	07/13/2011
H	Permit To Construct and Temporary Permit to Operate	DRAFT	07/13/2011
I	Compliance Plans & Schedules	DRAFT	07/13/2011
J	Air Toxics	DRAFT	07/13/2011
K	Title V Administration	DRAFT	07/13/2011
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	07/13/2011
B	Rule Emission Limits	DRAFT	07/13/2011

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR:	US GOVT, VETERANS ADMINISTRATION MED CTR
LEGAL OPERATOR (if different than owner):	
EQUIPMENT LOCATION:	16111 PLUMMER ST NORTH HILLS, CA 91343-2099
MAILING ADDRESS:	11301 WILSHIRE BLVD LOS ANGELES, CA 90073
RESPONSIBLE OFFICIAL:	BEN SPIVEY
TITLE:	CHIEF, EH&S
TELEPHONE NUMBER:	(310) 478-3711
CONTACT PERSON:	JOE OLSON
TITLE:	ENV. ENGR.
TELEPHONE NUMBER:	(310) 478-3711
TITLE V PERMIT ISSUED:	September 13, 2006
TITLE V PERMIT EXPIRATION DATE:	September 12, 2011

TITLE V	RECLAIM	
YES	NOx:	NO
	SOx:	NO
	CYCLE:	0
	ZONE:	INLAND

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

Facility Equipment and Requirements
(Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, copies of all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMITTED EQUIPMENT LIST

The following is a list of all permits to construct and permits to operate at this facility:

Application number	Permit number	Equipment description
117461	M38474	I C E (>500 HP) EM ELEC GEN-DIESEL
197557	M96612	SERV STAT STORAGE & DISPENSING GASOLINE
309912	F6507	BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL
309913	F6508	BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL
309914	F6509	BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL
311580	D97902	STORAGE TANK PRESSURE TANK LPG
311582	D97903	STORAGE TANK PRESSURE TANK LPG
367370	F27913	I C E (50-500 HP) EM ELEC GEN-DIESEL
367365	F36085	I C E (>500 HP) EM ELEC GEN-DIESEL
367369	F36086	I C E (50-500 HP) EM ELEC GEN-DIESEL
367367	F36090	I C E (>500 HP) EM ELEC GEN-DIESEL
378209	F36218	I C E (>500 HP) EM ELEC GEN-DIESEL
383298	F42606	I C E (50-500 HP) EM ELEC GEN-DIESEL

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

FACILITY WIDE CONDITION(S)

Condition(s):

1. EXCECT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMIN FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:

   A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
   B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION. (RULE 401)

2. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
   [RULE 431.2]

3. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER
   [RULE 431.2]

3. THE OPERATOR SHALL NOT USE NATURAL GAS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H2S, IN EXCESS OF 16 PARTS PER MILLION BY VOLUME (PPMV). THE OPERATOR SHALL NOT USE OTHER GASEOUS FUELS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H2S, IN EXCESS OF 40 PPMV AS MEASURED OVER 4 HOURS AVERAGING PERIOD.
   [RULE 431.1]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. M38474
A/N 117461

Equipment Description:

INTERNAL COMBUSTION ENGINE, COMPRESSION IGNITION, TURBOCHARGED, GENERAL MOTORS, MODEL 16-645-E4, SERIAL NO. 73MI-1056, 3000 HP, DIESEL FUEL FIRED, DRIVING A 2000 KW STANDBY ELECTRIC GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARTED RELATIVE TO STANDARD TIMING.
[RULE 1303 (a)(1)-BACT]

4. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

6. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

7. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

8. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

9. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

10. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

11. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

a. EMERGENCY USE.
b. MAINTENANCE AND TESTING.
c. OTHER (DESCRIBE THE REASON FOR OPERATING).
d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
[RULE 1303 (b)(2), RULE 1470]

12. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1303 (b)(2)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. M96612
A/N 197557

Equipment Description:

FUEL STORAGE AND DISPENSING FACILITY CONSISTING OF:

1. ONE ABOVEGROUND GASOLINE STORAGE TANK 1000 GALLON CAPACITY, NOT METHANOL COMPATIBLE.

2. ONE GASOLINE DISPENSING NOZZLE VENTED TO VAPOR RECOVERY SYSTEM.

3. ONE ABOVEGROUND DIESEL STORAGE TANK 500 GALLON CAPACITY, NOT METHANOL COMPATIBLE.

4. ONE DIESEL DISPENSING NOZZLE.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

3. EXCEPT FOR DIESEL TRANSFERS, PHASE I AND PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER THIS FACILITY IS IN USE. SUCH SYSTEMS SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CARB CERTIFICATION REQUIREMENTS.
[RULE 461]

Periodic Monitoring:

4. THE OPERATOR SHALL IMPLEMENT A DISTRICT-APPROVED SELF-COMPLIANCE PROGRAM IN ACCORDANCE WITH THE REQUIREMENTS OF RULE 461 (D).
[RULE 461, RULE 3004 (a)(4)]

5. THE OPERATOR SHALL CONDUCT AND SUCCESSFULLY PASS THE APPLICABLE PERFORMANCE AND/OR REVERIFICATION TEST(S) IN ACCORDANCE WITH THE REQUIREMENTS OF RULE 461 (E).
[RULE 461, RULE 3004 (a)(4)]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

   VOC: RULE 461

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F6507
A/N 309912

Equipment Description:

BOILER NO. 1, SUPERIOR MOHAWK, MODEL NO. 4X-2007-S200, WITH A 16,800,000 BTU PER HOUR LOW NOX INDUSTRIAL COMBUSTION BURNER, MODEL NO. LNDLG-210-P, NATURAL GAS OR PROPANE FIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, DURING MAINTENANCE TESTING OF THE BURNER NOT TO EXCEED 30 MINUTES PER MONTH, OR DURING COMPLIANCE TESTING.
[RULE 1303(a)(1)-BACT]

4. BOILER EMISSIONS SHALL NOT EXCEED 30 PPM FOR OXIDES OF NITROGEN (NOX) AND 400 PPM OF CARBON MONOXIDE (CO), MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O2.
[RULE 1146, RULE 1303(a)(1)-BACT]

5. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.

6. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).

7. RETAIN ALL RECORDS REQUIRED BY PERMIT FOR A PERIOD OF FIVE YEARS AND MAKE ALL RECORDS AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPM, RULE 407
CO: 400 PPM, RULE 1146

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

NOx: 30 PPMV, NATURAL GAS, RULE 1146, RULE 1303(a)(1)-BACT
NOx; 9 PPMV, NATURAL GAS, RULE 1146, EFFECTIVE 1/1/2012
NOX: 40 PPMV, FUEL OIL, RULE 1146
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F6508
A/N 309913

Equipment Description:

BOILER NO. 2 SUPERIOR MOHAWK, MODEL NO. 4X-2007-S200, WITH A 16,800,000 BTU PER HOUR LOW NOX INDUSTRIAL COMBUSTION BURNER, MODEL NO. LNDLG-210-P, NATURAL GAS OR PROPANE FIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, DURING MAINTENANCE TESTING OF THE BURNER NOT TO EXCEED 30 MINUTES PER MONTH, OR DURING COMPLIANCE TESTING.
[RULE 1303(a)(1)-BACT]

4. BOILER EMISSIONS SHALL NOT EXCEED 30 PPM FOR OXIDES OF NITROGEN (NOX) AND 400 PPM OF CARBON MONOXIDE (CO), MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O2.
[RULE 1146, 1303(a)(1)-BACT]

5. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.

6. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).

7. RETAIN ALL RECORDS REQUIRED BY PERMIT FOR A PERIOD OF FIVE YEARS AND MAKE ALL RECORDS AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

   CO: 2000 PPM, RULE 407
   CO: 400 PPM, RULE 1146

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

NOx: 30 PPMV, NATURAL GAS, RULE 1146, RULE 1303(a)(1)-BACT
NOx; 9 PPMV, NATURAL GAS, RULE 1146, EFFECTIVE 1/1/2012
NOX: 40 PPMV, FUEL OIL, RULE 1146
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F6509
A/N 309914

Equipment Description:

BOILER NO. 3 SUPERIOR MOHAWK, MODEL NO. 4X-2007-S200, WITH A 16,800,000 BTU PER HOUR LOW NOX INDUSTRIAL COMBUSTION BURNER, MODEL NO. LNDLG-210-P, NATURAL GAS OR PROPANE FIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

3. THIS BOILER SHALL BE FIRED ON NATURAL GAS ONLY EXCEPT DURING PERIODS OF NATURAL GAS CURTAILMENT, DURING MAINTENANCE TESTING OF THE BURNER NOT TO EXCEED 30 MINUTES PER MONTH, OR DURING COMPLIANCE TESTING.
[RULE 1303(a)(1)-BACT]

4. BOILER EMISSIONS SHALL NOT EXCEED 30 PPM FOR OXIDES OF NITROGEN (NOX) AND 400 PPM OF CARBON MONOXIDE (CO), MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O2.
[RULE 1146, 1303(a)(1)-BACT]

5. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.

6. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).

7. RETAIN ALL RECORDS REQUIRED BY PERMIT FOR A PERIOD OF FIVE YEARS AND MAKE ALL RECORDS AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

Emissions And Requirements:

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

   CO: 2000 PPM, RULE 407
   CO: 400 PPM, RULE 1146

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

NOx: 30 PPMV, NATURAL GAS, RULE 1146, RULE 1303(a)(1)-BACT
NOx; 9 PPMV, NATURAL GAS, RULE 1146, EFFECTIVE 1/1/2012
NOX: 40 PPMV, FUEL OIL, RULE 1146
PM: 0.1 GR/SCF, RULE 409

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. D97902
A/N 311580

Equipment Description:

STORAGE TANK, PROPANE GAS, PRESSURIZED, UNDERGROUND, 10'-10" DIA. X 47'-2" L, 30,000 GALLON CAPACITY, SERIAL NO. 12805-1.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
   [RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
   [RULE 204]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. D97903
A/N 311582

Equipment Description:

STORAGE TANK, PROPANE GAS, PRESSURIZED, UNDERGROUND, 10'-10" DIA. X 47'-2" L., 30,000 GALLON CAPACITY, SERIAL NO. 12805-2

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
   [RULE 204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
   [RULE 204]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F27913
A/N 367370

Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPIILLAR, MODEL 3406DITA, SERIAL NO. 4ZR00528, DIESEL FUEL, TURBOCHARGED AND AFTERCOOLED, RATED AT 449 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARTED RELATIVE TO STANDARD TIMING.
[RULE 1303 (a)(1)-BACT]

4. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

6. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

7. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

8. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

9. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

10. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

11. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

a. EMERGENCY USE.
b. MAINTENANCE AND TESTING.
c. OTHER (DESCRIBE THE REASON FOR OPERATING).
d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
[RULE 1303 (b)(2), RULE 1470]

12. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1303 (b)(2)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F36085
A/N 367365

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL VTA-28-G5, SERIAL NO. 25212931, DIESEL FUEL, FOUR CYCLE, TWELVE CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 900 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARTED RELATIVE TO STANDARD TIMING.
[RULE 1303 (a)(1)-BACT]

4. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

6. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

7. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

8. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

9. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

10. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

11. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

a. EMERGENCY USE.
b. MAINTENANCE AND TESTING.
c. OTHER (DESCRIBE THE REASON FOR OPERATING).
d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
[RULE 1303 (b)(2), RULE 1470]

12. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1303 (b)(2)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F36086
A/N 367369

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL 8063-7305 (6V-92T, SERIAL NO. 6VF215524, DIESEL FUEL, FOUR CYCLE, SIX CYLINDERS, TURBOCHARGED, RATED AT 352 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARTED RELATIVE TO STANDARD TIMING.
[RULE 1303 (a)(1)-BACT]

4. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

6. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

7. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

8. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

9. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

10. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

11. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

a. EMERGENCY USE.
b. MAINTENANCE AND TESTING.
c. OTHER (DESCRIBE THE REASON FOR OPERATING).
d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
[RULE 1303 (b)(2), RULE 1470]

12. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1303 (b)(2)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F36090
A/N 367367

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, MODEL 16V-92, SERIAL NO. 16VF002520, DIESEL FUEL, TWO CYCLE, SIXTEEN CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 821 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARTED RELATIVE TO STANDARD TIMING.
[RULE 1303 (a)(1)-BACT]

4. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

6. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

7. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

8. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

9. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

10. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

11. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

a. EMERGENCY USE.
b. MAINTENANCE AND TESTING.
c. OTHER (DESCRIBE THE REASON FOR OPERATING).
d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
[RULE 1303 (b)(2), RULE 1470]

12. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1303 (b)(2)]

Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F36218
A/N 378209

Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL VTA-28-G5, SERIAL NO. 25212933, DIESEL FUEL, FOUR CYCLE, TWELVE CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 900 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

4. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

7. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

8. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

10. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

    a. EMERGENCY USE.
    b. MAINTENANCE AND TESTING.
    c. OTHER (DESCRIBE THE REASON FOR OPERATING).
    d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
    [RULE 1303 (b)(2), RULE 1470]

11. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

    THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

    THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

    THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
    [RULE 1303 (b)(2)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

    PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
    PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

PERMIT TO OPERATE

Permit No. F42606
A/N 383298

Equipment Description:

INTERNAL COMBUSTION ENGINE, GENERAC, MODEL 133DTA (20A05021S), DIESEL FUEL, SIX CYLINDERS, TURBOCHARGED AND AFTERCOOLED, RATED AT 440 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[204]

2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[204]

3. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.
[RULE 1470]

4. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT.
[RULE 1303 (a)-BACT]

5. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 15 PPM BY WEIGHT.
[RULE 1470]

6. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE.
[RULE 1110.2, RULE 1303 (a), RULE 1304 (a)(4), RULE 1470]

7. OPERATING BEYOND THE 30 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
[RULE 1470]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

8. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
[RULE 1110.2, RULE 1303 (b)(2), RULE 1470]

9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.
[RULE 1304 (a)(4), RULE 1470]

10. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:

a. EMERGENCY USE.
b. MAINTENANCE AND TESTING.
c. OTHER (DESCRIBE THE REASON FOR OPERATING).
d. IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.
[RULE 1303 (b)(2), RULE 1470]

11. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:

THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.
[RULE 1303 (b)(2)]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM: RULE 1470

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

   FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONATINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISITING OF (A) COATING TYPE, (B) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (C) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

   FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONATINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSITING OF (A) COATING TYPE, (B) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (C) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.
   [RULE 3004(a)(4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

   VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS
   VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
   a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
   b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
   c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statues of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]

6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]

7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]

   a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]

   b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]

   c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]

   d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO2) and be averaged over 15 consecutive minutes; [407]

   e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO2) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION E: ADMINISTRATIVE CONDITIONS

f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O2) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]

8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]

a. Brief description of the equipment tested.

b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.

c. Operating conditions under which the test will be performed.

d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).

e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.

f. Description of calibration and quality assurance procedures.

g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).

9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]

a. The results of the source test.

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION E: ADMINISTRATIVE CONDITIONS

b. Brief description of the equipment tested.

c. Operating conditions under which the test was performed.

d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).

e. Field and laboratory data forms, strip charts and analyses.

f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.

10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]

11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

NONE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION J: AIR TOXICS

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]

2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

   (B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]

4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:

   (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.

   (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.

   (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:

   (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or

   (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

   Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:

   (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;

   (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

   (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and

   (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]

15. Nothing in this permit or in any permit shield can alter or affect:

    (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;

    (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;

    (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;

    (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;

    (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and

    (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]

16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency[1] constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:

    (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:

        (1) An emergency occurred and the operator can identify the cause(s) of the emergency;

        (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;

        (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,

        (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and

    (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]

18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

1 "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

    (A) The date, place as defined in the Title V permit, and time of sampling or measurements;

    (B) The date(s) analyses were performed;

    (C) The company or entity that performed the analyses;

    (D) The analytical techniques or methods used;

    (E) The results of such analyses; and

    (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:

    (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

(B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.

(C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.

(D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]

23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]

24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:

(A) Identification of each permit term or condition that is the basis of the certification;

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

(B) The compliance status during the reporting period;

(C) Whether compliance was continuous or intermittent;

(D) The method(s) used to determine compliance over the reporting period and currently, and

(E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1110.2	7-9-2010	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	6-3-2011	Non federally enforceable
RULE 1113	7-9-2004	Non federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1470	3-4-2005	Non federally enforceable
RULE 1472	3-7-2008	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3007	10-8-1993	Federally enforceable

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 429	12-21-1990	Non federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	1-9-2004	Federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 701	6-13-1997	Federally enforceable

FACILITY PERMIT TO OPERATE
US GOVT, VETERANS ADMINISTRATION MED CTR

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

NONE

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

(1) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6) of Rule 1113, no person shall supply, sell, offer for sale, market, manufacture, blend, repackage, apply, store at a worksite, or solicit the application of any architectural coating within the District:

(A) That is listed in the Table of Standards 1 and contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified; or

(B) That is not listed in the Table of Standards 1, and contains VOC (excluding any colorant added to tint bases) in excess of 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, until January 1, 2014, at which time the limit drops to 50 grams of VOC per liter of coating, less water, less exempt compounds (0.42 pounds per gallon).

(2) No person within the District shall add colorant at the point of sale that is listed in the Table of Standards 2 and contains VOC in excess of the corresponding VOC limit specified in the Table of Standards 2, after the effective date specified.

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]
TABLE OF STANDARDS 1
VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds

COATING CATEGORY	Ceiling Limit[1]	Current Limit[2]	Effective Date		
			7/1/08	1/1/12	1/1/14
Bond Breakers		350			
Clear Wood Finishes		275			
Varnish	350	275			
Sanding Sealers	350	275			
Lacquer		275			
Concrete-Curing Compounds		100			
Concrete-Curing Compounds For Roadways and Bridges[3]		350			
Concrete Surface Retarder		250			50
Driveway Sealer		100		50	
Dry-Fog Coatings		150			50
Faux Finishing Coatings					
Clear Topcoat		350		200	
Decorative Coatings		350			100
Glazes		350			
Japan		350			
Trowel Applied Coatings		350		150	50
Fire-Proofing Coatings		350			150
Flats	250	50	50		
Floor Coatings	100	50			
Form Release Compound		250			100
Graphic Arts (Sign) Coatings		500			150
Industrial Maintenance (IM) Coatings	420	100			
High Temperature IM Coatings		420			
Non-Sacrificial Anti-Graffiti Coatings		100			
Zinc-Rich IM Primers	340	100			
Magnesite Cement Coatings		450			
Mastic Coatings		300			100
Metallic Pigmented Coatings	500	500			150
Multi-Color Coatings		250			
Nonflat Coatings	150	50			
Pre-Treatment Wash Primers		420			
Primers, Sealers, and Undercoaters	200	100			
Reactive Penetrating Sealers		350			
Recycled Coatings		250			
Roof Coatings	250	50			
Roof Coatings, Aluminum		100			

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

Roof Primers, Bituminous	350	350			
Rust Preventative Coatings	400	100			
Stone Consolidant		450			
Sacrificial Anti-Graffiti Coatings		100		50	
Shellac					
Clear		730			
Pigmented		550			
Specialty Primers	350	100			
Stains		100			

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

COATING CATEGORY	Ceiling Limit[1]	Current Limit[2]	Effective Date		
			7/1/08	1/1/12	1/1/14
Stains, Interior	250	250			
Swimming Pool Coatings					
Repair		340			
Other		340			
Traffic Coatings		100			
Waterproofing Sealers	250	100			
Waterproofing Concrete/Masonry Sealers	400	100			
Wood Preservatives		350			

1. The specified ceiling limits are applicable to products sold under the Averaging Compliance Option.
2. The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.
3. Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

TABLE OF STANDARDS 1 (cont.)
VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

TABLE OF STANDARDS 2
VOC LIMITS FOR COLORANTS

Grams of VOC Per Liter of Colorant
Less Water and Less Exempt Compounds

COLORANT	Limit[4]
Architectural Coatings, excluding IM Coatings	50
Solvent-Based IM	600
Waterborne IM	50

4. Effective January 1, 2014.

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter"Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter" Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

FACILITY PERMIT TO OPERATE
US GOVT. VETERANS ADMINISTRATION MED CTR

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter"Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100

South Coast Air Quality Management District

Form 400-A

Application Form for Permit or Plan Approval

List only one piece of equipment or process per form.

Mail To:
SCAQMD
P.O. Box 4944
Diamond Bar, CA 91765-0944

Tel: (909) 396-3385
www.aqmd.gov

Section A - Operator Information

1. Facility Name (Business Name of Operator to Appear on the Permit):
US Gov't., Veterans Administration Medical Ctr

2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD):
005679

3. Owner's Business Name (If different from Business Name of Operator):

Section B - Equipment Location Address

4. Equipment Location Is: ○ Fixed Location ○ Various Location
(For equipment operated at various locations, provide address of initial site.)

16111 Plummer Street
Street Address
North Hills , CA 91343
City Zip
Joe Olson Env. Engineer
Contact Name Title
(310) 478-3711 44039 (310) 268-4840
Phone # Ext. Fax #
E-Mail: Joseph.Olson@va.gov

Section C - Permit Mailing Address

5. Permit and Correspondence Information:
☒ Check here if same as equipment location address

11301 Wilshire Blvd, Building 218, Room 310
Address
Los Angeles , CA 90073
City State Zip
Joe Olson Env. Engineer
Contact Name Title
(310) 478-3711 44039 (310) 268-4840
Phone # Ext. Fax #
E-Mail: Joseph.Olson@va.gov

Section D - Application Type

6. The Facility Is: ○ Not In RECLAIM or Title V ○ In RECLAIM ◉ In Title V ○ In RECLAIM & Title V Programs

7. Reason for Submitting Application (Select only ONE):

7a. New Equipment or Process Application:
- ○ New Construction (Permit to Construct)
- ○ Equipment On-Site But Not Constructed or Operational
- ○ Equipment Operating Without A Permit *
- ○ Compliance Plan
- ○ Registration/Certification
- ○ Streamlined Standard Permit

7b. Facility Permits:
- ◉ Title V Application or Amendment (Also submit Form 500-A1)
- ○ RECLAIM Facility Permit Amendment

7c. Equipment or Process with an Existing/Previous Application or Permit:
- ○ Administrative Change
- ○ Alteration/Modification
- ○ Alteration/Modification without Prior Approval *
- ○ Change of Condition
- ○ Change of Condition without Prior Approval *
- ○ Change of Location
- ○ Change of Location without Prior Approval *
- ○ Equipment Operating with an Expired/Inactive Permit *

Existing or Previous Permit/Application
If you checked any of the items in 7c., you MUST provide an existing Permit or Application Number:

* A Higher Permit Processing Fee and additional Annual Operating Fees (up to 3 full years) may apply (Rule 301(c)(1)(D)(i)).

8a. Estimated Start Date of Construction (mm/dd/yyyy):	8b. Estimated End Date of Construction (mm/dd/yyyy):	8c. Estimated Start Date of Operation (mm/dd/yyyy):

9. Description of Equipment or Reason for Compliance Plan (list applicable rule):
Title V Renewal Application

10. For Identical equipment, how many additional applications are being submitted with this application?
(Form 400-A required for each equipment / process)

11. Are you a Small Business as per AQMD's Rule 102 definition?
(10 employees or less and total gross receipts are $500,000 or less OR a not-for-profit training center) ◉ No ○ Yes

12. Has a Notice of Violation (NOV) or a Notice to Comply (NC) been issued for this equipment? ◉ No ○ Yes
If Yes, provide NOV/NC#:

Section E - Facility Business Information

13. What type of business is being conducted at this equipment location?
Healthcare

14. What is your business primary NAICS Code?
(North American Industrial Classification System) 622110

15. Are there other facilities in the SCAQMD jurisdiction operated by the same operator? ○ No ◉ Yes

16. Are there any schools (K-12) within 1000 feet of the facility property line? ◉ No ○ Yes

Section F - Authorization/Signature

I hereby certify that all information contained herein and information submitted with this application are true and correct.

17. Signature of Responsible Official:

18. Title of Responsible Official:
Chief, EH&S

19. I wish to review the permit prior to issuance.
(This may cause a delay in the application process.) ◉ No ○ Yes

20. Print Name:
Ben K. Spivey

21. Date:
2/16/11

22. Do you claim confidentiality of data? (If Yes, see instructions.) ◉ No ○ Yes

23. Check List: ☒ Authorized Signature/Date ☒ Form 400-CEQA ☒ Supplemental Form(s) (ie., Form 400-E-xx) ☒ Fees Enclosed

AQMD USE ONLY	APPLICATION TRACKING #	CHECK #	AMOUNT RECEIVED	PAYMENT TRACKING #	VALIDATION
	519383	3302	$ 1956.84		3/2/11 ak

DATE	APP REJ	DATE	APP REJ	CLASS I II III	BASIC CONTROL	EQUIPMENT CATEGORY CODE	TEAM	ENGINEER	REASON/ACTION TAKEN
							E		

© South Coast Air Quality Management District, Form 400-A (2009.04)

TS #11

(93034)