



MAY 29 2013

Darren Filkins
WM Bolthouse Farms Inc–North Avenal,
7200 East Brundage Lane
Bakersfield, CA 93307

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # C-7837
Project # C-1131114**


Dear Mr. Filkins:

The Air Pollution Control Officer has modified the Title V permit for WM Bolthouse Farms Inc–North Avenal, Section 15, Township 22E, Range 17E in Avenal, Fresno County, CA. The facility is proposing a Title V minor permit modification to replace 40 CFR 63 Subpart ZZZZ conditions 16 through 26 with conditions conforming to the requirements of the January 30, 2013 amendments to 40 CFR Part 63 Subpart ZZZZ, Section 63.6603(d).

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on April 15, 2013. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

for 
David Warner
Director of Permit Services

DW:jms

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



MAY 29 2013

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # C-7837
Project # C-1131114**

Dear Mr. Rios:

The Air Pollution Control Officer has modified the Title V permit for WM Bolthouse Farms Inc–North Avenal, Section 15, Township 22E, Range 17E in Avenal, Fresno County, CA. The facility is proposing a Title V minor permit modification to replace 40 CFR 63 Subpart ZZZZ conditions 16 through 26 with conditions conforming to the requirements of the January 30, 2013 amendments to 40 CFR Part 63 Subpart ZZZZ, Section 63.6603(d).

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on April 15, 2013. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,


David Warner
Director of Permit Services

DW:jms

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-7837-17-2

EXPIRATION DATE: 08/31/2017

EQUIPMENT DESCRIPTION:

325 BHP JOHN DEERE MODEL 6125H SERIAL #RG6125H030975 TIER 2 DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL WELL PUMP (ENG 316)

PERMIT UNIT REQUIREMENTS

1. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 1070 and Fresno County Rule 107] Federally Enforceable Through Title V Permit
2. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 1070 and Fresno County Rule 107] Federally Enforceable Through Title V Permit
3. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain an engine operating log to demonstrate compliance with District Rule 4702. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, the purpose of the operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance with District Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit
10. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 4702] Federally Enforceable Through Title V Permit
11. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 4702 and 40 CFR 63.6660] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. This certified Tier 1 or Tier 2 engine shall be replaced with a new certified Tier 4 engine by January 1, 2015 or 12 years from the installation of the engine, whichever is later, to be in compliance with Rule 4702. Authority to Construct (ATC) application for new certified Tier 4 engine must be submitted to the District at least six months before the compliance date. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)] Federally Enforceable Through Title V Permit
14. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63.6585/63.6595(a)] Federally Enforceable Through Title V Permit
15. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115, 40 CFR 63.6604, and Fresno County Rule 406] Federally Enforceable Through Title V Permit
16. The engine's oil and filter shall be changed every 1,000 hours of operation or every 12 months, whichever comes first. [40 CFR 63.6603/66.6640 Table 2d, Row 1.a] Federally Enforceable Through Title V Permit
17. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 1.b] Federally Enforceable Through Title V Permit
18. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 1.c] Federally Enforceable Through Title V Permit
19. The permittee shall maintain monthly records of all required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63.6655(a)(3)/§63.10(b)(2)(viii) and §63.6655(a)(4)] Federally Enforceable Through Title V Permit
20. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63.6655(a)(2) and (a)(5)] Federally Enforceable Through Title V Permit
21. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-7837-18-2

EXPIRATION DATE: 08/31/2017

EQUIPMENT DESCRIPTION:

425 BHP CUMMINS MODEL N14 SERIAL #11865582 TIER 1 DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL WELL PUMP (ENG 97)

PERMIT UNIT REQUIREMENTS

1. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 1070 and Fresno County Rule 107] Federally Enforceable Through Title V Permit
2. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 1070 and Fresno County Rule 107] Federally Enforceable Through Title V Permit
3. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain an engine operating log to demonstrate compliance with District Rule 4702. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, the purpose of the operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance with District Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit
10. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 4702] Federally Enforceable Through Title V Permit
11. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 4702 and 40 CFR 63.6660] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. This certified Tier 1 or Tier 2 engine shall be replaced with a new certified Tier 4 engine by January 1, 2015 or 12 years from the installation of the engine, whichever is later, to be in compliance with Rule 4702. Authority to Construct (ATC) application for new certified Tier 4 engine must be submitted to the District at least six months before the compliance date. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)] Federally Enforceable Through Title V Permit
14. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63.6585/63.6595(a)] Federally Enforceable Through Title V Permit
15. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115, 40 CFR 63.6604, and Fresno County Rule 406] Federally Enforceable Through Title V Permit
16. The engine's oil and filter shall be changed every 1,000 hours of operation or every 12 months, whichever comes first. [40 CFR 63.6603/66.6640 Table 2d, Row 1.a] Federally Enforceable Through Title V Permit
17. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 1.b] Federally Enforceable Through Title V Permit
18. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 1.c] Federally Enforceable Through Title V Permit
19. The permittee shall maintain monthly records of all required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63.6655(a)(3)/§63.10(b)(2)(viii) and §63.6655(a)(4)] Federally Enforceable Through Title V Permit
20. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63.6655(a)(2) and (a)(5)] Federally Enforceable Through Title V Permit
21. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.