



OCT 26 2010

Mr. Donny Homer
SFPP, LP
1100 Town and Country Road
Orange, CA 92868

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # C-1100182**

Dear Mr. Homer:


The Air Pollution Control Officer has issued an Authority to Construct (ATC # C-1077-53-0) with a Certificate of Conformity to SFPP, LP. The applicant proposes to install a new 500 gallon fuel additive storage tank with PV valve linked by pipe to the loading rack listed in permit C-1077-51.

Enclosed is the Authority to Construct and invoice. The application and proposal were sent to US EPA Region IX on September 20, 2010. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Enclosures
st

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



OCT 26 2010

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # C-1100182**


Dear Mr. Rios:

The Air Pollution Control Officer has issued an Authority to Construct (ATC # C-1077-53-0) with a Certificate of Conformity to SFPP, LP. The applicant proposes to install a new 500 gallon fuel additive storage tank with PV valve linked by pipe to the loading rack listed in permit C-1077-51.

Enclosed are copies of the Authority to Construct. The application and proposal were sent to US EPA Region IX on September 20, 2010. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Enclosures
st

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: C-1077-53-0

ISSUANCE DATE: 10/25/2010

LEGAL OWNER OR OPERATOR: SFPP, L.P.
MAILING ADDRESS: 1100 TOWN & COUNTRY ROAD
ORANGE, CA 92868

LOCATION: 4149 S MAPLE AVE
FRESNO, CA 93725

EQUIPMENT DESCRIPTION:
500 GALLON FUEL ADDITIVE STORAGE TANK WITH PV VALVE LINKED BY PIPE TO LOADING RACK LISTED IN PERMIT C-1077-51

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
6. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.4 psia under all storage conditions. [District Rule 2201]
7. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO


DAVID WARNER, Director of Permit Services

C-1077-53-0 Oct 25 2010 9:18AM -- TOMS : Joint Inspection NOT Required

8. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit. [District Rule 2201]
9. Daily throughput of this tank shall not exceed 500 gallons per day. [District Rule 2201]
10. Annual throughput of this tank shall not exceed 6,000 gallons per year. [District Rule 2201]
11. VOC emission rate from the tank shall not exceed 0.5 lb/day. [District Rule 2201]
12. Permittee shall maintain daily records of organic liquid throughput and shall keep accurate records of each organic liquid stored in the tank, including its storage temperature and TVP. [District Rule 1070]
13. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 1070]