



FEB 20 2013

Andy Schoorl  
Wm Bolthouse Farms Inc - North Avenal  
7200 E. Brundage Ln  
Bakersfield, CA 93307

**Re: Notice of Minor Title V Permit Modification  
District Facility # C-7837  
Project # C-1130140**

Dear Mr. Schoorl:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued Authority to Construct (ATC) permits C-7837-30-0, -34-0, and -36-0 into the Title V operating permit. Each ATC authorizes the installation of a new Tier 3 certified diesel-fired IC engine.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued ATCs C-7837-30-0, -34-0, and -36-0, emission increases, and application. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney at (559) 230-5900.

Sincerely,

David Warner  
Director of Permit Services

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



FEB 20 2013

Gerardo C. Rios, Chief  
Permits Office  
Air Division  
U.S. EPA - Region IX  
75 Hawthorne St  
San Francisco, CA 94105

Re: **Notice of Minor Title V Permit Modification**  
**District Facility # C-7837**  
**Project # C-1130140**

Dear Mr. Rios:

Enclosed for you to review is an application for minor Title V permit modification for the facility identified above. Wm Bolthouse Farms Inc - North Avenal is proposing a Title V minor permit modification to incorporate the recently issued Authority to Construct (ATC) permits C-7837-30-0, -34-0, and -36-0 into the Title V operating permit. Each ATC authorizes the installation of a new Tier 3 certified diesel-fired IC engine.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued ATCs C-7837-30-0, -34-0, and -36-0, emission increases, and application. Please submit your written comments on this project within the 45-day comment period that begins on the date you receive this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney at (559) 230-5900.

Sincerely,

David Warner  
Director of Permit Services

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

# **TITLE V APPLICATION REVIEW**

Minor Modification  
Project #: C-1130140

Engineer: Jerry Sandhu  
Date: February 11, 2013

Facility Number: C-7837  
Facility Name: Wm Bolthouse Farms Inc - North Avenal  
Mailing Address: 7200 E. Brundage Ln  
Bakersfield, CA 93307

Contact Name: Andy Schoolt  
Phone: (661) 366-7209 ext. 1208

Responsible Official: Andy Schoolt  
Title: Manager

---

## **I. PROPOSAL**

Wm Bolthouse Farms Inc – North Avenal is proposing a Title V minor permit modification to incorporate the recently issued Authority to Construct (ATC) permits C-7837-30-0, -34-0, and -36-0 into the Title V operating permit. Each ATC authorizes the installation of a new Tier 3 certified diesel-fired IC engine powering an agricultural irrigation pump. The three proposed engines will be replacing three existing diesel-fired IC engines at the facility.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

## **II. FACILITY LOCATION**

The facility is located at Township 22S, Range 17E in North Avenal, CA.

## **III. EQUIPMENT DESCRIPTION**

**C-7837-30-1: 400 BHP CUMMINS MODEL QSX11 S/N 35230740 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 382)**

**C-7837-34-1:** 450 BHP CUMMINS MODEL QSX15 S/N 79317718 TIER 3  
CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN  
AGRICULTURAL IRRIGATION PUMP (ENG 385)

**C-7837-36-1:** 254 BHP JOHN DEERE MODEL 6090H S/N RG6090L072051  
TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN  
AGRICULTURAL IRRIGATION PUMP (ENG 353)

#### **IV. SCOPE OF EPA AND PUBLIC REVIEW**

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

#### **V. APPLICABLE REQUIREMENTS**

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

#### **VI. DESCRIPTION OF PROPOSED MODIFICATIONS**

Wm Bolthouse Farms Inc – North Avenal is proposing to install three new Tier 3 certified diesel-fired IC engines, each powering an agricultural irrigation pump. The proposed engines will each be replacing an existing IC engine at the facility.

Since these are new units, the following description will only detail the differences between the ATCs and the newly proposed permits.

C-7837-30-1, -34-1, and -36-1:

Condition 1 on each ATC has been removed and will not be added to the proposed PTOs. This condition requires each existing engine being replaced to be removed or rendered inoperable. The District has confirmed that each of the existing engines has been removed, and the PTO for each existing engine has subsequently been deleted.

Condition 3 on each ATC has been removed and will not be added to the proposed PTOs. This condition requires that no air contaminant shall be released into the atmosphere which causes a public nuisance. This condition is already on the facility-wide permit, C-7837-0-0, as condition 39.

Condition 5 on each ATC has been removed and will not be added to the proposed PTOs. This condition states that no air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as or darker than Ringelmann 1

or 20% opacity. This condition is already on the facility-wide permit as condition 22.

All remaining ATC conditions have been added to the proposed permit.

## **VII. COMPLIANCE**

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
  - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
  - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

## **VIII. ATTACHMENTS**

- A. Proposed Modified Title V Operating Permits C-7837-30-1, -34-1, and -36-1
- B. Authorities to Construct C-7837-30-0, -34-0, and -36-0
- C. Emissions Increases
- D. Application

# **ATTACHMENT A**

**Proposed Modified Title V Operating Permits  
C-7837-30-1, -34-1, and -36-1**

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** C-7837-30-1

**EXPIRATION DATE:** 08/31/2017

**EQUIPMENT DESCRIPTION:**

400 BHP CUMMINS MODEL QSX11 S/N 35230740 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 382)

## PERMIT UNIT REQUIREMENTS

---

1. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operation of this engine shall not exceed 5,350 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. Emissions from this unit shall not exceed any of the following limits: 2.69 g-NOx/bhp-hr, 0.14 g-VOC/bhp-hr, or 0.67 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.07 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
9. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart III] Federally Enforceable Through Title V Permit
10. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
11. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: WM BOLTHOUSE FARMS INC - NORTH AVENAL

Location: TS-22S, R-17E, AVENAL, CA

C-7837-30-1 : Feb 4 2013 4:23PM - SANDHUG

13. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

**DRAFT**

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** C-7837-34-1

**EXPIRATION DATE:** 08/31/2017

**EQUIPMENT DESCRIPTION:**

450 BHP CUMMINS MODEL QSX15 S/N 79317718 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 385)

## PERMIT UNIT REQUIREMENTS

1. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. Emissions from this unit shall not exceed any of the following limits: 2.55 g-NO<sub>x</sub>/bhp-hr, 0.13 g-VOC/bhp-hr, or 0.52 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.07 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
9. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
10. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
11. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

13. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** C-7837-36-1

**EXPIRATION DATE:** 08/31/2017

**EQUIPMENT DESCRIPTION:**

254 BHP JOHN DEERE MODEL 6090H S/N RG6090L072051 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE  
POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 353)

## PERMIT UNIT REQUIREMENTS

1. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. Emissions from this unit shall not exceed any of the following limits: 2.55 g-NOx/bhp-hr, 0.13 g-VOC/bhp-hr, or 0.37 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.09 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
9. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart III] Federally Enforceable Through Title V Permit
10. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
11. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

13. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# **ATTACHMENT B**

**Authorities to Construct  
C-7837-30-0, -34-0, and -36-0**



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-7837-30-0

**ISSUANCE DATE:** 06/08/2012

**LEGAL OWNER OR OPERATOR:** WM BOLTHOUSE FARMS INC - NORTH AVENAL  
**MAILING ADDRESS:** 7200 E BRUNDAGE LN  
BAKERSFIELD, CA 93307

**LOCATION:** TS-22S, R-17E  
AVENAL, CA

**EQUIPMENT DESCRIPTION:**

400 BHP CUMMINS MODEL QSX11 S/N 35230740 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 382) (REPLACEMENT FOR PERMIT UNIT C-7837-16) (REVISED JANUARY 17, 2013)

### CONDITIONS

1. Within 90 days after startup of the equipment authorized by this Authority to Construct, Permit to Operate C-7837-16 shall be surrendered to the District and the associated equipment shall be removed or rendered inoperable. [District Rule 2201]
2. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702]
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
7. Operation of this engine shall not exceed 5,350 hours per year. [District Rule 2201]
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

C-7837-30-0 Jan 17 2013 8:18AM - SANDHUG Joint Inspection NOT Required

9. Emissions from this unit shall not exceed any of the following limits: 2.69 g-NO<sub>x</sub>/bhp-hr, 0.14 g-VOC/bhp-hr, or 0.67 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart III]
10. PM<sub>10</sub> emissions shall not exceed 0.07 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60 Subpart III]
11. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart III]
12. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart III]
13. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
14. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702]
15. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
16. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702]



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-7837-31-0

**ISSUANCE DATE:** 06/08/2012

**LEGAL OWNER OR OPERATOR:** WM BOLTHOUSE FARMS INC - NORTH AVENAL  
**MAILING ADDRESS:** 7200 E BRUNDAGE LN  
BAKERSFIELD, CA 93307

**LOCATION:** TS-22S, R-17E  
AVENAL, CA

**EQUIPMENT DESCRIPTION:**

TRANSPORTABLE 125 BHP JOHN DEERE MODEL 4045H S/N PE4045L168268 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 386) (REPLACEMENT FOR PERMIT UNIT C-7837-19) (REVISED JANUARY 17, 2013)

### CONDITIONS

1. Within 90 days after startup of the equipment authorized by this Authority to Construct, Permit to Operate C-7837-19 shall be surrendered to the District and the associated equipment shall be removed or rendered inoperable. [District Rule 2201]
2. Owner/operator may also operate this permit unit at any of the following facilities: C-7843, C-6982, C-7842, and S-7633. [District Rule 2201]
3. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702]
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
6. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
7. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
8. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.**

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

C-7837-31-0 : Jan 17 2013 9:18AM -- SAND:RUG : Joint Inspection NOT Required

9. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
10. Emissions from this unit shall not exceed any of the following limits: 2.48 g-NOx/bhp-hr, 0.13 g-VOC/bhp-hr, or 1.19 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115]
11. PM10 emissions shall not exceed 0.15 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115]
12. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115]
13. This engine shall be operated at one location or site at a facility for no more than 12 consecutive months, or if at a seasonal source, the engine shall not be operated at one location or site at a facility for more than the duration of the season. [District Rules 2201 and 4701 and 17 CCR 93115]
14. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
15. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
16. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702]
17. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
18. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702]



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-7837-32-0

**ISSUANCE DATE:** 06/08/2012

**LEGAL OWNER OR OPERATOR:** WM BOLTHOUSE FARMS INC - NORTH AVENAL  
**MAILING ADDRESS:** 7200 E BRUNDAGE LN  
BAKERSFIELD, CA 93307

**LOCATION:** TS-22S, R-17E  
AVENAL, CA

**EQUIPMENT DESCRIPTION:**

TRANSPORTABLE 155 BHP JOHN DEERE MODEL 6068 S/N PE6068L156918 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 388) (REPLACEMENT FOR PERMIT UNIT C-7837-21) (REVISED JANUARY 17, 2013)

### CONDITIONS

1. Within 90 days after startup of the equipment authorized by this Authority to Construct, Permit to Operate C-7837-21 shall be surrendered to the District and the associated equipment shall be removed or rendered inoperable. [District Rule 2201]
2. Owner/operator may also operate this permit unit at any of the following facilities: C-7843, C-6982, C-7842, and S-7633. [District Rule 2201]
3. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702]
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
6. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
7. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
8. Operation of this engine shall not exceed 5,871 hours per year. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

  
DAVID WARNER, Director of Permit Services  
C-7837-32-0 Jan 17 2013 9:18AM - BAKDHUG Joint Inspection NOT Required

9. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
10. Emissions from this unit shall not exceed any of the following limits: 2.48 g-NO<sub>x</sub>/bhp-hr, 0.13 g-VOC/bhp-hr, or 1.19 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115]
11. PM<sub>10</sub> emissions shall not exceed 0.15 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115]
12. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115]
13. This engine shall be operated at one location or site at a facility for no more than 12 consecutive months, or if at a seasonal source, the engine shall not be operated at one location or site at a facility for more than the duration of the season. [District Rules 2201 and 4701 and 17 CCR 93115]
14. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
15. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
16. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702]
17. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
18. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702]



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-7837-34-0

**ISSUANCE DATE:** 06/08/2012

**LEGAL OWNER OR OPERATOR:** WM BOLTHOUSE FARMS INC - NORTH AVENAL  
**MAILING ADDRESS:** 7200 E BRUNDAGE LN  
BAKERSFIELD, CA 93307

**LOCATION:** TS-22S, R-17E  
AVENAL, CA

**EQUIPMENT DESCRIPTION:**

450 BHP CUMMINS MODEL QSX15 S/N 79317718 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 385) (REPLACEMENT FOR PERMIT UNIT C-7837-27) (REVISED JANUARY 17, 2013)

### CONDITIONS

1. Within 90 days after startup of the equipment authorized by this Authority to Construct, Permit to Operate C-7837-27 shall be surrendered to the District and the associated equipment shall be removed or rendered inoperable. [District Rule 2201]
2. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702]
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
7. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 2201]
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

C-7837-34-0 Jan 17 2013 9:18AM - SANDHUG - Joint Inspection NOT Required

9. Emissions from this unit shall not exceed any of the following limits: 2.55 g-NOx/bhp-hr, 0.13 g-VOC/bhp-hr, or 0.52 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart IIII]
10. PM10 emissions shall not exceed 0.07 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60 Subpart IIII]
11. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart IIII]
12. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart IIII]
13. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
14. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702]
15. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
16. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702]



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-7837-36-0

**ISSUANCE DATE:** 06/08/2012

**LEGAL OWNER OR OPERATOR:** WM BOLTHOUSE FARMS INC - NORTH AVENAL  
**MAILING ADDRESS:** 7200 E BRUNDAGE LN  
BAKERSFIELD, CA 93307

**LOCATION:** TS-22S, R-17E  
AVENAL, CA

**EQUIPMENT DESCRIPTION:**

254 BHP JOHN DEERE MODEL 6090H S/N RG6090L072051 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE  
POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG 353) (REPLACEMENT FOR PERMIT UNIT C-7837-23)  
(REVISED JANUARY 17, 2013)

### CONDITIONS

1. Within 90 days after startup of the equipment authorized by this Authority to Construct, Permit to Operate C-7837-23 shall be surrendered to the District and the associated equipment shall be removed or rendered inoperable. [District Rule 2201]
2. This IC engine shall only be used for the growing of crops or raising of fowl or animals. [District Rules 2201, 4701, and 4702]
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. The engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
7. Operation of this engine shall not exceed 6,500 hours per year. [District Rule 2201]
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Sayed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

C-7837-36-0: Jan 17 2013 9:18AM - SANDHUO Joint Inspection NOT Required

9. Emissions from this unit shall not exceed any of the following limits: 2.55 g-NO<sub>x</sub>/bhp-hr, 0.13 g-VOC/bhp-hr, or 0.37 g-CO/bhp-hr. [District Rules 2201 and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart IIII]
10. PM<sub>10</sub> emissions shall not exceed 0.09 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60 Subpart IIII]
11. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart IIII]
12. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart IIII]
13. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
14. The owner/operator shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, and any other information necessary to demonstrate compliance. [District Rule 4702]
15. The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
16. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702]

# **ATTACHMENT C**

## **Emissions Increases**

With the three existing engines removed from operation, the implementation of the new engines does not result in an increase in facility emissions.

	SSIPE (lb/yr)				
	NOx	SOx	PM10	CO	VOC
C-7837-16-0 (being replaced)	-21,890	-24	-720	-12,481	-1,152
C-7837-23-0 (being replaced)	-26,138	-29	-860	-14,903	-1,376
C-7837-27-0 (being replaced)	-44,494	-33	-2,579	-54,812	-6,448
C-7837-30-1	12,691	24	330	3,161	660
C-7837-34-1	16,443	33	451	2,889	838
C-7837-36-1	9,281	19	328	1,347	473
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

# ATTACHMENT D

Application

# San Joaquin Valley Air Pollution Control District


www.valleyair.org

RECEIVED  
JAN 15 2013

SJVAPCD  
Southern Region

## Permit Application For:

ADMINISTRATIVE AMENDMENT     MINOR MODIFICATION     SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: WM BOLTHOUSE FARMS INC- NORTH AVENAL	
2. MAILING ADDRESS:  STREET/P.O. BOX: <u>7200 E BRUNDAGE LN</u>  CITY: <u>Bakersfield</u> STATE: <u>CA</u> 9-DIGIT ZIP CODE: <u>93307</u>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED:  STREET: <u>TS-22E, R-17E</u> CITY: <u>AVENAL, CA</u>  _____ ¼ SECTION _____ TOWNSHIP _____ RANGE _____	INSTALLATION DATE: 06/08/2012
4. GENERAL NATURE OF BUSINESS: AGRICULTURAL	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary)  A REQUEST TO ADD PERMIT NUMBER C-7837-30-0 400 BHP CUMMINS MODEL QSX11 S/N 35230740 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG382) TO THE TITLE V PERMIT	
6. TYPE OR PRINT NAME OF APPLICANT: Andy Schoorl	TITLE OF APPLICANT: Manager
7. SIGNATURE OF APPLICANT: 	DATE: <u>1/11/13</u> PHONE: (661) 366-7209 x 1208 FAX: EMAIL: <u>aschoorl@bolthouse.com</u>

For APCD Use Only:

WZI INC.

DATE STAMP	FILING FEE RECEIVED: <u>\$ 57 / <del>\$19.00</del></u> CHECK#: <u>7931</u>
	DATE PAID: <u>PM 1-15-13</u>
	PROJECT NO: <u>C-1130140</u> FACILITY ID: <u>C-7837</u>

Title V - Minor Mod

# San Joaquin Valley Air Pollution Control District


www.valleyair.org

RECEIVED  
JAN 15 2013

SJVAPCD  
Southern Region

## Permit Application For:

[ ] ADMINISTRATIVE AMENDMENT     MINOR MODIFICATION    [ ] SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: <p style="text-align: center;">WM BOLTHOUSE FARMS INC- NORTH AVENAL</p>	
2. MAILING ADDRESS:  STREET/P.O. BOX: <u>7200 E BRUNDAGE LN</u>  CITY: <u>Bakersfield</u> STATE: <u>CA</u> ZIP CODE: <u>93307</u> <span style="float: right;">9-DIGIT</span>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED:  STREET: <u>TS-22E, R-17E</u> CITY: <u>AVENAL, CA</u>  _____ ¼ SECTION _____ TOWNSHIP _____ RANGE _____	INSTALLATION DATE: <p style="text-align: center;">06/08/2012</p>
4. GENERAL NATURE OF BUSINESS: AGRICULTURAL	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary)  A REQUEST TO ADD PERMIT NUMBER C-7837-34-0 450 BHP CUMMINS MODEL QSX15 S/N 79317718 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG385) TO THE TITLE V PERMIT	
6. TYPE OR PRINT NAME OF APPLICANT: Andy Schoorl	TITLE OF APPLICANT: Manager
7. SIGNATURE OF APPLICANT: 	DATE: <u>1/11/13</u>  PHONE: (661) 366-7209 x 1208 FAX: EMAIL: <u>aschoorl@bolthouse.com</u>

**For APCD Use Only:**

WZI INC

DATE STAMP	FILING FEE RECEIVED: <u>\$ 57.00 / <del>\$49.00</del></u> CHECK#: <u>7931</u> DATE PAID: <u>PM 1-15-13</u> PROJECT NO: <u>C-1130140</u> FACILITY ID: <u>C-7837</u>
------------	--

# San Joaquin Valley Air Pollution Control District

www.valleyair.org


RECEIVED

JAN 15 2013

SJVAPCD  
Southern Region

## Permit Application For:

[ ] ADMINISTRATIVE AMENDMENT     MINOR MODIFICATION    [ ] SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: WM BOLTHOUSE FARMS INC- NORTH AVENAL	
2. MAILING ADDRESS:  STREET/P.O. BOX: <u>7200 E BRUNDAGE LN</u>  CITY: <u>Bakersfield</u> STATE: <u>CA</u> 9-DIGIT ZIP CODE: <u>93307</u>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED:  STREET: <u>TS-22E, R-17E</u> CITY: <u>AVENAL, CA</u>  _____ ¼ SECTION _____ TOWNSHIP _____ RANGE _____	INSTALLATION DATE: 06/08/2012
4. GENERAL NATURE OF BUSINESS: AGRICULTURAL	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary)  A REQUEST TO ADD PERMIT NUMBER C-7837-36-0 254 BHP JOHN DEERE MODEL 6090H S/N RG6090L072051 TIER 3 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN AGRICULTURAL IRRIGATION PUMP (ENG353) TO THE TITLE V PERMIT	
6. TYPE OR PRINT NAME OF APPLICANT: Andy Schoorl	TITLE OF APPLICANT: Manager
7. SIGNATURE OF APPLICANT: 	DATE: <u>1/11/13</u> PHONE: (661) 366-7209 x 1208 FAX: EMAIL: <u>aschoorl@bolthouse.com</u>

**For APCD Use Only:**

*WZI INC.*

DATE STAMP	FILING FEE RECEIVED: \$ <u>57.00 / <del>19.00</del></u> CHECK#: <u>7931</u> DATE PAID: <u>PM 1-15-13</u> PROJECT NO: <u>C-1130140</u> FACILITY ID: <u>C-7837</u>
------------	--

San Joaquin Valley  
Unified Air Pollution Control District

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)


- SIGNIFICANT PERMIT MODIFICATION                       ADMINISTRATIVE AMENDMENT  
 MINOR PERMIT MODIFICATION

COMPANY NAME: WM BOLTHOUSE FARMS INC- NORTH AVENAL	FACILITY ID: C 7837
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: WM BOLTHOUSE FARMS INC- NORTH AVENAL	
3. Agent to the Owner:	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

  
\_\_\_\_\_  
Signature of Responsible Official

1/11/13  
\_\_\_\_\_  
Date

ANDY SCHOORI  
\_\_\_\_\_  
Name of Responsible Official (please print)

MANAGER  
\_\_\_\_\_  
Title of Responsible Official (please print)