



OCT 25 2010

Melinda Hicks
ALON Bakersfield Refinery
6451 Rosedale Hwy
Bakersfield, CA 93308

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-33
Project # S-1072848**


Dear Ms. Hicks:

The Air Pollution Control Officer has modified the Title V permit for ALON Bakersfield Refinery by incorporating S-33-9-13. The facility is proposing to de-rate heaters 11H1 and 11H2 from 71.3 MMBtu/hr to 65 MMBtu/hr for Rule 4306 compliance.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on July 9, 2007. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

DW:vg

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



OCT 25 2010

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-33
Project # S-1072848**


Dear Mr. Rios:

The Air Pollution Control Officer has modified the Title V permit for ALON Bakersfield Refinery by incorporating S-33-9-13. The facility is proposing to de-rate heaters 11H1 and 11H2 from 71.3 MMBtu/hr to 65 MMBtu/hr for Rule 4306 compliance.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on July 9, 2007. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

DW:vg

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-33-9-14

EXPIRATION DATE: 08/31/2007

SECTION: 27 **TOWNSHIP:** 29S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

VACUUM UNIT #11 INCLUDING NATURAL GAS/REFINERY GAS FIRED VACUUM CHARGE HEATERS 11H1 AND 11H2 (DE-RATED AT 130 MMBTU/HR TOTAL), VACUUM TOWER, FOUR STAGE VACUUM SYSTEM WITH GAS AMINE CONTACTOR AND MISC. PUMPS, PIPING, AND VESSELS - AREA 1

PERMIT UNIT REQUIREMENTS

1. Permittee shall meet all applicable requirements of NSPS Subparts A and J. [District Rule 4001] Federally Enforceable Through Title V Permit
2. Vacuum system exhaust gas shall either be collected, compressed, and added to refinery gas; controlled and combusted in an appropriate firebox or incinerator with at least 90 percent VOC control efficiency; or controlled by an equivalent method approved by the APCO. [District Rule 4453, 3.2] Federally Enforceable Through Title V Permit
3. Maximum heat input of each de-rated heater, heaters 11H1 and 11H2, shall be less than or equal to 65 million Btu per hour. [District NSR Rule and District Rule 4306] Federally Enforceable Through Title V Permit
4. Emissions from the natural gas-fired vacuum heaters 11H1 and 11H2 shall not exceed any of the following limits: 30 ppmvd NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.0286 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 225 ppmvd CO @ 3% O₂ or 0.116 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District NSR Rule, and District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
5. All sampling connections, open ended valves or lines shall be equipped with two closed valves or be capped with blind flanges or threaded plugs except during actual use. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Continuous records of each heaters (heater 11H1 and 11H2) firing rate, including volumetric fuel consumption rate (corrected for temperature) and hhv of fuel burned shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
8. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
10. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
11. Source testing to measure NO_x and CO emissions from heaters 11H1 and 11H2 while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
12. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
16. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
17. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305 and 4306] Federally Enforceable Through Title V Permit
18. Permittee shall maintain records of hhv of fuel burned and cumulative annual fuel use for a period of five years and shall make such records readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081(amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 19,1993). [District Rule 1081, and Kern County Rule 108.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
23. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
24. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
28. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
29. Nitrogen oxide (NO_x) emission concentrations in ppmv shall be referenced at dry stack gas conditions, and shall be calculated to 3.00 percent by volume stack gas oxygen and averaged over 60 minutes, and lb/MMBtu rates shall be calculated as lb NO₂/MMBtu of heat input (hhv). [District Rule 4305, 5.0, 8.2 and/or 4351, 8.1] Federally Enforceable Through Title V Permit
30. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2] Federally Enforceable Through Title V Permit
31. The operator shall meet operating, inspection and re-inspection, maintenance, process pressure relief device (PRD) and component identification requirements of District Rule 4455 (4/20/05) for all components containing or contacting VOC, except for those components specifically exempted in Sections 4.1 and 4.2. [District Rule 4455, 5.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. The operator shall not use any component that leaks in excess of the allowable leak standards, except as follows. A component identified as leaking in excess of an allowable leak standard may be used provided it has been identified with a tag for repair, has been repaired, or is awaiting re-inspection after repair, within the applicable time period specified within the rule. [District Rule 4455, 5.1.1] Federally Enforceable Through Title V Permit
33. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4455, 5.1.2] Federally Enforceable Through Title V Permit
34. A component shall be considered leaking if one of more of the conditions specified in Sections 5.1.4.1 through 5.1.4.4 of the rule exist at the facility. [District Rule 4455, 5.1.4] Federally Enforceable Through Title V Permit
35. The operator shall audio-visually inspect for leaks all accessible operating pumps, compressors and PRD in service at least once every 24 hours, except when operators do not report to the facility for that given 24 hours. Any identified leak that cannot be immediately repaired shall be reinspected within 24 hours using EPA Method 21. If a leak is found, it shall be repaired as soon as practical but not later than the time frame specified in Table 3 of the rule. [District Rule 5.2.1 & 5.2.2] Federally Enforceable Through Title V Permit
36. The operator shall inspect all components at least once every calendar quarter. New, replaced, or repaired fittings, flanges and threaded connections shall be inspected immediately after being placed into service. Inaccessible components, unsafe-to-monitor components and pipes shall be inspected in accordance with the requirements set forth in Sections 5.2.5 through 5.2.7. Components shall be inspected using EPA Method 21. [District Rule 4455, 5.2.3, 5.2.4, 5.2.5, 5.2.6 & 5.2.7] Federally Enforceable Through Title V Permit
37. The operator may apply for a written approval from the APCO to change the inspection frequency from quarterly to annually for a component type, provided the operator meets all the criteria specified in Sections 5.2.8.1 through 5.2.8.3 of the rule. This approval shall apply to accessible component types, specifically designated by the APCO, except pumps, compressors, and PRDs which shall continue to be inspected on a quarterly basis. [District Rule 4455, 5.2.8] Federally Enforceable Through Title V Permit
38. An annual inspection frequency approved by the APCO shall revert to quarterly inspection frequency for a component type if either the operator inspection or District inspection demonstrates that a violation of the provisions of Sections 5.1, 5.2 and 5.3 of the rule exists for that component type, or the APCO issued a Notice of Violation for violating any of the provisions of this rule during the annual inspection period for that component type. When the inspection frequency changes from annual to quarterly inspections, the operator shall notify the APCO in writing within five (5) calendar days after changing the inspection frequency, giving the reason(s) and date of change to quarterly inspection frequency. [District Rule 4455, 5.2.9 and 5.2.10] Federally Enforceable Through Title V Permit
39. The operator shall initially inspect a process PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the time of the release. To insure that the process PRD is operating properly, and is leak-free, the operator shall re-inspect the process PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the date of the release using EPA Method 21. If the process PRD is found to be leaking at either inspection, the PRD leak shall be treated as if the leak was found during quarterly operator inspections. [District Rule 4455, 5.2.11] Federally Enforceable Through Title V Permit
40. Except for process PRD, a component shall be inspected within 15 calendar days after repairing the leak or replacing the component using EPA Method 21. [District Rule 4455, 5.2.12] Federally Enforceable Through Title V Permit
41. Upon detection of a leaking component, the operator shall affix to that component a weatherproof readily visible tag. The tag shall remain affixed to the component until the leaking component has been repaired or replaced; has been re-inspected using EPA Method 21; and is found to be in compliance with the requirements of this rule. [District Rule 4455, 5.3.1 & 5.3.2; 40 CFR 60.486(b)] Federally Enforceable Through Title V Permit
42. The tag shall include date and time of leak detection, date and time of leak measurement, indicate the leak concentration in ppmv (gas leaks), indicate whether it is a major or a minor leak (liquid leaks) and whether the leaking component is an essential component, unsafe-to-monitor component or critical component. [District Rule 4455, 5.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. All component leaks shall be immediately minimized to the extent possible, but not later than one (1) hour after detection of leaks, in order to stop or reduce leakage to the atmosphere. As soon as practicable but not later than the time period specified in Table 3 of the rule, components that have been identified as leaking and have had emissions minimized to the extent possible but do not meet the applicable leak standards of the rule shall either be: 1) repaired or replaced, or 2) vented to a closed vent system, or 3) removed from operation. [District Rule 4455, 5.3.] Federally Enforceable Through Title V Permit
44. For any leaking component that is an essential or critical component, and which cannot be immediately shut down for repairs, the operator shall minimize the leak within one hour after detection of the leak. If the leak has been minimized but still exceeds any of the applicable leak standards of this rule, the operator shall repair or replace the component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4455, 5.3.6] Federally Enforceable Through Title V Permit
45. For any component that has incurred five repair actions for major gas leaks or major liquid leaks (any combination) within a continuous 12-month period, the operator shall as soon as practicable but not later than 12 after the date of detection either: 1) replace or retrofit the component with the control technology specified in Table 4 of the rule, or 2) replace the component with Best Available Control Technology (BACT) equipment, as approved by the APCO, or 3) vent the component to an APCO approved closed vent system as defined in Section 3.0 of the rule, or 4) remove the component from operation. Inaccessible components, unsafe-to-monitor components, essential components, or critical components shall satisfy the above-listed requirement as soon as practicable but not later than the next turnaround or not later than two (2) years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes earlier. The APCO shall be notified in writing prior to the replacement or retrofitting of any component. [District Rule 4455, 5.3.7] Federally Enforceable Through Title V Permit
46. The operator shall monitor process PRD by using electronic process control instrumentation that allows for real time continuous parameter monitoring or by using telltale indicators for the process PRD where parameter monitoring is not feasible. [District Rule 4455, 5.4.1] Federally Enforceable Through Title V Permit
47. The operator shall comply with the process PRD release notification and record keeping requirements specified in Section 6.3 of the rule. After a release from process PRD in excess of 500 pounds of VOC in a continuous 24-hour period, the operator shall immediately conduct a failure analysis and implement corrective actions as soon as practicable but not later than 30 days to prevent the reoccurrence of similar release. [District Rule 4455, 5.4.3 and 5.4.4] Federally Enforceable Through Title V Permit
48. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and record keeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other APCO-approved system that enables an operator or District personnel to locate each individual component. The operator shall replace tags or labels that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4455, 5.5] Federally Enforceable Through Title V Permit
49. The operator shall keep a copy of the OMP at the facility and make it available to the APCO, ARB and US EPA upon request. By January 30 of each year, the operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved Operator Management Plan. [District Rule 4455, 6.1.2] Federally Enforceable Through Title V Permit
50. Operator shall maintain an inspection log containing the information set forth in Sections 6.2.1.1 through 6.2.1.10 of the rule. [District Rule 4455, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

51. The operator shall notify the APCO, by telephone or other APCO-approved methods, of any process PRD release in excess of 500 pounds of VOC in a continuous 24-hour period, and any release in excess of the reportable quantity limits as stipulated in 40 CFR, Part 117, Part 302 and Part 355, including any release in excess of 100 pounds of VOC, within one hour of such occurrence or within one hour of the time said person knew or reasonably should have known of its occurrence. The operator shall submit a written report to the APCO within thirty (30) calendar days of following notification of process PRD release subject to 6.3.1 of the rule. The written report shall include all of the information set forth in Sections 6.3.2.1 through 6.3.2.5 of the rule. [District Rule 4455, 6.3] Federally Enforceable Through Title V Permit
52. Measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument, calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. Operator shall keep a record of each instrument calibration in accordance with requirements as set forth Section 6.2.3 of the rule. [District Rule 4455, 6.4] Federally Enforceable Through Title V Permit
53. Operators shall not depressurize any vessel containing VOCs unless the process unit turnaround is accomplished by employing one of the following operating procedures: The organic vapors shall either be recovered, added to the refinery fuel gas system and combusted; or controlled and piped to an appropriate firebox or incinerated for combustion; or flared, until the pressure within the process vessel is as close to atmospheric pressure as is possible. All process vessels shall be depressurized into the control facilities to less than 1020 mm Hg (5 psig) before venting/opening to atmosphere. All organic compounds which emerge from a refinery process vessel during the purging of said vessel and which otherwise would be emitted to the atmosphere shall be either directed to a flare or incinerator or shall be used for fuel until such disposition of emissions is not technically feasible or is less safe than atmospheric venting. [District Rule 4454, 4.0] Federally Enforceable Through Title V Permit
54. The owner or operator may apply to the Administrator for a determination of equivalency for any means of emission limitation that achieves a reduction in emissions of VOC at least equivalent to the reduction in emissions of VOC achieved by the controls required in Subpart GGG. In doing so, the owner or operator shall comply with the requirements of 40 CFR 60.484. [40 CFR 60.592(c)] Federally Enforceable Through Title V Permit
55. Each pump in light liquid service (PLLS) shall be monitored monthly to detect leaks by the methods specified in 40 CFR 60.485(b), except as provided in 40 CFR 60.482-1(c) and 40 CFR 60.482-2(d), (e), and (f). Each pump in light liquid service shall be checked by visual inspection each calendar week for indications of liquids dripping from the pump seal. A leak is detected if an instrument reading of 10,000 ppm or greater is measured or if there are indications of liquids dripping from the pump seal. [40 CFR 60.482-2(a) and (b)] Federally Enforceable Through Title V Permit
56. When a leak is detected for each PLLS, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in 40 CFR 60.482-9. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected. [40 CFR 60.482-2(c)] Federally Enforceable Through Title V Permit
57. Each PLLS equipped with a dual mechanical seal system that includes a barrier fluid system is exempt from the requirements of 40 CFR 60.482-2(a) provided the requirements specified in 40 CFR 60.482-2(d)(1) through (6) are met. [40 CFR 60.482(d)] Federally Enforceable Through Title V Permit
58. Any PLLS that is designated, as described in 40 CFR 60.486(e)(1) and (2), for no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, is exempt from the requirements of 40 CFR 60.482-2(a), (c), and (d) if the pump meets the requirements specified in 40 CFR 60.482-2(e)(1), (2), and (3). [40 CFR 60.482-2(e)] Federally Enforceable Through Title V Permit
59. If any PLLS is equipped with a closed vent system capable of capturing and transporting leakage from the seal or seals to a control device that complies with the requirements of 40 CFR 60.482-10, it is exempt from the requirements of 40 CFR 60.482-2(a) through (e). [40 CFR 60.482-2(f)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

60. Any pump in PLLS that is designated, as described in 40 CFR 60.486(f)(1), as an unsafe-to-monitor pump is exempt from the monitoring and inspection requirements of 40 CFR 60.482-2(a) and 40 CFR 60.482-2(d)(4) through (6) if: 1) The owner or operator of the pump demonstrates that the pump is unsafe-to-monitor because monitoring personnel would be exposed to an immediate danger as a consequence of complying with 40 CFR 60.482-2(a); and 2) The owner or operator of the pump has a written plan that requires monitoring of the pump as frequently as practicable during safe-to-monitor times but not more frequently than the periodic monitoring schedule otherwise applicable, and repair of the equipment according to the procedures in 40 CFR 60.482-2(c) if a leak is detected. [40 CFR 60.482-2(g)] Federally Enforceable Through Title V Permit
61. Any pump that is located within the boundary of an unmanned plant site is exempt from the weekly visual inspection requirement of 40 CFR 60.482-2(a)(2) and (d)(4) and the daily requirements of 40 CFR 60.482-2(d)(5), provided that each pump is visually inspected as often as practicable and at least monthly. [40 CFR 60.482-2(h)] Federally Enforceable Through Title V Permit
62. Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in 40 CFR 60.485(c). [40 CFR 60.482-4(a)] Federally Enforceable Through Title V Permit
63. After each pressure release, the pressure relief device shall be returned to a condition of no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as soon as practicable, but no later than 5 calendar days after the pressure release, except as provided in 40 CFR 60.482-9. No later than 5 calendar days after the pressure release, the pressure relief device shall be monitored to confirm the conditions of no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, by the methods specified in 40 CFR 60.485(c). [40 CFR 60.482-4(b)] Federally Enforceable Through Title V Permit
64. Any pressure relief device that is routed to a process or fuel gas system or equipped with a closed vent system capable of capturing and transporting leakage through the pressure relief device to a control device as described in 40 CFR 60.482-10 is exempted from the requirements of 40 CFR 60.482-4(a) and (b). [40 CFR 60.482-4(c)] Federally Enforceable Through Title V Permit
65. Any pressure relief device that is equipped with a rupture disk upstream of the pressure relief device is exempt from the 40 CFR 60.482-4(a) and (b), provided the owner or operator complies with the requirements in 40 CFR 60.482-4(d)(2) of this section. After each pressure release, a new rupture disk shall be installed upstream of the pressure relief device as soon as practicable, but no later than 5 calendar days after each pressure release, except as provided in 40 CFR 60.482-9. [40 CFR 60.482-4(d)] Federally Enforceable Through Title V Permit
66. Except for in-situ sampling systems and sampling systems without purges, each sampling connection system shall be equipped with a closed-purge, closed-loop, or closed-vent system, except as provided in 40 CFR 60.482-1(c). Each closed-purge, closed-loop, or closed-vent system shall comply with the requirements specified in 40 CFR 60.482-5(b)(1), (2), (3), and (4). [40 CFR 60.482-5(a), (b), and (c)] Federally Enforceable Through Title V Permit
67. Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve, except as provided in 40 CFR 60.482-1(c). The cap, blind flange, plug, or second valve shall seal the open end at all times except during operations requiring process fluid flow through the open-ended valve or line. When a double block-and-bleed system is being used, the bleed valve or line may remain open during operations that require venting the line between the block valves but shall comply with this condition at all other times. [40 CFR 60.482-6(a) and (c)] Federally Enforceable Through Title V Permit
68. Each open-ended valve or line equipped with a second valve shall be operated in a manner such that the valve on the process fluid end is closed before the second valve is closed. [40 CFR 60.482-6(b)] Federally Enforceable Through Title V Permit
69. Open-ended valves or lines in an emergency shutdown system which are designed to open automatically in the event of a process upset are exempt from the requirements of 40 CFR 60.482-6(a), (b) and (c). [40 CFR 60.482-6(d)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

70. Open-ended valves or lines containing materials which would autocatalytically polymerize or would present an explosion, serious overpressure, or other safety hazard if capped or equipped with a double block and bleed system as specified in 40 CFR 60.482-6(a) through (c) are exempt from the requirements of 40 CFR 60.482-6(a) through (c). [40 CFR 60.482-6(e)] Federally Enforceable Through Title V Permit
71. Each valve in gas/vapor service and in light liquid service shall be monitored monthly to detect leaks by the methods specified in 40 CFR 60.485(b) and shall comply with 40 CFR 60.482-7(b) through (e), except as provided in 40 CFR 60.482-7(f), (g), and (h), 40 CFR 60.483-1, 40 CFR 60.483-2, and 40 CFR 60.482-1(c). A leak is detected if an instrument reading of 10,000 ppm or greater is measured. [40 CFR 60.482-7(a) and (b)] Federally Enforceable Through Title V Permit
72. Any valve in gas/vapor service or in light liquid service for which a leak is not detected for 2 successive months may be monitored the first month of every quarter, beginning with the next quarter, until a leak is detected. If a leak is detected, the valve shall be monitored monthly until a leak is not detected for 2 successive months. [40 CFR 60.482-7(c)] Federally Enforceable Through Title V Permit
73. When a leak is detected for any valve in gas/vapor service or in light liquid service, it shall be repaired as soon as practicable, but no later than 15 calendar days after the leak is detected, except as provided in 40 CFR 60.482-9. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected. First attempts at repair include, but are not limited to, the best practices specified in 40 CFR 60.482-7(e)(1), (2), (3), and (4), where practicable. [40 CFR 60.482-7(d) and (e)] Federally Enforceable Through Title V Permit
74. Any valve in gas/vapor service or in light liquid service that is designated, as described in 40 CFR 60.486(e)(2), for no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, is exempt from the requirements of 40 CFR 60.482-7(a) if the valve meets the requirements specified in 40 CFR 60.482-7(f)(1), (2), and (3). [40 CFR 60.482-7(f)] Federally Enforceable Through Title V Permit
75. Any valve in gas/vapor service or in light liquid service that is designated, as described in 40 CFR 60.486(f)(1), as an unsafe-to-monitor valve is exempt from the requirements of 40 CFR 60.482-7(a) if: 1) The owner or operator of the valve demonstrates that the valve is unsafe to monitor because monitoring personnel would be exposed to an immediate danger as a consequence of complying with 40 CFR 60.482-7(a); and 2) The owner or operator of the valve adheres to a written plan that requires monitoring of the valve as frequently as practicable during safe-to-monitor times. [40 CFR 60.482-7(g)] Federally Enforceable Through Title V Permit
76. Any valve in gas/vapor service or in light liquid service that is designated, as described in 40 CFR 60.486(f)(2), as a difficult-to-monitor valve is exempt from the requirements of 40 CFR 60.482-7(a) if: 1) The owner or operator of the valve demonstrates that the valve cannot be monitored without elevating the monitoring personnel more than 2 meters above a support surface; 2) The process unit within which the valve is located either becomes an affected facility through 40 CFR 60.14 or 40 CFR 60.15 or the owner or operator designates less than 3.0 percent of the total number of valves as difficult-to-monitor; and 3) The owner or operator of the valve follows a written plan that requires monitoring of the valve at least once per calendar year. [40 CFR 60.482-7(h)] Federally Enforceable Through Title V Permit
77. The owner or operator may elect to comply with the applicable provisions for valves in gas/vapor service and in light liquid service as specified in 40 CFR 60.483-1 and 60.483-2. [40 CFR 60.592(b)] Federally Enforceable Through Title V Permit
78. If evidence of a potential leak is found by visual, audible, olfactory, or any other detection method at pumps and valves in heavy liquid service, pressure relief devices in light liquid or heavy liquid service, and connectors, the owner or operator shall follow either one of the following procedures: 1) The owner or operator shall monitor the equipment within 5 days by the method specified in 40 CFR 60.485(b) and shall comply with the requirements of 40 CFR 60.482-8(b) through (d); or 2) The owner or operator shall eliminate the visual, audible, olfactory, or other indication of a potential leak. A leak is detected if an instrument reading of 10,000 ppm or greater is measured. [40 CFR 60.482-8(a) and (b)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

79. When a leak is detected in pumps and valves in heavy liquid service, pressure relief devices in light liquid or heavy liquid service, and connectors, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in 40 CFR 60.482-9. The first attempt at repair shall be made no later than 5 calendar days after each leak is detected. First attempts at repair include, but are not limited to, the best practices described under 40 CFR 60.482-7(e). [40 CFR 60.482-8(c) and (d)] Federally Enforceable Through Title V Permit
80. For closed vent systems and control devices, vapor recovery systems shall be designed and operated to recover the VOC emissions vented to them with an efficiency of 95 percent or greater, or to an exit concentration of 20 parts per million by volume, whichever is less stringent. [40 CFR 60.482-10(b)] Federally Enforceable Through Title V Permit
81. For closed vent systems and control devices, enclosed combustion devices shall be designed and operated to reduce the VOC emissions vented to them with an efficiency of 95 percent or greater, or to an exit concentration of 20 parts per million by volume, on a dry basis, corrected to 3 percent oxygen, whichever is less stringent or to provide a minimum residence time of 0.75 seconds at a minimum temperature of 816 degrees C. [40 CFR 60.482-10(c)] Federally Enforceable Through Title V Permit
82. Flares used to comply with Subpart GGG shall comply with the requirements of 40 CFR 60.18. [40 CFR 60.482-10(d)] Federally Enforceable Through Title V Permit
83. Owners or operators of control devices used to comply with the provisions of Subpart GGG shall monitor these control devices to ensure that they are operated and maintained in conformance with their designs. [40 CFR 60.482-10(e)] Federally Enforceable Through Title V Permit
84. Except as provided in 40 CFR 60.482-10(i) through (k), each closed vent system used to comply with the provisions of Subpart GGG shall be inspected according to the procedures and schedule specified in 40 CFR 60.482-10(f)(1) and (f)(2). Leaks, as indicated by an instrument reading greater than 500 parts per million by volume above background or by visual inspections, shall be repaired as soon as practicable except as provided in 40 CFR 60.482-10(h). A first attempt at repair shall be made no later than 5 calendar days after the leak is detected. Repair shall be completed no later than 15 calendar days after the leak is detected. [40 CFR 60.482-10(f) and (g)] Federally Enforceable Through Title V Permit
85. Delay of repair of a closed vent system for which leaks have been detected is allowed if the repair is technically infeasible without a process unit shutdown or if the owner or operator determines that emissions resulting from immediate repair would be greater than the fugitive emissions likely to result from delay of repair. Repair of such equipment shall be complete by the end of the next process unit shutdown. [40 CFR 60.482-10(h)] Federally Enforceable Through Title V Permit
86. If a vapor collection system or closed vent system is operated under a vacuum, it is exempt from the inspection requirements of 40 CFR 60.482-10(f)(1)(i) and (f)(2). [40 CFR 60.482-10(i)] Federally Enforceable Through Title V Permit
87. Any parts of the closed vent system that are designated, as described in 40 CFR 60.482-10(l)(1), as unsafe to inspect are exempt from the inspection requirements of 40 CFR 60.482-10(f)(1)(i) and (f)(2) if they comply with the requirements specified in 40 CFR 60.482-10(j)(1) and (j)(2). [40 CFR 60.482-10(j)] Federally Enforceable Through Title V Permit
88. Any parts of the closed vent system that are designated, as described in 40 CFR 60.482-10(l)(2), as difficult to inspect are exempt from the inspection requirements of 40 CFR 60.482-10(f)(1)(i) and (f)(2) if they comply with the requirements specified in 40 CFR 60.482-10(k)(1) through (k)(3). [40 CFR 60.482-10(k)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

89. The owner or operator shall record the following information: 1) Identification of all parts of the closed vent system that are designated as unsafe to inspect, an explanation of why the equipment is unsafe to inspect, and the plan for inspecting the equipment; 2) Identification of all parts of the closed vent system that are designated as difficult to inspect, an explanation of why the equipment is difficult to inspect, and the plan for inspecting the equipment; 3) For each inspection during which a leak is detected, a record of the information specified in 40 CFR 60.486(c); 4) For each inspection conducted in accordance with 40 CFR 60.485(b) during which no leaks are detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected; and 5) For each visual inspection conducted in accordance with 40 CFR 60.482-10(f)(1)(ii) during which no leaks are detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected. [40 CFR 60.482-10(l)] Federally Enforceable Through Title V Permit
90. Closed vent systems and control devices used to comply with provisions Subpart GGG shall be operated at all times when emissions may be vented to them. [40 CFR 60.482-10(m)] Federally Enforceable Through Title V Permit
91. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in 40 CFR 60, Appendix A or other methods and procedures as specified in 40 CFR 60.485, except as provided in 40 CFR 60.8(b). [40 CFR 60.485(a)] Federally Enforceable Through Title V Permit
92. The owner or operator shall determine compliance with the standards in 40 CFR 60.482, 60.483, and 60.484 as follows: Method 21 shall be used to determine the presence of leaking sources. The instrument shall be calibrated before use each day of its use by the procedures specified in Method 21. The following calibration gases shall be used: (i) Zero air (less than 10 ppm of hydrocarbon in air); and (ii) A mixture of methane or n-hexane and air at a concentration of about, but less than, 10,000 ppm methane or n-hexane. [40 CFR 60.485(b)] Federally Enforceable Through Title V Permit
93. The owner or operator shall determine compliance with the no detectable emission standards in 40 CFR 60.482-2(e), 60.482-3(i), 60.482-4, 60.482-7(f), and 60.482-10(e) as follows: 1) The requirements of 40 CFR 60.485(b) shall apply. 2) Method 21 shall be used to determine the background level. All potential leak interfaces shall be traversed as close to the interface as possible. The arithmetic difference between the maximum concentration indicated by the instrument and the background level is compared with 500 ppm for determining compliance. [40 CFR 60.485(c)] Federally Enforceable Through Title V Permit
94. The owner or operator shall test each piece of equipment unless demonstrated that a process unit is not in VOC service, i.e., that the VOC content would never be reasonably expected to exceed 10 percent by weight. For purposes of this demonstration, the following methods and procedures shall be used: 1) Procedures that conform to the general methods in ASTM E260-73, 91, or 96, E168-67, 77, or 92, E169-63, 77, or 93 (incorporated by reference as seen in 40 CFR 60.17) shall be used to determine the percent VOC content in the process fluid that is contained in or contacts a piece of equipment; 2) Organic compounds that are considered by the Administrator to have negligible photochemical reactivity may be excluded from the total quantity of organic compounds in determining the VOC content of the process fluid; and 3) Engineering judgment may be used to estimate the VOC content, if a piece of equipment had not been shown previously to be in service. If the Administrator disagrees with the judgment, the previous two procedures as specified in 40 CFR 60.485(d)(1) and (2) shall be used to resolve the disagreement. [40 CFR 60.485(d)] Federally Enforceable Through Title V Permit
95. The owner or operator shall demonstrate that an equipment is in light liquid service by showing that all the following conditions apply: 1) The vapor pressure of one or more of the components is greater than 0.3 kPa at 20 °C (1.2 in. H₂O at 68 degrees F). Standard reference texts or ASTM D2879-83, 96, or 97 (incorporated by reference as seen in 40 CFR 60.17) shall be used to determine the vapor pressures; 2) The total concentration of the pure components having a vapor pressure greater than 0.3 kPa at 20 degrees Celsius is equal to or greater than 20 percent by weight; and 3) The fluid is a liquid at operating conditions. [40 CFR 60.485(e)] Federally Enforceable Through Title V Permit
96. Samples used in conjunction with 40 CFR 60.485(d), (e), and (g) shall be representative of the process fluid that is contained in or contacts the equipment or the gas being combusted in the flare. [40 CFR 60.485(f)] Federally Enforceable Through Title V Permit
97. The owner or operator shall determine compliance with the standards of flares as specified in 40 CFR 60.485(g)(1), (2), (3), (4), (5), (6), and (7). [40 CFR 60.485(g)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

98. An owner or operator of more than one affected facility subject to the provisions Subpart GGG may comply with the recordkeeping requirements for these facilities in one recordkeeping system if the system identifies each record by each facility. [40 CFR 60.486(a)] Federally Enforceable Through Title V Permit
99. When each leak is detected as specified in 40 CFR 60.482-2, 60.482-3, 60.482-7, 60.482-8, and 60.483-2, the following requirements apply: 1) A weatherproof and readily visible identification, marked with the equipment identification number, shall be attached to the leaking equipment; 2) The identification on a valve may be removed after it has been monitored for 2 successive months as specified in 40 CFR 60.482-7(c) and no leak has been detected during those 2 months; and 3) The identification on equipment except on a valve, may be removed after it has been repaired. [40 CFR 60.486(b)] Federally Enforceable Through Title V Permit
100. When each leak is detected as specified in 40 CFR 60.482-2, 60.482-3, 60.482-7, 60.482-8, and 60.483-2, the following information shall be recorded in a log and shall be kept for 5 years in a readily accessible location: 1) The instrument and operator identification numbers and the equipment identification number; 2) The date the leak was detected and the dates of each attempt to repair the leak; 3) Repair methods applied in each attempt to repair the leak; 4) ``Above 10,000" if the maximum instrument reading measured by the methods specified in 40 CFR 60.485(a) after each repair attempt is equal to or greater than 10,000 ppm; 5) ``Repair delayed" and the reason for the delay if a leak is not repaired within 15 calendar days after discovery of the leak; 6) The signature of the owner or operator (or designate) whose decision it was that repair could not be effected without a process shutdown; 7) The expected date of successful repair of the leak if a leak is not repaired within 15 days; 8) Dates of process unit shutdown that occur while the equipment is unrepaired; and 9) The date of successful repair of the leak. [40 CFR 60.486(c) and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
101. The following information pertaining to the design requirements for closed vent systems and control devices described in 40 CFR 60.482-10 shall be recorded and kept in a readily accessible location: 1) Detailed schematics, design specifications, and piping and instrumentation diagrams; 2) The dates and descriptions of any changes in the design specifications; 3) A description of the parameter or parameters monitored, as required in 40 CFR 60.482-10(e), to ensure that control devices are operated and maintained in conformance with their design and an explanation of why that parameter (or parameters) was selected for the monitoring; 4) Periods when the closed vent systems and control devices required in 40 CFR 60.482-2, 60.482-3, 60.482-4, and 60.482-5 are not operated as designed, including periods when a flare pilot light does not have a flame; and 5) Dates of startups and shutdowns of the closed vent systems and control devices required in 40 CFR 60.482-2, 60.482-3, 60.482-4, and 60.482-5. [40 CFR 60.486(d)] Federally Enforceable Through Title V Permit
102. The following information pertaining to all equipment subject to the requirements in 40 CFR 60.482-1 to 60.482-10 shall be recorded in a log that is kept in a readily accessible location: 1) A list of identification numbers for equipment subject to the requirements of Subpart GGG; 2) (i) A list of identification numbers for equipment that are designated for no detectable emissions under the provisions of 40 CFR 60.482-2(e), 60.482-3(i) and 60.482-7(f). (ii) The designation of equipment as subject to the requirements of 40 CFR 60.482-2(e), 60.482-3(i) and 60.482-7(f) shall be signed by the owner or operator; 3) A list of equipment identification numbers for pressure relief devices required to comply with §60.482-4; 4) (i) The dates of each compliance test as required in 40 CFR 60.482-2(e), 60.482-3(i), §60.482-4, and 60.482-7(f). (ii) The background level measured during each compliance test. (iii) The maximum instrument reading measured at the equipment during each compliance test; and 5) A list of identification numbers for equipment in vacuum service. [40 CFR 60.486(e)] Federally Enforceable Through Title V Permit
103. The following information pertaining to all valves subject to the requirements of 40 CFR 60.482-7(g) and (h) and to all pumps subject to the requirements of 40 CFR 60.482-2(g) shall be recorded in a log that is kept in a readily accessible location: 1) A list of identification numbers for valves and pumps that are designated as unsafe-to-monitor, an explanation for each valve or pump stating why the valve or pump is unsafe-to-monitor, and the plan for monitoring each valve or pump; and 2) A list of identification numbers for valves that are designated as difficult-to-monitor, an explanation for each valve stating why the valve is difficult-to-monitor, and the schedule for monitoring each valve. [40 CFR 60.486(f)] Federally Enforceable Through Title V Permit
104. The following information shall be recorded for valves complying with 40 CFR 60.483-2: 1) A schedule of monitoring; 2) The percent of valves found leaking during each monitoring period. [40 CFR 60.486(g)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

105. The following information shall be recorded in a log that is kept in a readily accessible location: 1) Design criterion required in 40 CFR 60.482-2(d)(5) and 60.482-3(e)(2) and explanation of the design criterion; and 2) Any changes to this criterion and the reasons for the changes. [40 CFR 60.486(h)] Federally Enforceable Through Title V Permit
106. The following information shall be recorded in a log that is kept in a readily accessible location for use in determining exemptions as provided in 40 CFR 60.480(d): 1) An analysis demonstrating the design capacity of the affected facility; 2) A statement listing the feed or raw materials and products from the affected facilities and an analysis demonstrating whether these chemicals are heavy liquids or beverage alcohol; and 3) An analysis demonstrating that equipment is not in VOC service. [40 CFR 60.486(i)] Federally Enforceable Through Title V Permit
107. Information and data used to demonstrate that a piece of equipment is not in VOC service shall be recorded in a log that is kept in a readily accessible location. [40 CFR 60.486(j)] Federally Enforceable Through Title V Permit
108. The provisions of 40 CFR 60.7 (b) and (d) do not apply to affected facilities subject to Subpart GGG. [District 40 CFR 60.486(k)] Federally Enforceable Through Title V Permit
109. All semiannual reports to the Administrator shall include the following information, summarized from the information in 40 CFR 60.486: 1) Process unit identification; 2) For each month during the semiannual reporting period, i) Number of valves for which leaks were detected as described in 40 CFR 60.482-7(b) or 40 CFR 60.483-2, (ii) Number of valves for which leaks were not repaired as required in 40 CFR 60.482-7(d)(1), (iii) Number of pumps for which leaks were detected as described in 40 CFR 60.482-2(b) and (d)(6)(i), (iv) Number of pumps for which leaks were not repaired as required in 40 CFR 60.482-2(c)(1) and (d)(6)(ii), (v) Number of compressors for which leaks were detected as described in 40 CFR 60.482-3(f), (vi) Number of compressors for which leaks were not repaired as required in 40 CFR 60.482-3(g)(1), and (vii) The facts that explain each delay of repair and, where appropriate, why a process unit shutdown was technically infeasible; 3) Dates of process unit shutdowns which occurred within the semiannual reporting period; 4) Revisions to items reported in the semiannual report if changes have occurred since the initial report, as required in 40 CFR 60.487 (a) and (b), or subsequent revisions to the initial report. [40 CFR 60.487(c)] Federally Enforceable Through Title V Permit
110. An owner or operator electing to comply with the provisions of 40 CFR 60.483-1 and 60.483-2 shall notify the Administrator of the alternative standard selected 90 days before implementing either of the provisions. [40 CFR 60.487(d)] Federally Enforceable Through Title V Permit
111. An owner or operator shall report the results of all performance tests in accordance with 40 CFR 60.8 of the General Provisions. The provisions of 40 CFR 60.8(d) do not apply to affected facilities subject to the provisions of Subpart GGG except that an owner or operator must notify the Administrator of the schedule for the initial performance tests at least 30 days before the initial performance tests. [40 CFR 60.487(e)] Federally Enforceable Through Title V Permit
112. The semiannual reporting requirements of 40 CFR 60.487(a), (b), and (c) remain in force until and unless EPA, in delegating enforcement authority to a State under section 111(c) of the Act, approves reporting requirements or an alternative means of compliance surveillance adopted by such State. In that event, affected sources within the State will be relieved of the obligation to comply with the requirements of 40 CFR 60.487(a), (b), and (c), provided that they comply with the requirements established by the State. [40 CFR 60.487(f)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

113. Compressors are exempt from the standards of Subpart GGG if the owner or operator demonstrates that a compressor is in hydrogen service. Each compressor is presumed not to be in hydrogen service unless an owner or operator demonstrates that the piece of equipment is in hydrogen service. For a piece of equipment to be considered in hydrogen service, it must be determined that the percent hydrogen content can be reasonably expected always to exceed 50 percent by volume. For purposes of determining the percent hydrogen content in the process fluid that is contained in or contacts a compressor, procedures that conform to the general method described in ASTM E-260, E-168, or E-169 shall be used. An owner or operator may use engineering judgment demonstrate that the percent content exceeds 50 percent by volume, provided the engineering judgment demonstrates that the content clearly exceeds 50 percent by volume. When an owner or operator and the Administrator do not agree on whether a piece of equipment is in hydrogen service, however, the procedures that conform to the general method described in ASTM E-260, E-168, or E-169 shall be used to resolve the disagreement. If an owner or operator determines that a piece of equipment is in hydrogen service, the determination can be revised only after following the procedures that conform to the general method described in ASTM E-260, E-168, or E-169. [40 CFR 60.593(b)] Federally Enforceable Through Title V Permit
114. Any existing reciprocating compressor that becomes an affected facility under provisions of 40 CFR 60.14 or 40 CFR 60.15 is exempt from 40 CFR 60.482-3 (a), (b), (c), (d), (e), and (h) provided the owner or operator demonstrates that recasting the distance piece or replacing the compressor are the only options available to bring the compressor into compliance with the provisions of 40 CFR 60.482-3 (a), (b), (c), (d), (e), and (h). [40 CFR 60.593(c)] Federally Enforceable Through Title V Permit
115. An owner or operator may use the following provision in addition to 40 CFR 60.485(e): Equipment is in light liquid service if the percent evaporated is greater than 10 percent at 150 °C as determined by ASTM Method D86-78, 82, 90, 95, or 96. [40 CFR 60.593(d)] Federally Enforceable Through Title V Permit
116. Pumps in light liquid service and valves in gas/vapor and light liquid service within a procesic compounds of usually high molecular weight that consist of many repeated links, each link being a relatively light and simple molecule. [40 CFR 60.593(e)] Federally Enforceable Through Title V Permit
117. Equipment that is in vacuum service is excluded from the requirements of 40 CFR 60.482-2 to 40 CFR 60.482-10 if it is identified as required in 40 CFR 60.486(e)(5). [40 CFR 60.482-1(d)] Federally Enforceable Through Title V Permit
118. The operator shall not burn in any fuel gas combustion device any fuel that contains hydrogen sulfide (H₂S) in excess of 0.1 gr/dscf (230 mg/dscm) [40 CFR 60.104(a)(1)] Federally Enforceable Through Title V Permit
119. For fuel gas combustion devices, a continuous emissions monitoring system shall be installed, calibrated, operated, and reported according to EPA guidelines as specified under 40 CFR 60.105(a)(3). CEM results shall be calculated on a rolling three (3) hour basis. [40 CFR 60, 60.105(a)(3)] Federally Enforceable Through Title V Permit
120. For fuel gas combustion devices, operator shall report all rolling 3-hour periods during which the average concentration of H₂S as measured by the H₂S continuous monitoring system exceeds 0.10 gr/dscf (230 mg/dscm) or during which the average concentration of SO₂ as measured by the SO₂ continuous monitoring system exceeds 20 ppm (dry basis, zero percent excess air). [40 CFR 60.105(e)(3)] Federally Enforceable Through Title V Permit
121. Operator shall determine compliance with the H₂S standard using EPA Methods 11, 15, 15A, or 16. [40 CFR 60.106(e)] Federally Enforceable Through Title V Permit
122. For any periods for which sulfur dioxide or oxides emissions data are not available, the operator shall submit a signed statement indicating if any changes were made in operation of the emission control system during the period of data unavailability which could affect the ability of the system to meet the applicable emission limit. Operations of the control system and affected facility during periods of data unavailability are to be compared with operation of the control system and affected facility before and following the period of data unavailability. [40 CFR 60.107(d)] Federally Enforceable Through Title V Permit
123. The owner or operator shall submit the reports required under this subpart to the District semiannually for each six-month period. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. The owner or operator shall submit a signed statement certifying the accuracy and completeness of the information contained in the report. [40 CFR 60.107(e) and 60.107(f)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

124. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4455] Federally Enforceable Through Title V Permit
125. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4451 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
126. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4452 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
127. Compliance with permit conditions in the Title V permit shall be deemed compliance with 40 CFR 60 Subpart GGG. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.