

**MONTEREY BAY UNIFIED AIR POLLUTION CONTROL DISTRICT  
TITLE V OPERATING PERMIT TV65-01  
EVALUATION REPORT**

24580 Silver Cloud Court  
Monterey, CA 93940  
Telephone: (831) 647-9411

---

APPLICATION RECEIVED FROM:

Dynegy Moss Landing, LLC  
Moss Landing Power Plant  
P.O. Box 690  
Moss Landing, CA 95039-0690

PLANT SITE LOCATION:

Highway 1 and Dolan Road  
Moss Landing, CA 95039

APPLICATION PROCESSED BY:

Mike Sewell, Air Quality Engineer

---

APPROVED FOR RELEASE BY:

  
\_\_\_\_\_  
Gregory Chee  
Engineering Division Supervisor

NOV 14 2012  
\_\_\_\_\_  
Date

**MONTEREY BAY UNIFIED AIR POLLUTION CONTROL DISTRICT  
TITLE V OPERATING PERMIT TV65-01  
EVALUATION REPORT**

24580 Silver Cloud Court  
Monterey, CA 93940  
Telephone: (831) 647-9411

Dated: November 7, 2012

---

**APPLICATION RECEIVED FROM:**

Dynegy Moss Landing, LLC  
Moss Landing Power Plant  
P.O. Box 690  
Moss Landing, CA 95039-0690

**PLANT SITE LOCATION:**

Highway 1 and Dolan Road  
Moss Landing, CA 95039

**APPLICATION PROCESSED BY:**

Mike Sewell, Air Quality Engineer

---

ORIS Code: 0260

Nature of Business: Electric Power Generation

SIC Codes: 4911 - Electric Power Generation

**RESPONSIBLE OFFICIAL:**

Name: Peter J. Ziegler  
Title: Managing Director/Plant Manager  
Phone: (831) 633-6746

**ALTERNATIVE RESPONSIBLE OFFICIAL:**

Name: Rex A. Lewis  
Title: Production Superintendent  
Phone: (831) 633-6698

**FACILITY CONTACT PERSON:**

Name: Steve Abbott  
Title: Environmental Specialist  
Phone: (831) 633-6649

TABLE OF CONTENTS

|  |           |
|--|-----------|
| <b>PROJECT DESCRIPTION .....</b>   | <b>3</b>  |
| <b>FACILITY DESCRIPTION .....</b>  | <b>3</b>  |
| <b>EQUIPMENT DESCRIPTION.....</b>  | <b>3</b>  |
| <b>APPLICABLE FEDERAL REQUIREMENTS .....</b>                             | <b>6</b>  |
| <b>COMPLIANCE DETERMINATION FOR APPLICABLE FEDERAL REQUIREMENTS.....</b> | <b>7</b>  |
| <b>THE FOLLOWING WILL BE INCLUDED ON THE TITLE V PERMIT: .....</b>       | <b>13</b> |
| <b>FEDERALLY ENFORCEABLE EMISSION LIMITS AND STANDARDS.....</b>          | <b>14</b> |
| <b>TESTING REQUIREMENTS AND PROCEDURES.....</b>                          | <b>19</b> |
| <b>MONITORING AND RECORD KEEPING REQUIREMENTS.....</b>                   | <b>20</b> |
| <b>REPORTING REQUIREMENTS.....</b>                                       | <b>23</b> |
| <b>GENERAL CONDITIONS .....</b>  | <b>25</b> |
| <b>TITLE IV ACID RAIN PERMIT .....</b>                                   | <b>27</b> |

## **PROJECT DESCRIPTION**

The facilities' existing Title IV and Title V permit (TV45-02A) expires on December 31, 2012. This application is for renewal of these Permits on the required five-year renewal cycle.

## **FACILITY DESCRIPTION**

The Moss Landing Power Plant owned by Dynegy Moss Landing, LLC is an electric generating facility located in Moss Landing, California. The facility has a present net power production capacity of approximately 2,590 megawatts from two large boilers and two combined cycle gas turbine units. The two large boilers, Units 6 and 7 (Boilers 6-1 and 7-1) began operation in 1967 and 1968, respectively, and the two combined cycle gas turbine units had their first fires lit during the second quarter of 2002 and began commercial operation in the third quarter of 2002.

In addition to the boilers and the combined cycle gas turbine units, Dynegy Moss Landing, LLC operates ancillary equipment at the facility. This ancillary equipment will be included on the Title V permit for the facility.

Dynegy Moss Landing, LLC's facility is considered a federal Major Source and subject to the Title V permitting program due to the potential to emit Oxides of Nitrogen (NO<sub>x</sub>) and Carbon Monoxide (CO).

## **EQUIPMENT DESCRIPTION**

POWER GENERATION FACILITY CONSISTING OF:

TWO 765 MW UNITS - BOILERS NUMBER 6-1 AND 7-1 EACH CONSISTING OF:

Steam Generator, Babcock and Wilcox Company, Once-Through, Radiant, Reheat, Pressurized Furnace Type, Nominal 6500 MMBtu/hr, Natural Gas-Fired.

Combustion Control And Burner Management Provided By Foxboro Integrated Distributed Control System.

Steam Production Rate: Nominal 5,100,000 Lb/hr (At 1005° F And 3830 Psia)

Forced Draft Fans:

Two Forced Draft Fans, Howden Variax Variable Pitch Axial Flow Type ANT-2650/1200M, Each Powered By Teco Westinghouse 6,860 Hp Electric Motor.

Induced Draft Fans:

Two Induced Draft Fans, Howden Variax Variable Pitch Axial Flow Type ANN-3400/2000B, Each Powered By Teco Westinghouse 6,440 Hp Electric Motor.

Air Preheaters:

Two (2) Ljungstrom Regenerative Air Preheaters, Each With 334,800 Ft<sup>2</sup> Of Heating Surface And Equipped With Stainless Steel Intermediate And Cold-End Baskets.

Air Preheater Drain System And Stack Wash Collection System.

Burners And Overfire Air Ports:

Sixteen (16) Burner Cells Total, Eight (8) Front Wall, Eight (8) Back Wall.

Each Burner Cell Equipped With Three (3) Babcock & Wilcox S-Type Low NO<sub>x</sub> Burners, And Two (2) Ignitors.

Each S-Burner Equipped With Total Air Sliding Damper, Adjustable Spin Vanes, Core Air Sliding Disk, And Gas Spud Assembly.

Eight (8) Dual Zone Overfire Air Ports, Four (4) Front Wall, Four (4) Back Wall.

Gas Recirculation Fans:

Two (2) Flue Gas Recirculation Fans, Centrifugal Type, Each Rated At 252,000 CFM @ 12.5 Inches H<sub>2</sub>O Static Pressure.

Selective Catalytic Reduction (SCR) System:

Single Reactor Vessel With Associated Duct Work.

Catalyst, 169 M<sup>3</sup> Cormetech Type CM-37 Vanadium, Titanium, And Tungsten Oxide Honeycomb Catalyst, With The Ability To Add An Additional 84 M<sup>3</sup> If Necessary.

Ammonia Injection System, Two-Train Ammonia Flow Control System Providing Vaporized Aqueous Ammonia Via Flow Control Valves, Vaporizers, And Dilution Air Blowers To The Ammonia Injection Grid Located In The Economizer Outlet .

Continuous Emissions Monitoring System:

Two CiSCO Sample Acquisition Probes Located Approximately 120' Above Grade Inside The Stack.

Instrumentation Shelter, 8' x 10', Located At The Base Of The Stack., Shelter Houses Sample Transport And Conditioning Systems, And Analyzers.

Analyzers; Rosemount Model 951C Chemiluminescence Analyzer Measuring NO<sub>2</sub>; And Siemens Ultramat/Oxymat 6E Analyzer Measuring CO Via Non-Dispersive Infrared Measurement And O<sub>2</sub> Via Paramagnetic Measurement.

Data Acquisition System, VIM Technologies, Installed On An IBM Compatible Computer Located In The Energy Management Center.

Exhaust Stack:

500 Ft High Above Grade, 66 Ft O.D. At Base, 20 Ft O.D. At Top.

TWO 530 MW UNITS - COMBINED CYCLE UNITS 1 & 2 EACH CONSISTING OF:

Two Gas Turbine Generators, General Electric Frame 7, Model PG7241, Each Rated At 1,870 MMBtu/Hr Maximum Heat Input And 180 MW Nominal Electrical Output, With Dry Low-NO<sub>x</sub> Combuster.

Water Tube Type Heat Recovery Steam Generators (HRSG), Nominal Ratings: High Pressure Steam Capacity: 409,900 Lbs/Hr @ 1,903 psia And 1,047°F, Intermediate Pressure Steam Capacity: 484,500 Lbs/Hr @ 358 psia And 1,022°F, Low Pressure Steam Capacity: 55,300 Lbs/Hr @ 71 psia And 499°F.

Steam Turbine Generator And Condenser Serving Gas Turbine Units, Quadruple Admission, Triple Extraction, 196.8 MW Nominal Rated Electrical Output.

Selective Catalytic Reduction NO<sub>x</sub> Control Systems Located Within The HRSG.

Ammonia Injection Systems.

CEM Systems Designed To Continuously Record The Measured Gaseous Concentrations, And Calculate And Continuously Monitor And Record The NO<sub>x</sub> And CO Concentrations Corrected To Fifteen (15) Percent Oxygen (O<sub>2</sub>) On A Dry Basis.

AQUEOUS AMMONIA STORAGE TANKS

Aqueous Ammonia Storage Tank Farm Consisting Of 5 Storage Tanks Each With A Capacity Of 30,000 Gallons.

START-UP PACKAGE BOILER

One Self Contained Packaged Forced Draft Steam Boiler, With A Low NO<sub>x</sub> Burner Rated At 88.0 MMBtu/hr, Natural Gas Fired.

GASOLINE STORAGE TANK

One 1,000 Gallon Aboveground Gasoline Storage Tank With Dual Point Vapor Recovery And Submerged Fill Equipment.

ABRASIVE BLASTING EQUIPMENT

Abrasive Blasting Booth With Stationary Blast Equipment, Compressed Air Provided By Electric Compressor, And Portable Abrasive Blasting Equipment With Compressed Air Provided By Electric Or Diesel Fired Compressor.

#### PAINT SPRAY FACILITY

Outdoor Paint Spray Operations Authorized At Three Locations.

#### EMERGENCY GENERATOR

Caterpillar Engine Generator Set, 1502 BHp, 1,000 Kw Output.

#### EMERGENCY FIRE PUMPS

Caterpillar Engine Driven Fire Pump, 340 Bhp.

Two Cummins Engine Driven Fire Pumps, Each 370 BHp.

#### LABORATORY FUME HOODS

Fume Hoods, Located In Chemical Laboratory.

#### **APPLICABLE FEDERAL REQUIREMENTS**

- Rule 200 - Permits Required
- Rule 201 - Sources Not Requiring Permits
- Rule 207 - Review of New or Modified Sources
- Rule 213 - Continuous Emission Monitors
- Rule 214 - Breakdown Condition
- Rule 218 - Title V: Federal Operating Permits
- Rule 219 - Title IV: Acid Deposition Control
- Rule 300 - District Fees (Emission Statement - Section 4.4)
- Rule 308 - Title V: Federal Operating Permit Fees
- Rule 400 - Visible Emissions
- Rule 403 - Particulate Matter
- Rule 404 - Sulfur Compounds and Nitrogen Oxides
- Rule 412 - Sulfur Content of Fuels
- Rule 416 - Solvents
- Rule 418 - Transfer of Gasoline into Stationary Storage Containers
- Rule 426 - Architectural Coatings
- Rule 429 - Applications of Nonarchitectural Coatings
- Rule 431 - Emissions from Electric Power Boilers
- Rule 433 - Organic Solvent Cleaning

Rule 434 - Coating of Metal Parts and Products  
Rule 1002 - Transfer of Gasoline into Vehicle Fuel Tanks  
40 CFR Part 60, Subpart A - New Source Performance Standards, General Provisions  
40 CFR Part 60, Subpart Dc - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units  
40 CFR Part 60, Subpart GG - Standards of Performance for Stationary Gas Turbines  
40 CFR Part 61, Subpart M - National Emission Standard for Asbestos  
40 CFR Part 63, Subpart A - National Emission Standard for Hazardous Air Pollutants - General Provisions  
40 CFR Part 63, Subpart YYYY - National Emission Standard for Hazardous Air Pollutants from Combustion Turbines  
40 CFR Part 63, Subpart ZZZZ - National Emission Standard for Hazardous Air Pollutants from Reciprocating Internal Combustion Engines  
40 CFR Part 63, Subpart DDDDD - National Emission Standard for Hazardous Air Pollutants from Industrial, Commercial and Institutional Boilers and Process Heaters  
40 CFR Part 64 - Compliance Assurance Monitoring  
40 CFR Part 68 - Risk Management Planning: Accidental Release Prevention (Section 112r)  
40 CFR Part 82 - Protection of Stratospheric Ozone

## **COMPLIANCE DETERMINATION FOR APPLICABLE FEDERAL REQUIREMENTS**

### Rule 200 - Permits Required

This facility has historically complied with the requirements of this rule and continued compliance is expected.

### Rule 201 - Sources Not Requiring Permits

This rule identifies which equipment is exempt from District permitting requirements.

### Rule 207 - Review of New or Modified Sources

Boilers 6-1 and 7-1 predate this rule, and have not gone through NSR; however, the facility has undergone NSR review for the installation of new power generation equipment (Combined Cycle Gas Turbines) and has agreed to a facility cap for all power generation equipment at the facility. The Title V permit will include all conditions from the ATCs issued October 27, 2000 such that compliance with the emission limits established by this Rule will be continually monitored.

Local permitting of the ancillary equipment installed since the adoption of this rule has not triggered the NSR process. Therefore, no federally enforceable conditions will be imposed on the ancillary equipment by this rule.

### Rule 213 - Continuous Emissions Monitoring

This rule is applicable to Boilers 6-1 and 7-1 and the combined cycle gas turbines at the facility. Appropriate conditions will be included on the permit to ensure compliance with this rule.

Rule 214 - Breakdown Condition

This rule specifies conditions and procedures for breakdowns. A condition which incorporates these requirements will be included on the permit.

Rule 218 - Title V: Federal Operating Permits

This is the implementing regulation by which the District issues the federal Operating Permits. All requirements imposed by this rule will be included on the Title V permit.

Rule 219 - Title IV: Acid Deposition Control

This is the implementing regulation by which the District issues Acid Rain Permits and incorporates the requirements of 40 CFR Parts 72 and 75. All requirements imposed by this rule will be included on the Title IV permit which will be incorporated into the Title V permit.

Rule 300 (Emission Statement - Section 4.4)

Historically, the facility has been in compliance with the requirement to submit an *Emission Statement*. A condition will be included on the permit to ensure continued compliance.

Rule 308 - Title V: Federal Operating Permit Fees

This is the District's fee rule for Title V. Appropriate conditions will be included on the Title V permit to ensure compliance with the fee provisions contained in this rule.

Rule 400 - Visible Emissions

This rule is applicable to the emissions from the facility.

All of the power generation equipment (Boilers 6-1 and 7-1, and Combined Cycle Units 1 and 2) at the facility are fired on natural gas, therefore compliance with the opacity standard has historically been assumed. Opacity has been observed from the Gas Turbines on cold starts due to the configuration of their dry-low NO<sub>x</sub> combustors. However, this opacity is below the standard included in the August 15, 2012 revision to District Rule 400.

Appropriate conditions will be included on the permit to ensure compliance with the requirement of this rule.

Rule 403 - Particulate Matter

District Rule 403 specifically exempts stationary internal combustion engines from its requirements. Therefore, with the exception of IC engines, the 0.15 grains per dry cubic foot emission standard is applicable to all stationary fuel fired equipment at the facility.

Based upon the requirements of District Rule 403, the theoretical volumetric flow rate of 1,026,659 DSCFM  $[(7,048 \text{ MMBtu/hr}) / (60 \text{ min/hr}) * (\text{f factor for natural gas of } 8,740 \text{ DSCF/MMBtu}) = 1,026,659 \text{ DSCFM}]$  for Boilers 6-1 and 7-1 would establish an emission limit of 1320 lbs PM<sub>10</sub>/hr  $[(1,026,659 \text{ DSCFM}) * (0.15 \text{ grains/DSCF}) * (1 \text{ lb}/7000 \text{ grains}) * (60 \text{ M}/\text{Hr}) = 1,320 \text{ lbs PM}_{10}/\text{hr}]$  and each of the gas turbines would have an emission limit of 350 lbs PM<sub>10</sub>/hr based upon EPA's f-factor  $[(1,870 \text{ MMBtu/hr}) / (60 \text{ min/hr}) * (\text{f factor for natural gas of } 8,740 \text{ DSCF/MMBtu}) * (0.15 \text{ grains/DSCF}) * (1 \text{ lb}/7000 \text{ grains}) * (60 \text{ M}/\text{Hr}) = 350 \text{ lbs PM}_{10}/\text{hr}]$  and the startup

package boiler would have an emission limit of 15.4 lbs PM<sub>10</sub>/hr [(12,015 SDCFM)\* (0.15 grains/SDCF)\*(1 lb/7000 grains)\*(60 M/Hr) = 15.4 lbs PM<sub>10</sub>/hr].

Based upon AP-42 emissions factor (Table 1.4-2, dated 7/98), the particulate matter emissions from the Boilers 6-1 and 7-1 would be 52.5 lbs PM<sub>10</sub>/hr [(7,048 MMBtu/hr)\*(7.45E-3 lbs PM<sub>10</sub>/MMBtu) = 52.5 lbs PM<sub>10</sub>/hr] and the emissions from the startup Package Boiler would be 0.6 lbs PM<sub>10</sub>/hr [(76.9 MMBtu/hr)\*(7.45E-3 lbs PM<sub>10</sub>/MMBtu) = 0.6 lbs/hr]. Using the AP-42 emissions factor for gas turbines (Table 3.1-2a, dated 4/00), the particulate matter emissions from the gas turbines would be 12.3 lbs PM<sub>10</sub>/hr [(1,870 MMBtu/hr)\*(6.6E-3 lbs PM<sub>10</sub>/MMBtu) = 12.3 lbs PM<sub>10</sub>/hr].

These calculations based upon AP-42 emission factors show that this equipment would be unable to exceed the grain loading allowed by the rule. In addition, during the NSR permitting of the gas turbines, the NSR process established much more restrictive PM<sub>10</sub> emission limits on the boilers and the gas turbines - so the District Rule 403 0.15 grains/dscf limit could be considered subsumed under the NSR limits for the boilers and the gas turbine. Therefore, no testing will be required in the permit for the grain loading standard from this rule as compliance is assured from the above calculations.

Appropriate conditions will be included on the permit to ensure compliance with the requirements of this rule.

#### Rule 404 - Sulfur Compounds and Nitrogen Oxides

The Combined Cycle Gas Turbines are exempt from the emission limits of this rule due to the exemption contained in Section 1.3.2 based upon the imposition of BACT during the permitting process for the gas turbines, and Boilers 6-1 and 7-1 are exempt from the 225 ppm NO<sub>x</sub> limit contained in Section 3.1.3 based upon the exemption contained in Section 1.3.1 due to the fact that they are subject to the requirements of District Rule 431 (District Rule 431 limits Boilers 6-1 and 7-1 to a 10 ppm NO<sub>x</sub> limit).

Internal Combustion Sources (Diesel Engines) - Compliance with the 0.2% by volume (2000 ppmv) limit for SO<sub>2</sub> is assumed due to the following calculation based upon the AP-42 emission factor of 0.29 Lbs SO<sub>2</sub>/MMBtu heat input. Utilizing this emission factor and the F factor from EPA method 19, the SO<sub>2</sub> concentration for a diesel engine would equate to 186.6 ppmv [(0.29 Lbs SO<sub>2</sub>)\*(lbmoles SO<sub>2</sub>)/(64.1 lbs SO<sub>2</sub>)\*((379 Ft<sup>3</sup> Air)/(lbmole air))/(9,190 SDCF/MMBtu)\*(10<sup>6</sup>) = 186.6 ppmv] This value is well below the 2000 ppmv SO<sub>2</sub> allowed in this rule. Therefore, no monitoring/testing or record keeping will be included on the permit to show compliance with the SO<sub>2</sub> limit for the diesel fired engines.

Compliance with the NO<sub>x</sub> limit of 140 lb/hr from the diesel fired engines is assumed due to the following emission calculation based upon the AP-42 emission factors of 0.031 Lbs NO<sub>x</sub>/Hp-hr. An emission rate of 140 Lbs/hr would equate to an engine of 4516 Hp [(140 Lbs/hr)/(0.031 Lbs NO<sub>x</sub>/Hp-hr) = 4516 Hp]. The largest diesel engine at the facility is 1,505 Bhp, and is not capable of exceeding the 140 lb hour NO<sub>x</sub> limit. Therefore, no monitoring/testing or record keeping requirements will be included on the permit to show compliance with the 140 lb/hr NO<sub>x</sub> limit for the diesel fired engines.

Compliance with the 0.2% by volume (2000 ppmv) limit for SO<sub>2</sub> for external combustion of natural gas is assumed due to the following calculation based upon the AP-42 emission factor of 0.6 lbs SO<sub>2</sub>/MMCF combusted (Table 1.4-2 dated 7/98), which equates to 0.0006 lbs SO<sub>2</sub>/MMBtu heat input. Utilizing this emission factor and the F factor from EPA method 19, the SO<sub>2</sub> concentration for external combustion of natural gas would equate to 0.41 ppmv [(0.0006 lbs SO<sub>2</sub>/MMBtu)\*(lbmoles SO<sub>2</sub>)/(64.1 lbs SO<sub>2</sub>)\*((379 Ft<sup>3</sup> Air)/(lbmole air))/((8,710 SDCF/MMBtu))\*(10<sup>6</sup>) = 0.41 ppmv] This value is well below the 2000 ppmv SO<sub>2</sub> allowed in this rule. Therefore, no

monitoring/testing or record keeping will be included on the permit to show compliance with the SO<sub>2</sub> limit for the external combustion of natural gas.

The 140 pound per hour NO<sub>x</sub> limit for any new or expanded combustion unit is not applicable to Boilers 6-1 and 7-1 at the facility as Boilers 6-1 and 7-1 predate the rule and have not been expanded. Therefore, no NO<sub>x</sub> requirement(s) from this rule will be included on this permit.

Boilers 6-1 and 7-1 are not subject to the 140 lb/hr NO<sub>x</sub> limit because this equipment predates the rule and has not been "expanded". The Startup Package Boiler is assumed to be in compliance with the 140 lb/hr NO<sub>x</sub> limit based upon the following emission calculations. The NO<sub>x</sub> emissions from the Startup Package Boiler, based upon AP-42 factors (Table 1.4-1, dated 7/98), would be 7.5 lbs NO<sub>x</sub>/hr [(76.9 MMBtu/hr)\*(1 ft<sup>3</sup>/1020 Btu)\*(100 lbs/MMft<sup>3</sup> Natural Gas) = 7.5 lbs NO<sub>x</sub>/hr]. These calculated values are well below the 140 lb/hr limit contained in the rule.

#### Rule 412 - Sulfur Content of Fuels

This rule which requires that the sulfur content of fuels combusted be less than 50 grains per 100 cubic feet for gaseous fuel and less than 0.5% by weight for liquid or solid fuel is applicable to this facility. Presently, the only fuel source for power generation is PUC quality natural gas which assures compliance with the 50 grain limit.

Diesel fuel is utilized in the emergency generator and the some of the abrasive blasting compressors. The diesel fuel is assumed to be in compliance with the 0.5% sulfur content due to state law requirements on fuel sulfur content. Therefore, no testing will be required on the diesel fuel to show compliance with this rule requirement.

Appropriate conditions will be included on the permit to ensure compliance with the provisions of this rule.

#### Rule 416 - Solvents

This rule has specific emission limits and record keeping requirements for volatile organic compound (VOC) emissions. This rule applies to the paint spray operation at this facility. Historically, daily material usage records show that the facility has been operating below the 40 pound per day limit.

Appropriate conditions will be included on the permit to ensure compliance with the provisions of this rule.

#### Rule 418 - Transfer of Gasoline into Stationary Storage Containers

This rule requires that the gasoline storage tank have a submerged fill pipe and that Phase I Vapor recovery be utilized when filling the tank. The rule also requires specific record keeping regarding the quantity of fuel delivered to the facility. The facility is in compliance with the requirements of this rule.

Appropriate conditions will be included on the permit to ensure compliance with the requirements of this rule.

#### Rule 426 - Applications of Architectural Coatings

This rule is applicable to all applications of architectural coatings and limits the VOC content of these coatings. The facility is in compliance with the requirements of this rule.

An appropriate condition will be included on the permit to ensure compliance with the requirements of this rule.

Rule 429 - Applications of Nonarchitectural Coatings

This rule contains requirements on the application of nonarchitectural coatings, specifically that all coating operations be done in a complying enclosure unless specific rule criteria is met. During the permit issuance process for this equipment, it was determined that the enclosure met the rule requirements.

Therefore, the facility is in compliance with the requirements of this rule and no specific requirements will be included on the Title V permit.

Rule 431 - Emissions From Utility Power Boilers

This rule has provisions which apply to NO<sub>x</sub>, CO and NH<sub>3</sub> emissions from Boilers 6-1 and 7-1.

The rule contains a NO<sub>x</sub> limit of 10 ppm. The CO limit is set at 400 ppm based upon a 60-consecutive minute average and 1000 ppm based upon a one hour clock-hour average. The NH<sub>3</sub> limit (slip) from the installation of SCR is 10 ppm. Testing has shown both units to be in compliance with all these rule requirements. In addition, compliance has been, and will continue to be assured due to the required operation of CEMs with the data showing compliance at all times with the requirements of this rule.

The rule also contains additional NO<sub>x</sub> limits of 0.3 lbs/MMBtu heat input and an average of 9.64 tons/day during the period of May 1 through October 31 each year. These NO<sub>x</sub> limits are subsumed under the 10 ppm limit, as 10 ppm equates to 0.012 lbs/MMBtu and at full load both units will emit less than 2.1 tons in a 24 hour period.

Appropriate conditions will be included on the permit to ensure compliance with the existing and future provisions of this rule.

Rule 433 - Organic Solvent Cleaning

This rule contains specific operational and record keeping requirements for solvent cleaning and degreasing operations.

Appropriate conditions will be included on the permit to ensure compliance with the provisions of this rule.

Rule 434 - Coating of Metal Parts and Products

This rule contains specific VOC content limits for coatings used on *metal parts and products*.

Appropriate conditions will be included on the permit to ensure compliance with the provisions of this rule.

Rule 1002 - Transfer of Gasoline into Vehicle Fuel Tanks

This rule contains specific requirements for the installation and operation of ARB Certified Vapor Recover (Phase II) systems on gasoline dispensing facilities.

Appropriate conditions will be included on the permit to ensure compliance with the provisions of this rule.

40 CFR Part 60, Subpart A - New Source Performance Standards, General Provisions

This facility is subject to the requirements of 60.7 (notification and record keeping), 60.8 (performance tests), 60.11 (compliance with standards and maintenance requirements), and 60.13 (monitoring requirements) because the Startup Package Boiler is subject to Subpart Dc and the Gas Turbines are subject to Subpart GG.

The District asserts that compliance with the conditions on the Title V permit shall be considered compliance with the monitoring, record keeping, and reporting requirements contained in 40 CFR Parts 60.7, 60.8, 60.11, and 60.13.

40 CFR Part 60, Subpart Dc - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units

The startup package boiler at the facility is subject to the requirements of this part based upon the definition of a "steam generating unit". Although the boiler is subject to this part, no SO<sub>x</sub> and PM requirements are imposed due to the fact that the unit is fired exclusively on natural gas.

40 CFR Part 60, Subpart GG -Standards Of Performance For Stationary Gas Turbines

The Gas Turbines are subject to the requirements of this NSPS. In addition to utilizing good combustion practices and combusting only natural gas, the Gas Turbines utilize dry-low NO<sub>x</sub> combustors, and the back-end control of SCR to limit pollutant emissions.

The allowable NO<sub>x</sub> concentration limit derived from §60.332(a)(1) would be 141 ppmvd. This 141 ppmvd limit far exceeds the 2.5 ppmvd limit established by the BACT requirements of District Rule 207. Therefore, the NO<sub>x</sub> limit from the NSPS will be subsumed under the NSR permit requirements that will be included on the permits.

The allowable SO<sub>2</sub> concentration limit derived from §60.333 would be 150 ppmv. Compliance with this limit is assured due to limits established by the BACT requirements of Rule 207 contained in the permits of 1.3 lbs/hr for each Gas Turbine. The SO<sub>2</sub> concentration at this permitted emission level would be 0.5 ppmv for the turbine  $[(1.3 \text{ lbs SO}_2/\text{hr}) * ((\text{lbmoles SO}_2) / (64.1 \text{ lbsSO}_2)) * ((379 \text{ Ft}^3 \text{ Air}) / (\text{lbmole air})) / ((272,396 \text{ SDCFM}) * (60 \text{ M/Hr})) * (10^6)] = 0.5 \text{ ppmv}$ . This value is well below the 150 ppmv SO<sub>2</sub> allowed for in the NSPS. Therefore, the SO<sub>2</sub> emission standard from this NSPS will be subsumed under the NSR permit requirement that will be included on the permits.

The testing and monitoring requirements contained in §§60.334 and 60.335 will be subsumed under the testing and monitoring requirements established under the NSR conditions contained on the permits. This will include the annual emissions testing requirement and the requirement to monitor operations with the use of CEMs.

40 CFR Part 61, Subpart A -General Provisions

The facility is subject to the requirements of this part because the facility is subject to 40 CFR Part 61, Subpart M. Historically, the facility has been in compliance with these requirements and continued compliance is expected.

40 CFR Part 61, Subpart M - National Emission Standard for Asbestos

This facility on an as needed basis is subject to Section 61.145 through 61.147 - standards for the demolition and renovation of asbestos. Historically, the facility has been in compliance with the requirements of these standards. An appropriate condition will be included on the permit to ensure compliance with these requirements.

40 CFR Part 63, Subpart A - National Emission Standard for Hazardous Air Pollutants - General Provisions

The facility is not subject to the requirements of this part as the facility is not a major source for hazardous air pollutant emissions.

40 CFR Part 63, Subpart YYYYY - National Emission Standard for Hazardous Air Pollutants from Combustion Turbines

The facility is not subject to the requirements of this part as the facility is not a major source for hazardous air pollutant emissions.

40 CFR Part 63, Subpart ZZZZ - National Emission Standard for Hazardous Air Pollutants from Reciprocating Internal Combustion Engines

The facility is not subject to the requirements of this part as the facility is not a major source for hazardous air pollutant emissions.

40 CFR Part 63, Subpart DDDDD - National Emission Standard for Hazardous Air Pollutants from Industrial, Commercial and Institutional Boilers and Process Heaters

The facility is not subject to the requirements of this part as the facility is not a major source for hazardous air pollutant emissions..

40 CFR Part 64 - Compliance Assurance Monitoring (CAM)

Boilers 6-1 and 7-1 and the four combustion turbine are each equipped with selective catalytic reduction (SCR) systems for the reduction of emission of oxides of nitrogen (NO<sub>x</sub>). As each of these units have pre-control potential to emit greater than the major source threshold, each of these units are subject to CAM.

However, each of these boilers and gas turbines are equipped with a continuous emissions monitoring system (CEMS). Therefore, Duke Energy has proposed no additional CAM monitoring as the CEMS satisfy the requirements for 40 CFR Part 64 as stated in part 64.3(d).

40 CFR Part 68 - Risk Management Planning: Accidental Release Prevention (Section 112r)

The facility is subject to the requirements of this part. The facility has submitted an RMP to EPA which was deemed completed by EPA on January 27, 2009. The facility will be required to submit a revised and updated RMP by January 23, 2014 as required by 40 CFR §68.190. An appropriate condition will be included on the permit to ensure compliance with these requirements.

40 CFR Part 82 - Protection of Stratospheric Ozone

This facility is in compliance with the requirements of this part. An appropriate condition will be included on the permit to ensure compliance with these requirements.

**THE FOLLOWING WILL BE INCLUDED ON THE TITLE V PERMIT:**

**FEDERALLY ENFORCEABLE EMISSION LIMITS AND STANDARDS**

1. The heat input rate to each Boiler (6-1 and 7-1) shall not exceed 7,048 MMBtu/hr. [District Rule 207]
2. The heat input rate to each Gas Turbine shall not exceed 1,870 MMBtu/hr. [District Rule 207]
3. The pollutant mass emission rates in the exhaust discharged to the atmosphere from each Boiler (6-1 and 7-1) shall not exceed the following limits [District Rule 207, District Rule 431 limits of 0.3 lbs NO<sub>x</sub>/MMBtu and 9.64 tons NO<sub>x</sub>/day when averaged over the May 1 through October 31 annually.]:

| <u>Pollutant</u>                                   | <u>Lbs/Hour</u> | <u>Lbs/Day</u> |
|--|-----------------|----------------|
| Oxides of Nitrogen (NO <sub>x</sub> )              | 85.6            | 2,054.4        |
| Carbon Monoxide (CO)                               | 862.7           | 20,704.8       |
| Particulate Matter <10 microns (PM <sub>10</sub> ) | 52.5            | 1,260.0        |
| Volatile Organic Compounds (VOC)                   | 38.0            | 912.0          |
| Ammonia (NH <sub>3</sub> )                         | 31.6            | 758.4          |
| Sulfur Dioxide (SO <sub>2</sub> )                  | 4.9             | 117.6          |

4. The maximum daily combined emissions from the Gas Turbines, including start-ups and shutdowns and combustor tuning periods, shall not exceed the following limits [District Rule 207]:

| <u>Pollutant</u>                                   | <u>Lbs/Day</u> |
|--|----------------|
| Oxides of Nitrogen (NO <sub>x</sub> )              | 2,589.4        |
| Carbon Monoxide (CO)                               | 17,301.8       |
| Particulate Matter <10 microns (PM <sub>10</sub> ) | 864.0          |
| Volatile Organic Compounds (VOC)                   | 620.0          |
| Ammonia (NH <sub>3</sub> )                         | 1,224.0        |
| Sulfur Dioxide (SO <sub>2</sub> )                  | 124.8          |

5. The pollutant mass emission rates in the exhaust discharged to the atmosphere from each Gas Turbine shall not exceed the following limits [District Rule 207]:

| <u>Pollutant</u>                                   | <u>Lbs/Hour</u> | <u>Lbs/Day</u> |
|--|-----------------|----------------|
| Oxides of Nitrogen (NO <sub>x</sub> )              | 17.23           | 413.5          |
| Carbon Monoxide (CO)                               | 37.76           | 906.2          |
| Particulate Matter <10 microns (PM <sub>10</sub> ) | 9.00            | 216.0          |
| Volatile Organic Compounds (VOC)                   | 4.79            | 115.0          |
| Ammonia (NH <sub>3</sub> )                         | 12.75           | 306.0          |
| Sulfur Dioxide (SO <sub>2</sub> )                  | 1.30            | 31.2           |

These limits shall not apply during start-up or shutdown, which is not to exceed two (2) hours, or during steam turbine cold start-up or combustor tuning or energy regulatory agency required performance testing, which are not to exceed six (6) hours. SCR catalytic controls and good engineering practices shall be used to the fullest extent practical during start-up and shutdown to minimize pollutant emissions.

Steam turbine cold start-up periods are start-up periods that follow a shutdown of the steam turbine for at least 72 hours. Combustor tuning activities include all testing, adjustment, tuning, and calibration activities recommended by the gas turbine manufacturer to insure safe and reliable steady state operation of the gas turbine following replacement of the combustor. This includes, but is not limited to, adjusting the amount of fuel distributed between the combustion turbine's staged fuel system to simultaneously minimize NO<sub>x</sub>, CO, and VOC production while ensuring combustor stability. Energy regulatory agency required performance testing includes, but is not limited to load ramp rate performance verification, generating system stability testing, emergency response testing or emergency blackout recovery. Energy regulatory agencies include Federal, Regional or State agencies.

6. The pollutant concentrations discharged to the atmosphere from each Gas Turbine shall not exceed the following limits, calculated at 15 percent O<sub>2</sub> [District Rule 207]:

| <u>Pollutant</u>                         | <u>Concentration (ppm)</u>       |
|--|----------------------------------|
| Oxides of Nitrogen (as NO <sub>2</sub> ) | 2.5 (clock hour average)         |
| Carbon Monoxide (CO)                     | 9.0 (rolling three-hour average) |
| Ammonia (NH <sub>3</sub> )               | 5.0 (3-60 minute averages)       |

These limits shall not apply during start-up or shutdown, which is not to exceed two (2) hours, or during steam turbine cold start-up or combustor tuning, which is not to exceed six (6) hours. SCR catalytic controls and good engineering practices shall be used to the fullest extent practical during start-up, shutdown and combustor tuning to minimize pollutant emissions.

7. The pollutant emission rates discharged to atmosphere from each Gas Turbine during a start-up, shutdown or combustor tuning activities shall not exceed the following limits. These limits apply to any start-up or shutdown period which shall not exceed two (2) hours, and to any steam turbine cold start-up or combustor tuning, which shall not exceed six (6) hours. [District Rule 207]

| <u>Pollutant</u>                                 | <u>Lbs/Start-Up</u> | <u>Lbs/Cold Start-up or<br/>Combustor Tuning</u> | <u>Lbs/Shutdown</u> |
|--|---------------------|--|---------------------|
| Oxides of Nitrogen (as NO <sub>2</sub> )         | 320.0               | 480.0  | 160.0               |
| Carbon Monoxide (CO)                             | 3,608.0             | 5,412.0  | 1,804.0             |
| Volatile Organic Compounds (as CH <sub>4</sub> ) | 64.0                | 214.0  | 32.0                |

8. Exceedance of the hourly NO<sub>x</sub> emission limits specified in condition numbers 5 and 6 is allowed during short-term excursions which total less than 10 hours per rolling 12-month period. [District Rule 207]

Short-term excursions are defined as 15-minute periods designated by Dynergy Moss Landing, LLC that are a direct result of a diffusion mode switchover, not to exceed four consecutive 15-minute periods, when the 15-minute average NO<sub>x</sub> concentration exceeds 2.5 ppm corrected to 15% O<sub>2</sub>.

The maximum 1-hour average NO<sub>x</sub> concentration for periods that include short-term excursions shall not exceed 30 ppmvd corrected to 15% O<sub>2</sub>. All emissions during short-term excursions shall be included in all calculations of daily, quarterly, and annual mass emissions required by this permit.

9. The emissions concentration of oxides of nitrogen, as NO<sub>2</sub>, discharged to atmosphere from the Start-up

Package Boiler shall not exceed 25 ppmv dry, calculated at 3% O<sub>2</sub>. [District Rule 207]

10. The Start-up Package Boiler shall only be fired on natural gas, and shall be operated less than 876 hours per year. [District Rule 207 & 40 CFR Part 60, Subpart Db]
11. Cumulative emissions, including emissions generated during Start-ups, Shutdowns and Combustor Tuning Activities, from all power generation equipment and the start-up package boiler at the Moss Landing Power Plant shall not exceed the following quarterly limits [District Rule 207]:

| Pollutant                             | Pounds Of Emissions Per Calendar Quarter |           |           |           |
|---------------------------------------|--|-----------|-----------|-----------|
|                                       | First                                    | Second    | Third     | Fourth    |
| NO <sub>x</sub> (as NO <sub>2</sub> ) | 286,778                                  | 285,301   | 409,492   | 336,584   |
| SO <sub>x</sub>                       | 23,823                                   | 24,567    | 32,613    | 29,468    |
| VOC                                   | 144,537                                  | 150,294   | 212,540   | 188,206   |
| PM <sub>10</sub>                      | 213,533                                  | 221,488   | 307,505   | 273,879   |
| CO                                    | 2,929,068                                | 3,059,753 | 4,472,774 | 3,920,385 |

12. No more than one of the Gas Turbines shall be operated in support of a steam turbine cold start-up or undergo combustor tuning at any one time. [District Rule 207]
13. The total number of hours during which each Gas Turbine may be operated to support a steam turbine cold start-up or may undergo combustor tuning shall not exceed 30 hours per year. [District Rule 207]
14. Boiler 6-1, Boiler 7-1, and the Gas Turbines shall be abated by properly operated and maintained Selective Catalytic Reduction Systems. [District Rule 207]
15. Boiler and stack inspection and cleaning shall be conducted during Boiler 6-1 and 7-1 outages of 21 days or more. [District Rule 207]
16. Dynergy Moss Landing, LLC shall hold Sulfur Dioxide Allowances not less than the total annual emissions of sulfur dioxide for the previous calendar year from Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A) . [District Rule 219]
17. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three (3) minutes in any one (1) hour which is as dark or darker than Ringelmann 1, or equivalent 20%

opacity. [District Rule 400 Adopted 8/15/12]

This limit shall not apply to the gas turbines during start-up, which is not to exceed two (2) hours. Good engineering practices shall be used to the fullest extent practical during start-up to minimize pollutant emissions.

18. During periods of gas turbine start-up, which is not to exceed two (2) hours, no air contaminant shall be discharged into the atmosphere from the gas turbines for a period or periods aggregating more than three (3) minutes in any one (1) hour which is as dark or darker than Ringelmann 2, or equivalent 40% opacity. [District Rule 400 Adopted 8/15/12]
19. Particulate matter shall not exceed 0.15 grains per standard dry cubic foot in any exhaust stream, except stationary internal combustion engines. [District Rule 403]
20. Sulfur compounds calculated as sulfur dioxide (SO<sub>2</sub>) shall not exceed 0.2 percent by volume in any exhaust stream. [District Rule 404]
21. Oxides of Nitrogen, calculated as nitrogen dioxide (NO<sub>2</sub>), from the Start-up Package Boiler or the Emergency Generator shall not exceed 140 lbs/hr. [District Rule 404]
22. The sulfur content on any gaseous fuel used at the facility shall not contain sulfur compounds, calculated as hydrogen sulfide at standard conditions, in excess of 50 grains per 100 cubic feet. [District Rule 412]
23. The sulfur content on any fuel oil used at the facility shall not exceed 0.5 percent by weight. [District Rule 412]
24. No more than 40 pounds per day of Volatile Organic Compounds shall be discharged from any permit unit using or applying any solvent. [District Rule 416 Adopted 1/17/01]
25. Dynergy Moss Landing, LLC shall operate the Gasoline Storage Tank with a permanent submerged fill pipe and a Phase I vapor recovery system which has been certified by the California Air Resources Board. [District Rule 418]
26. Dynergy Moss Landing, LLC shall operate a Phase II vapor recovery system on the dispenser served by the Gasoline Storage Tank which has been certified by the Air Resources Board. [District Rule 1002]
27. Dynergy Moss Landing, LLC shall limit emissions of volatile organic compounds by the use of architectural coatings which comply with the requirements of District Rule 426. [District Rule 426]

28. The emission concentration of oxides of nitrogen, as NO<sub>2</sub>, from Boilers 6-1 and 7-1 shall not exceed 10 ppm during operation on natural gas. This limit is based on a one (1) hour average at three (3) percent oxygen (O<sub>2</sub>) on a dry basis. [District Rule 431]
29. The NH<sub>3</sub> emission concentration from any emissions control device installed and operated pursuant to the requirements of District Rule 431 shall not exceed 10 ppm, based upon the average of three 60-consecutive minute averages at three (3) percent oxygen (O<sub>2</sub>) on a dry basis. [District Rule 431]
30. The CO emission concentration from Boilers 6-1 and 7-1 shall not exceed 400 ppm during steady-state compliance tests based upon a 60-consecutive minute average and shall not exceed 1000 ppm during normal operations based upon a one (1) hour clock-hour average at three (3) percent oxygen (O<sub>2</sub>) on a dry basis. [District Rule 431]
31. The limits contained in condition numbers 3, 28, 29, and 30 shall not apply during start-up, the time period during which the boiler has no fires in it, until the unit that it serves has reached minimum operating load, the catalytic reaction temperature and main breaker closure, or shutdown, the time period during which a unit is reduced below minimum load or catalytic reduction temperature, to a condition where the fires in the boiler are extinguished, not to exceed eight (8) hours. SCR catalytic controls and good engineering practices shall be used to the fullest extent practical during start-up to minimize pollutant emissions. [District Rule 431]
32. Dynergy Moss Landing, LLC shall limit emissions of volatile organic compounds during solvent cleaning and degreasing operations pursuant to the requirements of District Rule 433. [District Rule 433]
33. If total combined usage of coatings applied to metal parts and products, as defined by District Rule 434, equals or exceeds 55 gallons per year, each coating used for metal parts and products must not exceed the following volatile organic compound content limits: [District Rule 434]

| <u>Coating Category</u>  | <u>VOC Content Limit, as Applied</u> |                |
|--------------------------|--------------------------------------|----------------|
|                          | <u>grams/liter</u>                   | <u>lbs/gal</u> |
| Pretreatment Wash Primer | 780                                  | 6.5            |
| All Other Coatings       | 420                                  | 3.5            |

34. Dynergy Moss Landing, LLC shall comply with the requirements of Sections 61.145 through 61.147 of the National Emission Standard for Asbestos for all demolition and renovation projects. [40 CFR Part 61, Subpart M]
35. Dynergy Moss Landing, LLC shall comply with the requirements of 40 CFR Part 68 - Risk Management Plans. Dynergy Moss Landing, LLC's Risk Management Plan must be revised and updated by January 23, 2014 as required by 40 CFR §68.190. Dynergy Moss Landing, LLC shall certify compliance with these requirements as part of the annual compliance certification required by 40 CFR Part 70 and this permit. [40 CFR Part 68]

36. Dynegy Moss Landing, LLC shall comply with the requirements of 40 CFR Part 82 - Protection of Stratospheric Ozone [40 CFR Part 82]

#### TESTING REQUIREMENTS AND PROCEDURES

37. Annual performance tests of Boilers 6-1 and 7-1 and the Gas Turbines shall be conducted in accordance with the Monterey Bay Unified Air Pollution Control District test procedures, and the written results of the performance tests shall be provided to the District within thirty (30) days after testing. A testing protocol shall be submitted to the District no later than thirty (30) days prior to the testing, and notification to the District at least ten (10) days prior to the actual date of testing shall be provided so that a District observer may be present. Changes to the test date made subsequent to the initial ten day notification may be communicated by telephone or other acceptable means no less than forty-eight (48) hours prior to the new test date. [District Rules 207 & 218]
38. No testing is specified for the generic (District Rule 400) opacity requirement from condition numbers 17 or 18. The equipment is assumed to be in compliance with the opacity requirement due to historical operations and local compliance inspections without opacity violations. If testing is conducted for condition numbers 17 or 18, Dynegy Moss Landing, LLC should conduct testing in accordance with the methodology contained in EPA Method 9 or equivalent method and the averaging/aggregating period contained in District Rule 400. [District Rule 218]
39. No testing is specified for the (District Rule 403) particulate matter emission standard from condition number 19. The fuel burning equipment is assumed to be in compliance with the particulate matter emission standard based upon the engineering calculations contained in the evaluation report. If testing is conducted for condition number 19, Dynegy Moss Landing, LLC should conduct testing in accordance with the methodology contained in EPA Method 5 or equivalent method. [District Rule 218]
40. No testing is specified for the (District Rule 404) sulfur concentration limit in condition number 20. The fuel burning equipment is assumed to be in compliance with this sulfur concentration limit based upon the engineering calculations contained in the evaluation report. If testing is conducted for condition number 20, Dynegy Moss Landing, LLC should conduct testing in accordance with the methodology contained in EPA Method 6 or equivalent method. [District Rule 218]
41. No testing is specified for the (District Rule 404) NO<sub>x</sub> (oxides of nitrogen) limit in condition number 21. The fuel burning equipment is assumed to be in compliance with these NO<sub>x</sub> limits based upon the engineering calculations contained in the evaluation report. If testing is conducted for condition number 21, Dynegy Moss Landing, LLC should conduct testing in accordance with the methodology contained in EPA Method 7E or equivalent method. [District Rule 218]
42. Dynegy Moss Landing, LLC shall cause testing to be performed to verify compliance with the Ammonia (NH<sub>3</sub>) slip limits established in condition numbers 6 and 29 as follows:

- a) Boiler testing shall be performed at the frequency as required by 40 CFR Part 75 for relative accuracy test audits (RATA); and
- b) Gas turbine testing shall be performed every EPA operating quarter, as defined in 40 CFR Part 72, or in the next EPA operating quarter if a gas turbine cannot be tested in an EPA operating quarter due to the unit being non-operational at the time of scheduled testing.

Dynergy Moss Landing, LLC shall conduct this testing in accordance with the collection method specified in BAAQMD Source Test Procedure ST-1B and the analysis specified in EPA method 350.3. [District Rules 207, 218, & 431]

- 43. No testing is specified for the (District Rule 431) normal operation CO limit contained in condition number 30. Continuing compliance with these limits will be assured by the continuous emission monitoring (CEM) system. Compliance with the steady state limit will be verified by the testing required by condition number 37. [District Rules 207 & 218]

#### **MONITORING AND RECORD KEEPING REQUIREMENTS**

- 44. CEM Systems shall be installed and operated on Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A). These systems shall be designed to continuously record the measured gaseous concentrations, and calculate and continuously monitor and record the CO, O<sub>2</sub>, and NO<sub>x</sub> concentrations corrected to three (3) percent oxygen (O<sub>2</sub>) for the Boilers and fifteen (15) percent oxygen (O<sub>2</sub>) for the Gas Turbines on a dry basis. [District Rules 207, 213 & 219, 40 CFR Part 64]
- 45. The equipment installed on Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A) for the continuous monitoring of CO<sub>2</sub> or O<sub>2</sub> and NO<sub>x</sub> shall be maintained and operated in accordance with 40 CFR Parts 72 and 75. [District Rule 219]
- 46. The equipment for the continuous monitoring of CO on Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A) shall be maintained and operated in accordance with 40 CFR Part 60 Appendix F and with the ability to calculate CO emission concentrations corrected to three (3) percent oxygen for the Boilers and fifteen (15) percent oxygen for the Turbines on a dry basis. [District Rule 431]

For periods of missing CO data, CO hourly values shall be substituted from valid hourly average data from the previous thirty (30) unit operating days, excluding periods of start-up, shutdown and combustor tuning. The CO data shall be substituted based on equivalent incremental load ranges.

- 47. A written Quality Assurance program for Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A) CEMs must be established in accordance with 40 CFR Part 75, Appendix B for NO<sub>x</sub> and 40 CFR Part 60, Appendix F for CO which includes, but is not limited to:

procedures for daily calibration testing, quarterly linearity and leak testing, record keeping and reporting implementation, and relative accuracy testing. [District Rule 219]

48. Dynergy Moss Landing, LLC shall demonstrate compliance by using properly operated and maintained continuous emission monitors (during all hours of operation including equipment Start-up and Shutdown periods and Combustor Tuning Activities, except for periods of CEM maintenance performed in accordance with District requirements) for all of the following parameters [District Rules 207 and 431]:

- a) Firing hours and Fuel Flow Rates.
- b) Oxygen (O<sub>2</sub>) Concentrations, Nitrogen Oxide (NO<sub>x</sub>) Concentrations, and Carbon Monoxide (CO) Concentrations.
- c) Ammonia Injection Rates.

Dynergy Moss Landing, LLC shall record all of the above parameters every 15 minutes (excluding normal calibration periods) and shall summarize all of the above parameters for each clock hour. For each calendar day, Dynergy Moss Landing, LLC shall calculate and record the total Firing Hours, the average hourly Fuel Flow Rates, and pollutant emission concentrations.

Dynergy Moss Landing, LLC shall use the parameters measured above and District-approved calculation methods to calculate the following parameters:

- d) Heat Input Rate.
- e) Corrected NO<sub>x</sub> concentrations, NO<sub>x</sub> mass emissions (as NO<sub>2</sub>), corrected CO concentrations, and CO mass emissions.

For each source, Dynergy Moss Landing, LLC shall record the parameters specified in d) and e) of this Condition every 15 minutes (excluding normal calibration periods). As specified below, Dynergy Moss Landing, LLC shall calculate and record the following data:

- f) Total Heat Input Rate for every clock hour.
- g) The NO<sub>x</sub> mass emissions (as NO<sub>2</sub>), and corrected average NO<sub>x</sub> emission concentration for every clock hour.
- h) The CO mass emissions, and corrected average CO emission concentration for every clock hour.
- i) On an hourly basis, the cumulative total NO<sub>x</sub> mass emission (as NO<sub>2</sub>) and the cumulative total CO mass emissions.
- j) For each calendar day, the cumulative total NO<sub>x</sub> mass emission (as NO<sub>2</sub>) and the cumulative total CO mass emissions.
- k) For each calendar quarter, the cumulative total NO<sub>x</sub> mass emission (as NO<sub>2</sub>) and the cumulative total CO mass emissions.
- l) For each calendar year, the cumulative total NO<sub>x</sub> mass emission (as NO<sub>2</sub>) and the cumulative total CO mass emissions.

49. Dynergy Moss Landing, LLC shall calculate and record on a daily basis, the Volatile Organic Compound (VOC) mass emissions, Fine Particulate Matter (PM<sub>10</sub>) mass emissions, Sulfur Dioxide (SO<sub>2</sub>) mass emissions, and Ammonia (NH<sub>3</sub>) mass emissions from each power generating source. Dynergy Moss Landing, LLC shall use the actual heat input rates, actual Start-up times, actual Shutdown times, actual Combustor Tuning times and District-approved emission factors to calculate these emissions. The calculated emissions shall be presented as follows [District Rule 207]:

- a) For each calendar day, VOC, PM<sub>10</sub>, SO<sub>2</sub>, and NH<sub>3</sub> mass emissions shall be summarized for each source.
  - b) On a daily basis, the cumulative total VOC, PM<sub>10</sub>, SO<sub>2</sub> and NH<sub>3</sub> mass emissions shall be summarized for each calendar quarter and for the calendar year.
50. To demonstrate compliance with condition number 13, Dynergy Moss Landing, LLC shall record the start time, end time and duration of each steam turbine cold start-up and each combustor tuning period. This information shall be compiled and supplied to the District in the semiannual monitoring report as specified in Condition 62. [District Rule 207]
51. Instrumentation must be operated to measure the SCR catalyst inlet temperature and pressure differential across the SCR catalyst. [District Rule 207]
52. Dynergy Moss Landing, LLC shall monitor SO<sub>2</sub> emissions from Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A) in accordance with 40 CFR Part 72 and 75. [District Rule 219]
53. Dynergy Moss Landing, LLC shall maintain daily records to document compliance with condition number 24. [District Rule 416 Adopted 4/20/94]
54. Dynergy Moss Landing, LLC shall maintain records showing the quantity of all gasoline delivered to the gasoline storage tank. [District Rule 418]
55. As applicable Dynergy Moss Landing, LLC shall maintain the following general records of required monitoring information [District Rule 218]:
- a) the date and time of sampling or measurements;
  - b) the date(s) analyses were performed;
  - c) the company or entity that performed the analyses;
  - d) the analytical techniques or methods used;
  - e) the results of such analyses;
  - f) the operating conditions existing at the time of sampling or measurement; and
  - g) the records of quality assurance for continuous monitoring systems (including, but not limited to quality control activities, audits, and calibration drift checks) and source testing methods.
56. Dynergy Moss Landing, LLC shall maintain records on the occurrence and duration of any start-up, shutdown, or malfunction in the operation of any CEM. [District Rule 213]
57. Dynergy Moss Landing, LLC shall retain records of all required monitoring data and support information for

a period of at least five (5) years from the date of the monitoring, sample collection, measurement, report, and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. [District Rule 218]

## REPORTING REQUIREMENTS

58. Dynergy Moss Landing, LLC shall submit monthly reports on the continuous emissions monitoring systems to the District, in a District approved format, within 30 days from the end of the month and these shall include [District Rules 207, 213, & 218] :
- a) the time intervals, date and magnitude of excess emissions, nature and cause of the excess (if known), corrective actions and preventative measures adopted; and
  - b) the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant in question; and
  - c) time and date of each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of system repairs and adjustments; and
  - d) a negative declaration specifying when no excess emissions occurred; and
  - e) a summary of actual monthly emissions from the CEM for all equipment which operated during the month.
59. Dynergy Moss Landing, LLC shall report all breakdowns which results in the inability to comply with any emission standard or requirement contained on this permit to the Air Pollution Control Officer (APCO) within 1 hour of the occurrence; this one hour period may be extended up to six hours for good cause by the APCO. The APCO may elect to take no enforcement action if Dynergy Moss Landing, LLC demonstrates to the APCO's satisfaction that a breakdown condition exists.

The estimated time for repair of the breakdown shall be supplied to the APCO within 24 hours of the occurrence and a written report shall be supplied to the APCO with 5 days after the occurrence has been corrected. This report shall include at a minimum [District Rule 214]:

- a) a statement that the condition or failure has been corrected and the date of correction; and
- b) a description of the reasons for the occurrence; and
- c) a description of the corrective measures undertaken and/or to be undertaken to avoid such an occurrence in the future; and
- d) an estimate of the emissions caused by the condition or failure.

60. If combined annual emissions from the entire facility are greater than 25 tons of either NO<sub>x</sub> or VOC, Dynegy Moss Landing, LLC shall submit an Emission Statement for each Permit to Operate and Authority to Construct in accordance with the mandatory provisions of Section 182(a)(3)(B)(ii) of the federal Clean Air Act. [District Rule 300, Section 4.4]
61. Dynegy Moss Landing, LLC shall submit quarterly Electronic Data Reports (EDR) to EPA for Boilers 6-1 and 7-1 and Combined Cycle Units 1 (Gas Turbines 1A & 2A) and 2 (Gas Turbines 3A & 4A). These reports must be submitted within 30 days following the end of each calendar quarter and shall include all information required in §75.64. [40 CFR Part 75]
62. Dynegy Moss Landing, LLC shall submit semiannual monitoring reports to the District, in a District approved format, no later than August 15 for the period of January 1 through June 30 and no later than February 15 for the period of July 1 through December 31. [District Rule 218]

These monitoring reports shall include at a minimum:

- a) the time intervals, date and magnitude of excess emissions, nature and cause of the excess (if known), corrective actions and preventative measures adopted; and
  - b) the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant in question; and
  - c) all information pertaining to any monitoring as required by this permit; and
  - d) a negative declaration specifying when no excess emissions occurred.
63. Dynegy Moss Landing, LLC shall submit an annual compliance certification report to the District and EPA, in a District approved format, no later than February 15 for the period of January 1 through December 31 of the preceding year. [District Rule 218]

This report shall include a written statement from the responsible official which certifies the truth, accuracy, and completeness of the report and shall include at a minimum:

- a) identification of each term or condition of the permit that is the basis of the certification; and
- b) the compliance status; and
- c) whether compliance was continuous or intermittent; and
- d) the method(s) used for determining the compliance status of the source, currently and over the reporting period.

## GENERAL CONDITIONS

64. Dynegy Moss Landing, LLC shall comply with all conditions of this federal operating permit. Any noncompliance with a permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. [District Rule 218]
65. In an enforcement action, the fact that Dynegy Moss Landing, LLC would have to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit is not a defense. [District Rule 218]
66. This permit may be modified, revoked, reopened and reissued, or terminated for cause as determined by the District. The filing of a request by Dynegy Moss Landing, LLC for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 218]
67. This permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. [District Rule 218]
68. Dynegy Moss Landing, LLC shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. Upon request, Dynegy Moss Landing, LLC shall also furnish to the District copies of records required to be retained by this permit. [District Rule 218]
69. For applicable requirements that will become effective during the permit term, Dynegy Moss Landing, LLC shall meet such requirements on a timely basis unless a more detailed schedule is expressly required by the applicable requirement. [District Rule 218]
70. Any document submitted to the District pursuant to this permit shall contain certification by the responsible official of truth, accuracy and completeness. All certifications shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Dynegy Moss Landing, LLC shall promptly, upon discovery, report to the District a material error or omission in these records, reports, plans, or other documents. [District Rule 218]
71. Dynegy Moss Landing, LLC shall report any violation of any requirement contained in this permit to the District within 96 hours after such occurrence. The violation report shall include the time intervals, date and magnitude of excess emissions; nature and cause of the excess (if known), corrective actions and preventive measures adopted. [District Rules 214 and 218]

72. Upon any administrative or judicial challenge, all the emission limits, specific and general conditions, monitoring, record keeping, and reporting requirements of this permit, except those being challenged, remain valid and must be complied with. [District Rule 218]
73. For this federal operating permit to remain valid through the permit term of five years from the date of issuance, Dynegy Moss Landing, LLC shall pay an annual emission fee based upon the requirements of District Rule 308. [District Rule 218]
74. Dynegy Moss Landing, LLC shall have available at the facility at all times a copy of this federal operating permit. [District Rule 218]
75. For protection from enforcement action based upon an emergency, as defined in District Rule 218, the responsible official for Dynegy Moss Landing, LLC shall submit to the District relevant evidence which demonstrates [District Rule 218]:
- a) an emergency occurred; and
  - b) that Dynegy Moss Landing, LLC can identify the cause(s) of the emergency; and
  - c) that the facility was being properly operated at the time of the emergency; and
  - d) that all steps were taken to minimize the emissions resulting from the emergency; and
  - e) within two working days of the emergency event, Dynegy Moss Landing, LLC provided the District with a description of the emergency and any mitigating or corrective actions taken.
76. Upon presentation of credentials, Dynegy Moss Landing, LLC shall allow the District, the ARB, the EPA, or an authorized representative, to perform the following [District Rule 218]:
- a) enter upon the premises where the federal operating permit source is located or in which any records are required to be kept under the terms and conditions of this federal operating permit;
  - b) to have access to and copy any records required to be kept under the terms and conditions of this federal operating permit;
  - c) to inspect any equipment, operation, or process described or required in this federal operating permit; and,
  - d) to sample emissions from the source.

\*\*\*\*

**MONTEREY BAY UNIFIED AIR POLLUTION CONTROL DISTRICT  
TITLE IV ACID RAIN PERMIT**

24580 Silver Cloud Court  
Monterey, CA 93940  
Telephone: (831) 647-9411

Proposed January 1, 2013 through December 31, 2017

---

ISSUED TO:

Dynegy Moss Landing, LLC  
Moss Landing Power Plant  
P.O. Box 690  
Moss Landing, CA 95039

PLANT SITE LOCATION:

Highway 1 and Dolan Road  
Moss Landing, CA 95039

ISSUED BY:

---

Richard Stedman, Air Pollution Control Officer

---

Proposed Effective Date

---

ORIS Code: 0260

Nature of Business: Electric Power Generation

SIC Code: 4911 - Electric Power Generation

DESIGNATED REPRESENTATIVE:

Name: Peter J. Ziegler  
Title: Managing Director/Plant Manager  
Phone: (831) 633-6746

ALTERNATIVE DESIGNATED REPRESENTATIVE:

Name: Rex A. Lewis  
Title: Production Superintendent  
Phone: (831) 633-6698

FACILITY CONTACT PERSON:

Name: Steve Abbott  
Title: Environmental Specialist  
Phone: (831) 633-6649

**ACID RAIN PERMIT CONTENTS**

- 1) Statement of Basis
- 2) SO<sub>2</sub> allowances allocated under this permit and NO<sub>x</sub> requirements for each affected unit.
- 3) Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements or conditions.
- 4) The permit application submitted for this source. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.

**1) STATEMENT OF BASIS**

Statutory and Regulatory Authorities: In accordance with District Rules 218 and 219 and Titles IV and V of the Clean Air Act, the Monterey Bay Unified Air Pollution Control District issues this permit pursuant to District Rules 218 and 219.

**2) SO<sub>2</sub> ALLOWANCE ALLOCATIONS**

|          | Year   | 2013  | 2014  | 2015  | 2016  | 2017  |
|----------|--|---|-------|-------|-------|-------|
| UNIT 6-1 | SO <sub>2</sub> allowances under Tables 2, 3, or 4 of 40 CFR Part 73 | 8125*   | 8125* | 8125* | 8125* | 8125* |
|          | NO <sub>x</sub> Limit  | This unit is not subject to the NO <sub>x</sub> requirements from 40 CFR Part 76 as this unit is not capable of firing on coal. |       |       |       |       |

|          | Year   | 2013  | 2014 | 2015 | 2016 | 2017 |
|----------|--|---|------|------|------|------|
| UNIT 7-1 | SO <sub>2</sub> allowances under Tables 2, 3, or 4 of 40 CFR Part 73 | 694*  | 694* | 694* | 694* | 694* |
|          | NO <sub>x</sub> Limit  | This unit is not subject to the NO <sub>x</sub> requirements from 40 CFR Part 76 as this unit is not capable of firing on coal. |      |      |      |      |

|         |  |   |      |      |      |      |
|---------|--|---|------|------|------|------|
| UNIT 1A | Year   | 2013  | 2014 | 2015 | 2016 | 2017 |
|         | SO <sub>2</sub> allowances under Tables 2, 3, or 4 of 40 CFR Part 73 | 0   | 0    | 0    | 0    | 0    |
|         | NO <sub>x</sub> Limit  | This unit is not subject to the NO <sub>x</sub> requirements from 40 CFR Part 76 as this unit is not capable of firing on coal. |      |      |      |      |

|         |  |   |      |      |      |      |
|---------|--|---|------|------|------|------|
| UNIT 2A | Year   | 2013  | 2014 | 2015 | 2016 | 2017 |
|         | SO <sub>2</sub> allowances under Tables 2, 3, or 4 of 40 CFR Part 73 | 0   | 0    | 0    | 0    | 0    |
|         | NO <sub>x</sub> Limit  | This unit is not subject to the NO <sub>x</sub> requirements from 40 CFR Part 76 as this unit is not capable of firing on coal. |      |      |      |      |

|         |  |   |      |      |      |      |
|---------|--|---|------|------|------|------|
| UNIT 3A | Year   | 2013  | 2014 | 2015 | 2016 | 2017 |
|         | SO <sub>2</sub> allowances under Tables 2, 3, or 4 of 40 CFR Part 73 | 0   | 0    | 0    | 0    | 0    |
|         | NO <sub>x</sub> Limit  | This unit is not subject to the NO <sub>x</sub> requirements from 40 CFR Part 76 as this unit is not capable of firing on coal. |      |      |      |      |

|         |  |   |      |      |      |      |
|---------|--|---|------|------|------|------|
| UNIT 4A | Year   | 2013  | 2014 | 2015 | 2016 | 2017 |
|         | SO <sub>2</sub> allowances under Tables 2, 3, or 4 of 40 CFR Part 73 | 0   | 0    | 0    | 0    | 0    |
|         | NO <sub>x</sub> Limit  | This unit is not subject to the NO <sub>x</sub> requirements from 40 CFR Part 76 as this unit is not capable of firing on coal. |      |      |      |      |

\*- The number of allowances actually held by an affected source in a unit account may differ from

the number allocated by USEPA. This condition would not necessitate a revision to the unit SO<sub>2</sub> allowance allocations identified in this permit.

**3) COMMENTS, NOTES AND JUSTIFICATIONS**

None

**4) PERMIT APPLICATION**

Attached

\*\*\*\*



|                          |
|--------------------------|
| Plant Name (from Step 1) |
|--------------------------|

### Permit Requirements

#### STEP 3

Read the  
standard  
requirements

- (1) The designated representative of each affected source and each affected unit at the source shall:
  - (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
  - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
  - (ii) Have an Acid Rain Permit.

### Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

### Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another affected unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**STEP 3,  
Cont'd.**

**Nitrogen Oxides Requirements** The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**Excess Emissions Requirements**

- (1) The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

**Recordkeeping and Reporting Requirements**

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or authority:
  - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and
  - (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

**Liability**

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.

|                          |
|--------------------------|
| Plant Name (from Step 1) |
|--------------------------|

Step 3,  
Cont'd.**Liability, Cont'd.**

(5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.

(6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

**Effect on Other Authorities**

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;


(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,

(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4

Read the  
certification  
statement,  
sign, and  
date**Certification**

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

|           |   |              |
|-----------|---|--------------|
| Name      | Elton E. McCrillis  |              |
| Signature |  | Date 4-26-07 |