



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



HEALTHY AIR LIVING™

OCT 25 2013

Mr. Joe Rossi, General Manager and Vice President
San Joaquin Valley Concentrates
5631 E Olive Ave
Fresno, CA 93727-2708

Re: Notice of Minor Title V Permit Modification
District Facility # C-3275
Project # C-1132674

Dear Mr. Rossi:


Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to modify Permit(s) to Operate (PTOs) C-3275-0-1, '-2-1, and '-3-1 of the facility's current Title V operating permit. The modifications consist of the removal of duplicative permit conditions on several permits and the removal of permit conditions relating to ancillary source testing requirements (e.g. approved source test methods) for a small boiler not subject to periodic source testing either on the current permit or in the rules to which it is subject.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V PTO(s) C-3275-0-1, '-2-2, and '-3-2, application, and previous Title V permit. This project will be finalized after the 45-day EPA comment period.

If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Thank you for your cooperation in this matter.

Sincerely,



David Warner
Director of Permit Services

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

TITLE V APPLICATION REVIEW

Minor Modification
Project #: C-1132674

Engineer: Brian Clerico
Date: October 21, 2013

Facility Number: C-3275
Facility Name: San Joaquin Valley Concentrates
Mailing Address: 5631 E Olive Ave
Fresno, CA 93727-2708

Contact Name: Joe Rossi
Phone: (661) 845-0761

Responsible Official: Joe Rossi
Title: General Manager and VP

I. PROPOSAL

San Joaquin Valley Concentrates (SJVC) is proposing a Minor Modification to their Title V Permit. The Minor Modification consists of the removal of duplicative permit conditions on several permits and the removal of permit conditions relating to ancillary source testing requirements (e.g. approved source test methods) for a small boiler not subject to periodic source testing either on the current permit or in the rules to which it is subject.

SJVC was issued their Title V permit on June 30, 2013. No new Authority to Construct permits are associated with this Minor Modification.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements, and to provide the legal and factual basis for the proposed revisions.

II. FACILITY LOCATION

SJVC is located at 5631 East Olive Avenue, Fresno.

III. EQUIPMENT DESCRIPTION

C-3275-2-2: 4.9 MMBTU/HR DIXON MODEL S-M NATURAL GAS-FIRED BOILER WITH AN INDUSTRIAL COMBUSTION MODEL LNDG-63P-20 LOW NOX BURNER (FACILITY OPTED FOR PERMIT TO OPERATE IN LIEU OF A PERMIT EXEMPT EQUIPMENT REGISTRATION)

C-3275-3-2: 33.66 MMBTU/HR CLEAVER-BROOKS MODEL NBI-800-250-LN-SKID NATURAL GAS-FIRED BOILER EQUIPPED WITH A CLEAVER-BROOKS MODEL CBI.700.800.250 LOW NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND O2 CONTROLLER SERVED BY A NATIONWIDE MODEL CATASTAK SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

Then following revisions to the permits were recommended by District Compliance with SJVC's concurrence.

C-3275-0-1: Facility-wide permit

The current facility-wide permit has two conditions limiting visible emissions stating the same requirement from District Rule 4101. Condition #2 will be removed and condition #26 will be retained because condition #26 contains the same prohibition as well as a more complete explanation of the visible emissions requirement.

2. {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]

26. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)]

In addition, condition #46 was revised as follows:

46. On June 30, 2013, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date begin every July 1, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520]

C-3275-2-2: 4.9 MMBtu/hr natural gas-fired boiler

Condition #1 will be removed from the current PTO because it is already listed on the facility-wide permit C-3275-0-1.

This boiler was subject to initial source testing requirements but not periodic source testing. The initial source test to demonstrate compliance with the permitted emission limits was completed on 4/28/2009. Ongoing monitoring requirements to ensure compliance with the permitted emission limits are satisfied by biannual tuning and monthly monitoring of the "operational characteristics" of the boiler as recommended by the manufacturer. In lieu of tuning the boiler, the facility has the option of conducting monthly monitoring of the NOx emissions with a portable analyzer. Conditions #10 through #14, #16, and #17 on the current PTO all pertain to source testing. Since periodic source testing is not required for this unit, these conditions are not pertinent and will, therefore, be removed.

C-3275-3-2: 33.66 MMBtu/hr natural gas-fired boiler

Condition #2 will be removed from the current PTO because it is already present on the facility-wide permit C-3275-0-1 (#44).

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;

the source would otherwise be subject. Such terms and conditions include;

- a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
 6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

VIII. ATTACHMENTS

- A. Proposed Modified Title V Operating Permits
- B. Previous Title V Operating Permit
- C. Application
- D. Compliance Certification Form

ATTACHMENT A

Proposed Modified Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: C-3275-0-1

EXPIRATION DATE: 02/28/2018

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
3. Facilities C-447 and C-3275 are part of the same stationary source for Rule 2201 purposes. [District Rule 2201]
4. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1 and Fresno County Rule 110] Federally Enforceable Through Title V Permit
5. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0 and Fresno County Rule 110] Federally Enforceable Through Title V Permit
6. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
7. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (8/18/11). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
8. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
9. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
10. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
11. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SAN JOAQUIN VALLEY CONCENTRATES
Location: 5631 E OLIVE AVE, FRESNO, CA 93727
C-3275-0-1; Oct 21 2013 2:15PM - CLERICOB

12. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
14. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
15. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
16. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
17. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
18. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
19. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
20. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
23. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
24. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

25. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
26. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
27. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
28. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
29. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
30. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
31. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
32. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
33. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
34. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
35. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
36. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

37. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
38. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
39. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
40. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
41. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
42. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
43. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
44. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201]
45. On June 30, 2013, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin every July 1, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3275-2-2

EXPIRATION DATE: 02/28/2018

EQUIPMENT DESCRIPTION:

4.9 MMBTU/HR DIXON MODEL S-M NATURAL GAS-FIRED BOILER WITH AN INDUSTRIAL COMBUSTION MODEL LNDG-63P-20 LOW NOX BURNER (FACILITY OPTED FOR PERMIT TO OPERATE IN LIEU OF A PERMIT EXEMPT EQUIPMENT REGISTRATION)

PERMIT UNIT REQUIREMENTS

1. The boiler shall only be fired on PUC-quality natural gas. [District Rule 4307] Federally Enforceable Through Title V Permit
2. This boiler shall be equipped with an operational non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas consumed which must be installed by July 1, 2009. [District Rule 4307] Federally Enforceable Through Title V Permit
3. When fired on natural gas, emissions from the boiler shall not exceed any of the following limits: 30 ppmvd NOx @ 3% O2 or 0.036 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.0076 lb-PM10/MMBtu, 400 ppmvd CO @ 3% O2 or 0.2956 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 4307] Federally Enforceable Through Title V Permit
4. The owner/operator shall monitor, at least once a month, the operational characteristics recommended by the manufacturer and approved by the APCO. [District Rule 4307] Federally Enforceable Through Title V Permit
5. The owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rule 4307] Federally Enforceable Through Title V Permit
6. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rule 4307] Federally Enforceable Through Title V Permit
7. In lieu of tuning the unit twice each calendar year, the owner/operator shall monitor the emissions with a portable NOx analyzer at least twice each calendar year and adjust the unit's operating parameters accordingly to assure compliance with the emission limits of this rule. [District Rule 4307] Federally Enforceable Through Title V Permit
8. The owner/operator shall maintain records to verify that the required monitoring of the operational characteristics, and tune-ups or portable NOx analyzing has been performed. [District Rule 4307] Federally Enforceable Through Title V Permit
9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4307. [District Rule 4307] Federally Enforceable Through Title V Permit
10. Tune-up records shall include: 1) date of tune-up, 2) name of technician performing tune-up, and 3) reason that they are qualified. [District Rule 4307] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Portable analyzer records shall include: 1) date of emissions analyzing, 2) results of emissions analyzing, 3) name of technician performing analyzing, 4) make and model of analyzer, 5) date of last calibration of the analyzer, and 6) a description of any adjustments made to the unit's operating parameters for the purposes of assuring compliance. [District Rule 4307] Federally Enforceable Through Title V Permit
12. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070 and 4307] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3275-3-2

EXPIRATION DATE: 02/28/2018

EQUIPMENT DESCRIPTION:

33.66 MMBTU/HR CLEAVER-BROOKS MODEL NBI-800-250-LN-SKID NATURAL GAS-FIRED BOILER EQUIPPED WITH A CLEAVER-BROOKS MODEL CBI.700.800.250 LOW NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND O2 CONTROLLER SERVED BY A NATIONWIDE MODEL CATASTAK SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All equipment shall be constructed, maintained and operated according to the specifications and plans contained in the permit application except as otherwise specified herein. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. The boiler shall be equipped with an economizer system that consists of, at a minimum, a single stage economizer section which will recover energy from the boiler flue gas by heat exchange with the boiler feed water. The economizer system shall be designed at maximum boiler firing rate to either 1) reduce the temperature of the economizer flue gas outlet to a value no greater than 20 deg F above the temperature of the boiler feed water at maximum firing rate, or 2) heat the boiler feed water to a temperature which is no less than 30 deg F below the steam temperature at the steam drum, or 3) reduce the final temperature of the boiler's flue gas to a temperature no greater than 200 deg F. [California Environmental Quality Act]
4. Electric motors driving combustion air fans or induced draft fans shall have an efficiency meeting the standards of the National Electric Manufacturer's Association (NEMA) for "premium efficiency" motors and shall each be operated with a variable speed control or equivalent for control of flow through the fan. [California Environmental Quality Act]
5. The boiler shall be equipped with an O2 trim system designed to control oxygen content of the stack gases to a maximum of 3% by volume dry basis except during any period where the rate of fuel consumption by the boiler is less than 20% of maximum rated firing. [California Environmental Quality Act]
6. The boiler shall be designed to limit the recirculation of flue gas to a value not exceeding 10 percent of total flue gas volume while meeting the applicable requirements for control of NOx emissions from the boiler. [California Environmental Quality Act]
7. The boiler blowdown rate shall not exceed 8% of steam production. [California Environmental Quality Act]
8. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48 (c)(g)] Federally Enforceable Through Title V Permit
9. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
10. Except during start-up and shutdown, emissions from this unit shall not exceed any of the following limits: 5 ppmvd NOx @ 3% O2 or 0.006 lb-NOx/MMBtu; 0.00285 lb-SOx/MMBtu; 0.0076 lb-PM10/MMBtu; 200 ppmvd CO @ 3% O2 (equivalent to 0.147 lb-CO/MMBtu); or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. During start-up and shutdown, emissions from this unit shall not exceed any of the following limits: 0.1 lb-NO_x/MMBtu; 0.00285 lb-SO_x/MMBtu; 0.0076 lb-PM₁₀/MMBtu; 200 ppmvd CO @ 3% O₂ (equivalent to 0.147 lb-CO/MMBtu); or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. The total duration of start-up time shall not exceed 2.0 hours per day. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The total duration of startup time shall not exceed 2.0 hours per occurrence. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The total duration of shutdown time shall not exceed 2.0 hours per day. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. The total duration of shutdown time shall not exceed 2.0 hours per occurrence. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The permittee shall maintain daily records of start-up and shutdown durations and number of occurrences of each. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The ammonia (NH₃) emissions shall not exceed 10 ppmvd @ 3% O₂ over a 15 minute averaging period. [District Rule 4102]
18. Source testing to measure natural gas combustion NO_x, CO, and NH₃ emissions from this unit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests when unit is fired on natural gas, the unit shall be tested not less than once every 36 months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 2201, 4102, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. Nitrogen oxide (NO_x) emission concentrations in ppmv referenced at dry stack emissions shall be corrected to 3% O₂ and lb/MMBtu rates shall be calculated as lb NO₂/MMBtu of heat input (hhv). [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 4102]
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

27. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. NH₃ monitoring shall be conducted utilizing Draeger tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within five days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4102, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. If the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than one hour of operation after detection. If the portable analyzer or the ammonia monitoring equipment continue to show emission limit violations after one hour of operation following detection, the permittee shall notify the District within the following one hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. All NO_x, CO, O₂ and NH₃ emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The NO_x, CO and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. NH₃ emission readings shall be conducted at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rule 4102]
31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃, and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO, and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
32. Operator shall provide that fuel hhv be certified by third party fuel supplier or determined annually by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. Permittee shall determine sulfur content of combusted natural gas annually or shall demonstrate that the combusted natural gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
34. Permittee shall maintain daily records of the type and quantity of fuel combusted by the boiler. [District Rule 2201 and 40 CFR 60.48 (c)(g)] Federally Enforceable Through Title V Permit
35. All records shall be maintained and retained on-site for a minimum of five years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B
Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: C-3275-0-1

EXPIRATION DATE: 02/28/2018

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. Facilities C-447 and C-3275 are part of the same stationary source for Rule 2201 purposes. [District Rule 2201]
5. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1 and Fresno County Rule 110] Federally Enforceable Through Title V Permit
6. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0 and Fresno County Rule 110] Federally Enforceable Through Title V Permit
7. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
8. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (8/18/11). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
9. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
10. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
11. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
12. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SAN JOAQUIN VALLEY CONCENTRATES
Location: 5631 E OLIVE AVE, FRESNO, CA 93727
C-3275-0-1 : Oct 21 2013 11:34AM - CLERICOB

13. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
14. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
15. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
16. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
17. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
18. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
19. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
20. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
21. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
23. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
24. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
25. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
27. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
28. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
29. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
30. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
31. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
32. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
33. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
34. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
35. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
36. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
37. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

38. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
39. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
40. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
41. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
42. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
43. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
44. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
45. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201]
46. On June 30, 2013, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3275-2-1

EXPIRATION DATE: 02/28/2018

EQUIPMENT DESCRIPTION:

4.9 MMBTU/HR DIXON MODEL S-M NATURAL GAS-FIRED BOILER WITH AN INDUSTRIAL COMBUSTION MODEL LNDG-63P-20 LOW NOX BURNER (FACILITY OPTED FOR PERMIT TO OPERATE IN LIEU OF A PERMIT EXEMPT EQUIPMENT REGISTRATION)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The boiler shall only be fired on PUC-quality natural gas. [District Rule 4307] Federally Enforceable Through Title V Permit
3. This boiler shall be equipped with an operational non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas consumed which must be installed by July 1, 2009. [District Rule 4307] Federally Enforceable Through Title V Permit
4. When fired on natural gas, emissions from the boiler shall not exceed any of the following limits: 30 ppmvd NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 400 ppmvd CO @ 3% O₂ or 0.2956 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 4307] Federally Enforceable Through Title V Permit
5. The owner/operator shall monitor, at least once a month, the operational characteristics recommended by the manufacturer and approved by the APCO. [District Rule 4307] Federally Enforceable Through Title V Permit
6. The owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rule 4307] Federally Enforceable Through Title V Permit
7. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rule 4307] Federally Enforceable Through Title V Permit
8. In lieu of tuning the unit twice each calendar year, the owner/operator shall monitor the emissions with a portable NO_x analyzer at least twice each calendar year and adjust the unit's operating parameters accordingly to assure compliance with the emission limits of this rule. [District Rule 4307] Federally Enforceable Through Title V Permit
9. The owner/operator shall maintain records to verify that the required monitoring of the operational characteristics, and tune-ups or portable NO_x analyzing has been performed. [District Rule 4307] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rule 4307] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rule 4307] Federally Enforceable Through Title V Permit
13. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 4307] Federally Enforceable Through Title V Permit
14. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rule 4307] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4307. [District Rule 4307] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rule 4307] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 4307] Federally Enforceable Through Title V Permit
18. Tune-up records shall include: 1) date of tune-up, 2) name of technician performing tune-up, and 3) reason that they are qualified. [District Rule 4307] Federally Enforceable Through Title V Permit
19. Portable analyzer records shall include: 1) date of emissions analyzing, 2) results of emissions analyzing, 3) name of technician performing analyzing, 4) make and model of analyzer, 5) date of last calibration of the analyzer, and 6) a description of any adjustments made to the unit's operating parameters for the purposes of assuring compliance. [District Rule 4307] Federally Enforceable Through Title V Permit
20. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070 and 4307] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3275-3-1

EXPIRATION DATE: 02/28/2018

EQUIPMENT DESCRIPTION:

33.66 MMBTU/HR CLEAVER-BROOKS MODEL NBI-800-250-LN-SKID NATURAL GAS-FIRED BOILER EQUIPPED WITH A CLEAVER-BROOKS MODEL CBI.700.800.250 LOW NOX BURNER, FLUE GAS RECIRCULATION SYSTEM, AND O2 CONTROLLER SERVED BY A NATIONWIDE MODEL CATASTAK SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All equipment shall be constructed, maintained and operated according to the specifications and plans contained in the permit application except as otherwise specified herein. [District Rule 2201] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. The boiler shall be equipped with an economizer system that consists of, at a minimum, a single stage economizer section which will recover energy from the boiler flue gas by heat exchange with the boiler feed water. The economizer system shall be designed at maximum boiler firing rate to either 1) reduce the temperature of the economizer flue gas outlet to a value no greater than 20 deg F above the temperature of the boiler feed water at maximum firing rate, or 2) heat the boiler feed water to a temperature which is no less than 30 deg F below the steam temperature at the steam drum, or 3) reduce the final temperature of the boiler's flue gas to a temperature no greater than 200 deg F. [California Environmental Quality Act]
5. Electric motors driving combustion air fans or induced draft fans shall have an efficiency meeting the standards of the National Electric Manufacturer's Association (NEMA) for "premium efficiency" motors and shall each be operated with a variable speed control or equivalent for control of flow through the fan. [California Environmental Quality Act]
6. The boiler shall be equipped with an O2 trim system designed to control oxygen content of the stack gases to a maximum of 3% by volume dry basis except during any period where the rate of fuel consumption by the boiler is less than 20% of maximum rated firing. [California Environmental Quality Act]
7. The boiler shall be designed to limit the recirculation of flue gas to a value not exceeding 10 percent of total flue gas volume while meeting the applicable requirements for control of NOx emissions from the boiler. [California Environmental Quality Act]
8. The boiler blowdown rate shall not exceed 8% of steam production. [California Environmental Quality Act]
9. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48 (c)(g)] Federally Enforceable Through Title V Permit
10. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Except during start-up and shutdown, emissions from this unit shall not exceed any of the following limits: 5 ppmvd NO_x @ 3% O₂ or 0.006 lb-NO_x/MMBtu; 0.00285 lb-SO_x/MMBtu; 0.0076 lb-PM₁₀/MMBtu; 200 ppmvd CO @ 3% O₂ (equivalent to 0.147 lb-CO/MMBtu); or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. During start-up and shutdown, emissions from this unit shall not exceed any of the following limits: 0.1 lb-NO_x/MMBtu; 0.00285 lb-SO_x/MMBtu; 0.0076 lb-PM₁₀/MMBtu; 200 ppmvd CO @ 3% O₂ (equivalent to 0.147 lb-CO/MMBtu); or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The total duration of start-up time shall not exceed 2.0 hours per day. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The total duration of startup time shall not exceed 2.0 hours per occurrence. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. The total duration of shutdown time shall not exceed 2.0 hours per day. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The total duration of shutdown time shall not exceed 2.0 hours per occurrence. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The permittee shall maintain daily records of start-up and shutdown durations and number of occurrences of each. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. The ammonia (NH₃) emissions shall not exceed 10 ppmvd @ 3% O₂ over a 15 minute averaging period. [District Rule 4102]
19. Source testing to measure natural gas combustion NO_x, CO, and NH₃ emissions from this unit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests when unit is fired on natural gas, the unit shall be tested not less than once every 36 months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 2201, 4102, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. Nitrogen oxide (NO_x) emission concentrations in ppmv referenced at dry stack emissions shall be corrected to 3% O₂ and lb/MMBtu rates shall be calculated as lb NO₂/MMBtu of heat input (hhv). [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 4102]
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

28. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. NH₃ monitoring shall be conducted utilizing Draeger tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within five days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4102, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. If the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than one hour of operation after detection. If the portable analyzer or the ammonia monitoring equipment continue to show emission limit violations after one hour of operation following detection, the permittee shall notify the District within the following one hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. All NO_x, CO, O₂ and NH₃ emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The NO_x, CO and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. NH₃ emission readings shall be conducted at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rule 4102]
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃, and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO, and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. Operator shall provide that fuel hhv be certified by third party fuel supplier or determined annually by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
34. Permittee shall determine sulfur content of combusted natural gas annually or shall demonstrate that the combusted natural gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of the type and quantity of fuel combusted by the boiler. [District Rule 2201 and 40 CFR 60.48 (c)(g)] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C
Application

RECEIVED

SEP 03 2013


Permits Srvc
SJVAPCD

San Joaquin Valley Air Pollution Control District

www.valleyair.org

Permit Application For:

ADMINISTRATIVE AMENDMENT MINOR MODIFICATION SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: <u>San Joaquin Valley Concentrates</u>	
2. MAILING ADDRESS: STREET/P.O. BOX: <u>5631 E. Olive Ave.</u> CITY: <u>Fresno</u> STATE: <u>CA</u> 9-DIGIT ZIP CODE: <u>93727-2708</u>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: <u>5631 E. Olive Ave.</u> CITY: <u>Fresno</u> SECTION: _____ TOWNSHIP: _____ RANGE: _____	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: <u>Manufacture grape juice concentrate.</u>	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary) <u>On separate page.</u>	
6. TYPE OR PRINT NAME OF APPLICANT: <u>Joe Rossi</u>	TITLE OF APPLICANT: <u>General Manager & VP</u>
7. SIGNATURE OF APPLICANT: 	DATE: <u>8/22/2013</u> PHONE: (559) 458-2546 FAX: (559) 458-2564 EMAIL: joe.rossi@sjvconc.com

For APCD Use Only:

DATE STAMP	FILING FEE RECEIVED: \$ _____ CHECK#: _____
	DATE PAID: _____
	PROJECT NO: <u>C-1132674</u> FACILITY ID: <u>C-3275</u>

Central Regional Office • 1990 E. Gettysburg Avenue • Fresno, CA 93726-0244 • (559) 230-5900 • FAX (559) 230-6061

Permit# C-3275-0-1:

Remove condition #2. Condition #26 is sufficient and a better written condition. Having both is repetitive.

Update condition #46. The facility and compliance have established that the reporting periods for the (report of required monitoring) RRM and (annual compliance certification) ACC will begin on 7-1-13 to coincide with the beginning of the month. Reporting dates have already been added in the comments section for the facility as follows:

RRM:07/01/XX - 12/31/XX Due: 01/30/XX

01/01/XX - 06/30/XX Due: 07/30/XX

ACC: 07/01/XX - 06/30/XX Due: 07/30/XX

Permit# C-3275-2-1:

Remove condition 1 because it is included in the facility-wide requirements and does not need to be listed here.

Remove conditions 10, 11, 12, 13, 14, 16, & 17. These conditions have to do with source testing, but there are no source testing requirements for this unit.

Permit# C-3275-3-0:

Remove condition 2 from the permit. This is already listed in the facility-wide requirements.

ATTACHMENT D
Compliance Certification Form

**San Joaquin Valley
Unified Air Pollution Control District**

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

COMPANY NAME: <i>San Joaquin Valley Concentrates</i>	FACILITY ID: <i>C-3275</i>
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: <i>E. & J. Gallo Winery</i>	
3. Agent to the Owner:	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

Joe Rossi
Signature of Responsible Official

8/22/2013
Date

JOE ROSSI
Name of Responsible Official (please print)

J. Pres. & Gen. Mgr.
Title of Responsible Official (please print)