FACILITY PERMIT TO OPERATE

SO CAL EDISON CO
8662 CERRITOS AVE
STANTON, CA 90680

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By _____
Carol Coy
Deputy Executive O cer
Engineering & Compliance

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	02/14/2007
B	RECLAIM Annual Emission Allocation	DRAFT	02/14/2007
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	DRAFT	02/14/2007
E	Administrative Conditions	DRAFT	02/14/2007
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	02/14/2007
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	02/14/2007
H	Permit To Construct and Temporary Permit to Operate	DRAFT	02/14/2007
I	Compliance Plans & Schedules	DRAFT	02/14/2007
J	Air Toxics	DRAFT	02/14/2007
K	Title V Administration	DRAFT	02/14/2007
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	02/14/2007
B	Rule Emission Limits	DRAFT	02/14/2007

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR:	SO CAL EDISON CO
LEGAL OPERATOR (if different than owner):	
EQUIPMENT LOCATION:	8662 CERRITOS AVE STANTON, CA 90680
MAILING ADDRESS:	2244 WALNUT GROVE AVENUE ROSEMEAD, CA 91770
RESPONSIBLE OFFICIAL:	NADER MANSOUR
TITLE:	MANAGER, ENVIRONMENTAL POLICY
TELEPHONE NUMBER:	(626) 302-9459
CONTACT PERSON:	UVE SILLAT
TITLE:	ENVIRONMENTAL ENGINEER
TELEPHONE NUMBER:	(626) 302-4047
TITLE V PERMIT ISSUED:	February 14, 2007
TITLE V PERMIT EXPIRATION DATE:	February 13, 2012

TITLE V	RECLAIM	
YES	NOx:	NO
	SOx:	NO
	CYCLE:	0
	ZONE:	COASTAL

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION B: RECLAIM Annual Emission Allocation

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : POWER GENERATION					
System 2 : EMERGENCY IC ENGINE					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, DETROIT DIESEL, MODEL 6063-TK35, WITH AFTERCOOLER, TURBOCHARGER, 415 BHP A/N: 375764	D7			**CO:** 8.5 GRAM/BHP-HR (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*] ; **NOX:** 6.9 GRAM/BHP-HR (4) **[RULE 1303(a)(1)-BACT,5-10-1996** *RULE 1303(a)(1)-BACT,12-6-2002*] ; **PM10:** 0.38 GRAM/BHP-HR (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*] ; **VOC:** 1 GRAM/BHP-HR (4) **[RULE 1303(a)(1)-BACT,5-10-1996** *RULE 1303(a)(1)-BACT,12-6-2002*]	C1.5, E193.3, K67.3
System 4 : RULE 219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES					
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E8			**VOC:** (9) **[RULE 1113,11-8-1996;***RULE 1113,6-9-2006;***RULE 1171,11-7-2003;***RULE 1171,7-14-2006*]	K67.4
RULE 219 EXEMPT EQUIPMENT, EXEMPT HAND WIPING OPERATIONS	E9			**VOC:** (9) **[RULE 1171,11-7-2003;***RULE 1171,7-14-2006*]	
RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS	E10				H23.2

* (1)(1A)(1B)Denotes RECLAIM emission factor (2)(2A)(2B)Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B)Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B)Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
D7	1	1	2
E8	1	1	4
E9	1	1	4
E10	1	1	4

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

F14.1 The operator shall not use diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive O cer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).

b). The operator shall submit any additional relevant information requested by the Executive O cer or designated agency.

[40CFR 68 - Accidental Release Prevention, 5-24-1996]

DEVICE CONDITIONS

C. Throughput or Operating Parameter Limits

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.5 The operator shall limit the operating time to no more than 199 hour(s) in any one year.

The 199 hours per year limit may include up to 20 hours per year operating time to maintain engine readiness..

To comply with this condition, the operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and O set Exemption, 6-14-1996**; RULE 1401, 3-4-2005]

[Devices subject to this condition : D7]

E. Equipment Operation/Construction Requirements

E193.3 The operator shall operate and maintain this equipment according to the following specifications:

The operation of this equipment beyond 20 hours per year for testing and maintenance and performance testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the utility distribution company has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in e ect.

[RULE 1470, 11-3-2005]

[Devices subject to this condition : D7]

H. Applicable Rules

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H23.2 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415

[RULE 1415, 10-14-1994]

[Devices subject to this condition : E10]

K. Record Keeping/Reporting

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The date of operation

Indication of whether the engine is started manually or automatically

Time reading in hours at the beginning and end of operation

The elapsed time in hours

The reason for operation

The annual total hours of operation (include hours for manual and automatic operation) which shall be recorded no later than January 15th of the following year

The records shall be kept for a minimum of five calendar years prior to the current year and made available to District personnel upon request.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and O set Exemption, 6-14-1996**; RULE 1401, 3-4-2005; RULE 1470, 11-3-2005]

[Devices subject to this condition : D7]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.4 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : E8]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]

    a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
    b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
    c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]

2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]

3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statues of other governmental agencies. [204]

4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]

6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION E: ADMINISTRATIVE CONDITIONS

7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]

   a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
   b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
   c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
   d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO2) and be averaged over 15 consecutive minutes; [407]
   e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO2) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]
   f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O2) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]

8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]

   a. Brief description of the equipment tested.
   b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
   c. Operating conditions under which the test will be performed.
   d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream)
      .

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION E: ADMINISTRATIVE CONDITIONS

e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
f. Description of calibration and quality assurance procedures.
g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).

9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]

a. The results of the source test.
b. Brief description of the equipment tested.
c. Operating conditions under which the test was performed.
d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream) .
e. Field and laboratory data forms, strip charts and analyses.
f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.

10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]

11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION F: RECLAIM Monitoring and Source Testing Requirements

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION G: Recordkeeping and Reporting Requirements for RECLAIM Sources

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : POWER GENERATION					
System 1 : GAS TURBINE					
GAS TURBINE, PEAKING UNIT, UNIT NO. 1, NATURAL GAS, GENERAL ELECTRIC, MODEL LM6000PC SPRINT, SIMPLE CYCLE, HEAT INPUT REFERENCED AT 88 DEGREES FAHRENHEIT, WITH WATER INJECTION, 448.5 MMBTU/HR WITH A/N:	D1	C3 C4 S5		**CO:** 2000 PPMV (5) **[RULE 407,4-2-1982]** ; **CO:** 6 PPMV NATURAL GAS (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*]	A63.1, A63.2, A63.3, A63.4, A99.1, A99.2, A195.1, A195.2, A195.3, A327.1, C1.1, C1.2, C1.3,
				NOX: 25 PPMV NATURAL GAS (8) **[40CFR 60 Subpart KKKK,7-6-2006]** ; **NOX:** 2.5 PPMV NATURAL GAS (4) **[RULE 1303(a)(1)-BACT,5-10-1996** *RULE 1303(a)(1)-BACT,12-6-2002*] ; **PM:** 0.1 GRAINS/SCF (5) **[RULE 409,8-7-1981]** ; **PM:** 11 LBS/HR (5A) **[RULE 475,10-8-1976** *RULE 475,8-7-1978*] ; **PM:** 0.01 GRAINS/SCF (5B) **[RULE 475,10-8-1976;***RULE 475,8-7-1978*] ; **SO2:** (9) **[40CFR 72 - Acid Rain Provisions,11-24-1997]**	D12.1, D29.1, D29.2, D29.3, D82.1, E193.1, H23.1, K40.1, K67.1
				SOX: 0.06 LBS/MMBTU (8) **[40CFR 60 Subpart KKKK,7-6-2006]** ; **VOC:** 2 PPMV NATURAL GAS (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*]	

* (1)(1A)(1B)Denotes RECLAIM emission factor (2)(2A)(2B)Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B)Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B)Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : POWER GENERATION					
GENERATOR, 45.4 MW					
CO OXIDATION CATALYST, BASF, 80 CUBIC FEET OF TOTAL CATALYST VOLUME A/N:	C3	D1			E193.1
SELECTIVE CATALYTIC REDUCTION, CORMETECH CMHT-21, WITH 547 CUBIC FEET OF TOTAL CATALYST VOLUME, WIDTH: 18 FT; HEIGHT: 25 FT 9 IN; LENGTH: 2 FT 6 IN WITH A/N: AMMONIA INJECTION	C4	D1		**NH3:** 5 PPMV (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*]	A195.4, D12.2, D12.3, D12.4, E179.1, E179.2, E193.1
STACK, HEIGHT: 80 FT; DIAMETER: 13 FT A/N:	S5	D1			
System 2 : EMERGENCY IC ENGINE					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, WAUKESHA, MODEL VGF36 GL/GLD, WITH TURBOCHARGER, 865 BHP A/N:	D6			**CO:** 224 PPMV (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*] ; **NOX:** 107 PPMV (4) **[RULE 1303(a)(1)-BACT,5-10-1996** *RULE 1303(a)(1)-BACT,12-6-2002*] ; **VOC:** 111 PPMV (4) **[RULE 1303(a)(1)-BACT,5-10-1996;***RULE 1303(a)(1)-BACT,12-6-2002*]	C1.4, D12.5, D29.4, E162.1, E193.1, E193.2, K67.2

* (1)(1A)(1B)Denotes RECLAIM emission factor (2)(2A)(2B)Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B)Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B)Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : POWER GENERATION					
System 3 : INORGANIC CHEMICAL STORAGE					
STORAGE TANK, FIXED ROOF, 19% AQUEOUS AMMONIA, 10000 GALS A/N:	D11				C157.1, E144.1, E193.1

* (1)(1A)(1B)Denotes RECLAIM emission factor
(2)(2A)(2B)Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5)(5A)(5B)Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8)(8A)(8B)Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
(9) See App B for Emission Limits
(10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: DEVICE ID INDEX

Device Index For Section H			
Device ID	**Section H Page No.**	**Process**	**System**
D1	1	1	1
C3	2	1	1
C4	2	1	1
S5	2	1	1
D6	2	1	2
D11	3	1	3

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

F14.1 The operator shall not use diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive O cer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).

b). The operator shall submit any additional relevant information requested by the Executive O cer or designated agency.

[40CFR 68 - Accidental Release Prevention, 5-24-1996]

DEVICE CONDITIONS

A. Emission Limits

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 1590 LBS IN ANY ONE MONTH
PM10	Less than 1499 LBS IN ANY ONE MONTH
CO	Less than 2200 LBS IN ANY ONE MONTH
SOX	Less than 89 LBS IN ANY ONE MONTH
VOC	Less than 453 LBS IN ANY ONE MONTH

The operator shall calculate the emission limit(s) by using fuel use data and the following emission factors: VOC: 3.07 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf.

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If NOx and CO CEMS data is not available, NOx and CO emissions shall be calculated using fuel usage and the following factors- NOx: 10.07 lb/mmcf and CO: 14.75 lbs/mmcf during normal operations, and NOx: 7.74 lbs/start, 6.53 lbs/shutdown, CO: 8.74 lbs/start, 7.86 lbs/shutdown.

[RULE 1303(b)(2)-O set, 5-10-1996; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

A63.2 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 6783 LBS IN ANY ONE YEAR
PM10	Less than 5454 LBS IN ANY ONE YEAR
CO	Less than 8885 LBS IN ANY ONE YEAR
SOX	Less than 324 LBS IN ANY ONE YEAR
VOC	Less than 1702 LBS IN ANY ONE YEAR

The operator shall calculate the emission limit(s) by using fuel use data and the following emission factors: During commissioning with no control- NOx: 245.71 lbs/mmcf; CO: 115.57 lbs/mmcf, VOC: 11.17 lbs/mmcf; PM10: 10.63 lbs/mmcf, and SOx: 0.63 lb/mmcf . During commissioning with water injection- NOx: 100.7 lbs/mmcf, all other factors remain the same. During normal operation- VOC: 3.07 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf. THIS CONDITION APPLIES DURING THE 1ST 12 MONTHS OF OPERATION ONLY

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If NOx and CO CEMS data is not available, NOx and CO emissions shall be calculated using fuel usage and the following factors- NOx: 10.07 lbs/mmcf and CO: 14.75 lbs/mmcf during normal operations, and NOx: 7.74 lbs/start, 6.53 lbs/shutdown, CO: 8.74 lbs/start, 7.86 lbs/shutdown.

For the purposes of this condition, the yearly emission limit shall be defined as a period of twelve (12) consecutive months determined on a rolling basis with a new 12 month period beginning on the first day of each calendar month.

[**RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

A63.3 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 6783 LBS IN ANY ONE YEAR
PM10	Less than 6443 LBS IN ANY ONE YEAR
CO	Less than 9421 LBS IN ANY ONE YEAR
SOX	Less than 383 LBS IN ANY ONE YEAR
VOC	Less than 1942 LBS IN ANY ONE YEAR

The operator shall calculate the emission limit(s) by using fuel use data and the following emission factors: VOC: 3.07 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf. THIS CONDITION APPLIES AFTER THE 1st 12 MONTHS OF OPERATION.

The operator shall calculate the emission limit(s) and compliance with the NOx and CO emission limits shall be verified through CEMS data. If NOx and CO CEMS data is not available, NOx and CO emissions shall be calculated using fuel usage and the following factors- NOx: 10.07 lbs/mmcf and CO: 14.75 lbs/mmcf during normal operations, and NOx: 7.74 lbs/start, 6.53 lbs/shutdown, CO: 8.74 lbs/start, 7.86 lbs/shutdown.

For the purposes of this condition, the yearly emission limit shall be defined as a period of twelve (12) consecutive months determined on a rolling basis with a new 12 month period beginning on the first day of each calendar month.

[**RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

A63.4 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 2867 LBS IN ANY ONE MONTH
PM10	Less than 1499 LBS IN ANY ONE MONTH
CO	Less than 3277 LBS IN ANY ONE MONTH
SOX	Less than 89 LBS IN ANY ONE MONTH
VOC	Less than 540 LBS IN ANY ONE MONTH

The operator shall calculate the emission limit(s)) by using fuel use data and the following emission factors: During commissioning with no control- NOx: 245.71 lbs/mmcf; CO: 115.57 lbs/mmcf, VOC: 11.17 lbs/mmcf; PM10: 10.63 lbs/mmcf, and SOx: 0.63 lb/mmcf . During commissioning with water injection- NOx: 100.7 lbs/mmcf, all other factors remain the same. During normal operation- VOC: 3.07 lbs/mmcf, PM10: 10.63 lbs/mmcf, and SOx: 0.63 lbs/mmcf. THIS CONDITION APPLIES DURING THE 1ST 12 MONTHS OF OPERATION ONLY.

Compliance with the NOx and CO emission limits shall be verified through CEMS data. If NOx and CO CEMS data is not available, NOx and CO emissions shall be calculated using fuel usage and the following factors- NOx: 10.07 lb/mmcf and CO: 14.75 lbs/mmcf during normal operations, and NOx: 7.74 lbs/start, 6.53 lbs/shutdown, CO: 8.74 lbs/start, 7.86 lbs/shutdown.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1]

A99.1 The 2.5 PPM NOX emission limit(s) shall not apply during commissioning, start-up, and shutdown periods. Commissioning shall not exceed 25 hrs, with no more than 5 hrs uncontrolled and no more than 20 hrs with water injection. Each start-up shall not exceed 15 min. Each shutdown shall not exceed 10 min. There shall be no more than 60 start ups per year in the first year of operation, and 120 start-ups per year thereafter. NOx emissions for the hour which includes a start shall not exceed 7.82 lbs, and for the hour which includes a shutdown 6.61 lbs.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1303(b)(1)-Modeling, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

A99.2 The 6.0 PPM CO emission limit(s) shall not apply during commissioning, start-up, and shutdown periods. Commissioning shall not exceed 25 hrs, with no more than 5 hrs uncontrolled and no more than 20 hrs with water injection. Each start-up shall not exceed 15 min. Each shutdown shall not exceed 10 min. There shall be no more than 60 start ups per year in the first year of operation, and 120 start-ups per year thereafter. CO emissions for the hour which includes a start shall not exceed 8.82 lbs, and for the hour which includes a shutdown 7.95 lbs.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1303(b)(1)-Modeling, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

A195.1 The 2.5 PPM NOX emission limit(s) is averaged over 60 minutes at 15 percent O2, dry.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1303(b)(1)-Modeling, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

A195.2 The 6.0 PPM CO emission limit(s) is averaged over 60 minutes at 15 percent O2, dry.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1303(b)(1)-Modeling, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

A195.3 The 2.0 PPM VOC emission limit(s) is averaged over 60 minutes at 15 percent O2, dry.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1303(b)(1)-Modeling, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

A195.4 The 5 PPMV NH3 emission limit(s) is averaged over over 60 minutes at 15% O2, dry basis.

The operator shall calculate and continuously record the NH3 slip concentration using the following: NH3 (ppmv) = [a-b*c/1E+ 06]*1E+ 06/b, where

a = NH3 injection rate (lbs/hr)/17(lb/lb-mol)

b = dry exhaust gas flow rate (scf/hr)/385.3 scf/lb-mol)

c = change in measured NOx across the SCR (ppmvd at 15% O2)

The operator shall install and maintain a NOx analyzer to measure the SCR inlet NOx ppmv accurate to plus or minus 5 percent calibrated at least once every twelve months. The NOx analyzer shall be installed and operated within 90 days of initial start-up.

The operator shall use the above described method or another alternative method approved by the Executive O cer. The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information without corroborative data using an approved reference method for the determination of ammonia.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

A327.1 For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[**RULE 475, 10-8-1976**; RULE 475, 8-7-1978]

[Devices subject to this condition : D1]

C. Throughput or Operating Parameter Limits

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

C1.1 The operator shall limit the fuel usage to no more than 4.70 MM cubic feet per day.

The operator shall maintain records in a manner approved by the District to demonstrate compliance with this condition.

[**RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

C1.2 The operator shall limit the fuel usage to no more than 513 MM cubic feet per year.

The operator shall maintain records in a manner approved by the District to demonstrate compliance with this condition and the records shall be made available upon AQMD request.

For the purpose of this condition, the yearly fuel use limit shall apply only during the 1st 12 months of operation.

[**RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

C1.3 The operator shall limit the fuel usage to no more than 603 MM cubic feet per year.

The operator shall maintain records in a manner approved by the District to demonstrate compliance with this condition and the records shall be made available upon AQMD request.

For the purpose of this condition, the yearly fuel use limit shall apply after the 1st 12 months of operation. The yearly emission limit shall be defined as a period of twelve (12) consecutive months determined on a rolling basis with a new 12 month period beginning on the first day of each calendar month.

[**RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

C1.4 The operator shall limit the operating time to no more than 7 hour(s) in any one year.

The 7 hours per year limit may include up to a half hour per month operating time to maintain engine readiness.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and O set Exemption, 6-14-1996**; RULE 1401, 3-4-2005]

[Devices subject to this condition : D6]

C157.1 The operator shall install and maintain a pressure relief valve set at 50 psig.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D11]

D. Monitoring/Testing Requirements

D12.1 The operator shall install and maintain a(n) flow meter to accurately indicate the fuel usage being supplied to the turbine.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[**RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D12.2 The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

D12.3 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

D12.4 The operator shall install and maintain a(n) pressure gauge to accurately indicate the di erential pressure across the SCR catalyst bed in inches of water column.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

D12.5 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and O set Exemption, 6-14-1996**; RULE 1401, 3-4-2005]

[Devices subject to this condition : D6]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet of the SCR serving this equipment
CO emissions	District method 100.1	1 hour	Outlet of the SCR serving this equipment
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample
VOC	Approved District method	1 hour	Outlet of the SCR serving this equipment
PM10 emissions	Approved District method	District-approved averaging time	Outlet of the SCR serving this equipment
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment

The test shall be conducted after AQMD approval of the source test protocol, but no later than 180 days after initial start-up. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted in accordance with AQMD approved test protocol. The protocol shall be submitted to the AQMD engineer no later than 45 days before the proposed test date and shall be approved by the AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at loads of 100, 75, and 50 percent.

For natural gas fired turbines only, VOC compliance shall be demonstrated as follows: a) Stack gas samples are extracted into Summa canisters maintaining a final canister pressure between 400-500 mm Hg absolute, b) Pressurization of canisters are done with zero gas analyzed/certified to contain less than 0.05 ppmv total hydrocarbon as carbon, and c) Analysis of canisters are per EPA Method TO-12 (with pre concentration) and temperature of canisters when extracting samples for analysis is not below 70 deg F.

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval except for the determination of compliance with the VOC BACT level of 2.0 ppmv calculated as carbon for natural gas fired turbines.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Because the VOC BACT level was set using data derived from various source test results, this alternate VOC compliance method provides a fair comparison and represents the best sampling and analysis technique for this purpose at this time. The test results shall be reported with two significant digits.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment

The test shall be conducted and the results submitted to the District within 45 days after the test date. The AQMD shall be notified of the date and time of the test at least 7 days prior to the test.

The test(s) shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The NOx concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NOx emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample
VOC emissions	Approved District method	1 hour	Outlet of the SCR serving this equipment
PM10 emissions	Approved District method	District-approved averaging time	Outlet of the SCR serving this equipment

The test(s) shall be conducted at least once every three years.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine generating output in MW.

The test shall be conducted in accordance with AQMD approved test protocol. The protocol shall be submitted to the AQMD engineer no later than 45 days before the proposed test date and shall be approved by the AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at 100 percent load.

The test shall be conducted for compliance verification of the BACT VOC 2.0 ppmv limit.

For natural gas fired turbines only, VOC compliance shall be demonstrated as follows: a) Stack gas samples are extracted into Summa canisters maintaining a final canister pressure between 400-500 mm Hg absolute, b) Pressurization of canisters are done with zero gas analyzed/certified to contain less than 0.05 ppmv total hydrocarbon as carbon, and c) Analysis of canisters are per EPA Method TO-12 (with pre concentration) and temperature of canisters when extracting samples for analysis is not below 70 deg F.

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval except for the determination of compliance with the VOC BACT level of 2.0 ppmv calculated as carbon for natural gas fired turbines.

Because the VOC BACT level was set using data derived from various source test results, this alternate VOC compliance method provides a fair comparison and represents the best sampling and analysis technique for this purpose at this time. The test results shall be reported with two significant digits.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

D29.4 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet
CO emissions	District method 100.1	1 hour	Outlet
VOC emissions	Approved District method	1 hour	Outlet

The test shall be conducted after AQMD approval of the source test protocol, but no later than 180 days after initial start-up. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the engine output in hp.

The test shall be conducted in accordance with AQMD approved test protocol. The protocol shall be submitted to the AQMD engineer no later than 45 days before the proposed test date and shall be approved by the AQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at a load of 100 percent.

The test shall be conducted for compliance verification of the NOx, CO, and VOC BACT limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D6]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D82.1 The operator shall install and maintain a CEMS to measure the following parameters:

NOx and CO concentration in ppmv.

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the turbine, in accordance with an approved AQMD Rule 218 CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from AQMD.

The CEMS will convert the actual NOX and CO concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS shall be installed and operated to measure the NOx and CO concentration over a 15 minute averaging time period. The CEMS shall convert the actual CO concentrations to mass emission rates (lbs/hr) using the equation below and record the hourly emission rates on a continuous basis.

CO Emission Rate, lbs/hr = K*Cco*Fd[20.9/(20.9%-%O2 d)][(Qg*HHV)/10E6], where

K = 7.267*10-8 (lbs/scf)/ppm

Cco = Average of 4 consecutive 15 min. average CO concentrations, ppm

Fd = 8710 dscf/MMBTU natural gas

%O2, d = Hourly average % by volume O2 dry, corresponding to Cco

Qg = Fuel gas usage during the hour, scf/hr

HHV = Gross high heating value of the fuel gas, BTU/scf

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002; **RULE 218, 8-7-1981**; RULE 218, 5-14-1999]

[Devices subject to this condition : D1]

E. Equipment Operation/Construction Requirements

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

E144.1 The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D11]

E162.1 The operator shall use this equipment only during utility failure periods, except for maintenance purposes.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and O set Exemption, 6-14-1996**; RULE 1401, 3-4-2005]

[Devices subject to this condition : D6]

E179.1 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.

Condition Number D 12- 2

Condition Number D 12- 3

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

E179.2 For the purpose of the following condition number(s), continuous monitoring shall be defined as measuring at least once every month and shall be calculated based upon the average of the continuous monitoring for that month.

Condition Number D 12- 4

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C4]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

E193.1 The operator shall upon completion of construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the Negative Declaration prepared for this project (CEQA State Clearinghouse No. 2006121113).

[CA PRC CEQA, 11-23-1970]

[Devices subject to this condition : D1, C3, C4, D6, D11]

E193.2 The operator shall operate and maintain this equipment according to the following specifications:

The TA Luft carburetor settings shall be maintained at all times.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D6]

H. Applicable Rules

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
SOX	40CFR60, SUBPART	KKKK
NOX	40CFR60, SUBPART	KKKK

[40CFR 60 Subpart KKKK, 7-6-2006]

[Devices subject to this condition : D1]

K. Record Keeping/Reporting

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

K40.1 The operator shall provide to the District a source test report in accordance with the following specifications:

Source test results shall be submitted to the District no later than 60 days after the source test was conducted.

Emission data shall be expressed in terms of (ppmv) corrected to 15 percent oxygen (dry basis). In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains per DSCF.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM).

All moisture concentration shall be expressed in terms of percent corrected to 15 percent oxygen.

Source test results shall also include the oxygen levels in the exhaust, fuel flow rate (CFH), the flue gas temperature, and the generator power output (MW) under which the test was conducted.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-O set, 5-10-1996**; RULE 1303(b)(2)-O set, 12-6-2002]

[Devices subject to this condition : D1]

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Commissioning hours and type of control and fuel use

Date and time of each start-up and shutdown

Natural gas fuel use after the commissioning period and prior to CEMS certification

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Date of operation, the elapsed time, in hours, and the reason for operation. Records shall be kept and maintained on file for a minimum of two years and made available to district personnel upon request.

[RULE 1110.2, 6-3-2005; **RULE 1304(a)-Modeling and O set Exemption, 6-14-1996**; RULE 1401, 3-4-2005]

[Devices subject to this condition : D6]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION J: AIR TOXICS

NOT APPLICABLE

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]

2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under Section 129(e) of the Clean Air Act, this permit shall expire five years from the date that the initial Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

   (B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive O cer at least every five years from the date of issuance. [3004(f)(2)]

4. To renew this permit, the operator shall submit to the Executive O cer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive O cer or designee within a reasonable time as specified in writing by the Executive O cer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

Reopening for Cause

7. The Executive O cer will reopen and revise this permit if any of the following circumstances occur:

   (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the e ective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

(B) The Executive O cer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.

(C) The Executive O cer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:

(A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or

(B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

9. The operator shall allow the Executive O cer or authorized representative, upon presentation of appropriate credentials to:

(A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;

(B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and

(D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate o ense. [3004(g)]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise a ect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]

15. Nothing in this permit or in any permit shield can alter or a ect:

    (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;

    (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;

    (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;

    (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;

    (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and

    (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]

16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency[1] constitutes an a rmative defense to an action brought for non-compliance with a technology-based emission limit only if:

    (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:

        (1) An emergency occurred and the operator can identify the cause(s) of the emergency;

        (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;

        (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,

        (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and

    (B) The operator complies with the breakdown provisions of Rule 430 - Breakdown Provisions, or subdivision (i) of Rule 2004 - Requirements, whichever is applicable. [3002(g), 430, 2004(i)]

18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive O cer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

1 "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or imporper operation, or operator error.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

    (A) The date, place as defined in the Title V permit, and time of sampling or measurements;

    (B) The date(s) analyses were performed;

    (C) The company or entity that performed the analyses;

    (D) The analytical techniques or methods used;

    (E) The results of such analyses; and

    (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(o)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:

    (A) Breakdowns shall be reported as required by Rule 430 - Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

    (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

(C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.

(D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]

23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]

24. The operator shall submit to the Executive O cer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:

(A) Identification of each permit term or condition that is the basis of the certification;

(B) The compliance status during the reporting period;

(C) Whether compliance was continuous or intermittent;

(D) The method(s) used to determine compliance over the reporting period and currently, and

(E) Any other facts specifically required by the Executive O cer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible o cial (as defined in Rule 3000). [3004(a)(12)]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the Title V application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations:

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the e ective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1110.2	6-3-2005	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	6-9-2006	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	7-14-2006	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	12-6-2002	Non federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-O set	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-O set	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and O set Exemption	6-14-1996	Federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 1470	11-3-2005	Non federally enforceable
RULE 218	5-14-1999	Non federally enforceable
RULE 218	8-7-1981	Federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3003	3-16-2001	Non federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3005	3-16-2001	Non federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 430	7-12-1996	Non federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
40CFR 60 Subpart GG	2-24-2006	Federally enforceable
40CFR 60 Subpart KKKK	7-6-2006	Federally enforceable
40CFR 68 - Accidental Release Prevention	5-24-1996	Federally enforceable
40CFR 72 - Acid Rain Provisions	11-24-1997	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable
CA PRC CEQA	11-23-1970	Non federally enforceable

FACILITY PERMIT TO OPERATE
SO CAL EDISON CO

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

NONE

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-8-1996]

(1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.

(2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						
Industrial Maintenance							

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-8-1996]

Primers and Topcoats							
Alkyds	420						
Catalyzed Epoxy	420						
Bituminous Coatings	420						
Materials							
Inorganic Polymers	420						
Vinyl Chloride Polymers	420						
Chlorinated Rubber	420						
Acrylic Polymers	420						
Urethane Polymers	420						
Silicones	420						
Unique Vehicles	420						
Japans/Faux Finishing	350	700		350			
Coatings							
Magnesite Cement Coatings	600			450			
Mastic Coatings	300						
Metallic Pigmented Coatings	500						
Multi-Color Coatings	420		250				
Pigmented Lacquer	680		550			275	
Pre-Treatment Wash Primers	780						
Primers, Sealers, and	350						
Undercoaters							
Quick-Dry Enamels	400						
Roof Coatings	300						
Shellac							
Clear	730						
Pigmented	550						
Stains	350						
Swimming Pool Coatings							
Repair	650						
Other	340						
Traffic Coatings	250		150				
Waterproofing Sealers	400						
Wood Preservatives							
Below-Ground	350						
Other	350						

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-8-1996]

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 6-9-2006]

(1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.

(2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 6-9-2006]

TABLE OF STANDARDS VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 6-9-2006]

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings Roof Coatings, Aluminum	300 500		250		50 100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac Clear Pigmented	 730 550							
Specialty Primers	350					250	100	
Stains Stains, Interior	350 250		250				100	
Swimming Pool Coatings Repair Other	 650 340		340					
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing Concrete/Masonry Sealers	400					100		
Wood Preservatives Below-Ground Other	 350 350							

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 6-9-2006]

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

** Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

*** The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.

TABLE OF STANDARDS (cont.)
VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-7-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 7-14-2006]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2008
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 7-14-2006]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008
SOLVENT CLEANING ACTIVITY (cont.)	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printingl	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components		
(I) Newsprint	100 (0.83)	

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 7-14-2006]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008
SOLVENT CLEANING ACTIVITY (cont.)	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(II) Other Substrates	500 (4.2)	100 (0.83)
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	500 (4.2)	100 (0.83)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

1. A Title V permit revision is not required for emission increases that are authorized by allowances acquired under the Acid Rain Program, provided that the increases do not trigger a Title V permit revision under any other applicable requirement. [70.6 (a)(4)(ii)]

Monitoring Requirements

2. The owners and operators and, to the extent applicable, the designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Parts 74, 75, and 76. [40 CFR 72.50, 72.31, 72.9(b)(1)]

3. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the acid rain emissions limitations and emissions reduction requirements for sulfur dioxide (SO_2) under the Acid Rain Program. [40 CFR 72.9(b)(2), 40 CFR 75.2]

4. The requirements of 40 CFR Parts 74 and 75 shall not affect the responsibility of the operator to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements and other provisions of this permit. [40 CFR 72.9(b)(3), 40 CFR 72.5]

Sulfur Dioxide Requirements

5. The owners and operators of each source and each affected unit at the source shall:
(A) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR Part 73, Section 73.34(C)) not less than the total annual emissions of SO_2 for the previous calendar year from the unit; and, [40 CFR 72.9(c)(i)],

(B) Comply with the applicable acid rain emissions limitations for SO_2.[40 CFR 72.9(c)(ii)]

6. Each ton of SO_2 emitted in excess of the acid rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72.9(g)(7)]

7. SO_2 allowances shall be held in, deducted from, or transferred among allowance tracking system accounts in accordance with the Acid Rain Program. [40 CFR 72.9(g)(4)]

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS
[40CFR 72 - Acid Rain Provisions 11-24-1997]

8. A SO_2 allowance shall not be deducted in order to comply with the requirements under paragraph 41(A) of the SO_2 requirements prior to the calendar year for which the allowance was allocated. [40 CFR 72.9(g)(5)]

9. An affected unit shall be subject to the SO_2 requirements under the Acid Rain Program as follows:[40 CFR 72.6(a)]

   (A) Starting January 1, 2000, an affected unit under 40 CFR Part 72, Section 72.6(a)(2); or [40 CFR 72.6(a)(2)]

   (B) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR Part 75, an affected unit under 40 CFR Part 72, Section 72.6(a)(3). [40CFR 72.6(a)(3)]

10. An allowance allocated by the EPA administrator under the Acid Rain Program is a limited authorization to emit SO_2 in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the acid rain permit application, the acid rain permit, or the written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14, and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72.9 (c)(6)]

11. An allowance allocated by the EPA Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72.9(c)(7)]

Excess Emissions Requirements

12. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 72.9(e)]

13. The owners and operators of an affected unit that has excess emissions in any calendar year shall: [40 CFR 72.9(e)(2)]

   (A) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and[40 CFR 72.9(e)(2)(i)]

   (B) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77. [40 CFR 72.9(e)(2)(ii)]

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS
[40CFR 72 - Acid Rain Provisions 11-24-1997]

Recordkeeping and Reporting Requirements

14. Unless otherwise provided, the owners and operators of the source and each affected unit at the source that are subject to the acid rain provisions under Title IV shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the EPA Administrator or the Executive Officer: [40 CFR 72.9(f)(1)]

    (A) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative; [40 CFR 72.9(f)(1)(i)]

    (B) All emissions monitoring information, in accordance with 40 CFR Part 75; [40 CFR 72.9(f)(1)(ii)]

    (C) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and, [40 CFR 72.9(f)(1)(iii)]

    (D) Copies of all documents used to complete an acid rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program. [40 CFR 72.9(f)(1)(iv)]

15. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72 Subpart I and 40 CFR Part 75. [40 CFR 72.9(f)(2)]

Liability

16. Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete acid rain permit application, an acid rain permit, or a written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to Section 113(c) of the Act. [40 CFR 72.9 (g)(1)]

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

17. Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to Section 113(c) of the Act and 18 U.S.C. 1001. [40 CFR 72.9 (g)(2)]

18. No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect. [40 CFR 72.9 (g)(3)]

19. Each affected source and each affected unit shall meet the requirements of the Acid Rain Program. [40 CFR 72.9 (g)(4)]

20. Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source. [40 CFR 72.9 (g)(5)]

21. Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR Part 72, Section 72.44 (Phase II repowering extension plans) and 40 CFR Part 76, Section 76.11 (NOx averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR Part 75, Sections 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative. [40 CFR 72.9 (g)(6)]

22. Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act. [40 CFR 72.9 (g)(7)]

Effect on Other Authorities

23. No provision of the Acid Rain Program, an acid rain permit application, an acid rain permit, or a written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14 shall be construed as: [40 CFR 72.9 (h)]

FACILITY PERMIT TO OPERATE

SO CAL EDISON CO

APPENDIX B: RULE EMISSION LIMITS
[40CFR 72 - Acid Rain Provisions 11-24-1997]

(A) Except as expressly provided in Title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of Title I of the Act relating to applicable National Ambient Air Quality Standards or state implementation plans; [40 CFR 72.9 (h)(1)]

(B) Limiting the number of allowances a unit can hold; *provided,* that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act; [40 CFR 72.9 (h)(2)]

(C) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law; [40 CFR 72.9 (h)(3)]

(D) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or, [40 CFR 72.9 (h)(4)]

(E) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established. [40 CFR 72.9 (h)(5)]