San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUG 25 2011

Raymond Rodriguez
Occidental of Elk Hills Inc.
10800 Stockdale Highway
Bakersfield, CA 93311

Re: Notice of Preliminary Decision - Federally Mandated Operating Permit
District Facility # S-1216
Project # S-1075158

Dear Mr. Rodriguez:

Enclosed for your review and comment is the District's analysis of Occidental of Elk Hills Inc.'s application for the Federally Mandated Operating Permit for its oil and natural gas production facility, Western Light Oil Source, Kern County, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

cc: Juscelino Siongco, Permit Services Engineer

Attachments

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

www.valleyair.org www.healthyairliving.com

Printed on recycled paper.

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUG 25 2011

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

Re: Notice of Preliminary Decision - Federally Mandated Operating Permit
District Facility # S-1216
Project # S-1075158

Dear Mr. Rios:

Enclosed for your review and comment is the District's analysis of Occidental of Elk Hills Inc.'s application for the Federally Mandated Operating Permit for its oil and natural gas production facility, Western Light Oil Source, Kern County, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 45-day comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

cc: Juscelino Siongco, Permit Services Engineer

Attachments

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

www.valleyair.org www.healthyairliving.com

Printed on recycled paper.

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUG 25 2011

Mike Tollstrup, Chief
Project Assessment Branch
Air Resources Board
P O Box 2815
Sacramento, CA 95812-2815

Re: Notice of Preliminary Decision - Federally Mandated Operating Permit
District Facility # S-1216
Project # S-1075158

Dear Mr. Tollstrup:

Enclosed for your review and comment is the District's analysis of Occidental of Elk Hills Inc.'s application for the Federally Mandated Operating Permit for its oil and natural gas production facility, Western Light Oil Source, Kern County, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

cc: Juscelino Siongco, Permit Services Engineer

Attachments

Seyed Sadredin
Executive Director/Air Pollution Control Dfficer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

www.valleyair.org www.healthyairliving.com

Printed on recycled paper.

Bakersfield Californian

NOTICE OF PRELIMINARY DECISION
FOR THE PROPOSED ISSUANCE OF
FEDERALLY MANDATED OPERATING PERMITS

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed issuance of the Federally Mandated Operating permits to Occidental of Elk Hills Inc. for its oil and natural gas production facility, Western Light Oil Source, Kern County, California.

The District's analysis of the legal and factual basis for this proposed action, project #S-1075158, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the District office at the address below. There are no emission changes associated with this proposed action. This will be the public's only opportunity to comment on the specific conditions of the proposed Federally Mandated Operating initial permits. If requested by the public, the District will hold a public hearing regarding issuance of this initial permit. For additional information, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900. Written comments on the proposed initial permit must be submitted within 30 days of the publication date of this notice to DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CALIFORNIA 93726-0244.

SAN JOAQUIN VALLEY
UNIFIED AIR POLLUTION CONTROL DISTRICT

Occidental of Elk Hills Inc
Facility #S-1216

PROPOSED ENGINEERING EVALUATION

TABLE OF CONTENTS

Section		Page
I.	PROPOSAL	1
II.	FACILITY LOCATION	1
III.	EQUIPMENT LISTING	1
IV.	GENERAL PERMIT TEMPLATE USAGE	1
V.	SCOPE OF EPA AND PUBLIC REVIEW	2
VI.	APPLICABLE REQUIREMENTS ADDRESSED BY GENERAL PERMIT TEMPLATES	2
VIII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	4
IX.	COMPLIANCE	4
X.	PERMIT SHIELD	80
XI.	PERMIT CONDITIONS	81

ATTACHMENT A - DETAILED FACILITY PRINTOUT
ATTACHMENT B - INSIGNIFICANT ACTIVITIES OR EQUIPMENT
ATTACHMENT C - SJVUAPCD PREVIOUS PERMITS
ATTACHMENT D - STRINGENCY ANALYSIS OF DISTRICT RULE 4311

TITLE V APPLICATION REVIEW

Project #: S-1075158
Deemed Complete: November 19, 2007

Engineer: Juscelino Siongco
Date: July 27, 2011

Facility Number:	S-1216
Facility Name:	Occidental of Elk Hills, Inc
Mailing Address:	PO Box 1001 Tupman, CA 93276-1001
Contact Name:	Raymond Rodriguez
Phone:	(661) 204-9236
Responsible Official:	Roger Tucker
Title:	Non-unit Development Manager

I. PROPOSAL

Occidental of Elk Hills Inc is proposing that an initial Title V permit be issued for its existing oil and natural gas production facility in Kern County, CA. The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with those applicable requirements, and to provide the legal and factual basis for proposed permit conditions.

II. FACILITY LOCATION

Occidental of Elk Hills Inc. is located in the western light oil stationary source in Kern County, CA.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is shown in Attachment A.

A summary of the exempt equipment categories which describe the insignificant activities or equipment at the facility not requiring a permit is shown in Attachment B. This equipment is not exempt from facility-wide requirements.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is requesting to use the following model general permit templates:

A. SJV-UM-0-3, Facility-wide Umbrella General Permit Template

The applicant has requested to utilize template #SJV-UM-0-3, Facility-wide Umbrella General Permit Template for unit S-1216-0-1. Based on the information submitted on the Template Qualification Form, the applicant qualifies for the use of this template.

V. SCOPE OF EPA AND PUBLIC REVIEW

Certain segments of the proposed Operating Permit are based on model general permit templates that have been previously subject to EPA and public review. The terms and conditions from the model general permit templates are included in the proposed permit and are not subject to further EPA and public review.

For permit applications utilizing model general permit templates, public and agency comments on the District's proposed actions are limited to the applicant's eligibility for model general permit template, applicable requirements not covered by the model general permit template, and the applicable procedural requirements for issuance of Title V Operating Permits.

The following permit conditions, including their underlying applicable requirements, originate form model general permit templates and are not subject to further EPA or public review.

Conditions 1 through 40 of the requirements for permit unit S-1216-0-1.

VI. APPLICABLE REQUIREMENTS ADDRESSED BY GENERAL PERMIT TEMPLATES

District Rule 1100, Equipment Breakdown (amended December 17, 1992) (Non-SIP replacement for Kern County Rule 111)

District Rule 1160, Emission Statements (adopted November 18, 1992)

District Rule 2010, Permits Required (amended December 17, 1992)

District Rule 2020, Exemptions (amended December 20, 2007)

District Rule 2031, Transfer of Permits (amended December 17, 1992)

District Rule 2040, Applications (amended December 17, 1992)

District Rule 2070, Standards for Granting Applications (amended December 17, 1992)

District Rule 2080, Conditional Approval (amended December 17, 1992)

District Rule 2520, Sections 5.2, 9.1.1, 9.4, 9.5, 9.7, 9.8, 9.9, 9.13.1, 9.13.2, 9.16 and 10.0, Federally Mandated Operating Permits (amended June 21, 2001)

District Rule 4101, Visible Emissions (amended February 17, 2005)

District Rule 4601, Architectural Coatings (amended Decernber 17, 2009)

District Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities (amended August 19, 2004)

District Rule 8031, Bulk Materials (amended August 19, 2004)

District Rule 8041, Carryout and Trackout (amended August 19, 2004)

District Rule 8051, Open Areas (amended August 19, 2004)

District Rule 8061, Paved and Unpaved Roads (amended August 19, 2004)

District Rule 8071, Unpaved Vehicle/Equipment Traffic Areas (amended September 16, 2004)

40 CFR Part 82, Subpart B and F, Stratospheric Ozone

40 CFR Part 61, Subpart M, National Emission Standard for Asbestos

VII. APPLICABLE REQUIREMENTS NOT ADDRESSED BY GENERAL PERMIT TEMPLATES

District New and Modified Stationary Source Review Rule

District Rule 1081, Source Sampling (amended December 16, 1993)

District Rule 2520, Federally Mandate Operating Permits (amended June 21, 2001)

District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)

District Rule 4301, Fuel Burning Equipment (amended December 17, 1992)

District Rule 4311, Flares (amended June 18, 2009)

District Rule 4305, Boilers, Steam Generators, and Process Heaters – Phase 2 (amended August 21, 2003)

District Rule 4306, Boilers, Steam Generators, and Process Heaters – Phase 3 (amended October 16, 2008)

District Rule 4320, Advance Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr (amended October 16, 2008)

District Rule 4408, Glycol Dehydration Systems (adopted December 19, 2002)

District Rule 4409, Components at Light Crude Oil Production Facilities, Natural Gas Production Facilities, and Natural Gas Processing Facilities (adopted April 20, 2005)

District Rule 4623, Storage of Organic Liquids (amended May 19, 2005)

District Rule 4701, Internal Combustion Engines–Phase 1 (amended August 21, 2003)

District Rule 4702, Internal Combustion Engines–Phase 2 (amended January 18, 2007)

District Rule 4801, Sulfur Compounds (amended December 17, 1992)

40 CFR 60, Subpart JJJJ, Standards of Performance for Stationary Spark Ignition Internal Combustion Engines

40 CFR 63, Subpart HH, National Emission Standards for Hazardous Air Pollutants from Oil and Natural Gas Production Facilities

40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (amended January 18, 2008)

40 CFR Part 64, Compliance Assurance Monitoring (CAM)

Kern County Rule 407, Sulfur Compounds

Kern County Rule 424, Sulfur Compounds from Oil Field Steam Generators

VIII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as Federally Enforceable through Title V Permit.

This facility is subject to the following rules that are not currently federally enforceable:

1. District Rule 4102, Nuisance

   - For this facility, condition 41 of the requirements for permit unit S-1216-0-1 are based on the rule listed above and are not Federally Enforceable through Title V.

IX. COMPLIANCE

A. Requirements Addressed by Model General Permit Templates

1. Facility Wide Requirements

The applicant is proposing to use a general permit template to address federally applicable facility-wide requirements. Section IV of template SJV-UM-0-3 includes a demonstration of compliance for all applicable requirements. Template conditions have been added to the facility wide

requirements as condition numbers 1 through 40 to assure compliance with these requirements.

B. Requirements Not Addressed by Model General Permit Templates

1. New and Modified Stationary Source Review Rule (District NSR Rule)

The permit units were subject to the District NSR Rule upon application for Authority to Construct (ATC). In accordance with the White Paper for Streamlined Development of Part 70 Permit Applications, dated July 10, 1995, conditions from the resulting Permit to Operate (PTO) were addressed to define how NSR permit terms should be incorporated into the Title V permit.

a. S-1216-1-2: 125 BBL Fixed Roof Wash Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

b. S-1216-2-2: 1000 BBL Fixed Roof Petroleum Storage Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

c. S-1216-3-2: 1000 BBL Fixed Roof Petroleum Storage Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

d. S-1216-7-2: 500 BBL Fixed Roof Wash Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

e. S-1216-8-2: 2000 BBL Fixed Roof Petroleum Storage Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

f. S-1216-10-2: 180 BBL Fixed Roof Wash Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

g. S-1216-11-2: 2000 BBL Fixed Roof Storage Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 4 from the PTO was included as condition 8 of the requirements for this permit unit.

h. S-1216-20-2: 500 BBL Fixed Roof Wash Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Condition 2 from the PTO was deleted since the tank is exempt from the requirements of District Rule 4623 except for testing and recordkeeping.

- Conditions 3 and 4 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 5 from the PTO was included as condition 8 of the requirements for this permit unit.

i. S-1216-21-2: 500 BBL Fixed Roof Stock Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Condition 2 from the PTO was deleted since the tank stores organic liquids with a TVP < 0.5 psia that exempts it from the requirements of District Rule 4623 except for testing and recordkeeping.
- Conditions 3 and 4 from the PTO were deleted since the conditions were obsolete and required only for small producers as defined in District Rule 4623.
- Condition 5 from the PTO was included as condition 8 of the requirements for this permit unit.

j. S-1216-22-2: 490 BBL Fixed Roof Wash Tank

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 and 3 from the PTO were included as conditions 1 and 2 of the requirements for this permit unit.
- Condition 4 from the PTO was deleted since the facility is not a small producer as defined in District Rule 4623.
- Conditions 5 through 8 from the PTO were included as conditions 3 through 6 of the requirements for this permit unit.
- Condition 9 from the PTO was deleted since the facility is not a small producer as defined in District Rule 4623.
- Condition 10 from the PTO was included as condition 14 of the requirements for this permit unit.

k. S-1216-42-1: 500 BBL Fixed Roof Crude Oil Production Tank Served by Vapor Control System

- Conditions 1 and 3 through 6 from the PTO were replaced by updated District Rule 4623 conditions and included as conditions 1 through 17 of the requirements for this permit unit.
- Condition 2 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

l. S-1216-43-1: 500 BBL Fixed Roof Crude Oil Production Tank Served by Vapor Control System

- Conditions 1 and 3 through 6 from the PTO were replaced by updated District Rule 4623 conditions and included as conditions 1 through 17 of the requirements for this permit unit.
- Condition 2 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

m. S-1216-44-1: 2000 BBL Fixed Roof Petroleum Wash Tank Served by Vapor Control System

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Conditions 2 through 6 from the PTO were included as conditions1 through 5 of the requirements for this permit unit. Permit S-1216-131 was included in conditions 1 and 2 as sharing the gas gathering line with permit units S-1216-44 and S-1216-46 since S-1216-131 was inadvertently left out during the NSR transfer of the unit from another facility.
- Condition 7 from the PTO was removed and included as part of the District Rule 4623 tank inspection and maintenance conditions 99 through 107 in the facility-wide requirements.
- Conditions 8 through 10 from the PTO were included as conditions 6 through 8 of the requirements for this permit unit.
- Condition 11 from the PTO was deleted since it is extraneous to tanks with vapor recovery system.
- Condition 12 from the PTO was included as condition 9 of the requirements for this permit unit. Permit unit S-1216-131 was included with the total combined volatile organic compound emissions limit for the same reason stated above.
- Condition 13 from the PTO was deleted since it is extraneous to tanks with vapor recovery system.

n. S-1216-45-1: 500 BBL Fixed Roof Petroleum Wash Tank

- Conditions 1, 2, and 3 from the PTO were deleted since the tank stores organic liquids with a TVP < 0.5 psia that exempts it from the requirements of District Rule 4623 except for testing and recordkeeping.
- Condition 4 from the PTO was included as condition 1 of the requirements for this permit unit.
- Conditions 5 through 10 from the PTO were updated to District Rule 4623 exemption requirements for storing organic liquids with a TVP < 0.5 psia.
- Condition 11 from the PTO was included as condition 13 on the requirements for this permit unit.

o. S-1216-46-1: 1,000 BBL Fixed Roof Petroleum Shipping Tank with Vapor Control

- Condition 1 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Condition 2 from the PTO was included as condition 1 of the requirements for this permit unit.
- Condition 3 from the PTO was deleted since the PV valve condition was extraneous to tanks with vapor control system.
- Conditions 4 through 7 from the PTO were included as conditions 2 through 5 of the requirements for this permit unit. Permit S-1216-131 was included in conditions 2 and 3 as sharing the gas gathering line with permit units S-1216-44 and S-1216-46 since S-1216-131 was inadvertently left out during the NSR transfer of the unit from another facility.
- Conditions 8, 9, and 10 from the PTO were replaced with the condition that references District Rule 4623 tank inspection and maintenance conditions 99 through 107 in the facility-wide requirements.
- Conditions 11, 12, 13, and 14 from the PTO were included as conditions 6, 7, 8, and 23 on the requirements for this permit unit. In condition 6, permit unit S-1216-131 was included with the total combined volatile organic compound emissions limit for the same reason stated above.

p. S-1216-47-1: 300 BBL Fixed Roof Petroleum Wash Tank

- Condition 1 from the PTO was updated to current District Rule 4623 language and included as condition 1 on the requirements for this permit unit.
- Condition 2 from the PTO was removed since the requirement was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 3 from the PTO was included as condition 2 on the requirements from this permit unit.
- Condition 4 from the PTO was deleted since the condition was extraneous for tanks with pressure-vacuum (PV) relief valve.
- Conditions 5 and 6 from the PTO were replaced with current District Rule 4623 language and included as conditions 4, 5, and 6 on the requirements for this permit unit.
- Conditions 7, 8, and 9 from the PTO were included as conditions 7, 9, and 15 on the requirements for this permit unit.
- Condition 10 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

q. S-1216-48-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Condition 1 from the PTO was updated to current District Rule 4623 language and included as condition 1 on the requirements for this permit unit.
- Conditions 2 through 6 from the PTO were included as conditions 2 through 6 on the requirements for this permit unit.
- Condition 7 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Conditions 8 through 15 from the PTO were replaced with the condition that references District Rule 4623 tank inspection and maintenance conditions 99 through 107 in the facility-wide requirements.
- Conditions 16 and 17 from the PTO were updated to current District Rule 4623 language and included as condition 8 on the requirements for this permit unit.
- Condition 18 from the PTO was included as condition 9 on the requirements for this permit unit.
- Conditions 19, 20, and 21 from the PTO were replaced with District Rule 4623 tank cleaning conditions and included as conditions 10 through 20 on the requirements for this permit unit.
- Condition 22 and 23 from the PTO were included as conditions 21 and 22 on the requirements for this permit unit.

r. S-1216-49-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Condition 1 from the PTO was updated to current District Rule 4623 language and included as condition 1 on the requirements for this permit unit.
- Condition 2 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Conditions 3, 4, and 5 from the PTO were included as conditions 2, 3, and 4 on the requirements for this permit unit.
- Condition 6 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Conditions 7, 8, 9, and 10 from the PTO were not included as requirements for this permit unit. The conditions were obsolete startup conditions to determine if the tank was subject to District Rule 4409 (Replacement for District Rule 4403).
- Condition 11 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

s. S-1216-50-1: 750 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

- Condition 1 from the PTO was updated to current District Rule 4623 language and included as condition 1 on the requirements for this permit unit.
- Conditions 2 through 5 from the PTO were included as conditions 2 through 5 on the requirements for this permit unit.
- Condition 6 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 7 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

t. S-1216-50-1: 5,000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 4 from the PTO were included as conditions 1 through 4 on the requirements for this permit unit.
- Condition 5 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

u. S-1216-52-1: 750 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 4 from the PTO were included as conditions 1 through 4 on the requirements for this permit unit.
- Condition 5 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

v. S-1216-53-1: 1000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 8 from the PTO were included as conditions 1 through 8 on the requirements for this permit unit.
- Condition 9 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

w. S-1216-54-1: 500 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

- Condition 1 from the PTO was updated to current District Rule 4623 language and included as condition 1 on the requirements for this permit unit.
- Conditions 2 and 3 from the PTO were included as conditions 2 and 3 on the requirements for this permit unit.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 5 from the PTO was included as condition 5 on the requirements for this permit unit.

- Condition 6 from the PTO was deleted since the condition is extraneous for tanks with vapor recovery systems.
- Condition 7 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

x. S-1216-55-1: 200 BBL Fixed Roof Crude Oil Production Tank

- Condition 1 from the PTO was updated to current District Rule 4623 language and included as condition 1 on the requirements for this permit unit.
- Condition 2 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 3 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since the tank stores organic liquids with a TVP < 11 psia and equipped with a pressure-vacuum valve.
- Conditions 4 and 5 from the PTO were updated to current District Rule 4623 language and included as conditions 3, 4, and 5 on the requirements for this permit unit.
- Conditions 6, 7, and 8 from the PTO were included as conditions 6, 8, and 14 on the requirements for this permit unit.
- Condition 9 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

y. S-1216-56-1: 500 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 8 from the PTO were replaced with District Rule 4623 exemption requirements for storing organic liquids with a TVP < 0.5 psia and included as conditions 1 through 7 on the requirements for this permit unit.
- Condition 9 from the PTO was included as condition 8 on the requirements for this permit unit.
- Condition 10 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

z. S-1216-57-1: 1,000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 4 from the PTO were included as conditions 1 through 4 on the requirements for this permit unit.
- Condition 5 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

aa. S-1216-58-1: 1,000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 4 from the PTO were included as conditions 1 through 4 on the requirements for this permit unit.

- Condition 5 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

bb. S-1216-59-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Conditions 1 through 5 from the PTO were included as conditions 1 through 5 on the requirements for this permit unit.
- Condition 6 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 7 from the PTO was extraneous and deleted since components are included in the inspection and maintenance (I&M) program implemented pursuant to Section 5.7 of District Rule 4623, and exempt from the requirements of District Rule 4409 (replacement for District Rule 4403).
- Conditions 8 and 9 from the PTO were included as conditions 7 and 8 on the requirements for this permit unit.
- Condition 5 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

cc. S-1216-60-1: 500 BBL Fixed Roof Crude Oil Storage Tank with Vapor Recovery

- Conditions 1 through 3 from the PTO were included as conditions 1 through 3 on the requirements for this permit unit.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 5 from the PTO was included as condition 4 on the requirements for this permit unit.
- Condition 6 from the PTO was deleted since the condition is extraneous for tanks with vapor recovery systems.
- Condition 7 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

dd. S-1216-61-1: 500 BBL Fixed Roof Crude Oil Storage Tank with Vapor Recovery

- Conditions 1 through 3 from the PTO were included as conditions 1 through 3 on the requirements for this permit unit.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 5 from the PTO was included as condition 4 on the requirements for this permit unit.
- Condition 6 from the PTO was deleted since the condition is extraneous for tanks with vapor recovery systems.
- Condition 7 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

ee. S-1216-62-1: 1,000 BBL Fixed Roof Crude Oil Wash Tank with Vapor Recovery

- Conditions 1 through 3 from the PTO were included as conditions 1 through 3 on the requirements for this permit unit.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 5 from the PTO was included as condition 4 on the requirements for this permit unit.
- Condition 6 from the PTO was deleted since the condition is extraneous for tanks with vapor recovery systems.
- Condition 7 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

ff. S-1216-63-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Conditions 1 through 5 from the PTO were included as conditions 1 through 5 on the requirements for this permit unit.
- Condition 6 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Conditions 7 and 8 from the PTO were included as conditions 6 and 7 on the requirements for this permit unit.
- Condition 9 from the PTO was extraneous and not included as a requirement for this permit unit since components are included in the inspection and maintenance (I&M) program implemented pursuant to Section 5.7 of District Rule 4623, and exempt from the requirements of District Rule 4409 (replacement for District Rule 4403).
- Condition 10 from the PTO was included as condition 8 on the requirements for this permit unit.
- Condition 11 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

gg. S-1216-64-2: 3,000 BBL Fixed Roof Wash Tank with Vapor Recovery

- Condition 1 from the PTO was obsolete and not included as a requirement for this permit unit. The condition was a pre-construction requirement that had been complied with.
- Conditions 2 through 5 from the PTO were included as conditions 2 through 4 on the requirements for this permit unit.
- Conditions 6 through 12 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 13 from the PTO was revised to current rule language and included as condition 5 on the requirements for this permit unit.
- Conditions 14 and 15 from the PTO were included as conditions 6 and 7 on the requirements for this permit unit.

- Conditions 16 through 19 from the PTO were subsumed by tank cleaning conditions 9 through 19 on the requirements for this permit unit.
- Condition 20 from the PTO was included as condition 20 on the requirements for this permit unit.
- Condition 21 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

hh. S-1216-66-1: 3,000 BBL Fixed Roof Wash Tank

- Conditions 1 through 6 from the PTO were included as conditions 1 through 6 on the requirements for this permit unit.
- Condition 7 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 8 from the PTO was included as condition 7 on the requirements for this permit unit.
- Condition 9 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 10 from the PTO was included as condition 8 on the requirements for this permit unit.
- Conditions 11 through 15 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions.
- Condition 16 from the PTO was extraneous and not included as a requirement for this permit unit since components are included in the inspection and maintenance (I&M) program implemented pursuant to Section 5.7 of District Rule 4623, and exempt from the requirements of District Rule 4409 (replacement for District Rule 4403).
- Condition 17 from the PTO was revised to current rule language and included as condition 9 on the requirements for this permit unit.
- Condition 18 from the PTO was included as condition 10 on the requirements for this permit unit.
- Conditions 19 through 23 from the PTO were subsumed by tank cleaning conditions 12 through 23 on the requirements for this permit unit.
- Condition 24 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

ii. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (Non-Compliant Dormant Emissions Unit)

- Condition 1 from the ATC was obsolete and not included with the requirements for this permit unit. The condition was a pre-construction requirement that had been complied with.

- Conditions 2 through 24 from the ATC had been included as conditions 1 through 23 on the requirements for this permit unit.
- Conditions 25 through 40 from the ATC had not been included in the requirements for this permit unit since these conditions were duplicates of conditions in the facility-wide requirements.

jj. S-1216-68-1: Glycol Gas Dehydration Operation Including Glycol Reboiler with 0.75 MMBtu/hr After burner

- Conditions 1 through 20 from the ATC were included as conditions 3 through 22 on the requirements for this permit unit.

kk. S-1216-69-1: Emergency Gas Plant Flare

- Conditions 1, 2, and 3 from the PTO had been included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Conditions 4 through 19 from the PTO had not been included in the requirements for this permit unit since these conditions were subsumed by conditions 1 through 22 on the facility-wide requirements.

ll. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

- Condition 1 from the ATC was obsolete and not included in the requirements for this permit unit. The condition was a pre-construction requirement that had been complied with.
- Conditions 2 through 5 from the ATC had been included as conditions 1 through 4 on the requirements for this permit unit.
- Condition 6 from the ATC was not included in the requirements for this permit unit since the condition was subsumed by condition 22 in the facility-wide requirements.
- Conditions 7 through 29 from the ATC had been included as conditions 5 through 27 on the requirements for this permit unit.
- Conditions 30 through 45 from the ATC had not been included in the requirements for this permit unit since these conditions were subsumed by conditions 1 through 22 on the facility-wide requirements.

mm. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

- Condition 1 from the PTO was not included as a requirement for this permit unit since the condition was subsumed by condition 22 on the facility-wide requirements.
- Conditions 2 through 24 from the PTO were included as conditions 1 through 23 on the requirements for this permit unit.
- Conditions 25 through 40 from the PTO had not been included in the requirements for this permit unit since these conditions were subsumed by conditions 1 through 22 on the facility-wide requirements.

nn. S-1216-72-1: 16,000 BBL Fixed Roof Production Tank with Vapor Control System

- Condition 1 from the PTO was updated to current rule condition and included as condition 1 on the requirements for this permit unit.
- Conditions 2, 3, and 4 from the PTO were included as conditions 2, 3, and 4 on the requirements for this permit unit.
- Conditions 5 through 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 12 from the PTO was updated to current rule condition and included as condition 5 on the requirements for this permit unit.
- Condition 13 and 14 from the PTO were included as conditions 6 and 7 on the requirements for this permit unit.
- Condition 15 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 16 from the PTO was included as condition 8 on the requirements for this permit unit.
- Condition 17 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 18 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 19 from the PTO was included as condition 21 on the requirements for this permit unit.
- Condition 20 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

oo. S-1216-73-1: 1,500 BBL Fixed Roof Production Tank with Vapor Control System

- Condition 1 from the PTO was updated to current rule condition and included as condition 1 on the requirements for this permit unit.

- Conditions 2, 3, and 4 from the PTO were included as conditions 2, 3, and 4 on the requirements for this permit unit.
- Conditions 5 through 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 12 from the PTO was updated to current rule condition and included as condition 5 on the requirements for this permit unit.
- Condition 13 and 14 from the PTO were included as conditions 6 and 7 on the requirements for this permit unit.
- Condition 15 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 16 from the PTO was included as condition 8 on the requirements for this permit unit.
- Condition 17 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 18 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 19 from the PTO was included as condition 21 on the requirements for this permit unit.
- Condition 20 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

pp. S-1216-75-1: 1,500 BBL Fixed Roof Production Tank with Vapor Control System

- Condition 1 from the PTO was updated to current rule condition and included as condition 1 on the requirements for this permit unit.
- Conditions 2, 3, and 4 from the PTO were included as conditions 2, 3, and 4 on the requirements for this permit unit.
- Conditions 5 through 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 12 from the PTO was updated to current rule condition and included as condition 5 on the requirements for this permit unit.
- Condition 13 and 14 from the PTO were included as conditions 6 and 7 on the requirements for this permit unit.
- Condition 15 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 16 from the PTO was included as condition 8 on the requirements for this permit unit.
- Condition 17 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 18 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 19 from the PTO was included as condition 21 on the requirements for this permit unit.

- Condition 20 from the PTO was removed and included as condition 41 of the requirements for the facility-wide permit, S-1216-0-1.

qq. S-1216-78-1: 1,000 BBL Fixed Roof Slop Oil Tank with Vapor Control System

- Conditions 1 and 2 from the PTO were obsolete and not included as conditions on the requirements for this permit unit. The conditions were preconstruction requirements that had been complied with.
- Conditions 3 and 4 from the PTO were included as conditions 22 and 41 of the requirements for the facility-wide permit, S-1216-0-1.
- Condition 5 from the PTO was included as condition 1 on the requirements for this permit unit.
- Condition 6 from the PTO was updated to current rule condition and included as condition 2 on the requirements for this permit unit.
- Conditions 7, 8, and 9 from the PTO were included as conditions 3, 4, and 5 on the requirements for this permit unit.
- Conditions 10 through 16 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 17 from the PTO was updated to current rule condition and included as condition 6 on the requirements for this permit unit.
- Condition 18 from the PTO was included as condition 7 on the requirements for this permit unit.
- Condition 19 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Condition 20 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 21 from the PTO was subsumed by tank cleaning conditions 11 through 22 on the requirements for this permit unit.
- Conditions 22 and 23 from the PTO were included as conditions 8 and 21 on the requirements for this permit unit.

rr. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator with North American 4211 GLE Burner and FGR (Compliant Dormant Emissions Unit)

- Conditions 1 through 6 from the ATC were included as conditions 1 through 6 on the requirements for this permit unit.
- Condition 7 from that ATC was included as condition 41 on the facility-wide requirements.
- Conditions 8 through 30 from the ATC were included as conditions 7 through 29 of the requirements for this permit unit.

ss. S-1216-86-1: 100 BBL Fixed Roof Production Tank with Vapor Control System

- Condition 1 from the PTO was revised to current rule condition and included as condition 1 on the requirements for this permit unit.
- Conditions 2 through 6 from the PTO were included as conditions 2 through 6 on the requirements for this permit unit.
- Conditions 7 through 14 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 15 and 16 from the PTO were superseded by current rule condition 7 on the requirements for this permit unit.
- Condition 17 from the PTO was included as condition 8 on the requirements for this permit unit.
- Condition 18 from the PTO was subsumed by tank cleaning conditions 12 through 23 on the requirements for this permit unit.
- Condition 19 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 20 from the PTO was subsumed by tank cleaning conditions 12 through 23 on the requirements for this permit unit.
- Conditions 21 and 22 from the PTO were included as conditions 9 and 23 on the requirements for this permit unit.

tt. S-1216-87-2: 44.58 MMBtu/hr Well Safety Flare

- Conditions 1, 2, and 3 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Conditions 4 through 79 from the PTO were subsumed by conditions 1 through 98 on the facility-wide requirements.

uu. S-1216-88-1: 44.58 MMBtu/hr Emergency Well Safety Flare

- Conditions 1 through 5 from the PTO were included as conditions 13 through 17 on the requirements for this permit unit.
- Conditions 6 and 7 from the PTO were subsumed by conditions 1 through 12 on the requirements for this permit unit.
- Conditions 8 through 107 from the PTO were subsumed by conditions 1 through 98 on the facility-wide requirements.

vv. S-1216-89-1: 0.028 MMBtu/hr Tank Vapor Recovery System Flare

- Conditions 1 through 5 from the PTO were included as conditions 13 through 17 on the requirements for this permit unit.
- Conditions 6 and 7 from the PTO were subsumed by conditions 1 through 12 on the requirements for this permit unit.

- Conditions 8 through 107 from the PTO were subsumed by conditions 1 through 98 on the facility-wide requirements.

ww. S-1216-93-2: 1,000 BBL Fixed Roof Wash Tank with Vapor Recovery System

- Condition 1 from the ATC was included as condition 27 on the requirements for this permit unit.
- Conditions 2, 3, and 4 from the ATC were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 5 from the ATC was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 6 through 12 from the ATC were included as conditions 4 through 10 on the requirements for this permit unit.
- Condition 13 from the ATC was included as condition 24 on the requirements for this permit unit.
- Condition 14 from the ATC was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 15 from the ATC was included as condition 25 on the requirements for this permit unit.
- Conditions 16 through 57 from the ATC were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 58 from the ATC was included as condition 26 on the requirements for this permit unit.

xx. S-1216-94-1: 3,300 BBL Fixed Roof Wash Tank with Vapor Recovery System

- Condition 1 from the PTO was included as condition 20 on the requirements for this permit unit.
- Condition 2 from the PTO was included as condition 1 on the requirements for this permit unit.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition was applicable only to small producers as defined in District Rule 4623.
- Conditions 4 and 5 from the PTO were included as conditions 2 and 3 on the requirements for this permit unit.
- Condition 6 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 7 from the PTO was included as condition 4 on the requirements for this permit unit.

- Conditions 8, 9, and 10 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 11 from the PTO was included as condition 18 on the requirements for this permit unit.
- Condition 12 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 13 from the PTO was included as condition 19 on the requirements for this permit unit.
- Conditions 14 through 55 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 56 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

yy. S-1216-95-3: Waterflood Plant/Water Cleaning and Injection Operation Including One 5,000 BBL Wash Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 27 on the requirements for this permit unit.
- Conditions 2 through 11 from the PTO were included as conditions 1 through 10 on the requirements for this permit unit.
- Conditions 12 through 19 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 20 and 21 from the PTO were subsumed by tank cleaning conditions 15 through 26 on the requirements for this permit unit.
- Condition 22 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 23 from the PTO was included as condition 11 on the requirements for this permit unit.
- Condition 24 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 25 from the PTO was included as condition 25 on the requirements for this permit unit.
- Conditions 26 through 67 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 68 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

zz. S-1216-96-2: 2,000 BBL Fixed Roof Storage/Shipping Tank (#3) with Vapor Recovery

- Condition 1 from the PTO was included as condition 20 on the requirements for this permit unit.
- Condition 2 from the PTO was included as condition 1 on the requirements for this permit unit.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 4 and 5 from the PTO were included as conditions 2 and 3 on the requirements for this permit unit.
- Conditions 6 and 8 through 10 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 7 from the PTO was included as condition 4 on the requirements for this permit unit.
- Condition 11 from the PTO was included as condition 18 on the requirements for this permit unit.
- Condition 12 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 13 from the PTO was included as condition 19 on the requirements for this permit unit.
- Conditions 14 through 55 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 56 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

aaa. S-1216-97-2: 1,000 BBL Fixed Roof Filter Feed Tank (T5) with Vapor Recovery

- Condition 1 from the PTO was included as condition 25 on the requirements for this permit unit.
- Conditions 2 through 8 from the PTO were included as conditions 1 through 8 on the requirements for this permit unit.
- Conditions 9 through 16 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 17 and 18 from the PTO were subsumed by tank cleaning conditions 13 through 24 on the requirements for this permit unit.
- Condition 19 from the PTO was included as condition 107 on the facility-wide requirements.

- Condition 20 from the PTO was included as condition 9 on the requirements for this permit unit.
- Condition 21 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 22 from the PTO was included as condition 23 on the requirements for this permit unit.
- Conditions 23 through 64 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 65 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

bbb. S-1216-98-2: 2,000 BBL Fixed Roof Crude Oil Production Tank (T4) with Vapor Recovery

- Condition 1 from the PTO was included as condition 25 on the requirements for this permit unit.
- Conditions 2 through 8 from the PTO were included as conditions 1 through 8 on the requirements for this permit unit.
- Conditions 9 through 16 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 17 and 18 from the PTO were subsumed by tank cleaning conditions 13 through 24 on the requirements for this permit unit.
- Condition 19 from the PTO was included as condition 107 on the facility-wide requirements.
- Condition 20 from the PTO was included as condition 9 on the requirements for this permit unit.
- Condition 21 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 22 from the PTO was included as condition 23 on the requirements for this permit unit.
- Conditions 23 through 64 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 65 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

ccc. S-1216-100-1: 532 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 21 on the requirements for this permit unit.

- Conditions 2 and 5 from the PTO were not included as conditions on the requirements for this permit unit. The conditions were extraneous and not required for tanks with vapor recovery.
- Conditions 3 and 4 from the PTO were included as conditions 1 and 2 on the requirements for this permit unit.
- Condition 6 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 7, 8, and 10 from the PTO were included as conditions 3, 4, and 5 on the requirements for this permit unit.
- Conditions 9, 11, 12, and 13 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 14 and 16 from the PTO were included as conditions 19 and 20 on the requirements for this permit unit.
- Conditions 17 through 58 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 59 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

ddd. S-1216-101-1: 1,968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.
- Condition 2 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous and not required for tanks with vapor control.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition restated the requirement in the equipment description.
- Condition 4 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 5, 6, and 8 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 7, 9, 10, and 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 12 from the PTO was included as condition 17 on the requirements for this permit unit.
- Condition 13 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.

- Condition 14 from the PTO was included as condition 18 on the requirements for this permit unit.
- Conditions 15 through 56 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 57 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

eee. S-1216-103-1: 1,968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.
- Condition 2 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous and not required for tanks with vapor control.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition restated the requirement in the equipment description.
- Condition 4 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 5, 6, and 8 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 7, 9, 10, and 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 12 from the PTO was included as condition 17 on the requirements for this permit unit.
- Condition 13 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 14 from the PTO was included as condition 18 on the requirements for this permit unit.
- Conditions 15 through 56 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 57 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

fff. S-1216-104-1: 1,968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.

- Condition 2 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous and not required for tanks with vapor control.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition restated the requirement in the equipment description.
- Condition 4 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 5, 6, and 8 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 7, 9, 10, and 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 12 from the PTO was included as condition 17 on the requirements for this permit unit.
- Condition 13 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 14 from the PTO was included as condition 18 on the requirements for this permit unit.
- Conditions 15 through 56 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 57 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

ggg. S-1216-105-1: 1,968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.
- Condition 2 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous and not required for tanks with vapor control.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition restated the requirement in the equipment description.
- Condition 4 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 5, 6, and 8 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Conditions 7, 9, 10, and 11 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.

- Condition 12 from the PTO was included as condition 17 on the requirements for this permit unit.
- Condition 13 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 14 from the PTO was included as condition 18 on the requirements for this permit unit.
- Conditions 15 through 56 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 57 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

hhh. S-1216-106-1: 191 BBL Fixed Roof Petroleum Storage Tank

- Condition 1 from the PTO was included as condition 16 on the requirements for this permit unit.
- Conditions 2, 4, and 7 from the PTO were not included as conditions on the requirements for this permit unit. The conditions applied only to small producers as defined in District Rule 4623.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Condition 5 from the PTO was included as condition 1 on the requirements for this permit unit.
- Condition 6 from the PTO was included as condition 9 on the requirements for this permit unit.
- Condition 8 from the PTO was included as condition 15 on the requirements for this permit unit.
- Conditions 9 through 50 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 51 from the PTO was not included as a condition on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

iii. S-1216-107-2: 191 BBL Fixed Roof Petroleum Storage Tank

- Conditions 1 through 5 from the ATC were included as conditions 1 through 5 on the requirements for this permit unit.
- Condition 6 from ATC was not included as a condition on the requirements for this permit unit. The condition was not required for tanks that store liquids with a TVP of less than 0.5 psia.
- Condition 7 from the ATC was subsumed by condition 41 on the facility-wide requirements.

- Condition 8 from the ATC was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Conditions 9 through 17 from the ATC were included as conditions 6 through 14 on the requirements for this permit unit.

jjj. S-1216-108-3: 191 BBL Fixed Roof Petroleum Storage Tank

- Conditions 1 through 3 from the ATC were included as conditions 1 through 3 on the requirements for this permit unit.
- Condition 7 from the ATC was subsumed by condition 41 on the facility-wide requirements.
- Condition 8 from the ATC was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Condition 6 from the ATC was included as condition 4 on the requirements for this permit unit.

kkk. S-1216-109-1: 532 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the ATC was included as condition 27 on the requirements for this permit unit.
- Conditions 2, 3, and 4 from the ATC were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 5 from the ATC was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 6 through 13 from the ATC were included as conditions 4 through 10 and 24 on the requirements for this permit unit.
- Condition 14 from the ATC was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Condition 15 from the ATC was included as condition 25 on the requirements for this permit unit.
- Conditions 16 through 57 from the ATC were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 58 from the ATC was included as condition 27 on the requirements for this permit unit.

lll. S-1216-110-2: 532 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the ATC was included as condition 27 on the requirements for this permit unit.
- Conditions 2, 3, and 4 from the ATC were included as conditions 1, 2, and 3 on the requirements for this permit unit.

- Condition 5 from the ATC was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 6 through 13 from the ATC were included as conditions 4 through 10 and 24 on the requirements for this permit unit.
- Condition 14 from the ATC was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Condition 15 from the ATC was included as condition 25 on the requirements for this permit unit.
- Conditions 16 through 57 from the ATC were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 58 from the ATC was included as condition 27 on the requirements for this permit unit.

mmm. S-1216-111-1: 1571 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.
- Condition 2 from the PTO was included as condition 41 on the facility-wide requirements.
- Conditions 3, 4, and 6 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Conditions 5, and 7 through 9 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 10 from the PTO was included as condition 17 on the requirements for this permit unit.
- Condition 11 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 12 from the PTO was included as condition 18 on the requirements for this permit unit
- Conditions 13 through 53 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Conditions 54 and 55 from the PTO were not included as conditions on the requirements for this permit unit. The conditions applied only to small producers as defined in District Rule 4623.

nnn. S-1216-122-1: 1000 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.

- Condition 2 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 3, 4, and 6 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Conditions 5, and 7 through 9 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 10 from the PTO was included as condition 17 on the requirements for this permit unit.
- Condition 11 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 12 from the PTO was included as condition 18 on the requirements for this permit unit
- Conditions 13 through 54 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 55 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

ooo. S-1216-123-1: 10,000 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 20 on the requirements for this permit unit.
- Conditions 2, 4, and 5 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 3 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 6, and 8 through 10 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 7 from the PTO was included as condition 4 on the requirements for this permit unit.
- Condition 11 from the PTO was included as condition 18 on the requirements for this permit unit.
- Condition 12 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 13 from the PTO was included as condition 19 on the requirements for this permit unit
- Conditions 14 through 55 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.

- Condition 56 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

ppp. S-1216-124-1: 10,221 BBL Fixed Roof Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 19 on the requirements for this permit unit.
- Conditions 2 and 3 from the PTO were not included as conditions on the requirements for this permit unit. The conditions applied only to small producers as defined in District Rule 4623.
- Condition 4 from the PTO was not included as a condition of the requirements for this permit unit. The condition is obsolete since the permit unit is subject to District Rule 4623.
- Condition 5 from the PTO was included as condition 17 of the requirements for this permit unit.
- Condition 6 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 7 from the PTO was included as condition 18 on the requirements for this permit unit.
- Conditions 8 through 49 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 50 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

qqq. S-1216-125-1: 10,221 BBL Fixed Roof Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 20 on the requirements for this permit unit.
- Conditions 2, 4, and 5 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 3 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 6, 8, 9, and 10 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 11 from the PTO was included as condition 18 of the requirements for this permit unit.
- Condition 12 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on

the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.

- Condition 13 from the PTO was included as condition 19 on the requirements for this permit unit.
- Conditions 14 through 55 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 56 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

rrr. S-1216-126-1: 10,221 BBL Fixed Roof Storage Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 20 on the requirements for this permit unit.
- Conditions 2, 4, and 5 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 3 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 6, 8, 9, and 10 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 11 from the PTO was included as condition 18 of the requirements for this permit unit.
- Condition 12 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 13 from the PTO was included as condition 19 on the requirements for this permit unit.
- Conditions 14 through 55 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 56 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

sss. S-1216-127-2: 250 BBL Fixed Roof Crude Oil Drain Tank Served by a P/V Relief Valve

- Condition 1 from the ATC was included as condition 1 on the requirements for this permit unit.
- Condition 2 from the ATC was subsumed condition 41 on the facility-wide requirements.
- Condition 3 from the ATC was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.

- Condition 4 from the ATC was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 5 through 12 from the ATC were included as conditions 2 through 9 of the requirements for this permit unit.
- Condition 13 from the ATC was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 14 from the ATC was included as condition 15 on the requirements for this permit unit.

ttt. S-1216-128-1: 2,000 BBL Fixed Roof Wash Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 20 on the requirements for this permit unit.
- Conditions 2, 5, and 6 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Condition 4 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Conditions 7, 9, 10, and 11 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 8 from the PTO was included as condition 4 of the requirements for this permit unit.
- Condition 12 from the PTO was included as condition 18 on the requirements for this permit unit.
- Condition 13 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 14 from the PTO was included as condition 19 on the requirements for this permit unit.
- Conditions 15 through 56 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 57 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

uuu. S-1216-129-1: 140 BBL Fixed Roof Storage Tank

- Condition 1 from the PTO was included as condition 16 on the requirements for this permit unit.

- Conditions 2 and 4 from the PTO were not included as conditions on the requirements for this permit unit. The conditions applied only to small producers as defined in District Rule 4623.
- Condition 3 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous since the tank was not subject to District Rule 4801.
- Condition 5 from the PTO was included as condition 1 on the requirements for this permit unit.
- Condition 6 from the PTO was included as condition 9 on the requirements for this permit unit.
- Condition 7 from the PTO was not included as a condition on the requirements for this permit unit. The permit shield was based on the previous amendment of the District Rule 4623 and no longer applicable to the current amended rule.
- Condition 8 from the PTO was included as condition 15 on the requirements for this permit unit.
- Conditions 9 through 50 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 51 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

vvv. S-1216-130-1: 2400 BBL Fixed Roof Petroleum Wash Tank with Vapor Recovery

- Condition 1 from the PTO was included as condition 1 on the facility-wide requirements.
- Conditions 2 through 5 from the PTO were included as condition 1 through 4 on the requirements for this permit unit.
- Condition 6 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 7 from the PTO was included as condition 5 on the requirements for this permit unit.
- Condition 8 from the PTO was not included as a condition on the requirements for this permit unit. The condition was extraneous since PV valves are not required on tanks with vapor recovery.
- Condition 9 from the PTO was included as condition 20 on the requirements for this permit unit.
- Conditions 10 through 51 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 52 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

www. S-1216-131-1: 1000 BBL Fixed Roof Petroleum Wash Tank with Vapor Recovery

- Conditions 1 through 5 from the PTO were included as conditions 1 through 5 of the requirements for this permit unit.
- Condition 6 from the PTO was removed and included as part of the District Rule 4623 tank inspection and maintenance conditions 99 through 107 in the facility-wide requirements.
- Conditions 7 and 8 from the PTO were included as conditions 6 and 7 on the requirements for this permit unit. Reference to permit units S-1641-42 and S-1641-45 was corrected to the S-1216-44 and S-1216-46, which are the permit numbers assigned when the units were transferred to this facility.
- Condition 9 from the PTO was included as condition 8 on the requirements for this permit unit. Reference to S-1651-42 was corrected to S-1216-131.
- Condition 10 from the PTO was not included as a condition since it was not applicable to this permit unit.
- Conditions 11 and 12 from the PTO were included as conditions 9 and 10 of the requirements for this permit unit.
- Condition 13 from the PTO was deleted since it is extraneous to tanks with vapor recovery system.
- Condition 14 from the PTO was included as condition 11 on the requirements for this permit unit. Reference to permit units S-1641-42 and S-1641-45 was corrected to S-1216-44, S-1216-46, and S-1216-131.
- Condition 15 from the PTO was deleted since it is extraneous to tanks with vapor recovery system.

xxx. S-1216-132-2: WEMCO Model 84 Oil/Water Separator with Vapor Recovery

- Conditions 1 and 2 from the PTO were included as conditions 41 and 22 of the facility-wide requirements.
- Conditions 3 through 9 from the PTO were included as conditions 1 through 7 on the requirements for this permit unit.
- Conditions 10 through 56 from the PTO were replaced by condition 8 that references District Rule 4409 conditions 44 through 98 on the facility-wide requirements.
- Conditions 57 through 98 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 99 from the PTO was not included as a condition on the requirements for this permit unit. The condition is extraneous and applied only to small producers as defined in District Rule 4623.

yyy. S-1216-133-2: 500 BBL Fixed Roof Crude Oil Production Tank (T6) with Vapor Recovery

- Condition 1 from the PTO was not included as a condition on the requirements for this permit unit. The condition is obsolete since the requirement had been complied with.
- Conditions 2 through 8 from the PTO were included as conditions 1 through 7 of the requirement for this permit unit.
- Conditions 9 through 15, 19, and 20 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 16 from the PTO was included as condition 8 on the requirements for this permit unit.
- Conditions 17 and 18 from the PTO were subsumed by tank cleaning conditions 10 through 21 on the requirements for this permit unit.
- Conditions 21 through 62 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 63 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

zzz. S-1216-134-2: 500 BBL Fixed Roof Crude Oil Production Tank (T7) with Vapor Recovery

- Conditions 1 through 7 from the PTO were included as conditions 1 through 7 of the requirement for this permit unit.
- Conditions 8 through 14, 18, and 19 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 15 from the PTO was included as condition 8 on the requirements for this permit unit.
- Conditions 16 and 17 from the PTO were subsumed by tank cleaning conditions 10 through 21 on the requirements for this permit unit.
- Conditions 20 through 61 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 62 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

aaaa. S-1216-135-2: 10,000 BBL Fixed Roof Crude Oil Production Tank (T2) with Vapor Recovery

- Conditions 1 through 7 from the PTO were included as conditions 1 through 7 of the requirement for this permit unit.

- Conditions 8 through 14, 18, and 19 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 15 from the PTO was included as condition 8 on the requirements for this permit unit.
- Conditions 16 and 17 from the PTO were subsumed by tank cleaning conditions 10 through 21 on the requirements for this permit unit.
- Conditions 20 through 61 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 62 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

bbbb. S-1216-136-2: 2000 BBL Fixed Roof Crude Oil Production Tank (T8) with Vapor Recovery

- Conditions 1 through 7 from the PTO were included as conditions 1 through 7 of the requirement for this permit unit.
- Conditions 8 through 14, 18, and 19 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 15 from the PTO was included as condition 8 on the requirements for this permit unit.
- Conditions 16 and 17 from the PTO were subsumed by tank cleaning conditions 10 through 21 on the requirements for this permit unit.
- Conditions 20 through 61 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 62 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

cccc. S-1216-137-2: 500 BBL Fixed Roof Crude Oil Storage Tank (T9) with Vapor Recovery

- Conditions 1 through 5 from the PTO were included as conditions 1 through 5 on the requirement for this permit unit.
- Conditions 6 through 12, 16, and 17 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 13 from the PTO was included as condition 6 on the requirements for this permit unit.
- Conditions 14 and 15 from the PTO were subsumed by tank cleaning conditions 10 through 21 on the requirements for this permit unit.

- Conditions 18 through 59 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.
- Condition 60 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.

dddd. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 36 from the PTO were included as conditions 1 through 36 of the requirement for this permit unit.

eeee. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 34 from the PTO were included as conditions 1 through 34 of the requirement for this permit unit.

ffff. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 34 from the PTO were included as conditions 1 through 34 of the requirement for this permit unit.

gggg. S-1216-142-2: 2014 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1, 2, and 4 from the PTO were included as conditions 1, 2, and 3 on the requirements for this permit unit
- Conditions 3, 5, and 6 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 7 through 10 from the PTO were included as conditions 19, 20, 4, and 5 on the requirements for this permit unit.
- Conditions 11 through 18, and 21 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 19 from the PTO was included as condition 6 on the requirements for this permit unit.
- Condition 20 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.

hhhh. S-1216-143-1: 2500 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 and 2 from the PTO were included as conditions 1 and 2 on the requirements for this permit unit
- Conditions 2 and 4 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 10 from the PTO were included as conditions 20, 21, 22, 3, 4, and 5 on the requirements for this permit unit.
- Conditions 11 through 18, and 21 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 19 from the PTO was included as condition 6 on the requirements for this permit unit.
- Condition 20 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.
- Condition 22 from the PTO was included as condition 7 on the requirements for this permit unit.

iiii. S-1216-144-1: 2014 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 and 3 from the PTO were included as conditions 1 and 2 on the requirements for this permit unit
- Conditions 2 and 4 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 9 from the PTO were included as conditions 18, 19, 20, 3, and 4 on the requirements for this permit unit.
- Conditions 10 through 17, and 20 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 19 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.

jjjj. S-1216-145-1: 2014 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 and 3 from the PTO were included as conditions 1 and 2 on the requirements for this permit unit
- Conditions 2 and 4 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.

- Conditions 5 through 9 from the PTO were included as conditions 18, 19, 20, 3, and 4 on the requirements for this permit unit.
- Conditions 10 through 17, and 20 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 19 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.

kkkk. S-1216-146-1: 200 BBL Fixed Roof Petroleum Test Tank

- Conditions 1 through 5 from the PTO were included as conditions 1 through 5 on the requirements for this permit unit
- Conditions 6 through 13 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 14, 15, and 16 from the PTO were included as conditions 6, 12, and 13 on the requirements for this permit unit.

llll. S-1216-147-1: 200 BBL Fixed Roof Petroleum Test Tank

- Conditions 1 through 5 from the PTO were included as conditions 1 through 5 on the requirements for this permit unit
- Conditions 6 through 13 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 14, 15, and 16 from the PTO were included as conditions 6, 12, and 13 on the requirements for this permit unit.

mmmm. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich-Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 34 from the PTO were included as conditions 1 through 34 of the requirement for this permit unit.

nnnn. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich-Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 34 from the PTO were included as conditions 1 through 34 of the requirement for this permit unit.

oooo. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich-Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 34 from the PTO were included as conditions 1 through 34 of the requirement for this permit unit.

pppp. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich-Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1 through 28 from the PTO were included as conditions 1 through 28 of the requirement for this permit unit.

qqqq. S-1216-152-1: 2000 BBL Produced Water Tank with Vapor Recovery

- Conditions 1, 2, and 3 from the PTO were included as conditions 1, 2, and 3.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 8 from the PTO were included as conditions 4 through 7 on the requirements for this permit unit.
- Condition 9 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.
- Condition 10 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 11 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 12 from the PTO was included as condition 21 on the requirements for this permit unit.
- Conditions 13, 14, and 18 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 15, 16, and 17 from the PTO were included as conditions 22, 23, and 8 on the requirements for this permit unit.

rrrr. S-1216-153-1: 2000 BBL Produced Water Tank with Vapor Recovery

- Conditions 1, 2, and 3 from the PTO were included as conditions 1, 2, and 3.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 8 from the PTO were included as conditions 4 through 7 on the requirements for this permit unit.
- Condition 9 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.
- Condition 10 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.

- Condition 11 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 12 from the PTO was included as condition 21 on the requirements for this permit unit.
- Conditions 13, 14, and 18 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 15, 16, and 17 from the PTO were included as conditions 22, 23, and 8 on the requirements for this permit unit.

ssss. S-1216-154-1: 1000 BBL Produced Water Tank with Vapor Recovery

- Conditions 1, 2, and 3 from the PTO were included as conditions 1, 2, and 3.
- Condition 4 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 8 from the PTO were included as conditions 4 through 7 on the requirements for this permit unit.
- Condition 9 from the PTO was not included as a requirement for this permit unit. The condition was extraneous since there permit did not have a specified pressure relief valve setting.
- Condition 10 from the PTO was subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Condition 11 from the PTO was not included as conditions on the requirements for this permit unit. The condition applied only to small producers as defined in District Rule 4623.
- Condition 12 from the PTO was included as condition 21 on the requirements for this permit unit.
- Conditions 13, 14, 18, and 19 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 15, 16, and 17 from the PTO were included as conditions 22, 23, and 8 on the requirements for this permit unit.

tttt. S-1216-155-1: 10,000 BBL Fixed Roof Petroleum Production Tank with Vapor Recovery

- Conditions 1, 2, and 3 from the PTO were included as conditions 1, 2, and 3.
- Conditions 4 and 12 through 17 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 11 from the PTO were included as conditions 4 through 10 on the requirements for this permit unit.

- Conditions 18 through 29 from the PTO were included as conditions 14 through 25 on the requirements for this permit unit.
- Conditions 30 through 70 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.

uuuu. S-1216-156-1: 500 BBL Fixed Roof Petroleum Production Tank with Vapor Recovery

- Conditions 1, 2, and 3 from the PTO were included as conditions 1, 2, and 3.
- Conditions 4 and 12 through 17 from the PTO were subsumed by District Rule 4623 tank inspection and maintenance conditions 99 through 107 on the facility-wide requirements.
- Conditions 5 through 11 from the PTO were included as conditions 4 through 10 on the requirements for this permit unit.
- Conditions 18 through 29 from the PTO were included as conditions 14 through 25 on the requirements for this permit unit.
- Conditions 30 through 70 from the PTO were subsumed by conditions 1 through 41 on the facility-wide requirements.

2. District Rule 1081, Conditional Approval

The purpose of this rule is to ensure that any source operation which emits or may emit air contaminants provides adequate and safe facilities for use in sampling to determine compliance. This rule also specifies methods and procedures for source testing, sample collection, and compliance determination.

a. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (Non-Compliant Dormant Emissions Unit)

- Conditions 19, 20, and 21 comply with the requirements of this rule.

b. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

- Conditions 20, 21, and 22 comply with the requirements of this rule.

c. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

- Conditions 16, 17, and 18 comply with the requirements of this rule.

d. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator with Flue Gas Recirculation

- Conditions 12, 19, 20, 21, and 22 comply with the requirements of this rule.

e. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 28, 31, 32, and 34 comply with the requirements of this rule.

f. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 27, 29, 30, and 32 comply with the requirements of this rule.

g. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 27, 29, 30, and 32 comply with the requirements of this rule.

h. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 27, 29, 30, and 32 comply with the requirements of this rule.

i. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 27, 29, 30, and 32 comply with the requirements of this rule.

j. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 27, 29, 30, and 32 comply with the requirements of this rule.

k. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 21, 23, 24, and 26 comply with the requirements of this rule.

3. District Rule 2080, Conditional Approval

The purpose of this rule is to grant authority to the District to issue specific written conditions on an Authority to Construct or a Permit to Operate to assure compliance with air contaminant emission standards or limitations.

This rule allows the following storage tanks to participate in the voluntary tank inspection and maintenance (I & M) and tank interior cleaning programs even though the tanks are not subject to the requirements of District Rule 4623 when storing organic liquids with a true vapor pressure (TVP) < 0.5 psia.

a. S-1216-1-2, -2-2, -3-2, -7-2, -8-2, -10-2, -11-2, -20-2, -21-2, -53-1, and -56-1: Fixed Roof Tanks

- Conditions 9 through 13 comply with the requirements of this rule.

b. S-1216-51-1, -52-1, -57-1, and -58-1: Fixed Roof Tanks

- Condition 4 complies with the requirements of this rule.

c. S-1216-106-1: 191 BBL Fixed Roof Petroleum Storage Tank

- Conditions 10 through 14 comply with the requirements of this rule.

d. S-1216-107-2: 1042 BBL Fixed Roof Crude Oil Storage Tank

- Conditions 15 through 19 comply with the requirements of this rule.

e. S-1216-129-1: 140 BBL Fixed Roof Storage Tank

- Conditions 10 through 14 comply with the requirements of this rule.

4. District Rule 2520, Federally Mandated Operating Permits

The purpose of this rule is to provide an administrative mechanism for issuing operating permits for new and modified sources of air contaminants in accordance with requirements of 40 CFR Part 70; an administrative mechanism for issuing renewed operating permits for sources of air contaminants in accordance with requirements of 40 CFR Part 70; an administrative mechanism for revising, reopening, revoking, and terminating operating permits for sources of air contaminants in accordance with requirements of 40 CFR Part 70; an administrative mechanism for incorporating requirements authorized by preconstruction permits issued under District Rule 2201 (New and Modified Stationary

Source Review) in a Part 70 permit as administrative amendments, provided that such permits meet procedural requirements substantially equivalent to the requirements of 40 CFR 70.7 and 70.8, and compliance requirements substantially equivalent to those contained in 40 CFR 70.6; and the applicable federal and local requirements to appear on a single permit.

Section 5.3.2 requires the permittee file an application for a permit modification prior to implementing the requested change. This also applies to sources not previously subject to the requirements of this rule that become subject to the requirements due to a minor or significant modification.

In Section 9.3.2, where applicable requirements do not require periodic testing or instrumental or non-instrumental monitoring, periodic monitoring to yield reliable data for the relevant time period that are representative of the source's compliance with the permit.

Section 9.4.2 requires that all required monitoring data and support information be retained for a period of at least 5 years from the date of monitoring sample, measurement, or report.

a. S-1216-68-1: Glycol Gas Dehydration Operation

- Condition 1 complies with the requirements of this rule.

b. S-1216-132-2: WEMCO Model 84 Oil/Water Separator

- Conditions 2, 5, and 6 comply with the requirements of this rule.

Mandatory Greenhouse Gas Reporting

There are no federally applicable Greenhouse Gas (GHG) requirements for this source. It should be noted that the Mandatory Greenhouse Gas Reporting rule (40CFR Part 98) is not included in the definition of an applicable requirement within Title V (per 40CFR 71.2). Therefore, there will be no further discussion of GHG in this evaluation.

5. District Rule 4201, Particulate Matter Concentration

The purpose of this rule is to protect the ambient air quality by establishing a particulate matter emission standard. A person shall not release or discharge into the atmosphere from any single source operation, dust, fumes, or total suspended particulate matter emissions in excess of 0.1 grain per cubic foot of gas at dry standard conditions.

Steam Generator

The expected concentration of PM emitted from LPG-fired steam generator is shown by the following analysis.

$$\left(\frac{0.7\,lb-PM}{10^3\,gal}\right)\times\left(\frac{10^3\,gal}{9.5\times10^6\,Btu}\right)\times\left(\frac{7{,}000\,grains}{lb}\right)\times\left(\frac{10^6\,Btu}{8{,}710\,dscf}\right)=0.06\,\frac{grain}{dscf}$$

Where:

$\left(\frac{0.7\,lb-PM}{10^3\,gal}\right)$ = Total PM when filing on propane (AP-42, 07/08, Table 1.5-1)

$\left(\frac{9.5\times10^6\,Btu}{10^3\,gal}\right)$ = Heating value for propane (AP-42, 07/08, Table 1.5-1

$\left(\frac{10^6\,Btu}{8{,}710\,dscf}\right)$ = F Factor (40 CFR 60, Appendix A-7, Table 19-1)

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator

- Conditions 11 and 29 comply with the requirements of this rule.

<u>Internal Combustion (IC) Engines</u>

The following analysis shows that internal combustion (IC) engines are in compliance with this particulate matter (PM) emission limit.

The expected concentration of PM emitted from a natural gas fired IC engine is shown by the following analysis:

$$\left(\frac{0.019\,lb-PM}{10^6\,Btu}\right)\times\left(\frac{7{,}000\,grains}{lb}\right)\times\left(\frac{10^6\,Btu}{8{,}710\,dscf}\right)=0.015\,\frac{grain}{dscf}$$

Where:

$\left(\frac{0.019\,lb-PM}{10^6\,Btu}\right)$ = filterable and condensable PM (AP-42, 7/00, Table 3.2-3)

$\left(\frac{10^6\,Btu}{8{,}710\,dscf}\right)$ = F Factor (40 CFR 60, Appendix A-7, Table 19-1)

The preceding analysis demonstrates that IC engines firing on natural gas will be in compliance with the PM limits of this rule. The following permit conditions will assure compliance with the emissions limit of the rule.

a. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (Non-Compliant Dormant Emissions Unit)

   - Conditions 7 and 8 assure compliance with the requirements of this rule.

b. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

   - Conditions 5 and 27 comply with the requirements of this rule.

c. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

   - Conditions 1 and 23 comply with the requirements of this rule.

d. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 9 and 36 comply with the requirements of this rule.

e. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Condition 8 complies with the requirements of this rule.

f. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 8 and 34 comply with the requirements of this rule.

g. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 8 and 34 comply with the requirements of this rule.

h. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 8 and 34 comply with the requirements of this rule.

i. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 8 and 34 comply with the requirements of this rule.

j. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 7 and 28 comply with the requirements of this rule.

6. District Rule 4301 – Fuel Burning Equipment

The purpose of this rule is to limit the emission of air contaminants from fuel burning equipment. This rule limits the concentration of combustion contaminants and specifies maximum emission rates for sulfur dioxide, nitrogen oxide and combustion contaminant emissions. Section 5.1 of the rule limits the emission of combustion contaminants in the form of PM to 0.1 grain per cubic foot of gas corrected to 12% carbon dioxide.

Section 5.2 of the rule does not apply to mobile fuel burning equipment. The following unit is a portable (mobile) steam generator.

Assuming an excess air concentration of 0% in the exhaust results in the maximum particulate matter concentration for any given emission rate. In general, units firing on propane comply with these limits as follows.

$$\left(\frac{0.7\,lb-PM}{10^3\,gal}\right)\times\left(\frac{10^3\,gal}{9.5\times10^6\,Btu}\right)\times\left(\frac{7{,}000\,grains}{lb}\right)\times\left(\frac{10^6\,Btu}{8{,}710\,dscf}\right)=0.06\,\frac{grain}{dscf}$$

Where:

$\left(\frac{0.7\,lb-PM}{10^3\,gal}\right)$ = Total PM when filing on propane (AP-42, 07/08, Table 1.5-1)

$\left(\frac{9.5\times10^6\,Btu}{10^3\,gal}\right)$ = Heating value for propane (AP-42, 07/08, Table 1.5-1

$\left(\frac{10^6\,Btu}{8{,}710\,dscf}\right)$ = F Factor (40 CFR 60, Appendix A-7, Table 19-1)

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator

- Condition 29 complies with the requirements of this rule.

7. District Rule 4305 – Boilers, Steam Generators, and Process Heaters – Phase 2

The purpose of this rule is to limit emissions of oxides of nitrogen (NO_X) and carbon monoxide (CO) from any gaseous fuel or liquid fuel fired boilers, steam generators, and process heaters with a rated heat input greater than 5 million Btu per hour.

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator

- Conditions 10, 13 through 18, 22, 23, 24, and 25 comply with the requirements of this rule.

8. District Rule 4306 – Boilers, Steam Generators, and Process Heaters – Phase 3

The purpose of this rule is to limit emissions of oxides of nitrogen (NO_X) and carbon monoxide (CO) from any gaseous fuel or liquid fuel fired boilers, steam generators, and process heaters with a rated heat input greater than 5 million Btu per hour. The rule was amended in October 16, 2008.

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator

- Conditions 1 through 5, 10, 13 through 18, 22, 23, 24, and 25 comply with the requirements of this rule.

9. District Rule 4311 – Flares

The purpose of this rule is to limit the emissions of volatile organic compounds (VOC), oxides of nitrogen (NO_X), and sulfur oxides (SO_X) from the operation of flares.

The rule was amended in June 18, 2009 but had not been approved for inclusion in the District's State Implementation Plan (SIP). The stringency analysis in Attachment D shows that the amended rule is as stringent as the SIP approved version of the rule that was adopted in June 20, 2002.

a. S-1216-69-1: Emergency Gas Plant Flare

- Conditions 1, 4, 5, 6, 7, and 8 comply with the requirements of this rule.

b. S-1216-87-2: 44.58 MMBtu/hr Well Safety Flare

- Conditions 4 through 15 comply with the requirements of this rule.

c. S-1216-88-1: 44.58 MMBtu/hr Well Safety Flare

- Conditions 1 through 12 comply with the requirements of this rule.

d. S-1216-89-1: 0.028 MMBtu/hr Tank Vapor Recovery System Flare

- Conditions 1 through 12 comply with the requirements of this rule.

10. District Rule 4320 – Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr

The purpose of this rule is to limit the emissions of oxides of nitrogen (NO_X), carbon monoxide (CO), oxides of sulfur (SO_2), and particulate matter 10 microns or less (PM_{10}) from boilers, steam generators, and process heaters.

Section 5.1 states that operators of a unit(s) shall comply with all applicable requirements of the rule and one of the following, on a unit-by-unit basis:

Section 5.1.1 requires the unit comply with the emission limits specified in Sections 5.2 and 5.4; or

Section 5.1.2, Pay an annual emissions fee to the District as specified in Section 5.3 and comply with the control requirements specified in Section 5.4.

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator

- Conditions 6, 31, 32, and 33 comply with the requirements of this rule.

11. District Rule 4408, Glycol Dehydration Systems

The purpose of this rule is to limit VOC emissions from glycol dehydration systems.

Section 5.1 requires that no person shall operate a glycol dehydration system unless the VOC emissions from the glycol dehydration vents are controlled using one of the following:

5.1.1 A system that directs all vapors to a vapor recovery system, a fuel gas system or a sales gas system, or
5.1.2 A system in which VOC emissions are combusted by a flare, incinerator, reboiler, or thermal oxidizer. This system shall have all of the following features, as a minimum:

5.1.2.1 Operate continually in a smokeless mode,
5.1.2.2 Electronically controlled ignition system with a malfunction alarm system if the pilot flame fails,
5.1.2.3 Liquid knock-out system to condense any condensable vapors, and
5.1.2.4 Sight glass ports, if the flame is not visible.

In Section 5.2, the condensed hydrocarbon liquid stream from the glycol dehydration vent shall be stored and handled in a manner that will not cause or allow evaporation of VOC to the atmosphere.

Section 5.3 states that all control systems shall be maintained in a leak-free condition.

Section 6.1.1 requires that the operator of any glycol dehydration system shall maintain monthly records of the amount of gas dehydrated.

Section 6.1.2 requires the retention of the following information: Facility name, APCD permit number; location, size of glycol dehydrator reboiler and the type of glycol used; description of any installed VOC control system; flow diagram of dehydrator and any VOC controls; maintenance records of the VOC control system; reports of required source tests; and all records necessary to document the inputs to and outputs of GRI-GLYCalc software if used.

a. S-1216-68-1: Glycol Gas Dehydration Operation

- Conditions 10, 12, and 14 through 18 comply with the requirements of this rule.

12. District Rule 4409, Components at Light Crude Oil Production Facilities, Natural Gas Production Facilities, and Natural Gas Processing Facilities

The purpose of this rule is to limit VOC emissions from leaking components at light crude oil production facilities, natural gas production facilities, and natural gas processing facilities.

a. S-1216-0-1: Facility-Wide Requirements

- Conditions 44 through 98 comply with the requirements of this rule.

13. District Rule 4623, Storage of Organic Liquids

The purpose of this rule is to limit volatile organic compound (VOC) emissions from the storage of organic liquids. The rule applies to any tank with a capacity of 1,100 gallons or greater in which any organic liquid is placed, held, or stored.

Section 4.4 states that tanks exclusively receiving and/or storing an organic liquid with a true vapor pressure (TVP) less than 0.5 psia are exempt from all other requirements of the rule except for complying with the TVP and API gravity testing provisions of section 6.2, recordkeeping provisions of section 6.3.6, and test methods of section 6.4.

Section 5.1 requires that no organic liquid shall be placed, held, or stored in any tank unless the tank is equipped with a VOC control system identified in Table 1. All tanks subject to the control requirements shall be maintained in a leak-free condition.

Section 5.2 requires that pressure-vacuum relief valve shall be set to within ten (10) percent of the maximum allowable working pressure of the tank. The valves shall be permanently labeled with the operating pressure settings.

Section 5.6 requires that fixed roof tanks shall be fully enclosed and shall be maintained in a leak-free condition. The approved vapor recovery system shall consist of a closed system that collects all VOCs from the storage tank, and a VOC control device. This section also specifies the applicable VOC control device.

Section 5.7 states only operators who elect to participate in the voluntary tank preventive inspection and maintenance, and tank interior cleaning program shall be allowed to use the provisions specified in Tables 3 to 5 and Section 5.7.5.

Section 6.2 requires initial and periodic TVP testing of each uncontrolled fixed roof tank.

Section 6.3 requires that tank subject to the requirements of this rule shall keep an accurate record of each organic liquid stored in each tank, including its storage temperature, TVP, and API gravity, except for fixed roof tanks equipped with a vapor recovery system.

Section 6.4 addresses the test methods approved by the APCO and EPA.

a. S-1216-1-2, -2-2, -3-2, -7-2, -8-2, -10-2, -11-2, -20-2, and -21-2: Fixed Roof Tanks

    - Conditions 1 through 8 comply with the requirements of this rule.

b. S-1216-22-2: 490 BBL Fixed Roof Wash Tank

    - Conditions 3 and 6 through 16 comply with the requirements of this rule.

c. S-1216-42-1: 500 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

d. S-1216-43-1: 500 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

e. S-1216-44-1: 2,000 BBL Fixed Roof Petroleum Wash Tank with Vapor Recovery

- Conditions 1, 4, and 10 through 24 comply with the requirements of this rule.

f. S-1216-45-1: 500 BBL Fixed Roof Petroleum Wash Tank

- Conditions 1 through 7 comply with the requirements of this rule.

g. S-1216-46-1: 1,000 BBL Fixed Roof Petroleum Shipping Tank with Vapor Recovery

- Conditions 2, 4, 5, and 8 through 23 comply with the requirements of this rule.

h. S-1216-47-1: 300 BBL Fixed Roof Petroleum Wash Tank

- Conditions 1 and 3 through 15 comply with the requirements of this rule.

i. S-1216-48-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Conditions 1, 2, and 7 through 22 comply with the requirements of this rule.

j. S-1216-49-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Conditions 1, 3, and 4 through 18 comply with the requirements of this rule.

k. S-1216-50-1: 750 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

- Conditions 1, 2, and 6 through 19 comply with the requirements of this rule.

l. S-1216-51-1: 5,000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 and 2 comply with the requirements of this rule.

m. S-1216-52-1: 750 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 and 2 comply with the requirements of this rule.

n. S-1216-53-1: 1000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 8 comply with the requirements of this rule.

o. S-1216-54-1: 500 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

- Conditions 1 through 4 and 6 through 18 comply with the requirements of this rule.

p. S-1216-55-1: 200 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 14 comply with the requirements of this rule.

q. S-1216-56-1: 500 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 through 8 comply with the requirements of this rule.

r. S-1216-57-1 and -58-1: 1000 BBL Fixed Roof Crude Oil Production Tank

- Conditions 1 and 2 comply with the requirements of this rule.

s. S-1216-59-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Conditions 1, 3, 4, 5, 6, and 9 through 21 comply with the requirements of this rule.

t. S-1216-60-1 and -61-1: 500 BBL Fixed Roof Crude Oil Storage Tank with Vapor Recovery

- Conditions 1, 2, 3, and 5 through 18 comply with the requirements of this rule.

u. S-1216-62-1: 1000 BBL Fixed Roof Crude Oil Wash Tank with Vapor Recovery

- Conditions 1, 2, 3, and 5 through 18 comply with the requirements of this rule.

v. S-1216-63-1: 210 BBL Fixed Roof Shipping Tank with Vapor Recovery

- Conditions 1, 2, 3, and 9 through 22 comply with the requirements of this rule.

w. S-1216-64-3: 3000 BBL Fixed Roof Wash Tank with Vapor Recovery

- Conditions 1, 3, 4, 5, 6, and 8 through 20 comply with the requirements of this rule.

x. S-1216-66-1: 3000 BBL Fixed Roof Produced Water Tank with Vapor Recovery

- Conditions 2 and 5 through 23 comply with the requirements of this rule.

y. S-1216-72-1: 16,000 BBL Fixed Roof Production Tank with Vapor Recovery

- Conditions 1, 3, 4, 5, 6, and 9 through 21 comply with the requirements of this rule.

z. S-1216-73-1: 1,500 BBL Fixed Roof Production Tank with Vapor Recovery

- Conditions 1, 3, 4, 5, 6, and 9 through 21 comply with the requirements of this rule.

aa. S-1216-75-1: 1,500 BBL Fixed Roof Crude Oil Tank with Vapor Recovery

- Conditions 1, 3, 4, 5, 6, and 9 through 21 comply with the requirements of this rule.

bb. S-1216-78-1: 1,000 BBL Fixed Roof Slop Oil Tank with Vapor Recovery

- Conditions 2, 4, 5, 6, 7, and 9 through 21 comply with the requirements of this rule.

cc. S-1216-86-1: 100 BBL Fixed Roof Production Tank with Vapor Recovery

- Conditions 1, 2, 6, 7, 8, and 10 through 22 comply with the requirements of this rule.

dd. S-1216-93-2: 1,000 BBL Fixed Roof Wash Tank with Vapor Recovery

- Conditions 1, 3, 4, and 8 through 24 comply with the requirements of this rule.

ee. S-1216-94-1: 3,300 BBL Fixed Roof Wash Tank with Vapor Recovery

- Conditions 2 through 18 comply with the requirements of this rule.

ff. S-1216-95-3: Waterflood Plant/Water Cleaning and Injection Operation Including One 5,000 BBL Wash Tank with Vapor Recovery

- Conditions 4, 5, and 12 through 25 comply with the requirements of this rule.

gg. S-1216-96-2: 2000 BBL Fixed Roof Storage/Shipping Tank (#3) with Vapor Recovery

- Conditions 2 through 18 comply with the requirements of this rule.

hh. S-1216-97-2: 1,000 BBL Fixed Roof Filter Feed Tank (T5) with Vapor Recovery

- Conditions 1, 2, and 10 through 23 comply with the requirements of this rule.

ii. S-1216-98-2: 2000 BBL Fixed Roof Crude Oil Production Tank (T4) with Vapor Recovery

- Conditions 1, 2, 3, and 10 through 23 comply with the requirements of this rule.

jj. S-1216-100-1: 532 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 3 through 19 comply with the requirements of this rule.

kk. S-1216-101-1: 1968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

ll. S-1216-102-1: 532 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

mm. S-1216-103-1: 1968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

nn. S-1216-104-1: 1968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

oo. S-1216-105-1: 1968 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

pp. S-1216-106-1: 191 BBL Fixed Roof Petroleum Storage Tank

- Conditions 1 through 9 comply with the requirements of this rule.

qq. S-1216-107-2: 1042 BBL Fixed Roof Crude Oil Storage Tank

- Conditions 3 through 14 comply with the requirements of this rule.

rr. S-1216-108-3: 532 BBL Fixed Roof Crude Oil Storage Tank

- Conditions 1 through 4 comply with the requirements of this rule.

ss. S-1216-110-2: 532 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1, 4, and 8 through 24 comply with the requirements of this rule.

tt. S-1216-111-1: 1571 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

uu. S-1216-122-1: 1000 BBL Crude Oil Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

vv. S-1216-123-1: 10,000 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 2 through 18 comply with the requirements of this rule.

ww. S-1216-124-1: 10,221 BBL Fixed Roof Storage Tank with Vapor Recovery

- Conditions 1 through 17 comply with the requirements of this rule.

xx. S-1216-125-1: 10,221 BBL Fixed Roof Storage Tank with Vapor Recovery

- Conditions 2 through 18 comply with the requirements of this rule.

yy. S-1216-126-1: 10,221 BBL Fixed Roof Storage Tank with Vapor Recovery

- Conditions 2 through 18 comply with the requirements of this rule.

zz. S-1216-127-2: 250 BBL Fixed Roof Crude Oil Drain Tank

- Conditions 1 through 15 comply with the requirements of this rule.

aaa. S-1216-128-1: 2000 BBL Fixed Roof Wash Tank

- Conditions 2 through 18 comply with the requirements of this rule.

bbb. S-1216-129-1: 140 BBL Fixed Roof Storage Tank

- Conditions 1 through 9 comply with the requirements of this rule.

ccc. S-1216-130-1: 2400 BBL Fixed Roof Petroleum Wash Tank with Vapor Recovery

- Conditions 1, 2, 3, and 6 through 19 comply with the requirements of this rule.

ddd. S-1216-131-1: 1000 BBL Fixed Roof Petroleum Wash Tank with Vapor Recovery

- Conditions 1, 3, 4, and 12 through 24 comply with the requirements of this rule.

eee. S-1216-133-2: 500 BBL Fixed Roof Crude Oil Production Tank (T6) with Vapor Recovery

- Conditions 1, 2, and 9 through 21 comply with the requirements of this rule.

fff. S-1216-134-2: 500 BBL Fixed Roof Crude Oil Production Tank (T7) with Vapor Recovery

- Conditions 1, 2, and 9 through 22 comply with the requirements of this rule.

ggg. S-1216-135-2: 10,000 BBL Fixed Roof Crude Oil Production Tank (T2) with Vapor Recovery

- Conditions 1, 2, and 9 through 22 comply with the requirements of this rule.

hhh. S-1216-136-2: 2,000 BBL Fixed Roof Crude Oil Production Tank (T8) with Vapor Recovery

- Conditions 1, 2, and 9 through 22 comply with the requirements of this rule.

iii. S-1216-137-2: 500 BBL Fixed Roof Crude Oil Production Tank (T9) with Vapor Recovery

- Conditions 1, 2, 5, and 7 through 20 comply with the requirements of this rule.

jjj. S-1216-142-2: 2014 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1, 2, 3, and 6 through 18 comply with the requirements of this rule.

kkk. S-1216-143-1: 2500 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1, 2, and 6 through 20 comply with the requirements of this rule.

lll. S-1216-144-1: 2014 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1, 2, and 5 through 18 comply with the requirements of this rule.

mmm. S-1216-145-1: 2014 BBL Fixed Roof Petroleum Storage Tank with Vapor Recovery

- Conditions 1, 2, and 5 through 18 comply with the requirements of this rule.

nnn. S-1216-146-1: 200 BBL Fixed Roof Petroleum Test Tank

- Conditions 1 through 12 comply with the requirements of this rule.

ooo. S-1216-147-1: 200 BBL Fixed Roof Petroleum Test Tank

- Conditions 1 through 12 comply with the requirements of this rule.

ppp. S-1216-152-1: 2000 BBL Produced Water Tank with Vapor Recovery

- Conditions 2, 3, 4, 5, and 8 through 21 comply with the requirements of this rule.

qqq. S-1216-153-1: 2000 BBL Produced Water Tank with Vapor Recovery

- Conditions 2, 3, 4, 5, and 8 through 21 comply with the requirements of this rule.

rrr. S-1216-154-1: 1000 BBL Produced Water Tank with Vapor Recovery

- Conditions 2, 3, 4, 5, and 8 through 21 comply with the requirements of this rule.

sss. S-1216-155-1: 10,000 BBL Produced Water Tank with Vapor Recovery

- Conditions 1 through 6 and 11 through 25 comply with the requirements of this rule.

ttt. S-1216-156-1: 500 BBL Produced Water Tank with Vapor Recovery

- Conditions 1 through 6 and 11 through 25 comply with the requirements of this rule.

14. District Rule 4701, Internal Combustion Engines–Phase 1

The purpose of this rule is to limit the emissions of nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. Except as provided in Section 4.0, the provisions of this rule apply to any internal combustion engine, rated greater than 50 bhp, that requires a Permit to Operate (PTO).

There are 10 natural gas-fired IC engine involved with this project. Pursuant to Section 2.0 of District Rule 4701, these engines are subject to District Rule 4701–*Internal Combustion Engines–Phase 1*. In addition, these engine are also subject to District Rule 4702–*Internal Combustion Engines–Phase 2.*

Since the emissions limits of District Rule 4702 and all other requirements are equivalent or more stringent than District Rule 4701 requirements, compliance with 4702 rule requirements will satisfy requirements of District Rule 4701 and no further discussion is required.

15. District Rule 4702, Internal Combustion Engines–Phase 2

The purpose of this rule is to limit the emissions of nitrogen oxides (NO_X), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. This rule applies to any internal combustion (IC) engine with a rated brake horsepower greater than 50 horsepower.

a. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (Non-Compliant Dormant Emissions Unit)

   - Conditions 2 and 3 comply with the requirements of this rule.

b. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

   - Conditions 2, 3, 6, 7, 8, 14, 16 through 20, 23, 24, 25, and 26 comply with the requirements of this rule.

c. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

   - Conditions 2, 3, 4, 10, 12, 13, 14, 19, 20, 21, and 22 comply with the requirements of this rule.

d. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 4, 6, 7, 8, 10, 12, 13 through 20, 29, 30, 31, and 35 comply with the requirements of this rule.

e. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1, 5, 6, 7, 9, 11 through 19, 28, 29, 31, and 33 comply with the requirements of this rule.

f. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1, 2, 3, 6, 9, 11 through 19, 28, 29, 31, and 33 comply with the requirements of this rule.

g. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1, 2, 3, 6, 9, 11 through 19, 28, 29, 31, and 33 comply with the requirements of this rule.

h. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1, 2, 3, 6, 9, 11 through 19, 28, 29, 31, and 33 comply with the requirements of this rule.

i. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1, 2, 3, 6, 9, 11 through 19, 28, 29, 31, and 33 comply with the requirements of this rule.

j. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 1, 2, 3, 6, 8, 10, 11, 12, 13, 22, 23, 25, and 27 comply with the requirements of this rule.

16. District Rule 4801, Sulfur Compounds

The purpose of this rule is to limit the emissions of sulfur compounds. A maximum concentration and test method are specified.

Section 3.1 and 3.2 set forth the emissions limits and the test methods used to determine such emissions. District Rule 4801 has been submitted to the EPA to replace Kern County Rule 407. District Rule 4801 is at least as stringent as the county SIP rule addressing breakdowns, as demonstrated in Table 3.

Comparison of District Rule 4801 to Kern County Rule 407

REQUIREMENTS	District Rule 4801	Kern County Rule 407
A person shall not discharge into the atmosphere sulfur compounds, which would exist as a liquid or gas at standard conditions, exceeding in concentration at the point of discharge: two-tenths (0.2) percent by volume calculated as sulfur dioxide (SO2), on a dry basis averaged over 15 consecutive minutes.	X	X
EPA Method 8 and ARB Method 1-100 (Continuous Emission Stack Sampling) shall be used to determine such emissions.	X	

Steam Generator

The steam generator will be fueled solely on LPG which is a clean burning fuel. The maximum average SOx concentration emitted from the steam generator is calculated from the permitted emission limit.

$$\frac{0.001\ \frac{\text{lb}\cdot SO_2}{\text{MMBtu}}\cdot 379.5\ \frac{\text{dscf}}{\text{lb}\cdot\text{mol}}\cdot 10^6\cdot \text{ppmv}}{8710\ \frac{\text{dscf}}{\text{MMBtu}}\cdot 64\ \frac{\text{lb}\cdot SO_2}{\text{lb}\cdot\text{mol}}\cdot\frac{20.9}{17.9}} = 0.58\ \text{ppmv}\ @\ 3\%\ O_2$$

Where:

SOx (as SO_2) Molecular weight = 64 lb/mole
F factor for natural gas = 8710 dscf exhaust/MMBtu
Molar Volume of fuel = 379.5 dscf/lb-mol

The calculated SOx emissions are lower than the limit of 2,000 ppmv. Therefore, compliance is expected.

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator

- Conditions 10, 11, 22, and 28 comply with the requirements of this rule.

Natural Gas-Fire Internal Combustion (IC) Engine

The maximum fuel sulfur content that can be combusted in natural gas-fired IC engines that comply with this 2,000 ppmv emission limit is calculated as follows:

The combustion equation for natural gas is (neglecting NO_X and SO_X relative to O_2 in the exhaust):

$$CH_4 + (2+X)O_2 + (2+X)3.78N_2 + YS \Rightarrow CO_2 + 2H_2O + XO_2 + YSO_2 + (2+X)3.78N_2$$

Where:

Y = moles of sulfur in the fuel
X = moles of excess air

Solving an expression for the fraction of O_2 in the exhaust by volume gives:

$$\frac{X}{3 + X + (2+X)3.78} = 0.04 \Rightarrow X = 0.523$$

Where:

3 = combined total moles of CO_2 and H_2O in the exhaust
0.04 = fraction of O_2 in the exhaust by volume

Solving for Y in an expression for the fraction of SO_2 in the dry exhaust by volume gives:

$$\frac{Y}{1 + 0.523 + 9.54} = 0.002 \Rightarrow Y = 0.022$$

Where:

Y = mole fraction of S per mole of CH_4 combusted
1 = moles of CO_2 in the exhaust
9.54 = moles of N_2 in the exhaust
0.002 = 2,000 ppmv SOx emission limit

Using Y to calculate the weight fraction of S in one mole of CH_4:

$$\frac{(0.022)(32.06)}{16.04 + (0.022)(32.06)} = 0.042 = 4.2\% \text{ S by weight in the fuel}$$

Where:

32.06 = molecular weight of sulfur (S)
16.04 = molecular weight of CH_4
0.042 = fraction of S by weight in the fuel

Natural gas with a sulfur content of less than 4.2% by weight will satisfy each county's sulfur compounds rule.

The engines are allowed by permit condition to burn only natural gas containing less than or equal to 5 grains of total sulfur per 100 standard cubic feet. This limit can be converted to an expression of weight percent of sulfur in the natural gas (NG) calculated as follows:

$$\%S\left(\frac{lb-S}{lb-NG}\right)=100X\left(\frac{5gr}{100ft^3}\right)\left(\frac{1lb}{7000gr}\right)\left(\frac{24.45L}{mol-NG}\right)\left(\frac{1mol-NG}{16.04g}\right)\left(\frac{453.59g}{1lb}\right)\left(\frac{0.035ft^3}{1L}\right)$$

= 0.017% sulfur < 4.2% sulfur (0.2 percent by volume)

Therefore, the following conditions that include testing and recordkeeping assure compliance with the rule.

a. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (Non-Compliant Dormant Emissions Unit)

   - Conditions 6, 8, 9, 10, and 11 comply with the requirements of this rule.

b. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

   - Conditions 10, 28, 29, 30, and 21 comply with the requirements of this rule.

c. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

   - Conditions 6, 24, 25, 26, and 27 comply with the requirements of this rule.

d. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 11, 21, 22, 23, and 24 comply with the requirements of this rule.

e. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

   - Conditions 10, 20, 21, 22, and 23 comply with the requirements of this rule.

f. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 10, 20, 21, 22, and 23 comply with the requirements of this rule.

g. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 10, 20, 21, 22, and 23 comply with the requirements of this rule.

h. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 10, 20, 21, 22, and 23 comply with the requirements of this rule.

i. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 10, 20, 21, 22, and 23 comply with the requirements of this rule.

j. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- Conditions 9, 14, 15, 16, and 17 comply with the requirements of this rule.

17. 40 CFR Part 60, Subpart JJJJ, Standards of Performance for Stationary Spark Ignition Internal Combustion Engines

This subpart applies to owners and operators of stationary spark ignition (SI) internal combustion engines (ICE) that commence construction, modification, or reconstruction after June 12, 2006.

a. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (Non-Compliant Dormant Emissions Unit)

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

b. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

c. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

d. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

e. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

f. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

g. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

h. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

i. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

j. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- This engine was installed prior to June 12, 2006 and had not been modified or reconstructed. Therefore, the unit is not subject to this subpart.

18. 40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

This subpart establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions.

§63.6590(a)(1)(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

§63.6590(b)(3) A stationary RICE which is an existing spark ignition 4 stroke rich burn (4SRB) stationary RICE located at an area source, or an existing spark ignition 4SRB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source does not have to meet the requirements of this subpart and of subpart A of this part. Not initial notification is necessary.

a. S-1216-67-1: 225 bhp Caterpillar Model G342NA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Air/Fuel Ratio Controller Powering a Gas Compressor (<u>Non-Compliant Dormant Emissions Unit</u>)

- The facility is an <u>area source</u> of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

b. S-1216-70-1: 325 bhp Caterpillar Model 3406TA Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor (Compliant Dormant Emissions Unit)

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

c. S-1216-71-1: 1478 bhp Waukesha Model L7042GSI Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction and Automatic Air/Fuel Ratio Controller Powering a Gas Compressor

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

d. S-1216-139-1: 195 bhp Waukesha Model F-1197 Field Gas/Propane-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

e. S-1216-140-1: 135 bhp Waukesha Model F-817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

f. S-1216-141-1: 195 bhp Waukesha Model F-1197 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

g. S-1216-148-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

h. S-1216-149-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

i. S-1216-150-1: 147 bhp Minneapolis Moline Model HD800-6A Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

j. S-1216-151-1: 135 bhp Waukesha Model 817 Field Gas-Fired Rich Burn Cyclically Loaded IC Engine with NSCR

- The facility is an area source of HAP and this engine is an existing engine, installed prior to June 12, 2006. Therefore, the unit is not subject to this subpart.

19. 40 CFR Parts 64, Compliance Assurance Monitoring (CAM)

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

1) the unit must have an emission limit for the pollutant;
2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

a. S-1216-2-2, -3-2, -7-2, -8-2, -10-2, -11-2, -20-2, -21-2, and -22-2: Fixed-Roof Storage Tanks

The following fixed-roof storage tanks do not have an emission limit or control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

b. S-1216-42-1 and -43-1: 500 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

c. S-1216-44-1: 2000 BBL Fixed Roof Petroleum Wash Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

d. S-1216-45-1: 500 BBL Fixed Roof Petroleum Wash Tank

The fixed-roof storage tank does not have a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

e. S-1216-46-1: 1000 BBL Fixed Roof Petroleum Shipping Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

f. S-1216-47-1: 300 BBL Fixed Roof Petroleum Wash Tank

The fixed-roof storage tank does not have a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

g. S-1216-48-1, -49-1, and -50-1: Fixed Roof Storage Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

h. S-1216-51-1 and -52-1: Fixed Roof Crude Oil Production Tank

The fixed-roof storage tanks do not have a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

i. S-1216-53-1: 1000 BBL Fixed Roof Crude Oil Production Tank

The fixed-roof storage tank does not have a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

j. S-1216-54-1: 500 BBL Fixed Roof Crude Oil Production Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

k. S-1216-55-1, -56-1, -57-1, and -58-1: Fixed Roof Crude Oil Production Tank

The fixed-roof storage tanks do not have a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

l. S-1216-59-1: 210 BBL Fixed Roof Petroleum Shipping Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

m. S-1216-60-1, -61-1, and -62-1: Fixed Roof Crude Oil Storage Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

n. S-1216-63-1: 210 BBL Fixed Roof Petroleum Shipping Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

o. S-1216-64-3 and -66-1: 3000 BBL Fixed Roof Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

p. S-1216-67-1: 225 bhp Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction (NSCR)

The emissions unit has emissions limits for NO_X and CO as well as a NSCR control device for NO_X and CO. The following calculations show that the pre-control potential to emit for NO_X and CO are less than the major thresholds for NO_X and CO. Therefore this permit unit is not subject to CAM.

From AP-42, 7/00, Table 3.2-3, the uncontrolled emission factors for 4-stroke rich-burn engines are 2.27 lb-NO_X/MMBtu and 3.72 lb-CO/MMBtu.

NO_X = 225 bhp x 2.27 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
NO_X = 11,387 lb/yr < 20,000 lb/yr (Major Threshold for NO_X)

CO = 225 bhp x 3.72 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
CO = 18,660 lb/yr < 200,000 lb/yr (Major Threshold for CO)

q. S-1216-68-1: Glycol Gas Dehydration Operation with 0.75 MMBtu/hr Afterburner

The emissions unit is currently designated as a dormant emissions unit. A condition has been included in the proposed permit that the operator will submit a monitoring plan that satisfies the design requirements in 40 CFR 64.3 prior to recommencing operation of the unit.

Condition 2 complies with the requirements of this rule.

r. S-1216-69-1: Emergency Gas Plant Flare

The emissions unit has no emissions limits for any of the criteria pollutants. Therefore this permit unit is not subject to CAM.

s. S-1216-70-1: 325 bhp Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction (NSCR)

The emissions unit has emissions limits for NO_X and CO as well as a NSCR control device for NO_X and CO. The following calculations show that the pre-control potential to emit for NO_X and CO are less than the major thresholds for NO_X and CO. Therefore this permit unit is not subject to CAM.

From AP-42, 7/00, Table 3.2-3, the uncontrolled emission factors for 4-stroke rich-burn engines are 2.27 lb-NO_X/MMBtu and 3.72 lb-CO/MMBtu.

NO_X = 325 bhp x 2.27 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
NO_X = 16,448 lb/yr < 20,000 lb/yr (Major Threshold for NO_X)

CO = 325 bhp x 3.72 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
CO = 26,954 lb/yr < 200,000 lb/yr (Major Threshold for CO)

t. S-1216-71-1: 1478 bhp Natural Gas-Fired IC Engine with Non-Selective Catalytic Reduction (NSCR)

The emissions unit has emissions limits for NO_X and CO as well as a NSCR control device for NO_X and CO. The following calculations show that the pre-control potential to emit for NO_X and CO are greater than

the major thresholds for NO_X but less than the major threshold for CO. Therefore this permit unit is subject to CAM for NO_X.

From AP-42, 7/00, Table 3.2-3, the uncontrolled emission factors for 4-stroke rich-burn engines are 2.27 lb-NO_X/MMBtu and 3.72 lb-CO/MMBtu.

NO_X = 1478 bhp x 2.27 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
NO_X = 74,798 lb/yr > 20,000 lb/yr (Major Threshold for NO_X)

CO = 1478 bhp x 3.72 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
CO = 122,577 lb/yr < 200,000 lb/yr (Major Threshold for CO)

To comply with CAM, the facility will monitor and record the catalyst inlet and outlet temperatures daily whenever the engine is in operation.

- Conditions 28 through 35 comply with the requirements of this rule.

u. S-1216-72-1: 16,000 BBL Fixed Roof Production Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

v. S-1216-73-1 and -75-1: 1500 BBL Fixed Roof Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

w. S-1216-78-1: 1,000 BBL Fixed Roof Slop Oil Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

x. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator with North American 4211 GLE Burner and Flue Gas Recirculation

This unit is equipped with flue gas recirculation that meets the requirement of a control device for NO_X. There is also an emissions limit for NO_X. The following calculation shows that the pre-control potential to emit is less than the major source threshold for NO_X. Therefore this emissions unit is not subject to CAM.

AP-42, 07/08, Table 1.5-1, uncontrolled propane NO_X emission factor is 13 lb/10^3 gal. The North American 4211 GLE burner is a low-NO_X burner and is not a control device but is considered inherent process equipment by CAM rule. An inherent process equipment means equipment that is necessary for the proper or safe functioning of the process. Low-NOx burners reduce NO_X emissions by 40 to 85 percent (relative to uncontrolled levels) according to AP-42. A conservative control efficiency of 40% is used in this calculation. Propane heating value is 91.5 MMBtu/10^3gal.

NO_X = 13 lb/10^3gal x 10^3gal/91.5 MMBtu x 17.5 MMBtu/hr x 8760 hr/yr x (1-0.4)
NO_X = 13,068 lb-NO_X/yr < 20,000 lb-NO_X/yr (NO_X major threshold)

y. S-1216-86-1: 100 BBL Fixed Roof Production Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

z. S-1216-87-2 and -88-1: 44.58 MMBtu/hr Well Safety Flare

The emissions units have no emissions limits for any of the criteria pollutants. Therefore these units are not subject to CAM.

aa. S-1216-89-1: 0.028 MMBtu/hr Tank Vapor Recovery System Flare

The flare serves the vapor control system for permit-exempt Baker-type 500 bbl temporary storage tanks holding produced fluids. The emissions unit has no emissions limits for any of the criteria pollutants. Therefore this permit unit is not subject to CAM.

bb. S-1216-93-2 and -94-1: Fixed Roof Wash Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

cc. S-1216-95-3: Waterflood Plant/Water Cleaning and Injection Operation Including 5000 BBL Wash Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

dd. S-1216-96-2: 2000 BBL Fixed Roof Storage/Shipping Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

ee. S-1216-97-2 and -98-2: Fixed Roof Storage Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

ff. S-1216-100-1, -101-1, -102-1, -103-1, -104-1 and -105-1: Fixed Roof Petroleum Storage Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

gg. S-1216-106-1, -107-2, and -108-3: Fixed Roof Petroleum Storage Tank

The fixed-roof storage tanks do not have a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

hh. S-1216-109-2, -110-2, -111-1, -122-1, -123-1, -124-1, -125-1, and -126-1: Fixed Roof Petroleum Storage Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

ii. S-1216-127-2: Fixed Roof Crude Oil Drain Tank

The fixed-roof storage tank does not have a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

jj. S-1216-128-1: 2000 BBL Fixed Roof Wash Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

kk. S-1216-129-1: Fixed Roof Storage Tank

The fixed-roof storage tank does not have a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

ll. S-1216-130-1, and -131-1: Fixed Roof Petroleum Wash Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

mm. S-1216-132-2: Wemco Oil/Water Separator with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit unit is not subject to CAM.

nn. S-1216-133-2, -134-2, -135-2, -136-2, and -137-2: Fixed Roof Crude Oil Production Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

oo. S-1216-139-1, -140-1, and -141-1: Field Gas-Fired Rich-Burn IC Engine

The emissions units have emissions limits for NO_X and CO as well as a NSCR control device for NO_X and CO. The following calculations show that the pre-control potential to emit for NO_X and CO are less than the major thresholds for NO_X and CO. Therefore these permit units are not subject to CAM.

From AP-42, 7/00, Table 3.2-3, the uncontrolled emission factors for 4-stroke rich-burn engines are 2.27 lb-NO_X/MMBtu and 3.72 lb-CO/MMBtu. The calculation uses 195 bhp as the highest rating for the three engines.

NO_X = 195 bhp x 2.27 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
NO_X = 9,868 lb/yr < 20,000 lb/yr (Major Threshold for NO_X)

CO = 195 bhp x 3.72 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
CO = 16,172 lb/yr < 200,000 lb/yr (Major Threshold for CO)

pp. S-1216-142-2, -143-1, -144-1, and -145-1: Fixed Roof Crude Oil Production Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

qq. S-1216-146-1 and -147-1: Fixed Roof Storage Tank

The fixed-roof storage tanks do not have a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

rr. S-1216-148-1, -149-1, -150-1, and -151-1: Field Gas-Fired Rich-Burn IC Engine

The emissions units have emissions limits for NO_X and CO as well as a NSCR control device for NO_X and CO. The following calculations show that the pre-control potential to emit for NO_X and CO are less than the major thresholds for NO_X and CO. Therefore these permit units are not subject to CAM.

From AP-42, 7/00, Table 3.2-3, the uncontrolled emission factors for 4-stroke rich-burn engines are 2.27 lb-NO_X/MMBtu and 3.72 lb-CO/MMBtu. The calculation uses 147 bhp as the highest rating for the three engines.

NO_X = 147 bhp x 2.27 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
NO_X = 7,439 lb/yr < 20,000 lb/yr (Major Threshold for NO_X)

CO = 147 bhp x 3.72 lb/MMBtu x 0.002545 MMBtu/hp-hr x 8760 hr/yr
CO = 12,191 lb/yr < 200,000 lb/yr (Major Threshold for CO)

ss. S-1216-152-1, -153-1, -154-1, and -155-1: Fixed Roof Storage Tank with Vapor Recovery

The unit's VOC control system consists of venting the collected vapors to a gas pipeline that is not a control device as defined in the CAM rule. Therefore, the permit units are not subject to CAM.

20. Kern County Rule 407, Sulfur Compounds

See District Rule 4801 in this section.

21. Kern County Rule 424, Sulfur Compounds from Oil Field Steam Generators

This rule applies to steam generators used in oil field operations. The operator shall not exceed 0.11 lb of sulfur per million Btu of heat input.

a. S-1216-85-2: 17.5 MMBtu/hr Portable LPG-Fired Steam Generator with Flue Gas Recirculation

- Conditions 10, 22, and 30 comply with the requirements of this rule. Permit conditions limits SO_X emissions to 0.001 lb/MMBtu which is less than the rule requirement.

X. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

By using the model general permit template listed in Section IV of this evaluation, the applicant has requested that a permit shield be issued for requirements addressed in the template. The basis for each permit shield is discussed in the Permit Shield section of each template.

XI. PERMIT CONDITIONS

See final operating permit beginning on the following page.

San Joaquin Valley
Air Pollution Control District

FACILITY: S-1216-0-1 **EXPIRATION DATE:** 08/31/2010

DRAFT

FACILITY-WIDE REQUIREMENTS

1. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. {4363} The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

9. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

10. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

11. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

12. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

13. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

14. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

15. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

16. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

17. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

18. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

19. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

20. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

21. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

22. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

23. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

24. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

25. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

26. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

27. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

28. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit

29. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

30. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

31. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

32. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

33. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

34. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

35. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

36. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

37. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

38. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

39. {4400} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

40. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

42. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

43. Operator shall maintain accurate monthly records of Gas-to-oil ratio (GOR) and API gravity of liquids produced showing that facility exclusively processes, stores, or transfers black oil (as defined in 40 CFR 63.761). [40 CFR 63.10(b)] Federally Enforceable Through Title V Permit

44. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

45. For valves, threaded connections, flanges, pipes, pumps, compressors, and other components subject to the requirements of Rule 4409, but not specified in this permit; a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 2,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

46. For pressure relief devices (PRDs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 200 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 400 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

47. For polished rod stuffing boxes (PRSBs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

48. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.2] Federally Enforceable Through Title V Permit

49. Minor gas leaks from PRSBs detected during any District inspection shall not be counted toward determination of compliance with this rule provided the permittee repairs, replaces, or removes leaking PRSBs from VOC service as soon as practicable but not later than seven calendar days. [District Rule 4409, 5.1.3.1.2] Federally Enforceable Through Title V Permit

50. Leaks detected during quarterly operator inspections shall not be counted towards determination of compliance with the provisions of Rule 4409 provided the leaking components are repaired as soon as practicable but not later than the time frame specified in this permit. Leaks detected during quarterly operator inspections that are not repaired, replaced, or removed from operation as soon as practicable but not later than the time frame specified in this rule shall be counted toward determination of compliance with the provisions of Rule 4409. [District Rule 4409, 5.1.3.2.1 and 5.1.3.2.2] Federally Enforceable Through Title V Permit

51. Leaking components at this facility detected during annual operator inspections, as required by Rule 4409 for a specific component type, that exceed the leak standards specified in this permit, shall constitute a violation of this rule. This violation is regardless of whether or not the leaking components are repaired, replaced, or removed from operation within the allowable repair time frame specified in this permit. [District Rule 4409, 5.1.3.2.3] Federally Enforceable Through Title V Permit

52. An open-ended line, or a valve located at the end of the line, that is not sealed with either a blind flange, a plug, a cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended line is a leak. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.4.1] Federally Enforceable Through Title V Permit

53. A leak from a component is when there is a major liquid leak from the component. A major liquid leak from a component is when a visible mist or a continuous flow of liquid, that is not seal lubricant, leaks from the component. [District Rule 4409, 5.1.4.2] Federally Enforceable Through Title V Permit

54. A leak from a component is when gas emissions greater than 50,000 ppmv, as methane, leaks from the component. [District Rule 4409, 5.1.4.3] Federally Enforceable Through Title V Permit

55. A minor liquid leak from a component is when more than three drops of liquid per minute, that is not seal lubricant and is not a major liquid leak, leaks from the component. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

56. When 200 or fewer valves are inspected, a leak from a valve is when more than one valve has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 valves are inspected, a leak from a valve is when more than 0.5 % (rounded up to the nearest whole number) of the valves have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

57. When 200 or fewer threaded connections are inspected, a leak from a threaded connection is when more than one threaded connection has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 threaded connections are inspected, a leak from a threaded connection is when more than 0.5 % (rounded up to the nearest whole number) of the threaded connections have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

58. When 200 or fewer flanges are inspected, a leak from a flange is when more than one flange has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 flanges are inspected, a leak from a flange is when more than 0.5 % (rounded up to the nearest whole number) of the flanges have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

59. When 200 or fewer pumps are inspected, a leak from a pump is when more than two pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. When greater than 200 pumps are inspected, a leak from a pump is when more than 1.0 % (rounded up to the nearest whole number) of the pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

60. When compressors, PRDs, or other components not specified in this permit are inspected, a leak from these components is when more than one component has a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

61. When 200 or fewer PRSBs are inspected, a leak is when more than four have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 PRSBs are inspected, a leak is when more than 2.0 % (rounded up to the nearest whole number) of the PRSBs have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

62. When 200 or fewer wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than two or more pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than 1.0 % (rounded up to the nearest whole number) of the pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

63. When pipes at natural gas processing facilities are inspected, a leak from a pipe is when more than two have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

64. For manned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once every 24 hours except when operators do not report to the facility during a 24 hour period. [District Rule 4409, 5.2.1] Federally Enforceable Through Title V Permit

65. For unmanned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once per calendar week. [District Rule 4409, 5.2.2] Federally Enforceable Through Title V Permit

66. All accessible operating pumps, compressors, and PRDs, in service, that are found to be leaking by audio-visual inspection shall be attempted to be repaired immediately. The leaking component shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.3] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

67. Except for inaccessible components, unsafe-to-monitor components, or pipes, all components, in service, shall be tested for leaks at least once every calendar quarter. [District Rule 4409, 5.2.4] Federally Enforceable Through Title V Permit

68. All new, replaced, or repaired fittings, flanges, and threaded connections shall be tested for leaks immediately after being placed into service. [District Rule 4409, 5.2.5]

69. All inaccessible components shall be tested for leaks at least once every 12 months. [District Rule 4409, 5.2.6] Federally Enforceable Through Title V Permit

70. All unsafe-to-monitor components shall be tested for leaks during each turnaround. [District Rule 4409, 5.2.7] Federally Enforceable Through Title V Permit

71. All pipes shall be visually inspected for leaks at least once every 12 months. [District Rule 4409, 5.2.8] Federally Enforceable Through Title V Permit

72. All pipes, in service, that are found to be leaking by visual inspection shall be attempted to be repaired immediately. The leaking pipe shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.8.1] Federally Enforceable Through Title V Permit

73. The annual pipe inspection required by either the Department of Oil, Gas, and Geothermal Resources (DOGGR) pursuant to California Code of Regulation Title 14, Division 2, Subchapter 2, Section 1774 (Oilfield Facilities and Equipment Maintenance), or by the Spill Prevention Control and Countermeasure Plan (SPCC) pursuant to 40 Code of Federal Regulation Part 112 (Oil Prevention and Response: Non- Transportation-Related Onshore and Offshore Facilities) can be used as the annual pipe inspection required by District Rule 4409. [District Rule 4409, 5.2.8.2] Federally Enforceable Through Title V Permit

74. Except for pumps, compressors, and PRDs, the permittee may apply for written approval from the District to change the inspection frequency of accessible components from quarterly to annually for a specific component type provided the following two qualifying requirements are met. During the previous five consecutive quarterly inspections, for the specific component type, there shall be no more leaks than as allowed by this permit. The permittee also shall not have received a Notice of Violation (NOV) from the District during the previous 12 months for violating any provisions of District Rule 4409 for the specific component type. If these two qualifying requirements have not been met, then the inspection frequency shall revert back to quarterly. The written request shall include pertinent documentation to demonstrate that the operator has successfully met the two qualifying requirements. [District Rule 4409, 5.2.9 and 5.2.10] Federally Enforceable Through Title V Permit

75. The permittee shall notify the District in writing within five calendar days after changing the inspection frequency for a specific component type. The written notification shall include the reason(s) and date of change to a quarterly inspection frequency. [District Rule 4409, 5.2.11] Federally Enforceable Through Title V Permit

76. A PRD that releases to the atmosphere shall be inspected by the permittee for leaks as soon as practicable but not later than 24 hours after the time of the release. The permittee shall reinspect the PRD for leaks not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the date of the initial release. If the PRD is found by the permittee to be leaking during either inspection, the PRD leak shall be treated as if the leak was found during the required quarterly operator inspections. [District Rule 4409, 5.2.12] Federally Enforceable Through Title V Permit

77. Except for PRDs, a component shall be inspected for leaks not later than 15 calendar days after repairing the leak or replacing the component. [District Rule 4409, 5.2.13] Federally Enforceable Through Title V Permit

78. District inspections shall not be counted as an operator inspection required by District Rule 4409. Any attempt by an operator to count such District inspections as part of the operator's mandatory inspections is considered a willful circumvention of the rule and is a violation of this rule. [District Rule 4409, 5.2.14] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

79. The operator, upon detection of a leaking component, shall affix to that component a weatherproof, readily visible tag, bearing the date and time when the leak was detected and the date and time of the leak measurement. For gaseous leaks, the tag shall indicate the leak concentration in ppmv. For liquid leaks, the tag shall indicate whether it is a major liquid leak or a minor liquid leak. The tag shall indicate, when applicable, whether the component is an essential component, an unsafe-to-monitor component, or a critical component. The tag shall remain in place until the leaking component is repaired or replaced and reinspected and found to be in compliance with the requirements of this rule. [District Rule 4409, 5.3.1] Federally Enforceable Through Title V Permit

80. The operator shall minimize all component leaks immediately, to the extent possible, but not later than one hour after detection of the leak in order to stop or reduce leakage to the atmosphere. If the leak has been minimized but the leak still exceeds the applicable leak standards specified in this permit, the operator shall do one of the following within the timeframes specified within this permit: 1) repair or replace the leaking component; 2) vent the leaking component to a closed vent system; 3) or remove the leaking component from operation. A closed vent system is a District approved system that is not open to the atmosphere. It is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to a District approved control device that has a overall VOC collection and destruction or removal efficiency of at least 95%, or that transports gases or vapors back to a process system. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

81. The operator shall repair minor gas leaks within seven days. The operator shall repair major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, within three days. The operator shall repair major gas leaks, which are > 50,000 ppmv, within two days. The operator shall repair minor liquid leaks within three days. The operator shall repair major liquid leaks within two days. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period. The start of the repair period shall be the time of the initial leak detection. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

82. For each calendar quarter, the operator may extend the repair period for a total number of leaking components, not to exceed 0.05 % of the number of components inspected, by type, rounded upward to the nearest whole number. The repair period for minor gas leaks can be extended by seven additional days. The repair period for major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, can be extended by two additional days. [District Rule 4409, 5.3.5] Federally Enforceable Through Title V Permit

83. If a leaking component is an essential component or a critical component and which cannot be shut down immediately for repairs, the operator shall do the following: 1) minimize the leak within one hour after detection of the leak; 2) and if the leak has been minimized, but the leak still exceeds the applicable leak standards of Rule 4409 as specified in this permit, the essential component or critical component shall be repaired or replaced to eliminate the leak during the next process unit turnaround. The repair shall occur no later than one year from the date of the original leak detection. [District Rule 4409, 5.3.6] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

84. For any component that has incurred five repair actions for major gas leaks or major liquid leaks, or a combination of major gas leaks and major liquid leaks within a continuous 12-month period, the operator shall do one of the following four options. Options 1a through 1f require written notification to the District, option 2 requires written notification to the District and written District approval, options 3 and 4 do not require written notification to the District: 1a) For compressors replace the existing seal with either a dual mechanical seal, an oil film seal, a gas seal, or a face-type seal; 1b) for pumps replace the pump with a seal-less pump or replace the seal with a dual mechanical seal; 1c) for PRDs replace the PRD and install a rupture disc in the line which precedes the PRD such that the PRD is in series with and follows the rupture disc; 1d) for valves replace the valve with a sealed bellows valve, or for seal rings install graphite or Teflon chevron seal rings in a live-loaded packing gland; 1e) for threaded connections weld the connections or replace threaded connections with flanges; 1f) for sampling connections replace the sampling connection with a closed-loop sampling system; 2) Replace the component with Achieved-in-Practice Best Available Control Technology (BACT) equipment; 3) Vent the component to a District approved closed-vent system; 4) Remove the component from operation. For any component that is accessible, is not unsafe-to-monitor, is not an essential component, or is not a critical component, the operator shall comply with these requirements as soon as practicable but not later than twelve months after the date of detection of the fifth major leak within a continuous 12-month period. For any component that is inaccessible, is unsafe-to-monitor, is essential, or is a critical component, the operator shall comply with these requirements as soon as practicable but not later than the next turnaround or not later than two years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes first. [District Rule 4409, 5.3.7] Federally Enforceable Through Title V Permit

85. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and recordkeeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other system approved by the District that enables an operator or the District to locate each individual component. The operator shall replace physical identifications that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4409, 5.4.1] Federally Enforceable Through Title V Permit

86. The operator shall keep a copy of the District approved Operator Management Plan (OMP) at the facility and make it available to the District, ARB, and EPA upon request. [District Rule 4409, 6.1.2] Federally Enforceable Through Title V Permit

87. By January 30th of each year the operator shall submit to the District for approval, in writing, an annual report indicating any changes to the existing OMP on file at the District. [District Rule 4409, 6.1.4] Federally Enforceable Through Title V Permit

88. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4409, 6.2.1] Federally Enforceable Through Title V Permit

89. Records of leaks detected during quarterly or annual operator inspections, and each subsequent repair and re-inspection, shall be submitted to the District, ARB, and EPA upon request. [District Rule 4409, 6.2.2] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

90. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4409, 6.2.3] Federally Enforceable Through Title V Permit

91. All records required by this permit shall be retained on-site for a minimum of five years and made available for District, ARB, and EPA inspection upon request. [District Rule 4409, 6.2.4] Federally Enforceable Through Title V Permit

92. All measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instructions not more than 30 days prior to its use. [District Rule 4409, 6.3.1] Federally Enforceable Through Title V Permit

93. The VOC content by weight percent shall be determined using ASTM D-1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 for liquids. [District Rule 4409, 6.3.2] Federally Enforceable Through Title V Permit

94. The percent by volume liquid evaporated at 302 øF (150 øC) shall be determined using ASTM D-86. [District Rule 4409, 6.3.3] Federally Enforceable Through Title V Permit

95. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D-323, and converting the RVP to TVP at the maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures specified in Appendix A of District Rule 4409. [District Rule 4409, 6.3.4] Federally Enforceable Through Title V Permit

96. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM D-287 or ASTM 1298. Sampling for API gravity shall be performed in accordance with ASTM D-4057. [District Rule 4409, 6.3.5] Federally Enforceable Through Title V Permit

97. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4409, 6.3.6] Federally Enforceable Through Title V Permit

98. Halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422. [District Rule 4409, 6.3.7] Federally Enforceable Through Title V Permit

99. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

100. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

101. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

102. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

103. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the time frames specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

104. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

105. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

106. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

107. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

108. On month, day, year, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-1-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
125 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (MAYS LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-2-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13382 (MAYS LEASE)

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-3-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13381 (MAYS LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 el "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-7-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 02 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (TAFT LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-8-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 02 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #10752 (TAFT LEASE)

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-10-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 32 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
180 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (AIRPORT LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-11-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 32 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13303 (AIRPORT LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-20-2 **EXPIRATION DATE:** 08/31/2010

SECTION: NE21 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (BALBOA LEASE)

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-21-2 **EXPIRATION DATE:** 08/31/2010

SECTION: NE32 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL STOCK TANK SERVED BY A PRESSURE RELIEF DEVICE, #5384 (BALBOA LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-22-2 **EXPIRATION DATE:** 08/31/2010

SECTION: NW28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
490 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE/VACUUM RELIEF VENT VALVE (MAYS LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids introduced, placed, stored or held in this tank shall not exceed 1.0 psia. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Tank shall be designed and operated as a constant liquid level tank. [District NSR Rule] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph," as approved by ARB and EPA. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
4. Compliance with vapor pressure limit shall be demonstrated by District witnessed or authorized sample collection and analysis. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Permittee shall maintain accurate records of liquids stored, storage temperature, and true vapor pressure of such liquids. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
8. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
9. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
10. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
12. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit
13. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 4623] Federally Enforceable Through Title V Permit
14. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit
15. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit
16. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-42-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#.05GF17) SERVED BY VAPOR CONTROL SYSTEM INCLUDING COMPRESSOR(S) AND PIPING TO GAS PIPELINE SHARED WITH S-1216-43

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Formerly S-1641-39.

19. Formerly S-382-773.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-43-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#.05GF8) SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-42 (KING LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Formerly S-1641-40.

19. Formerly S-382-774.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-44-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED-ROOF PETROLEUM WASH TANK (#08002M06E) SERVED BY A VAPOR RECOVERY SYSTEM (LITTLE SIX LEASE)

PERMIT UNIT REQUIREMENTS

1. Tank shall vent exclusively to gas gathering line shared between permit units S-1216-44, S-1216-46, and S-1216-131. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
2. Operation shall include make-up gas line with Varec Fig. 181 valve regulator and piping through Varec Fig. 180 valve regulator to gas gathering line shared between permit units S-1216-44, S-1216-46, and S-1216-131. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. All piping, valves, and fittings shall be constructed and maintained in a leak free condition. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
6. Tank shall be operated at constant fluid level. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Varec Fig. 181 gas regulator shall activate when tank pressure falls below 2 in. H2O allowing make-up gas to enter tank. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Varec Fig. 180 gas regulator shall activate when tank pressure rises above 2 in-H20 allowing vapor to be drawn into gas gathering line. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Total combined volatile organic compound (VOC) emissions from tanks S-1216-44, S-1216-46, and S-1216-131 shall not exceed 0.24 lb per day. [District NSR Rule] Federally Enforceable Through Title V Permit
10. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

16. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

17. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

18. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

19. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

21. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

22. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

25. Formerly S-1130-12-2

26. Formerly S-1641-42.

27. Formerly S-382-775.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-45-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW14 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF PETROLEUM WASH TANK SERVED BY PRESSURE-VACUUM VENTS (SECTION 14 TANK SETTING, BUENA VISTA HILLS)

PERMIT UNIT REQUIREMENTS

1. Wash tank shall be operated at constant level. [District NSR Rule] Federally Enforceable Through Title V Permit
2. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
4. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit
9. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit
11. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit
12. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit
13. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
14. Formerly S-1130-14-3
15. Formerly S-1641-44.
16. Formerly S-382-776.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-46-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED-ROOF PETROLEUM SHIPPING TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-44 (LITTLE SIX LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Tank shall vent exclusively to gas blanketing/gathering line shared with permit unit S-1216-44, S-1216-46, and S-1216-131. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
3. Operation shall include make-up gas line with Varec Fig. 181 valve regulator and piping through Varec Fig. 180 valve regulator to gas gathering line shared with permit unit S-1216-44, S-1216-46, and S-1216-131. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
5. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
6. Fugitive VOC emissions from the components in gas/light liquid service and light crude oil service on tanks S-1216-44, S-1216-46, and S-1216-131, combined, shall not exceed 0.24 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb (1999), Screening Value Range emissions factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
9. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

11. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 105 and 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

12. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

15. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

16. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

17. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

18. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

20. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

22. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

23. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit

24. Formerly S-1130-24-0

25. Formerly S-1641-46.

26. Formerly S-382-777.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-47-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE10 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
300 BBL FIXED ROOF PETROLEUM WASH TANK SERVED BY A PRESSURE-VACUUM VENT (SECTION 10 TANK SETTING, BUENA VISTA HILLS)

PERMIT UNIT REQUIREMENTS

1. The pressure-vacuum relief valve shall be set to within ten (10) percent of the maximum allowable working pressure of the tank. The pressure-vacuum relief valve shall be permanently labeled with the operating pressure settings. The pressure-vacuum relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Wash tank shall be operated at constant level. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The tank shall exclusively receive and/or store crude oil with a TVP of less than 11 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
4. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
5. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
8. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit
12. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 4623] Federally Enforceable Through Title V Permit
13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit
14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit
15. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
16. Formerly S-1130-92-0
17. Formerly S-1641-48.
18. Formerly S-382-779.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-48-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-49, S-1216-50, S-1216-59, S-1216-63, AND S-1216-86 DISCHARGING TO FIELD GAS GATHERING LINE (SEC 26 BUENA VISTA LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
3. Collected vapors shall be discharged only to field gas gathering line. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
5. VOC emission rate from the components in gas and light oil service associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 0.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas and light oil service on the vapor control system shall not exceed 0.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
8. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623, 6.4.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District NSR Rule] Federally Enforceable Through Title V Permit

22. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-49-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1216-48 (SEC 26 FEE LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Tank roof appurtenances shall be maintained leak-free (as defined in Rule 4623). [District NSR Rule] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Formerly S-1130-99-3

20. Formerly S-1641-50.

21. Formerly S-382-781.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-50-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
750 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1216-48 (#REW 31, SECTION 8 LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
5. Tank roof appurtenances shall be maintained leak-free (as defined in Rule 4623). [District NSR Rule] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

9. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

10. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

11. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

13. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

14. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

16. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Formerly S-1130-117

21. Formerly S-1641-54.

22. Formerly S-382-784.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-51-1 **EXPIRATION DATE:** 08/31/2010

DRAFT

SECTION: NE08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #5GF6 (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Formerly S-1130-118-0
6. Formerly S-1641-55.
7. Formerly S-382-785.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-52-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
750 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Formerly S-1130-120-0
6. Formerly S-1641-57.
7. Formerly S-382-786.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-53-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #RECYCLE 3 (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit
12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit
13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit
14. Formerly S-1130-121-0
15. Formerly S-1641-58.
16. Formerly S-382-787.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-54-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK SERVED BY A VAPOR RECOVERY SYSTEM (SECTION 8 LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Tank shall vent vacuum line serving 1C gas plant. [District Rule 2010] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Formerly S-1130-122-0

20. Formerly S-1641-59.

21. Formerly S-382-788.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-55-1 **EXPIRATION DATE:** 08/31/2010

DRAFT

SECTION: NW10 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
200 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#02GF1, SECTION 10 TANK SETTING, BUENA VISTA HILLS) SERVED BY A PRESSURE-VACUUM VENT VALVE

PERMIT UNIT REQUIREMENTS

1. The pressure-vacuum relief valve shall be set to within ten (10) percent of the maximum allowable working pressure of the tank. The pressure-vacuum relief valve shall be permanently labeled with the operating pressure settings. The pressure-vacuum relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall exclusively receive and/or store crude oil with a TVP of less than 11 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit
11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 4623] Federally Enforceable Through Title V Permit
12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit
13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit
14. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
15. Formerly S-1130-123-0
16. Formerly S-1641-60.
17. Formerly S-382-789.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-56-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE14 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#5GF14, SECTION 14, BUENA VISTA HILLS) SERVED BY A PRESSURE-VACUUM VENT VALVE

PERMIT UNIT REQUIREMENTS

1. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
4. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
7. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

11. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

14. Formerly S-1130-124-0

15. Formerly S-1641-61.

16. Formerly S-382-790.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-57-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #1GF34 (SECTION 16A LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Formerly S-1130-125-0
6. Formerly S-1641-62.
7. Formerly S-382-791.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-58-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #1GF35 (SECTION 16A LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Formerly S-1130-127-0
6. Formerly S-1641-63.
7. Formerly S-382-792.

DRAFT

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-59-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-48 (SECTION 26 BUENA VISTA LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Tank roof appurtenances shall be maintained leak-free (as defined in Rule 4623). [District NSR Rule] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Average daily throughput of oil (on annual basis) shall not exceed 420 bbl per day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of the average daily throughput of oil. [District NSR Rule] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Formerly S-1130-133-0
23. Formerly S-1641-64.
24. Formerly S-382-793.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-60-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL STORAGE TANK SERVED BY A VAPOR CONTROL SYSTEM WITH A 25 HP COMPRESSOR SHARED WITH S-1216-61 AND '-62 (B.V. HILLS OILFIELD LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. True vapor pressure shall not exceed 4.7 psia. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit
9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit
10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit
11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit
12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit
14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit
15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit
16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit
17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
19. Formerly S-1130-134-3
20. Formerly S-1641-65.
21. Formerly S-382-794.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-61-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-60 (B.V. HILLS OILFIELD LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. True vapor pressure shall not exceed 4.7 psia. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit
9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit
10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit
11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit
12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit
14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit
15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit
16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit
17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
19. Formerly S-1130-135-2
20. Formerly S-1641-66.
21. Formerly S-382-795.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-62-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL WASH TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-60 (B.V. HILLS OILFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. True vapor pressure shall not exceed 4.7 psia. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Formerly S-1130-136-2

20. Formerly S-1641-67.

21. Formerly S-382-796.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-63-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-48 (SEC 26 BUENA VISTA LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Tank roof appurtenances shall be maintained leak-free (as defined in Rule 4623). [District NSR Rule] Federally Enforceable Through Title V Permit
6. True vapor pressure (TVP) of liquid stored in this permit unit shall not exceed 2.71 psia at storage temperature. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Average daily throughput of oil (on annual basis) shall not exceed 50 bbl per day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of the average daily throughput. [District Rule NSR] Federally Enforceable Through Title V Permit
9. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

13. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

14. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

16. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

17. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

19. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

22. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. Formerly S-1130-158-0
24. Formerly S-1641-68.
25. Formerly S-382-797.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-64-3 **EXPIRATION DATE:** 08/31/2010

SECTION: NE 23 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
3,000 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR CONTROL SYSTEM SHARED WITH S-1216-66, '-72, '-73, '-74 &'-75

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
7. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.3 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

11. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

12. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

14. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

15. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

17. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

20. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Formerly S-3506-1-0.
22. Formerly S-1641-69.
23. Formerly S-382-798.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-66-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE 23 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
3,000 BBL WELDED, FIXED ROOF PRODUCED WATER TANK SERVED BY VAPOR CONTROL SYSTEM LISTED ON S-1216-64 (ASPHALTO FEE)

PERMIT UNIT REQUIREMENTS

1. VOC emission rate from vapor, light liquid, and light crude oil service components associated with tank, up to the tie-in with the vapor control trunk-line, shall not exceed 0.5 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
2. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District NSR Rule and 4623, 3.11 and 6.4.8] Federally Enforceable Through Title V Permit
3. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions using California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2C: Oil and Gas Production Screening Value Ranges (<10,000 ppmv) Emission Factors with 100% VOC content in components. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Except as otherwise provided in this permit, tank roof appurtenances shall be maintained leak-free. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
6. The tank shall be equipped with a vapor control system consisting of a closed vent system that collects all VOCs from the storage tank to vapor control system S-1216-64 capable of reducing VOC emissions by at least 95%. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. [District NSR Rule & 4623, 5.6.1] Federally Enforceable Through Title V Permit
7. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
10. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

11. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

12. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

15. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

16. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

17. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

18. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

20. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

22. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. Formerly S-1641-75.

25. Formerly S-382-800.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-67-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW15 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
225 BHP CATERPILLAR MODEL G342NA NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION (NSCR) AND AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR (NON-COMPLIANT DORMANT EMISSIONS UNIT)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit to ensure that this unit is not operated. [District Rule 4702] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4702 and all other applicable District regulations. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Approved locations for this IC engine are NW 1/4 Sec 15, T30S, R22E and NW 1/4 Sec 23, T30S, R22E. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070 and Kern 107] Federally Enforceable Through Title V Permit
6. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern 407] Federally Enforceable Through Title V Permit
7. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
8. Engine shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District NSR Rule] Federally Enforceable Through Title V Permit
9. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 1070 and Kern 107] Federally Enforceable Through Title V Permit
10. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246. [District Rule 4801 and Kern 407] Federally Enforceable Through Title V Permit
11. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 4801 and Kern 407] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. The operator of an internal combustion (IC) engine shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4701] Federally Enforceable Through Title V Permit

13. Exhaust shall vent through catalytic converter only. [District NSR Rule] Federally Enforceable Through Title V Permit

14. Emissions shall not exceed the following: PM10: 9.8E-5 lb/hp-hr, NOx (as NO2): 7.8E-4 lb/hp-hr (25 ppmv at 15% O2), VOC: 3.26E-4 lb/hp-hr (30 ppmv at 15% O2) and CO: 1.52E-2 lb/hp-hr (800 ppmv at 15% O2). [District NSR Rule] Federally Enforceable Through Title V Permit

15. NOx, and CO emissions shall be measured at least once every 24 months with source test conducted by an independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 4701] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. [In-stack O2 monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4701] Federally Enforceable Through Title V Permit

17. If the NOx or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4701] Federally Enforceable Through Title V Permit

18. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4701] Federally Enforceable Through Title V Permit

19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance test, and a test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701] Federally Enforceable Through Title V Permit

22. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with rule 4701 for a period of five years and shall make such records readily available for District inspection upon request. [District Rule 4701] Federally Enforceable Through Title V Permit

23. An operating log record shall be maintained that includes compliance source test results, monitoring data, make and model of exhaust gas analyzer, exhaust gas analyzer calibration records, and catalyst maintenance and cleaning intervals. [District Rules 4701] Federally Enforceable Through Title V Permit

24. Formerly S-3507-7.

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. Formerly S-382-801.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-68-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE14 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:
GLYCOL GAS DEHYDRATION OPERATION INCLUDING GLYCOL REBOILER WITH 0.75 MMBTU/HR AFTERBURNER

PERMIT UNIT REQUIREMENTS

1. Prior to recommencing operation, the facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. Prior to recommencing operation, the facility shall submit a Compliance Assurance Monitoring (CAM) plan that satisfies the design requirements in 40 CFR 64, Section 64.3. [40 CFR 64.3] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080]
4. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080]
5. While dormant, normal source testing shall not be required. [District Rule 2080]
6. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080]
7. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080]
8. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
9. Total dehydrated gas by this permit unit shall not exceed 7.5 MMscf of gas in any one day. [District NSR Rule]
10. All glycol reboiler vent gas shall be burned in afterburner and none shall vent to atmosphere. [District Rule 2201 and 4408]
11. Only glycol shall be used as the dehydration medium. [District Rule 2201]
12. Condensate handling shall be conducted in closed systems resulting in fugitive component emissions only and no evaporation of VOCs. [District Rule 2201 and 4408]
13. The afterburner shall operate at all times when dehydration is taking place. [District NSR Rule]
14. Afterburner shall operate in a smokeless manner. [District Rule 4408]
15. Afterburner shall be equipped with electronically controlled ignition system with a malfunction alarm system if the pilot flame fails. [District Rule 4408]
16. Afterburner shall be equipped with liquid knockout system to condense any condensable vapors. [District Rule 4408]
17. Afterburner shall be equipped with a sight glass port if the flame is not visible. [District Rule 4408]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All piping, valves and other fittings shall be constructed and maintained in a gas-tight condition. "Gas-tight" shall be defined as emitting no more than 10,000 ppm of methane measured from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rules 2201 and 4408]
19. Glycol reboiler and afterburner shall be fired on PUC quality natural gas. [District NSR Rule]
20. Afterburner emissions shall not exceed any of the following: NOx - 1.8 lb/day, VOC - 0.5 lb/day, or CO - 1.5 lb/day. [District NSR Rule]
21. The VOC destruction efficiency from the glycol dehydration afterburner shall be maintained at or greater than 99.9%. [District NSR Rule]
22. The owner or operator shall maintain accurate daily records of gas dehydrated for a period of five years and shall make such records available for District inspection upon request. [District Rule 1070]
23. Formerly S-3507-11, S-1793-1 and S-382-802.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-69-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE24 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:
EMERGENCY GAS PLANT FLARE INCLUDING: AUTOMATIC ELECTRONIC IGNITER AND GAS LIQUID SEPARATOR

PERMIT UNIT REQUIREMENTS

1. Flare shall be equipped with automatic reignition provisions, e.g. electronic spark pilot light. [District NSR Rule and 4311, 5.3] Federally Enforceable Through Title V Permit
2. Flare shall operate with visible emissions less than 5% opacity. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Flare shall operate only during breakdown conditions pursuant to Rule 1100. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
5. Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an alternative equivalent device, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
6. Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
7. The operator shall maintain records of the duration of flare operation, amount of gas burned, and the nature of the emergency situation. [District Rule 4311, 6.1.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311] Federally Enforceable Through Title V Permit
9. Formerly S-3507-12.
10. Formerly S-1793-2-0.
11. Formerly S-382-803.

DRAFT

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-70-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW15 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
325 HP CATERPILLAR MODEL 3406 TA NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION AND AUTOMATIC AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit to ensure that this unit is not operated. [District Rule 4702] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
6. Upon recommencing operation the NOx emission concentration shall not exceed 5 ppmvd @ 15% O2. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
7. Upon recommencing operation the CO emission concentration shall not exceed 56 ppmvd @ 15% O2. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
8. Upon recommencing operation the VOC emission concentration shall not exceed 25 ppmvd, as methane, @ 15% O2. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
9. Upon recommencing operation the PM10 emissions shall not exceed 10.0 lbs/MMscf of natural gas used. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Upon recommencing operation the SOx emissions shall not exceed 2.85 lbs/MMscf of natural gas used. [District NSR Rule] Federally Enforceable Through Title V Permit
11. The VOC emission rate from fugitive emissions components shall not exceed 0.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
12. There shall be no leaks in excess of 10,000 ppmv measured pursuant to EPA Method 21 from fugitive emissions components associated with this permit. [District NSR Rule] Federally Enforceable Through Title V Permit
13. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c , Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) for <10,000 ppmv (no leaks). [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

14. Engine shall be equipped with nonresettable fuel and hourly meters. [District Rule 4702] Federally Enforceable Through Title V Permit
15. The engine shall be equipped with an automatic air to fuel ratio control system. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Upon recommencing operation source testing of the NOx, CO and VOC emission concentrations shall be conducted at least once every 12 months. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
17. Source testing for NOx emissions shall be conducted utilizing CARB 100 or EPA method 7E. [District Rule 4702] Federally Enforceable Through Title V Permit
18. Source testing for CO emissions shall be conducted utilizing CARB 100 or EPA method 10. [District Rule 4702] Federally Enforceable Through Title V Permit
19. Source testing for VOC emissions shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rule 4702] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
21. The results of each source test must be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
23. Upon recommencing operation the permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O2 monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit
24. Upon recommencing operation if either the NOx or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
25. Upon recommencing operation all alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. Upon recommencing operation the permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit

27. All records shall be retained for a minimum of five years, and shall be made available for District inspection upon request. [District Rule 1070 and 4702] Federally Enforceable Through Title V Permit

28. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

29. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. {2435} If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

31. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

32. Formerly S-3507-16.

33. Formerly S-382-804.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-71-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW25 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
1478 HP WAUKESHA MODEL L7042GSI NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION AND AUTOMATIC AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The NOx emission concentration shall not exceed 5 ppmvd @ 15% O2. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
3. The CO emission concentration shall not exceed 56 ppmvd @ 15% O2. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
4. The VOC emission concentration shall not exceed 25 ppmvd, as methane, @ 15% O2. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
5. The PM10 emissions shall not exceed 0.02 g/bhp-hr. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The SOx emissions shall not exceed 2.85 lbs/MMscf of natural gas used. [District NSR Rule] Federally Enforceable Through Title V Permit
7. VOC emission rate from fugitive emissions components shall not exceed 0.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. There shall be no leaks in excess of 10,000 ppmv measured pursuant to EPA Method 21 from fugitive emissions components associated with this permit. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c , Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) for <10,000 ppmv (no leaks). [District NSR Rule] Federally Enforceable Through Title V Permit
10. Engine shall be equipped with nonresettable fuel and hourly meters. [District Rule 4702] Federally Enforceable Through Title V Permit
11. The engine shall be equipped with an automatic air to fuel ratio control system. [District NSR Rule] Federally Enforceable Through Title V Permit
12. Source testing of the NOx, CO and VOC emission concentrations shall be conducted within 60 days of initial startup and at least once every 12 months thereafter. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
13. Source testing for NOx emissions shall be conducted utilizing CARB 100 or EPA method 7E. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

14. Source testing for CO emissions shall be conducted utilizing CARB 100 or EPA method 10. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit

15. Source testing for VOC emissions shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit

16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081] Federally Enforceable Through Title V Permit

17. The results of each source test must be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

18. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit

19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O2 monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701, 4702, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

20. If either the NOx or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4701, 4702, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701, 4702, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701, 4702, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

23. All records shall be retained for a minimum of five years, and shall be made available for District inspection upon request. [District Rule 1070 and 4702] Federally Enforceable Through Title V Permit

24. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. {2435} If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

27. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. The permittee shall monitor and record the catalyst inlet and outlet temperatures daily. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [40 CFR 64] Federally Enforceable Through Title V Permit

29. The minimum acceptable catalyst temperature differential shall be established by source testing this unit. [40 CFR 64] Federally Enforceable Through Title V Permit

30. If the catalyst temperature differential is lower than the normal range/level, the permittee shall return the temperature differential to the normal range/level as soon as possible, but no longer than 8 hours after detection. If the catalyst temperature differential rate is not returned to the normal range/level within 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new temperature differential. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100 (Amended 12/17/92), the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [40 CFR 64] Federally Enforceable Through Title V Permit

31. The permittee shall maintain records of the date and time of temperature measurements, and a description of any corrective action taken to maintain the temperature differential within the acceptable range. [40 CFR 64] Federally Enforceable Through Title V Permit

32. The operator shall submit a Title V minor modification application to incorporate catalyst temperature range established for this engine within twelve months from the date in which the initial Title V permit is issued. [District Rule 2520, 9.3.2 and 40 CFR 64] Federally Enforceable Through Title V Permit

33. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR Part 64.7. [40 CFR 64] Federally Enforceable Through Title V Permit

34. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR 64] Federally Enforceable Through Title V Permit

35. If the District or EPA determine that a Quality Improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR 64] Federally Enforceable Through Title V Permit

36. Formerly S-3507-17.

37. Formerly S-382-805.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-72-1 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
16,000 BBL FIXED ROOF PRODUCTION TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON WITH S-1216-64

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
7. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District NSR Rule] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-73-1 **EXPIRATION DATE:** 08/31/2010

DRAFT

EQUIPMENT DESCRIPTION:
1,500 BBL FIXED ROOF PRODUCTION TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
7. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.3 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District NSR Rule] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-75-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE23 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
1,500 BBL FIXED ROOF CRUDE OIL TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64 (REVISED 2/4/08)

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
7. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.3 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District NSR Rule] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-78-1 **EXPIRATION DATE:** 08/31/2010

DRAFT

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF SLOP OIL TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64

PERMIT UNIT REQUIREMENTS

1. VOC emission rate associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 0.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
8. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District NSR Rule] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-85-2 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
17.5 MMBTU/HR PORTABLE LPG-FIRED STEAM GENERATOR WITH NORTH AMERICAN 4211 GLE BURNER AND FLUE GAS RECIRCULATION

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct (ATC) for such modifications, except for changes specified in the conditions below. [District Rule 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit [District Rule 4306] Federally Enforceable Through Title V Permit
3. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 4306] Federally Enforceable Through Title V Permit
4. When designated as a dormant emissions unit, the permittee shall not be required to perform source testing or monitoring requirements otherwise required by this permit. [District Rule 4306] Federally Enforceable Through Title V Permit
5. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
6. This unit may not be operated after the applicable compliance schedule from Rule 4320, unless a valid ATC is implemented that approves the changes allowing this unit to comply with the applicable requirements of Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
7. The equipment shall not be located within 1,000 feet of any K-12 school. [CH&SC 42301.6]
8. Upon recommencing operation, flue gas recirculation system shall be operational at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Steam generator shall be fired exclusively on LPG and shall have no provisions for firing on fuel oil. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Emission rates shall not exceed any of the following: PM10: 0.006 lb/MMBtu, SOx (as SO2): 0.001 lb/MMBtu, NOx (as NO2): 14 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu or CO: 25 ppmv @ 3% O2. [District NSR Rule, 4305 and 4306] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, tests for SOx emissions shall be conducted at least once every 12 months by fuel gas sulfur content analysis and higher heating value analysis of fuel source. [District NSR Rule] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted under conditions representative of normal operation. [District Rule 1081] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Source tests for NOx and CO emissions shall be conducted at least once every 12 months. If compliance is demonstrated on two consecutive annual tests, frequency for NOx and CO source tests shall be reduced to at least once every 36 months. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing at least once every 36 months, frequency for NOx and CO source tests shall be increased to at least once every 12 months. [District NSR Rule, District Rule 4305 and 4306] Federally Enforceable Through Title V Permit

14. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. [District Rules 4305, 6.3.2 and 4306, 6.3.2] Federally Enforceable Through Title V Permit

15. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 4305, 6.3.2 and 4306, 6.3.2] Federally Enforceable Through Title V Permit

16. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 4305, 6.3.2 and 4306, 6.3.2] Federally Enforceable Through Title V Permit

17. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 4305, 6.3.2 and 4306, 6.3.2] Federally Enforceable Through Title V Permit

18. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 4305, 6.3.2 and 4306, 6.3.2] Federally Enforceable Through Title V Permit

19. Sample collection for source testing shall be District witnessed, or authorized, and be conducted by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4306] Federally Enforceable Through Title V Permit

23. Upon recommencing operation the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every month using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the unit unless monitoring has been performed within the last month. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. If the NOX and/or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit

25. Upon recommencing operation the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit

26. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit

27. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. [District Rule 4301] Federally Enforceable Through Title V Permit

28. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. [District Rule 4801 and Kern 407] Federally Enforceable Through Title V Permit

29. Particulate matter emissions shall not exceed 0.1 grain/dscf at operating conditions, nor 0.1 grain/dscf calculated to 12% CO2. [District Rule 4201 and District Rule 4301, 5.1] Federally Enforceable Through Title V Permit

30. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3-one hour periods. [Kern County Rule 424] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

33. On and after July 1, 2012, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit

34. Formerly S-382-704-1.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-86-1 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
100 BBL FIXED ROOF PRODUCTION TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1212-48

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Collected vapors shall be discharged only to vapor control system listed on S-1216-48. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
5. VOC emission rate from the components in gas and light oil service associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 0.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. All piping, valves and other fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.3.3] Federally Enforceable Through Title V Permit
7. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
8. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District NSR Rule] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

13. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

14. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

16. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

17. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

19. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-87-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 29 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
44.58 MMBTU/HR WELL SAFETY FLARE AUTHORIZED TO OPERATE AT VARIOUS UNSPECIFIED LOCATIONS WITHIN THE LIGHT OIL WESTERN STATIONARY SOURCE

PERMIT UNIT REQUIREMENTS

1. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070 and Kern 107] Federally Enforceable Through Title V Permit
2. The flare shall not operate within 2300 feet of any receptor. [District Rule 4102]
3. Flare shall not be located within 1000 ft of a school. [District Rule CH&SC 42301.6]
4. The flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
5. The outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311, 5.3] Federally Enforceable Through Title V Permit
6. Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an alternative equivalent device, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
7. Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
8. Flaring is prohibited unless it is consistent with an approved flare minimization plan (FMP), and all commitments listed in that plan have been met. This standard shall not apply if the APCO determines that the flaring is caused by an emergency and is necessary to prevent an accident, hazard or release of vent gas directly to the atmosphere. [District Rule 5.8] Federally Enforceable Through Title V Permit
9. The operator shall monitor the vent gas flow to the flare with a flow measuring device. [District Rule 4311, 5.10] Federally Enforceable Through Title V Permit
10. The operator shall maintain and retain on-site for a minimum of five years, and made available to the District, ARB, and EPA a copy of the approved flare minimization plan, a copy of annual reports submitted to the District, and all applicable flare monitoring data collected as required by this permit. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit
11. The operator of a flare subject to flare minimization shall notify the APCO of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, which ever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

12. Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare minimization shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. The report shall include, but is not limited to all of the following: the results of an investigation to determine the primary cause and contributing factors of the flaring event; any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; if appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and the date, time, and duration of the flaring event. [District Rule 4311, 6.2.2] Federally Enforceable Through Title V Permit

13. Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare monitoring requirements shall submit an annual report to the APCO within 30 days following the end of each 12 month period. The report shall include the following: the total volumetric flow of vent gas in standard cubic feet for each day; if the flow monitor used measures molecular weight, the average molecular weight for each hour of each month; for any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month; and the means used to determine flow; flare monitoring system downtime periods, including dates and times; and a flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing. [District Rule 4311, 6.2.3] Federally Enforceable Through Title V Permit

14. Vent gas flow shall be determined using one or more of the following methods: EPA Methods 1 and 2; a verification method recommended by the manufacturer of the flow monitoring equipment installed; tracer gas dilution or velocity; and other flow monitors or process monitors that can provide comparison data on a vent stream that is being directed past the ultrasonic flow meter. [District Rule 4311, 6.3.5] Federally Enforceable Through Title V Permit

15. The operator shall submit a flare minimization plan to the District for approval that complies with the requirements of section 6.5 of District Rule 4311 (6/18/09). [District Rule 4311, 6.5] Federally Enforceable Through Title V Permit

16. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. The operator shall test the sulfur content of the gases being flared and demonstrate the sulfur content does not exceed 3.3% by weight. [District Rule 2520, 9.3.2 and Kern County Rule 407] Federally Enforceable Through Title V Permit

17. To show compliance with sulfur emission limits, the gas being flared shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for the flared gas, then the compliance testing frequency shall be semi-annually. If a semi-annual sulfur content test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

18. The sulfur content of the gas being flared shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. The fuel higher heating value for the gases being flared shall be certified by third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. The permittee shall maintain accurate records of gas volume flared. These records and all records of required monitoring data and support information shall be maintained and retained for a period of 5 years and made available for inspection at any time. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

21. Formerly S-382-409-4.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-88-1

EXPIRATION DATE: 08/31/2010

DRAFT

SECTION: 29 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
44.58 MMBTU/HR WELL SAFETY FLARE

PERMIT UNIT REQUIREMENTS

1. The flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
2. The outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311, 5.3] Federally Enforceable Through Title V Permit
3. Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an alternative equivalent device, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
4. Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
5. Flaring is prohibited unless it is consistent with an approved flare minimization plan (FMP), and all commitments listed in that plan have been met. This standard shall not apply if the APCO determines that the flaring is caused by an emergency and is necessary to prevent an accident, hazard or release of vent gas directly to the atmosphere. [District Rule 5.8] Federally Enforceable Through Title V Permit
6. The operator shall monitor the vent gas flow to the flare with a flow measuring device. [District Rule 4311, 5.10] Federally Enforceable Through Title V Permit
7. The operator shall maintain and retain on-site for a minimum of five years, and made available to the District, ARB, and EPA a copy of the approved flare minimization plan, a copy of annual reports submitted to the District, and all applicable flare monitoring data collected as required by this permit. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit
8. The operator of a flare subject to flare minimization shall notify the APCO of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, which ever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare minimization shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. The report shall include, but is not limited to all of the following: the results of an investigation to determine the primary cause and contributing factors of the flaring event; any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; if appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and the date, time, and duration of the flaring event. [District Rule 4311, 6.2.2] Federally Enforceable Through Title V Permit

10. Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare monitoring requirements shall submit an annual report to the APCO within 30 days following the end of each 12 month period. The report shall include the following: the total volumetric flow of vent gas in standard cubic feet for each day; if the flow monitor used measures molecular weight, the average molecular weight for each hour of each month; for any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month; and the means used to determine flow; flare monitoring system downtime periods, including dates and times; and a flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing. [District Rule 4311, 6.2.3] Federally Enforceable Through Title V Permit

11. Vent gas flow shall be determined using one or more of the following methods: EPA Methods 1 and 2; a verification method recommended by the manufacturer of the flow monitoring equipment installed; tracer gas dilution or velocity; and other flow monitors or process monitors that can provide comparison data on a vent stream that is being directed past the ultrasonic flow meter. [District Rule 4311, 6.3.5] Federally Enforceable Through Title V Permit

12. The operator shall submit a flare minimization plan to the District for approval that complies with the requirements of section 6.5 of District Rule 4311 (6/18/09). [District Rule 4311, 6.5] Federally Enforceable Through Title V Permit

13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. The operator shall test the sulfur content of the gases being flared and demonstrate the sulfur content does not exceed 3.3% by weight. [District Rule 2520, 9.3.2 and Kern County Rule 407] Federally Enforceable Through Title V Permit

14. To show compliance with sulfur emission limits, the gas being flared shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for the flared gas, then the compliance testing frequency shall be semi-annually. If a semi-annual sulfur content test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. The sulfur content of the gas being flared shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. The fuel higher heating value for the gases being flared shall be certified by third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

17. The permittee shall maintain accurate records of gas volume flared. These records and all records of required monitoring data and support information shall be maintained and retained for a period of 5 years and made available for inspection at any time. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

18. Formerly S-382-410-3. [District NSR Rule]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-89-1

EXPIRATION DATE: 08/31/2010

DRAFT

SECTION: 29 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
0.028 MMBTU/HR TANK VAPOR RECOVERY SYSTEM FLARE

PERMIT UNIT REQUIREMENTS

1. The flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
2. The outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311, 5.3] Federally Enforceable Through Title V Permit
3. Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an alternative equivalent device, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
4. Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
5. Flaring is prohibited unless it is consistent with an approved flare minimization plan (FMP), and all commitments listed in that plan have been met. This standard shall not apply if the APCO determines that the flaring is caused by an emergency and is necessary to prevent an accident, hazard or release of vent gas directly to the atmosphere. [District Rule 5.8] Federally Enforceable Through Title V Permit
6. The operator shall monitor the vent gas flow to the flare with a flow measuring device. [District Rule 4311, 5.10] Federally Enforceable Through Title V Permit
7. The operator shall maintain and retain on-site for a minimum of five years, and made available to the District, ARB, and EPA a copy of the approved flare minimization plan, a copy of annual reports submitted to the District, and all applicable flare monitoring data collected as required by this permit. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit
8. The operator of a flare subject to flare minimization shall notify the APCO of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, which ever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare minimization shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. The report shall include, but is not limited to all of the following: the results of an investigation to determine the primary cause and contributing factors of the flaring event; any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; if appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and the date, time, and duration of the flaring event. [District Rule 4311, 6.2.2] Federally Enforceable Through Title V Permit

10. Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare monitoring requirements shall submit an annual report to the APCO within 30 days following the end of each 12 month period. The report shall include the following: the total volumetric flow of vent gas in standard cubic feet for each day; if the flow monitor used measures molecular weight, the average molecular weight for each hour of each month; for any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month; and the means used to determine flow; flare monitoring system downtime periods, including dates and times; and a flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing. [District Rule 4311, 6.2.3] Federally Enforceable Through Title V Permit

11. Vent gas flow shall be determined using one or more of the following methods: EPA Methods 1 and 2; a verification method recommended by the manufacturer of the flow monitoring equipment installed; tracer gas dilution or velocity; and other flow monitors or process monitors that can provide comparison data on a vent stream that is being directed past the ultrasonic flow meter. [District Rule 4311, 6.3.5] Federally Enforceable Through Title V Permit

12. The operator shall submit a flare minimization plan to the District for approval that complies with the requirements of section 6.5 of District Rule 4311 (6/18/09). [District Rule 4311, 6.5] Federally Enforceable Through Title V Permit

13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. The operator shall test the sulfur content of the gases being flared and demonstrate the sulfur content does not exceed 3.3% by weight. [District Rule 2520, 9.3.2 and Kern County Rule 407] Federally Enforceable Through Title V Permit

14. To show compliance with sulfur emission limits, the gas being flared shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for the flared gas, then the compliance testing frequency shall be semi-annually. If a semi-annual sulfur content test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. The sulfur content of the gas being flared shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. The fuel higher heating value for the gases being flared shall be certified by third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

17. The permittee shall maintain accurate records of gas volume flared. These records and all records of required monitoring data and support information shall be maintained and retained for a period of 5 years and made available for inspection at any time. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

18. Formerly S-382-411-3.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-93-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-94, 108, 109, 110)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
5. VOC fugitive emissions from the components in gas service on tank and tank vapor collection system shall not exceed 0.16 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Except as otherwise provided in this permit, the operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
9. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

11. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

16. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

17. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

18. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

19. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

22. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

23. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

25. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Formerly S-2010-2

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-94-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
3,300 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Formerly S-2010-7-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-95-3 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
WATERFLOOD PLANT/WATER CLEANING AND INJECTION OPERATION INCLUDING ONE 5,000 BBL WASH TANK (T1) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48

DRAFT

PERMIT UNIT REQUIREMENTS

1. Crude oil throughput of gauging/cleaning plant shall not exceed 1,800 bbl/day. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The operation shall include up to 6 liquid transfer pumps. [District Rule 2010] Federally Enforceable Through Title V Permit
3. The operation shall include vapor piping from tanks T1 (S-1216-95), T2 (S-1216-135), T3 (S-1216-96), T4 (S-1216-98), T5 (S-1216-97), T6 (S-1216-133), T7 (S-1216-134), T8 (S-1216-136) and Wemco (S-1216-132) to 1 C gas plant (S-48) collection system. [District Rule 2010] Federally Enforceable Through Title V Permit
4. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
6. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
7. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
9. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.063 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit

11. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

12. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

13. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

16. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

17. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

18. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

19. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

20. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit
22. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit
23. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
25. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
26. Formerly S-2010-17-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-96-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF STORAGE/SHIPPING TANK (#3) SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Formerly S-2010-18-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-97-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF FILTER FEED TANK (T5) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
5. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.026 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

11. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

12. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

15. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

16. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

17. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

18. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

20. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

23. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. Formerly S-2010-19-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-98-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T4) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
5. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.026 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

10. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

11. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

12. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

15. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

16. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

17. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

18. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

20. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

23. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. Formerly S-2010-21-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-100-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH TANKS S-1216-101, '-102, '-103, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. Tank vapors shall vent only through collection system and discharge only to gas gathering line. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Tank vapor control system shall include interconnecting piping between tanks, liquid knock out vessel, pressure control valve, emergency relief valves, piping connecting to gas gathering system. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

9. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

10. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

11. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

13. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

14. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

16. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

21. Formerly S-2010-65

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-101-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, '-102, '-103, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-66

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-102-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, '-101, '-103, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-67-1

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-103-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, -101, '-102, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-68

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-104-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, '-101, '-102, '-103, AND '-105

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-69

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-105-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, '-101, '-102, '-103, AND '-104

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-70

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-106-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
191 BBL FIXED ROOF PETROLEUM STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. {2641} This tank shall be subject to the requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.3] Federally Enforceable Through Title V Permit
2. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
4. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
5. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
8. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

12. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

15. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Formerly S-2010-72

17. Formerly S-3079-25

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-107-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,042 BBL FIXED ROOF CRUDE OIL STORAGE TANK

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit (DEU), at which time this permit will be administratively modified to remove DEU references. [District Rule 2080] Federally Enforceable Through Title V Permit
3. When this tank is not operated (dormant for Rule 4623), all liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Results of TVP test on material introduced to this tank upon reactivation shall be submitted to the District within 60 days of recommencing operation of this tank. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Upon recommencing operation, permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
7. In lieu of testing each uncontrolled fixed roof tank, an operator may conduct a TVP testing of a representative tank provided the following requirements are met. The selection of representative, uncontrolled fixed roof tanks is submitted in writing to the APCO, and written approval is granted by the APCO prior to conducting the test. One uncontrolled fixed roof tank represents some or all of the tanks in a tank battery. For crude oil production facilities, the representative uncontrolled fixed roof tank shall be the first line tank (or tanks) in a tank battery that is first receiving the produced fluids (mixture of oil, water, and gases) from the crude oil production wells. The stored organic liquid in each of the represented tanks is the same and came from the same source. The TVP and storage temperature of the stored organic liquid of the representative tank to be tested are the same or higher than those of the tanks it is to represent. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
8. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. If the tank stores crude oil or petroleum distillates, the operator shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
9. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit

11. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be subject to the control requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.2] Federally Enforceable Through Title V Permit

13. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

14. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

15. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

16. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

17. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

18. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

19. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

20. Formerly S-2010-74

21. Formerly S-3079-26

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-108-3

EXPIRATION DATE: 08/31/2010

DRAFT

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF CRUDE OIL STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. All liquids shall be removed from this dormant emissions unit and the produced crude oil inlet line shall be physically disconnected. [District Rule 4623] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued and implemented for all necessary retrofits to comply with the applicable requirements of District Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
5. Formerly S-2010-82
6. Formerly S-3079-28

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-109-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM LISTED ON PERMIT S-1216-93

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
5. VOC fugitive emissions from the components in gas service on tank shall not exceed 0.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Except as otherwise provided in this permit, the operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
9. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

11. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

16. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

17. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

18. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

19. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

22. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

23. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

25. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Formerly S-2010-83

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-110-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM LISTED ON PERMIT S-1216-93

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
5. VOC fugitive emissions from the components in gas service on tank shall not exceed 0.08 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Except as otherwise provided in this permit, the operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
9. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit

11. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

16. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

17. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

18. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

19. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

22. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

23. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

24. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

25. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Formerly S-2010-84

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-111-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE12 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1571 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1216-122

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-87

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-122-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE12 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL CRUDE OIL STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48 SHARED WITH S-1216-111

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-184

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-123-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
10,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM SHARED WITH TANKS S-1216-125 AND '-126 AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. This unit has a storage capacity of 420,000 gallons but is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Formerly S-2010-185

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-124-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
10,221 BBL FIXED ROOF STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

7. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

8. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

9. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. This unit is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Formerly S-2010-187

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-125-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
10,221 BBL FIXED ROOF STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-123 AND '-126) AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. This unit is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Formerly S-2010-188

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-126-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
10,221 BBL FIXED ROOF STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-123 AND '-125) AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. This unit is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Formerly S-2010-189

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-127-2 **EXPIRATION DATE:** 08/31/2010

SECTION: 27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
250 BBL FIXED ROOF CRUDE OIL DRAIN TANK SERVED BY A P/V RELIEF VALVE

DRAFT

PERMIT UNIT REQUIREMENTS

1. The pressure-vacuum relief valve shall be set to within ten (10) percent of the maximum allowable working pressure of the tank. The pressure-vacuum relief valve shall be permanently labeled with the operating pressure settings. The pressure-vacuum relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
2. TVP of material stored in tank shall not exceed 11 psia. [District Rule 4623 5.1.1] Federally Enforceable Through Title V Permit
3. Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. In lieu of testing each uncontrolled fixed roof tank, an operator may conduct a TVP testing of a representative tank provided the following requirements are met. The selection of representative, uncontrolled fixed roof tanks is submitted in writing to the APCO, and written approval is granted by the APCO prior to conducting the test. One uncontrolled fixed roof tank represents some or all of the tanks in a tank battery. For crude oil production facilities, the representative uncontrolled fixed roof tank shall be the first line tank (or tanks) in a tank battery that is first receiving the produced fluids (mixture of oil, water, and gases) from the crude oil production wells. The stored organic liquid in each of the represented tanks is the same and came from the same source. The TVP and storage temperature of the stored organic liquid of the representative tank to be tested are the same or higher than those of the tanks it is to represent. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. If the tank stores crude oil or petroleum distillates, the operator shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
6. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
7. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit

9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. Permittee shall also maintain monthly records of average daily throughput. [District Rules 4623] Federally Enforceable Through Title V Permit

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Formerly S-3079-48-0.

17. Formerly S-2010-190-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-128-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW21 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR CONTROL SYSTEM INCLUDING PIPING TO CHEVRON 1-C GAS PLANT (S-48)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Formerly S-2010-193

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-129-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW21 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
140 BBL FIXED ROOF STORAGE TANK

DRAFT

PERMIT UNIT REQUIREMENTS

1. {2641} This tank shall be subject to the requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.3] Federally Enforceable Through Title V Permit
2. {2587} True vapor pressure of the petroleum liquid stored shall be less than 0.5 psia. [District Rule 4623] Federally Enforceable Through Title V Permit
3. {2588} Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
4. {2589} For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
5. {2590} For other organic liquids, the true vapor pressure (TVP) shall be measured using Reid vapor pressure ASTM Method D323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance of the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulations for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4.3] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)." Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
8. Operator shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A of District Rule 4623 (5/19/05) to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 2080] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

12. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 2080] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

15. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. S-2010-194

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-130-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
2400 BBL FIXED-ROOF PETROLEUM WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM (BUENA VISTA)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Tank roof appurtenances shall be maintained leak free (less than 10,000 ppmv). [District NSR Rule] Federally Enforceable Through Title V Permit
5. Tank shall vent exclusively to vapor recovery system. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

10. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

11. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

13. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

14. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

16. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Formerly S-1641-43-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-131-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED-ROOF PETROLEUM WASH TANK (#IGF52) SERVED BY A VAPOR RECOVERY SYSTEM LISTED ON S-1216-44 (LITTLE SIX LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Tank roof appurtenances shall be maintained leak free (less than 10,000 ppmv). [District NSR Rule] Federally Enforceable Through Title V Permit
6. Operation shall include make-up gas line with Varec Fig. 181 valve regulator and piping through Varec Fig. 180 valve regulator to gas gathering line shared between permit units S-1216-44, S-1216-46, and S-1216-131. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Tank shall vent exclusively to vapor recovery system shared between permit units S-1216-44, S-1216-46, and S-1216-131. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Tank S-1216-131 shall be operated at constant fluid level. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Varec Fig. 181 gas regulator shall activate when tank pressure falls below 2 in. H2O allowing make-up gas to enter tank. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Varec Fig. 180 gas regulator shall activate when tank pressure rises above 2 in-H20 allowing vapor to be drawn into gas gathering line. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Total combined volatile organic compound (VOC) emissions from tanks S-1216-44, S-1216-46, and S-1216-131 shall not exceed 0.24 lb per day. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

13. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

16. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

17. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

18. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

19. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

20. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

22. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

23. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

25. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

26. Formerly S-1130-23-0

27. Formerly S-1641-45-0

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-132-2 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
WEMCO MODEL 84 OIL/WATER SEPARATOR RATED AT 40,000 BBL/DAY AND SERVED BY GAS PLANT VAPOR RECOVERY SYSTEM AT FACILITY S-48

PERMIT UNIT REQUIREMENTS

1. All piping, valves, and fittings shall be constructed and maintained in a leak-tight condition. [District NSR Rule] Federally Enforceable Through Title V Permit
2. A leak-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. Fugitive VOC emissions rate for the WEMCO oil/water separator shall be calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components in gas/light liquid service, shall not exceed 0.3 lb-VOC/day or 110 lb-VOC/yr. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. Components subject to District Rule 4409 shall be identified and categorized according to District Rule 4409 component types. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall comply with District Rule 4409 requirements of conditions 44 through 98 of the facility-wide requirements, S-1216-0-1. [District Rule 4409] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-133-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T6) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-134-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T7) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District NSR rule and 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit
9. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

13. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

14. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

16. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

17. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

19. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-135-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
10,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T2) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit
9. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

13. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

14. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

16. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

17. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

19. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-136-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T8) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit
9. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

13. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

14. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

15. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

16. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

17. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

19. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-137-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL STORAGE TANK T9 SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. Fugitive VOC emissions rate shall be calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule] Federally Enforceable Through Title V Permit
4. VOC fugitive emissions from the components in gas and light oil service shall not exceed 0.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
5. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
8. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

10. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

11. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

12. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

14. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

15. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

17. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

20. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-139-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW 20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
195 BHP WAUKESHA MODEL F-1197 SERIAL #265448 FIELD GAS/PROPANE -FIRED RICH BURN CYCLICALLY LOADED I.C. ENGINE WITH NON SELECTIVE CATALYTIC REDUCTION (NSCR) EMISSIONS CONTROL

PERMIT UNIT REQUIREMENTS

1. Unit shall not be located within 1000 feet of any K-12 school. [CH&SC 42301.6]
2. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall notify the District Compliance Division of each location at which the unit is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
6. When unit is dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
7. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
10. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. This unit shall be fired only on propane or gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
12. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

14. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

15. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit

16. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

17. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

22. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. {2437} The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

28. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

29. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits for propane combustion shall be conducted at startup. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

30. NOx, CO, and VOC emissions shall be measured (source tested) not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

31. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

32. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

33. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

35. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

36. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-140-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW 20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
135 BHP WAUKESHA MODEL F-817 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

DRAFT

PERMIT UNIT REQUIREMENTS

1. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
2. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
4. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
5. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
6. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
7. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

23. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. {2437} The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-141-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW 29 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
195 BHP WAUKESHA MODEL F-1197 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED I.C. ENGINE WITH NSCR

DRAFT

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

23. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. {2437} The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-142-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2014 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM INCLUDING COMPRESSOR(S) CONNECTED WITH TANKS S-1216-143 THROUGH '-145 AND '-152 THROUGH '-156 (555 STEVENS ZONE UNIT)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Vapor recovery system shall vent to gas plant (permit S-39-1) only. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

9. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

10. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

11. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

13. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

14. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

16. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-143-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2500 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Tank throughput shall not exceed 1,500 bbl/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
7. Operator shall maintain records of daily tank throughput. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
9. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

11. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

12. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

14. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

15. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

17. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

18. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

20. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

22. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-144-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2014 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-145-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2014 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. All piping valves and fittings shall be constructed and maintained in a leak-free condition [District Rule 4623] Federally Enforceable Through Title V Permit
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
6. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

12. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

13. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

15. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

16. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

18. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-146-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
200 BBL FIXED ROOF PETROLEUM TEST TANK (555 STEVENS ZONE UNIT)

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 11 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 4623] Federally Enforceable Through Title V Permit

10. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

12. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-147-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
200 BBL FIXED ROOF PETROLEUM TEST TANK (555 STEVENS ZONE UNIT)

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 11 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. This tank shall not be required to de-gas before commencing cleaning activities. All other applicable requirements shall be complied with before, during, and after tank cleaning activities. [District Rule 4623] Federally Enforceable Through Title V Permit

10. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

11. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

12. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

13. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-148-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. {2437} The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-149-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. {2437} The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701, 6.3.1 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-150-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on natural gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. {2437} The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rule 4701, 6.3.1 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-151-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
135 BHP WAUKESHA MODEL 817 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

DRAFT

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
7. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
8. Emissions from the engine shall not exceed any of the following limits: 50 ppmv NOx @ 15% O2 (equivalent to 0.7 g/bhp-hr), 2,000 ppmv CO @ 15% O2 (equivalent to 17.0 g/bhp-hr), 250 ppmv VOC @ 15% O2 (equivalent to 1.2 g/bhp-hr), and 0.063 g-PM10/bhp-hr. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
9. This unit shall be fired only on natural gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
10. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rule 4702] Federally Enforceable Through Title V Permit

12. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit

13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit

14. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

15. {2434} If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

17. {2436} If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

18. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

21. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

22. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit

26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

27. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit

28. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-152-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SE20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2000 BBL PRODUCED WATER TANK WITH VAPOR CONTROL (STEVENS LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The fixed-roof storage tank shall be vented to vapor control system described in PTO S-1738-251. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to relieve pressure at a pressure level higher than that required to actuate compressor. The P/V valve shall be permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District NSR Rule and Rule 4623] Federally Enforceable Through Title V Permit
6. The water level in the water seal hatch shall be kept in accordance with the manufacturer's specifications, maintaining a leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Operator shall inspect and replenish the water level in the water seal hatch on a daily basis. Records of the water level shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
8. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

23. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-153-1

EXPIRATION DATE: 08/31/2010

DRAFT

EQUIPMENT DESCRIPTION:
2000 BBL PRODUCED WATER TANK WITH VAPOR CONTROL (STEVENS LEASE)

PERMIT UNIT REQUIREMENTS

1. The fixed-roof storage tank shall be vented to vapor control system described in PTO S-1738-251. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping valves and fittings shall be constructed and maintained in a leak-free condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to relieve pressure at a pressure level higher than that required to actuate compressor. The P/V valve shall be permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District NSR Rule and Rule 4623] Federally Enforceable Through Title V Permit
6. The water level in the water seal hatch shall be kept in accordance with the manufacturer's specifications, maintaining a leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Operator shall inspect and replenish the water level in the water seal hatch on a daily basis. Records of the water level shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
8. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

23. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-154-1 **EXPIRATION DATE:** 08/31/2010

DRAFT

EQUIPMENT DESCRIPTION:
1000 BBL PRODUCED WATER TANK #508 WITH VAPOR CONTROL (STEVENS LEASE)

PERMIT UNIT REQUIREMENTS

1. The fixed-roof storage tank shall be vented to vapor control system described in PTO# S-1738-7. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to relieve pressure at a pressure level higher than that required to actuate compressor. The P/V valve shall be permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District NSR Rule and Rule 4623] Federally Enforceable Through Title V Permit
6. The water level in the water seal hatch shall be kept in accordance with the manufacturer's specifications, maintaining a leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Operator shall inspect and replenish the water level in the water seal hatch on a daily basis. Records of the water level shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
8. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623] Federally Enforceable Through Title V Permit

11. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623] Federally Enforceable Through Title V Permit

12. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623] Federally Enforceable Through Title V Permit

13. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623] Federally Enforceable Through Title V Permit

14. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid having a TVP of 0.5 psia or greater. [District Rule 4623] Federally Enforceable Through Title V Permit

15. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

16. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623] Federally Enforceable Through Title V Permit

17. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623] Federally Enforceable Through Title V Permit

18. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623] Federally Enforceable Through Title V Permit

19. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623] Federally Enforceable Through Title V Permit

20. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

21. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

23. {2608} This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-155-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
10,000 BBL FIXED ROOF PETROLEUM PRODUCTION TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. Tank shall be connected to the VOC vapor control system listed on S-1216-142. VOC vapors from tank shall vent only to the vapor control system. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
2. Storage tank pressure-vacuum cap(s) shall be set to relieve pressure at a pressure level higher than that required to actuate compressor. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
3. Storage tank pressure-vacuum cap(s) shall be leak-free (except for inbreathing) during normal operation. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR and District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 parts per million by volume (ppmv), as methane, above background on a portable hydrocarbon detection instrument that is calibrated with methane in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. [District NSR Rule and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR and District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in both gas and liquid service on this tank shall not exceed 0.2 lb-VOC/day [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed [District NSR Rule] Federally Enforceable Through Title V Permit
9. Except as otherwise provided in this permit, the operator shall ensure that the VOC vapor control system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Any component found to be leaking is in violation of the District's NSR Rule, even if it is under the voluntary inspection and maintenance program. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

13. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

15. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

16. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

17. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

18. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid is placed, held, or stored in this tank. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

22. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

23. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

24. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 4623, 5.7] Federally Enforceable Through Title V Permit

25. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-156-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF PETROLEUM PRODUCTION TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

DRAFT

PERMIT UNIT REQUIREMENTS

1. Tank shall be connected to the VOC vapor control system listed on S-1216-142. VOC vapors from tank shall vent only to the vapor control system. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
2. Storage tank pressure-vacuum cap(s) shall be set to relieve pressure at a pressure level higher than that required to actuate compressor. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
3. Storage tank pressure-vacuum cap(s) shall be leak-free (except for inbreathing) during normal operation. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR and District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 parts per million by volume (ppmv), as methane, above background on a portable hydrocarbon detection instrument that is calibrated with methane in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. [District NSR Rule and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR and District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in both gas and liquid service on this tank shall not exceed 0.2 lb-VOC/day [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed [District NSR Rule] Federally Enforceable Through Title V Permit
9. Except as otherwise provided in this permit, the operator shall ensure that the VOC vapor control system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Any component found to be leaking is in violation of the District's NSR Rule, even if it is under the voluntary inspection and maintenance program. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. The tank shall be maintained in a leak-free condition and equipped with an APCO approved vapor recovery system consisting of a closed system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in a leak-free condition. The VOC control device shall be one of the following: a condensation or vapor recovery system that connects to a gas processing plant, a field gas pipeline, a pipeline distributing PUC quality gas for sale, an injection well for disposal of vapors, or a VOC control device that reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4623] Federally Enforceable Through Title V Permit

13. The tank shall comply with the voluntary inspection and maintenance program requirements of conditions 99 through 107 of the Facility-Wide Permit S-1216-0-1. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

15. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

16. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

17. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

18. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid is placed, held, or stored in this tank. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

22. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

23. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

24. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 4623, 5.7] Federally Enforceable Through Title V Permit

25. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

Attachment A

Detailed Facility Printout

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

OCCIDENTAL OF ELK HILLS INC	FAC #	**S 1216**	TYPE:	**TitleV**	EXPIRE ON: 08/31/2010
LIGHT OIL WESTERN	STATUS:	**A**	TOXIC ID:	**50184**	AREA: 81 /
	TELEPHONE:				INSP. DATE: 06/12

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-1-1	5,250 gallons	3020-05 B	1	93.00	93.00	A	125 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (MAYS LEASE)
S-1216-2-1	42,000 gallons	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13382 (MAYS LEASE)
S-1216-3-1	42,000 gallons	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13381 (MAYS LEASE)
S-1216-7-1	21,000 gallons	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (TAFT LEASE)
S-1216-8-1	84,000 gallons	3020-05 D	1	185.00	185.00	A	2,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #10752 (TAFT LEASE)
S-1216-10-1	7,560 gallons	3020-05 B	1	93.00	93.00	A	180 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (AIRPORT LEASE)
S-1216-11-1	84,000 gallons	3020-05 D	1	185.00	185.00	A	2,000 BBL FIXED ROOF STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13303 (AIRPORT LEASE)
S-1216-20-1	21,000 gallons	3020-05 C	1	135.00	135.00	A	500 BBL WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (BALBOA LEASE)
S-1216-21-1	21,000 gallons	3020-05 C	1	135.00	135.00	A	500 BBL STOCK TANK SERVED BY A PRESSURE RELIEF DEVICE (#5384, BALBOA LEASE)
S-1216-22-1	20,580 gallons	3020-05 C	1	135.00	135.00	A	490 BARREL FIXED ROOF WASH TANK SERVED BY A PRESSURE/VACUUM RELIEF VENT VALVE (MAYS LEASE)
S-1216-42-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#.05GF17) SERVED BY VAPOR CONTROL SYSTEM INCLUDING COMPRESSOR(S) AND PIPING TO GAS PIPELINE SHARED WITH S-1216-43
S-1216-43-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#.05GF8) SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-42 (KING LEASE)
S-1216-44-0	84,000 GALLONS	3020-05 D	1	185.00	185.00	A	2,000 BBL FIXED-ROOF PETROLEUM WASH TANK (#08002M06E) SERVED BY A VAPOR RECOVERY SYSTEM (LITTLE SIX LEASE)
S-1216-45-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF PETROLEUM WASH TANK SERVED BY PRESSURE-VACUUM VENTS (SECTION 14 TANK SETTING, BUENA VISTA HILLS)
S-1216-46-2	42,000 GALLONS	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED-ROOF PETROLEUM SHIPPING TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-44 (LITTLE SIX LEASE)

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-47-0	12,600 GALLONS	3020-05 B	1	93.00	93.00	A	300 BBL FIXED ROOF PETROLEUM WASH TANK SERVED BY A PRESSURE-VACUUM VENT (SECTION 10 TANK SETTING, BUENA VISTA HILLS)
S-1216-48-2	8820 gallons	3020-05 B	1	93.00	93.00	A	210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-49, S-1216-50, S-1216-59, S-1216-63, AND S-1216-86 DISCHARGING TO FIELD GAS GATHERING LINE (SEC 26 BUENA VISTA LEASE)
S-1216-49-0	8,820 GALLONS	3020-05 B	1	93.00	93.00	A	210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1216-48 (SEC 26 FEE LEASE)
S-1216-50-0	31,500 GALLONS	3020-05 C	1	135.00	135.00	A	750 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1216-48 (#REW 31, SECTION 8 LEASE)
S-1216-51-0	210,000 gallons	3020-05 E	1	246.00	246.00	A	5,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #5GF6 (SECTION 8 LEASE)
S-1216-52-0	31,500 gallons	3020-05 C	1	135.00	135.00	A	750 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (SECTION 8 LEASE)
S-1216-53-0	42,000 GALLONS	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #RECYCLE 3 (SECTION 8 LEASE)
S-1216-54-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK SERVED BY A VAPOR RECOVERY SYSTEM (SECTION 8 LEASE)
S-1216-55-0	8,400 GALLONS	3020-05 B	1	93.00	93.00	A	200 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#02GF1, SECTION 10 TANK SETTING, BUENA VISTA HILLS) SERVED BY A PRESSURE-VACUUM VENT VALVE
S-1216-56-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#5GF14, SECTION 14, BUENA VISTA HILLS) SERVED BY A PRESSURE-VACUUM VENT VALVE
S-1216-57-0	42,000 gallons	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #1GF34 (SECTION 16A LEASE)
S-1216-58-0	42,000 gallons	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #1GF35 (SECTION 16A LEASE)
S-1216-59-0	8,820 GALLON CRUDE OIL TANK	3020-05 B	1	93.00	93.00	A	210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-48 (SECTION 26 BUENA VISTA LEASE)
S-1216-60-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL STORAGE TANK SERVED BY A VAPOR CONTROL SYSTEM WITH A 25 HP COMPRESSOR SHARED WITH S-1216-61 AND '-62 (B.V. HILLS OILFIELD LEASE)
S-1216-61-0	21,000 GALLONS	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-60 (B.V. HILLS OILFIELD LEASE)

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-62-0	42,000 GALLONS	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF CRUDE OIL WASH TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-60 (B.V. HILLS OILFIELD LEASE)
S-1216-63-0	8820 GAL STORAGE TANK	3020-05 B	1	93.00	93.00	A	210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-48 (SEC 26 BUENA VISTA LEASE)
S-1216-64-2	126,000 gallon	3020-05 E	1	246.00	246.00	A	3,000 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR CONTROL SYSTEM SHARED WITH S-1216-66, '-72, '-73, '-74 &'-75
S-1216-66-0	126,000 gallons	3020-05 E	1	246.00	246.00	A	3,000 BBL WELDED, FIXED ROOF PRODUCED WATER TANK SERVED BY VAPOR CONTROL SYSTEM LISTED ON S-1216-64 (ASPHALTO FEE)
S-1216-67-0	225 bhp	3020-10 C	1	240.00	240.00	A	225 BHP NATURAL GAS FIRED CATERPILLAR MODEL G342NA IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION (NSCR) AND AIR/FUEL RATIO CONTROLLER, POWERING A COMPRESSOR
S-1216-68-0	0.75 MMbtu/hr	3020-02 D	1	314.00	314.00	A	GLYCOL GAS DEHYDRATION OPERATION INCLUDING GLYCOL REBOILER WITH 0.75 MMBTU/HR-AFTERBURNER
S-1216-69-0	FLARE RATING > 15MMBTU/HR	3020-02 H	1	1,030.00	1,030.00	A	EMERGENCY GAS PLANT FLARE INCLUDING: AUTOMATIC ELECTRONIC IGNITER AND GAS LIQUID SEPARATOR
S-1216-70-0	325 bhp	3020-10 C	1	240.00	240.00	A	325 BHP CATERPILLAR MODEL 3406 TA NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION AND AUTOMATIC AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR
S-1216-71-0	1478 bhp	3020-10 F	1	749.00	749.00	A	1478 BHP WAUKESHA MODEL L7042GSI NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION AND AUTOMATIC AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR
S-1216-72-0	672,000 gallons	3020-05 F	1	301.00	301.00	A	16,000 BBL FIXED ROOF PRODUCTION TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON WITH S-1216-64
S-1216-73-0	63,000 gallons	3020-05 D	1	185.00	185.00	A	1,500 BBL FIXED ROOF PRODUCTION TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64
S-1216-75-0	63,000 gallon	3020-05 D	1	185.00	185.00	A	1,500 BBL FIXED ROOF CRUDE OIL TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64 (REVISED 2/4/08)
S-1216-78-0	42,000 gallon tank	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF SLOP OIL TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64
S-1216-85-0	17.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	17.5 MMBTU PORTABLE LPG-FIRED STEAM GENERATOR WITH NORTH AMERICAN 4211 GLE BURNER AND FLUE GAS RECIRCULATION
S-1216-86-0	4200 gallons	3020-05 A	1	75.00	75.00	A	100 BBL FIXED FIXED ROOF PRODUCTION TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH-1212-48

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-87-1	44.58 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	44.58 MMBTU/HR WELL SAFETY FLARE AUTHORIZED TO OPERATE AT VARIOUS UNSPECIFIED LOCATIONS WITHIN THE LIGHT OIL WESTERN STATIONARY SOURCE
S-1216-88-0	44.58 MMBTU/HR	3020-02 H	1	1,030.00	1,030.00	A	44.58 MMBTU/HR EMERGENCY WELL SAFETY FLARE
S-1216-89-0	0.028 MMBTU/HR	3020-02 A	1	87.00	87.00	A	0.028 MMBTU/HR TANK VAPOR RECOVERY SYSTEM FLARE
S-1216-93-0	42,000 Gallons	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-94 AND CONNECTED TO S-48 FIELD GAS COLLECTION HEADER)
S-1216-94-0	138,600 GALLONS	3020-05 E	1	246.00	246.00	A	3,300 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM
S-1216-95-0	210,000 gallons	3020-05 E	1	246.00	246.00	A	WATERFLOOD PLANT/WATER CLEANING AND INJECTION OPERATION INCLUDING ONE 5,000 BBL WASH TANK (T1) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-96-0	84,000 GALLONS	3020-05 D	1	185.00	185.00	A	2,000 BBL FIXED ROOF STORAGE/SHIPPING TANK (#3) SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48
S-1216-97-0	42,000 gallons	3020-05 C	1	135.00	135.00	A	1,000 BBL FIXED ROOF FILTER FEED TANK (T5) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-98-0	84,000 gallons	3020-05 D	1	185.00	185.00	A	2,000 BBL FIXED CRUDE OIL PRODUCTION TANK (T4) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-100-0	22,344 GALLONS	3020-05 C	1	135.00	135.00	A	532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH TANKS S-1216-101, '-102, '-103, '-104, AND '-105
S-1216-101-0	82,656 GALLONS	3020-05 D	1	185.00	185.00	A	1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-3079-19 SHARED WITH S-1216-100, '-102, '-103, '-104, AND '-105
S-1216-102-0	22,344 GALLONS	3020-05 C	1	135.00	135.00	A	532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, '-101, '-103, '-104, AND '-105
S-1216-103-0	82,656 GALLONS	3020-05 D	1	185.00	185.00	A	1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-100, -101, '-102, '-104, AND '-105
S-1216-104-0	82,656 GALLONS	3020-05 D	1	185.00	185.00	A	1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-100, '-101, '-102, '-103, AND '-105
S-1216-105-0	82,656 GALLONS	3020-05 D	1	185.00	185.00	A	1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-100, '-101, '-102, '-103, AND '-104
S-1216-106-0	8,022 GALLONS	3020-05 B	1	93.00	93.00	A	191 BBL FIXED ROOF PETROLEUM STORAGE TANK

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-107-0	43,764 GALLONS	3020-05 C	1	135.00	135.00	A	1,042 BBL FIXED ROOF PETROLEUM STORAGE TANK
S-1216-108-0	22,344 GALLONS	3020-05 C	1	135.00	135.00	A	532 BBL FIXED ROOF PETROLEUM STORAGE TANK
S-1216-109-0	22,344 GALLONS	3020-05 C	1	135.00	135.00	A	532 BBL FIXED ROOF PETROLEUM STORAGE TANK
S-1216-110-0	22,344 GALLONS	3020-05 C	1	135.00	135.00	A	532 BBL FIXED ROOF PETROLEUM STORAGE TANK
S-1216-111-0	65,982 GALLONS	3020-05 D	1	185.00	185.00	A	1571 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1216-122
S-1216-122-0	42,000 GALLON STORAGE TANK	3020-05 C	1	135.00	135.00	A	ONE 42,000 GALLON CRUDE OIL STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48 SHARED WITH S-1216-111
S-1216-123-0	420,000 GALLONS	3020-05 E	1	246.00	246.00	A	ONE 420,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM SHARED WITH TANKS S-1216-125 AND '-126 AT GAS PLANT S-48
S-1216-124-0	429,282 GALLONS	3020-05 E	1	246.00	246.00	A	ONE 429,282 GALLON FIXED ROOF STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48
S-1216-125-0	429,282 GALLONS	3020-05 E	1	246.00	246.00	A	ONE 429,282 GALLON FIXED ROOF STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-123 AND '-126) AT GAS PLANT S-48
S-1216-126-0	429,282 GALLONS	3020-05 E	1	246.00	246.00	A	ONE 429,282 GALLON FIXED ROOF STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-123 AND '-125) AT GAS PLANT S-48
S-1216-127-0	10,500 GALLONS	3020-05 B	1	93.00	93.00	A	ONE 10,500 GALLON FIXED ROOF CRUDE OIL SUMP REPLACEMENT TANK (DRAIN TANK) SERVED BY A P/V RELIEF VALVE
S-1216-128-0	84,000 GALLON TANK	3020-05 D	1	185.00	185.00	A	ONE 84,000 GALLON FIXED ROOF WASH TANK SERVED BY A VAPOR CONTROL SYSTEM INCLUDING PIPING TO CHEVRON 1-C GAS PLANT (S-48)
S-1216-129-0	5,880 GALLONS	3020-05 B	1	93.00	93.00	A	ONE 5,880 GALLON FIXED ROOF STORAGE TANK
S-1216-130-0	100,800 GALLONS	3020-05 E	1	246.00	246.00	A	ONE 100,800 GALLON FIXED-ROOF PETROLEUM WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM (BUENA VISTA)
S-1216-131-0	42,000 GALLONS	3020-05 C	1	135.00	135.00	A	ONE 42,000 GALLON FIXED-ROOF PETROLEUM WASH TANK (#IGF52) SERVED BY A VAPOR RECOVERY SYSTEM (LITTLE SIX LEASE)
S-1216-132-0	60.5 HP ELECTRIC MOTOR RATING	3020-01 C	1	197.00	197.00	A	WEMCO MODEL 84 OIL/WATER SEPARATOR RATED AT 40,000 BBL/DAY AND SERVED BY GAS PLANT VAPOR RECOVERY SYSTEM AT FACILITY S-48
S-1216-133-0	21,000 gallons	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T6) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-134-0	21,000 gallons	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T7) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-135-0	420,000 gallons	3020-05 E	1	246.00	246.00	A	10,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T2) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-136-0	84,000 gallons	3020-05 D	1	185.00	185.00	A	2000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T8) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-137-0	21,000 gallons	3020-05 C	1	135.00	135.00	A	500 BBL FIXED ROOF CRUDE OIL STORAGE TANK T9 SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48
S-1216-139-0	195 bhp IC engine	3020-10 B	1	117.00	117.00	A	195 BHP WAUKESHA MODEL F-1197 SERIAL #265448 FIELD GAS/PROPANE -FIRED RICH BURN CYCLICALLY LOADED I.C. ENGINE WITH NON SELECTIVE CATALYTIC REDUCTION (NSCR) EMISSIONS CONTROL
S-1216-140-0	135 bhp IC engine	3020-10 B	1	117.00	117.00	A	135 BHP WAUKESHA MODEL F-817 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR
S-1216-141-0	195 bhp IC engine	3020-10 B	1	117.00	117.00	A	195 BHP WAUKESHA MODEL F-1197 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED I.C. ENGINE WITH NSCR
S-1216-142-1	84,588 Gallons	3020-05 D	1	185.00	185.00	A	84,588 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM INCLUDING COMPRESSOR(S) CONNECTED WITH TANKS S-1216-143 THROUGH '-145 AND '-152 THROUGH '-156 (555 STEVENS ZONE UNIT)
S-1216-143-0	105,000 gallon storage	3020-05 E	1	246.00	246.00	A	105,000 GALLON (2500 BBL) FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)
S-1216-144-0	84,588 gallon storage	3020-05 D	1	185.00	185.00	A	84,588 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)
S-1216-145-0	84,588 gallon storage	3020-05 D	1	185.00	185.00	A	84,588 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)
S-1216-146-0	8,400 gallon storage	3020-05 B	1	93.00	93.00	A	8,400 GALLON FIXED ROOF PETROLEUM TEST TANK (555 STEVENS ZONE UNIT)
S-1216-147-0	8,400 gallon storage	3020-05 B	1	93.00	93.00	A	8,400 GALLON FIXED ROOF PETROLEUM TEST TANK (555 STEVENS ZONE UNIT)
S-1216-148-0	147 bhp IC engine	3020-10 B	1	117.00	117.00	A	147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR
S-1216-149-0	147 bhp IC engine	3020-10 B	1	117.00	117.00	A	147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

Detailed Facility Report

For Facility=1216 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1216-150-0	147 bhp IC engine	3020-10 B	1	117.00	117.00	A	147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR
S-1216-151-0	135 bhp IC engine	3020-10 B	1	117.00	117.00	A	135 BHP WAUKESHA MODEL 817 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR
S-1216-152-0	84,000 gallon storage	3020-05 D	1	185.00	185.00	A	84,000 GALLON PRODUCED WATER TANK WITH VAPOR CONTROL (STEVENS LEASE)
S-1216-153-0	84,000 gallon storage	3020-05 D	1	185.00	185.00	A	84,000 GALLON PRODUCED WATER TANK WITH VAPOR CONTROL (STEVENS LEASE)
S-1216-154-0	42,000 gallon storage	3020-05 C	1	135.00	135.00	A	42,000 GALLON PRODUCED WATER TANK #508 WITH VAPOR CONTROL (STEVENS LEASE)
S-1216-155-0	420,000 Gallons	3020-05 E	1	246.00	246.00	A	420,000 GALLON (10,000 BBL) FIXED ROOF PETROLEUM PRODUCTION TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)
S-1216-156-0	21,000 Gallons	3020-05 C	1	135.00	135.00	A	21,000 GALLON (500 BBL) FIXED ROOF PETROLEUM PRODUCTION TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

Number of Facilities Reported: 1

Attachment B

Insignificant Activities or Equipment

San Joaquin Valley
Unified Air Pollution Control District
Title V Application - INSIGNIFICANT ACTIVITIES

COMPANY NAME: Occidental of Elk Hills (OEHI) | FACILITY ID: S - 1216

Check the box next to the exemption category from Rule 2020 which describes any insignificant activity or equipment at your facility not requiring a permit.

Exemption Category	Rule 2020 Citation	√	Exemption Category	Rule 2020 Citation	√
Structure or incinerator assoc. with a structure designed as a dwelling for 4 families or less	4.1	√	Containers used to store refined lubricating oils	6.6.8	√
Locomotives, airplanes, and watercraft used to transport passengers or freight	4.4	√	Unvented pressure vessels used exclusively to store liquified gases or assoc with exempt equipment	6.6.9 or 6.13	√
Natural gas or LPG-fired boilers or other indirect heat transfer units of 5 MMBtu/hr or less	6.1.1	√	Portable tanks used exclusively to store produced fluids for ≤ six months	6.6.10	√
Piston-type i.c.engine with maximum continuous rating of 50 braking horsepower (bhp) or less	6.1.2	√	Mobile transport tanks on delivery vehicles of VOCs	6.6.11	√
Gas turbine engines with maximum heat input rating of 3 MMBtu/hr or less	6.1.3	√	Loading racks used for the transfer of less than 4,000 gal/day of unheated organic material with initial boiling point ≥ 302 F or of fuel oil with specific gravity ≥0.8251	6.7.1.1	√
Space heating equipment other than boilers	6.1.4	√	Loading racks used for the transfer of asphalt, crude or residual oil stored in exempt tanks, or crude oil with specific gravity ≥ 0.8762	6.7.1.2	√
Cooling towers with a circulation rate less than 10,000 gal/min, and that are not used for cooling of process water, or water from barometric jets or condensers++	6.2	√	Equipment used exclusively for the transfer of refined lubricating oil	6.7.2	√
:e of less than 2 gal/day of graphic arts materials	6.3	√	Equipment used to apply architectural coatings	6.8.1	√
Equipment at retail establishments used to prepare food for human consumption	6.4.1	√	Unheated, non-conveyorized cleaning equipment with < 10 ft^2 open area; using solvents with initial boiling point ≥ 248 F; and < 25 gal/yr. evaporative losses	6.9	√
Ovens at bakeries with total daily production less than 1,000 pounds and exempt by sec. 6.1.1	6.4.3	√	Brazing, soldering, or welding equipment	6.10	√
Equipment used exclusively for extruding or compression molding of rubber or plastics, where no plastisizer or blowing agent is used	6.5	√	Equipment used to compress natural gas	6.11	√
Containers used to store clean produced water	6.6.1	√	Fugitive emissions sources assoc. with exempt equipment	6.12	√
Containers ≤100 bbl used to store oil with specific gravity ≥ 0.8762	6.6.2	√	Pits and Ponds as defined in Rule 1020	6.15	√
Containers ≤ 100 bbl installed prior to 6/1/89 used to store oil with specific gravity ≥ 0.8762	6.6.3	√	On-site roadmix manufacturing and the application of roadmix as a road base material	6.17	√
Containers with a capacity ≤ 250 gallons used to store organic material where the actual storage temperature <150 F	6.6.4	√	Emissions less than 2 lb/day from units not included above	6.19	√
Containers used to store unheated organic material with an initial boiling point ≥ 302 F	6.6.5	√	Venting PUC quality natural gas from for sole purpose of pipeline and compressor repair and or maintenance	7.2	√
Containers used to store fuel oils or non-air-blown asphalt with specific gravity ≥0.9042	6.6.6	√	Non-structural repairs & maintenance to permitted equipment	7.3	√
Containers used to store petroleum distillates used as motor fuel with specific gravity ≥ 0.8251	6.6.7	√	Detonation of explosives ≤ 100 lb/day and 1,000 lb/year	7.4	√

☐ No insignificant activities (Check this box if no equipment in the above categories exist at your facility.)

Attachment C

SJVUAPCD Previous Permits

San Joaquin Valley
Air Pollution Control District

FACILITY: S-1216-0-0 **EXPIRATION DATE:** 08/31/2010

FACILITY-WIDE REQUIREMENTS

1. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District Rule 2201]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. Operator shall maintain accurate monthly records of Gas-to-oil ratio (GOR) and API gravity of liquids produced showing that facility exclusively processes, stores, or transfers black oil (as defined in 40 CFR 63.761). [40 CFR 63.10(b)]
4. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4409, 5.1.1]
5. For valves, threaded connections, flanges, pipes, pumps, compressors, and other components subject to the requirements of Rule 4409, but not specified in this permit; a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 2,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1]
6. For pressure relief devices (PRDs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 200 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 400 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1]
7. For polished rod stuffing boxes (PRSBs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1]
8. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.2]
9. Minor gas leaks from PRSBs detected during any District inspection shall not be counted toward determination of compliance with this rule provided the permittee repairs, replaces, or removes leaking PRSBs from VOC service as soon as practicable but not later than seven calendar days. [District Rule 4409, 5.1.3.1.2]
10. Leaks detected during quarterly operator inspections shall not be counted towards determination of compliance with the provisions of Rule 4409 provided the leaking components are repaired as soon as practicable but not later than the time frame specified in this permit. Leaks detected during quarterly operator inspections that are not repaired, replaced, or removed from operation as soon as practicable but not later than the time frame specified in this rule shall be counted toward determination of compliance with the provisions of Rule 4409. [District Rule 4409, 5.1.3.2.1 and 5.1.3.2.2]

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

11. Leaking components at this facility detected during annual operator inspections, as required by Rule 4409 for a specific component type, that exceed the leak standards specified in this permit, shall constitute a violation of this rule. This violation is regardless of whether or not the leaking components are repaired, replaced, or removed from operation within the allowable repair time frame specified in this permit. [District Rule 4409, 5.1.3.2.3]

12. An open-ended line, or a valve located at the end of the line, that is not sealed with either a blind flange, a plug, a cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended line is a leak. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.4.1]

13. A leak from a component is when there is a major liquid leak from the component. A major liquid leak from a component is when a visible mist or a continuous flow of liquid, that is not seal lubricant, leaks from the component. [District Rule 4409, 5.1.4.2]

14. A leak from a component is when gas emissions greater than 50,000 ppmv, as methane, leaks from the component. [District Rule 4409, 5.1.4.3]

15. A minor liquid leak from a component is when more than three drops of liquid per minute, that is not seal lubricant and is not a major liquid leak, leaks from the component. [District Rule 4409, 5.1.4.4]

16. When 200 or fewer valves are inspected, a leak from a valve is when more than one valve has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 valves are inspected, a leak from a valve is when more than 0.5 % (rounded up to the nearest whole number) of the valves have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

17. When 200 or fewer threaded connections are inspected, a leak from a threaded connection is when more than one threaded connection has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 threaded connections are inspected, a leak from a threaded connection is when more than 0.5 % (rounded up to the nearest whole number) of the threaded connections have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

18. When 200 or fewer flanges are inspected, a leak from a flange is when more than one flange has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 flanges are inspected, a leak from a flange is when more than 0.5 % (rounded up to the nearest whole number) of the flanges have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

19. When 200 or fewer pumps are inspected, a leak from a pump is when more than two pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. When greater than 200 pumps are inspected, a leak from a pump is when more than 1.0 % (rounded up to the nearest whole number) of the pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

20. When compressors, PRDs, or other components not specified in this permit are inspected, a leak from these components is when more than one component has a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

21. When 200 or fewer PRSBs are inspected, a leak is when more than four have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 PRSBs are inspected, a leak is when more than 2.0 % (rounded up to the nearest whole number) of the PRSBs have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

22. When 200 or fewer wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than two or more pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than 1.0 % (rounded up to the nearest whole number) of the pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

23. When pipes at natural gas processing facilities are inspected, a leak from a pipe is when more than two have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

24. For manned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once every 24 hours except when operators do not report to the facility during a 24 hour period. [District Rule 4409, 5.2.1]

25. For unmanned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once per calendar week. [District Rule 4409, 5.2.2]

26. All accessible operating pumps, compressors, and PRDs, in service, that are found to be leaking by audio-visual inspection shall be attempted to be repaired immediately. The leaking component shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.3]

27. Except for inaccessible components, unsafe-to-monitor components, or pipes, all components, in service, shall be tested for leaks at least once every calendar quarter. [District Rule 4409, 5.2.4]

28. All new, replaced, or repaired fittings, flanges, and threaded connections shall be tested for leaks immediately after being placed into service. [District Rule 4409, 5.2.5]

29. All inaccessible components shall be tested for leaks at least once every 12 months. [District Rule 4409, 5.2.6]

30. All unsafe-to-monitor components shall be tested for leaks during each turnaround. [District Rule 4409, 5.2.7]

31. All pipes shall be visually inspected for leaks at least once every 12 months. [District Rule 4409, 5.2.8]

32. All pipes, in service, that are found to be leaking by visual inspection shall be attempted to be repaired immediately. The leaking pipe shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.8.1]

33. The annual pipe inspection required by either the Department of Oil, Gas, and Geothermal Resources (DOGGR) pursuant to California Code of Regulation Title 14, Division 2, Subchapter 2, Section 1774 (Oilfield Facilities and Equipment Maintenance), or by the Spill Prevention Control and Countermeasure Plan (SPCC) pursuant to 40 Code of Federal Regulation Part 112 (Oil Prevention and Response: Non- Transportation-Related Onshore and Offshore Facilities) can be used as the annual pipe inspection required by District Rule 4409. [District Rule 4409, 5.2.8.2]

34. Except for pumps, compressors, and PRDs, the permittee may apply for written approval from the District to change the inspection frequency of accessible components from quarterly to annually for a specific component type provided the following two qualifying requirements are met. During the previous five consecutive quarterly inspections, for the specific component type, there shall be no more leaks than as allowed by this permit. The permittee also shall not have received a Notice of Violation (NOV) from the District during the previous 12 months for violating any provisions of District Rule 4409 for the specific component type. If these two qualifying requirements have not been met, then the inspection frequency shall revert back to quarterly. The written request shall include pertinent documentation to demonstrate that the operator has successfully met the two qualifying requirements. [District Rule 4409, 5.2.9 and 5.2.10]

35. The permittee shall notify the District in writing within five calendar days after changing the inspection frequency for a specific component type. The written notification shall include the reason(s) and date of change to a quarterly inspection frequency. [District Rule 4409, 5.2.11]

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

36. A PRD that releases to the atmosphere shall be inspected by the permittee for leaks as soon as practicable but not later than 24 hours after the time of the release. The permittee shall reinspect the PRD for leaks not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the date of the initial release. If the PRD is found by the permittee to be leaking during either inspection, the PRD leak shall be treated as if the leak was found during the required quarterly operator inspections. [District Rule 4409, 5.2.12]

37. Except for PRDs, a component shall be inspected for leaks not later than 15 calendar days after repairing the leak or replacing the component. [District Rule 4409, 5.2.13]

38. District inspections shall not be counted as an operator inspection required by District Rule 4409. Any attempt by an operator to count such District inspections as part of the operator's mandatory inspections is considered a willful circumvention of the rule and is a violation of this rule. [District Rule 4409, 5.2.14]

39. The operator, upon detection of a leaking component, shall affix to that component a weatherproof, readily visible tag, bearing the date and time when the leak was detected and the date and time of the leak measurement. For gaseous leaks, the tag shall indicate the leak concentration in ppmv. For liquid leaks, the tag shall indicate whether it is a major liquid leak or a minor liquid leak. The tag shall indicate, when applicable, whether the component is an essential component, an unsafe-to-monitor component, or a critical component. The tag shall remain in place until the leaking component is repaired or replaced and reinspected and found to be in compliance with the requirements of this rule. [District Rule 4409, 5.3.1]

40. The operator shall minimize all component leaks immediately, to the extent possible, but not later than one hour after detection of the leak in order to stop or reduce leakage to the atmosphere. If the leak has been minimized but the leak still exceeds the applicable leak standards specified in this permit, the operator shall do one of the following within the timeframes specified within this permit: 1) repair or replace the leaking component; 2) vent the leaking component to a closed vent system; 3) or remove the leaking component from operation. A closed vent system is a District approved system that is not open to the atmosphere. It is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to a District approved control device that has a overall VOC collection and destruction or removal efficiency of at least 95%, or that transports gases or vapors back to a process system. [District Rule 4409, 5.3.4 and 5.3.5]

41. The operator shall repair minor gas leaks within seven days. The operator shall repair major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, within three days. The operator shall repair major gas leaks, which are > 50,000 ppmv, within two days. The operator shall repair minor liquid leaks within three days. The operator shall repair major liquid leaks within two days. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period. The start of the repair period shall be the time of the initial leak detection. [District Rule 4409, 5.3.4 and 5.3.5]

42. For each calendar quarter, the operator may extend the repair period for a total number of leaking components, not to exceed 0.05 % of the number of components inspected, by type, rounded upward to the nearest whole number. The repair period for minor gas leaks can be extended by seven additional days. The repair period for major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, can be extended by two additional days. [District Rule 4409, 5.3.5]

43. If a leaking component is an essential component or a critical component and which cannot be shut down immediately for repairs, the operator shall do the following: 1) minimize the leak within one hour after detection of the leak; 2) and if the leak has been minimized, but the leak still exceeds the applicable leak standards of Rule 4409 as specified in this permit, the essential component or critical component shall be repaired or replaced to eliminate the leak during the next process unit turnaround. The repair shall occur no later than one year from the date of the original leak detection. [District Rule 4409, 5.3.6]

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

44. For any component that has incurred five repair actions for major gas leaks or major liquid leaks, or a combination of major gas leaks and major liquid leaks within a continuous 12-month period, the operator shall do one of the following four options. Options 1a through 1f require written notification to the District, option 2 requires written notification to the District and written District approval, options 3 and 4 do not require written notification to the District: 1a) For compressors replace the existing seal with either a dual mechanical seal, an oil film seal, a gas seal, or a face-type seal; 1b) for pumps replace the pump with a seal-less pump or replace the seal with a dual mechanical seal; 1c) for PRDs replace the PRD and install a rupture disc in the line which precedes the PRD such that the PRD is in series with and follows the rupture disc; 1d) for valves replace the valve with a sealed bellows valve, or for seal rings install graphite or Teflon chevron seal rings in a live-loaded packing gland; 1e) for threaded connections weld the connections or replace threaded connections with flanges; 1f) for sampling connections replace the sampling connection with a closed-loop sampling system; 2) Replace the component with Achieved-in-Practice Best Available Control Technology (BACT) equipment; 3) Vent the component to a District approved closed-vent system; 4) Remove the component from operation. For any component that is accessible, is not unsafe-to-monitor, is not an essential component, or is not a critical component, the operator shall comply with these requirements as soon as practicable but not later than twelve months after the date of detection of the fifth major leak within a continuous 12-month period. For any component that is inaccessible, is unsafe-to-monitor, is essential, or is a critical component, the operator shall comply with these requirements as soon as practicable but not later than the next turnaround or not later than two years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes first. [District Rule 4409, 5.3.7]

45. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and recordkeeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other system approved by the District that enables an operator or the District to locate each individual component. The operator shall replace physical identifications that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4409, 5.4.1]

46. The operator shall keep a copy of the District approved Operator Management Plan (OMP) at the facility and make it available to the District, ARB, and EPA upon request. [District Rule 4409, 6.1.2]

47. By January 30th of each year the operator shall submit to the District for approval, in writing, an annual report indicating any changes to the existing OMP on file at the District. [District Rule 4409, 6.1.4]

48. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4409, 6.2.1]

49. Records of leaks detected during quarterly or annual operator inspections, and each subsequent repair and re-inspection, shall be submitted to the District, ARB, and EPA upon request. [District Rule 4409, 6.2.2]

50. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4409, 6.2.3]

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

51. All records required by this permit shall be retained on-site for a minimum of five years and made available for District, ARB, and EPA inspection upon request. [District Rule 4409, 6.2.4]

52. All measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instructions not more than 30 days prior to its use. [District Rule 4409, 6.3.1]

53. The VOC content by weight percent shall be determined using ASTM D-1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 for liquids. [District Rule 4409, 6.3.2]

54. The percent by volume liquid evaporated at 302 øF (150 øC) shall be determined using ASTM D-86. [District Rule 4409, 6.3.3]

55. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D-323, and converting the RVP to TVP at the maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures specified in Appendix A of District Rule 4409. [District Rule 4409, 6.3.4]

56. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM D-287 or ASTM 1298. Sampling for API gravity shall be performed in accordance with ASTM D-4057. [District Rule 4409, 6.3.5]

57. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4409, 6.3.6]

58. Halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422. [District Rule 4409, 6.3.7]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-1-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
125 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (MAYS LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-2-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13382 (MAYS LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-3-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13381 (MAYS LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-7-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 02 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (TAFT LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-8-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 02 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #10752 (TAFT LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-10-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 32 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
180 BBL FIXED ROOF WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (AIRPORT LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-11-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 32 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE #13303 (AIRPORT LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
3. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
4. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-20-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE21 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (BALBOA LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
3. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
4. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
5. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-21-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NE32 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL STOCK TANK SERVED BY A PRESSURE RELIEF DEVICE (#5384, BALBOA LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
3. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
4. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
5. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-22-1 **EXPIRATION DATE:** 08/31/2010

SECTION: NW28 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
490 BARREL FIXED ROOF WASH TANK SERVED BY A PRESSURE/VACUUM RELIEF VENT VALVE (MAYS LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. True vapor pressure of liquids introduced, placed, stored or held in this tank shall not exceed 1.0 psia. [District Rule 2201]
3. Tank shall be designed and operated as a constant liquid level tank. [District Rule 2201]
4. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623]
5. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 2201]
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 2201]
7. Compliance with vapor pressure limit shall be demonstrated by District witnessed or authorized sample collection and analysis. [District Rule 2201]
8. Permittee shall maintain accurate records of liquids stored, storage temperature, and true vapor pressure of such liquids. [District Rule 2201]
9. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623]
10. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-42-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#.05GF17) SERVED BY VAPOR CONTROL SYSTEM INCLUDING COMPRESSOR(S) AND PIPING TO GAS PIPELINE SHARED WITH S-1216-43

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
5. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
6. Vapor control efficiency shall be maintained at no less than 95%. [District Rule 4623]
7. Formerly S-1641-39.
8. Formerly S-382-773.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-43-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#.05GF8) SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-42 (KING LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
5. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
6. Vapor control efficiency shall be maintained at no less than 95%. [District Rule 4623]
7. Formerly S-1641-40.
8. Formerly S-382-774.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-44-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED-ROOF PETROLEUM WASH TANK (#08002M06E) SERVED BY A VAPOR RECOVERY SYSTEM (LITTLE SIX LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Tank shall vent exclusively to gas gathering line shared between permit units S-1216-44 and S-1216-46. [District Rules 2201 and 4623]
3. Operation shall include make-up gas line with Varec Fig. 181 valve regulator and piping through Varec Fig. 180 valve regulator to gas gathering line shared between permit units S-1216-44 and S-1216-46. [District NSR Rule]
4. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
5. Any tank gauging or sampling device shall be equipped with a leak free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
6. All piping, valves, and fittings shall be constructed and maintained in a leak free condition. [District Rules 2201 and 4623]
7. A leak free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak or a liquid leak is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
8. Tank shall be operated at constant fluid level. [District NSR Rule]
9. Varec Fig. 181 gas regulator shall activate when tank pressure falls below 2 in. H2O allowing make-up gas to enter tank. [District NSR Rule]
10. Varec Fig. 180 gas regulator shall activate when tank pressure rises above 2 in-H20 allowing vapor to be drawn into gas gathering line. [District NSR Rule]
11. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
12. Total combined volatile organic compound (VOC) emissions from tanks S-1216-44 and S-1216-46 shall not exceed 0.24 lb per day. [District NSR Rule]
13. The operator shall maintain accurate records of types, storage temperature and true vapor pressure of liquids stored. [District Rule 1070]
14. Formerly S-1130-12-2
15. Formerly S-1641-42.
16. Formerly S-382-775.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-45-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NW14 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF PETROLEUM WASH TANK SERVED BY PRESSURE-VACUUM VENTS (SECTION 14 TANK SETTING, BUENA VISTA HILLS)

PERMIT UNIT REQUIREMENTS

1. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623]
2. This tank shall be in a gas-tight condition. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rule 4623]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. Wash tank shall be operated at constant level. [District NSR Rule]
5. True vapor pressure of any organic liquid introduced to the tank shall be less than 1.5 psia at liquid temperature. [District Rule 4623]
6. Permittee shall test the True Vapor Pressure (TVP) of organic liquids stored at actual storage temperature at least once every 24 months during summer (July - September) and/or whenever there is a change in the source or type of organic liquid stored. Permittee may use the TVP test results from a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 are met. Permittee shall submit the records of TVP and/or API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. [District Rule 4623]
7. If the tank stores crude oil or petroleum distillates, the permittee shall also conduct API gravity testing. [District Rule 4623]
8. TVP of liquids stored shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM 323-94, then converting the RVP to TVP at the maximum storage temperature using the equation in Rule 4623, Appendix B. As an alternative to ASTM D 323-94, the TVP of crude oil with an API gravity range greater than 20 degrees but less than or equal to 30 degrees may be determined by other equivalent test methods approved by APCO, ARB, and EPA. [District Rule 4623]
9. The API gravity of crude oil or petroleum distillate shall be determined by ASTM Method D 287-92 (2000) e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057-95 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products". [District Rule 4623]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623]
11. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]
12. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
13. Formerly S-1130-14-3
14. Formerly S-1641-44.
15. Formerly S-382-776.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-46-2 **EXPIRATION DATE:** 08/31/2010

SECTION: NE 6 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED-ROOF PETROLEUM SHIPPING TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-44 (LITTLE SIX LEASE)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
3. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
4. Tank shall vent exclusively to gas blanketing/gathering line shared with permit unit S-1216-44. [District Rules 2201 and 4623]
5. Operation shall include make-up gas line with Varec Fig. 181 valve regulator and piping through Varec Fig. 180 valve regulator to gas gathering line shared with permit unit S-1216-44. [District NSR Rule]
6. Any tank gauging or sampling device shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rules 2201 and 4623]
7. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rules 2201 and 4623]
8. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak or a liquid leak is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
9. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rules 2201 and 4623]
10. Any component found to be leaking on two consecutive annual inspections is in violation of Rule 4623. [District Rule 4623]
11. Fugitive VOC emissions from the components in gas/light liquid service and light crude oil service on tanks S-1216-44 and 46, combined, shall not exceed 0.24 lb/day. [District Rule 2201]
12. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb (1999), Screening Value Range emissions factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District Rule 2201]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rules 2201 and 4623]
14. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 1070 and 4623]
15. Formerly S-1130-24-0
16. Formerly S-1641-46.
17. Formerly S-382-777.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-47-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE10 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
300 BBL FIXED ROOF PETROLEUM WASH TANK SERVED BY A PRESSURE-VACUUM VENT (SECTION 10 TANK SETTING, BUENA VISTA HILLS)

PERMIT UNIT REQUIREMENTS

1. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623]
2. This tank shall be in a gas-tight condition. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rule 4623]
3. Wash tank shall be operated at constant level. [District NSR Rule]
4. Permittee shall test the True Vapor Pressure (TVP) of organic liquids stored at actual storage temperature at least once every 24 months during summer (July - September) and/or whenever there is a change in the source or type of organic liquid stored. Permittee may use the TVP test results from a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 are met. Permittee shall submit the records of TVP and/or API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. [District Rule 4623]
5. TVP of liquids stored shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM 323-94, then converting the RVP to TVP at the maximum storage temperature using the equation in Rule 4623, Appendix B. As an alternative to ASTM D 323-94, the TVP of crude oil with an API gravity range greater than 20 degrees but less than or equal to 30 degrees may be determined by other equivalent test methods approved by APCO, ARB, and EPA. [District Rule 4623]
6. If the tank stores crude oil or petroleum distillates, the permittee shall also conduct API gravity testing. [District Rule 4623]
7. The API gravity of crude oil or petroleum distillate shall be determined by ASTM Method D 287-92 (2000) e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057-95 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products". [District Rule 4623]
8. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623]
9. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
11. Formerly S-1130-92-0
12. Formerly S-1641-48.
13. Formerly S-382-779.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-48-2 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-49, S-1216-50, S-1216-59, S-1216-63, AND S-1216-86 DISCHARGING TO FIELD GAS GATHERING LINE (SEC 26 BUENA VISTA LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 95% by weight. [40 CFR 60.112a]
2. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2]
3. Collected vapors shall be discharged only to field gas gathering line. [District Rule 2201]
4. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule]
5. VOC emission rate from the components in gas and light oil service associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 0.1 lb/day. [District Rule 2201]
6. VOC fugitive emissions from the components in gas and light oil service on the vapor control system shall not exceed 0.4 lb/day. [District Rule 2201]
7. All piping, valves and other fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.3.3]
8. A leak free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
9. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
10. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)]
12. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)]
13. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]
14. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)]
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 4623]
16. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4]
17. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b, and analysis of halogenated exempt compounds shall be analyzed by ARB Method 422. [District Rule 4623, 6.2.5]
18. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rules 2201 and 4623]
19. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
20. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
21. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
22. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201]
23. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-49-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1216-48 (SEC 26 FEE LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rules 2201 and 4623]
2. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. API gravity of liquid stored shall not exceed 30 as determined by ASTM D-1298-85 or tanks shall be subject to the requirements of District Rule 4403. [District Rules 2201 and 4403]
8. Contents of tank shall be tested by independent laboratory to determine API gravity, upon startup, using ASTM method D-1298-85. [District Rule 1081]
9. The results of the laboratory test for API gravity shall be submitted to the District within 60 days of testing performed at startup. [District Rule 1081]
10. Permittee shall maintain records of API gravity. Such records shall be retained for a period of at least 2 years, and shall be made readily available for District inspection upon request. [District Rule 2201]
11. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
12. Formerly S-1130-99-3
13. Formerly S-1641-50.
14. Formerly S-382-781.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-50-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
750 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1216-48 (#REW 31, SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rules 2201 and 4623]
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rules 2201 and 4623]
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
4. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rules 2201 and 4623]
5. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. Formerly S-1130-117
9. Formerly S-1641-54.
10. Formerly S-382-784.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-51-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #5GF6 (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623]
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623]
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080]
5. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
6. Formerly S-1130-118-0
7. Formerly S-1641-55.
8. Formerly S-382-785.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-52-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
750 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623]
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623]
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080]
5. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
6. Formerly S-1130-120-0
7. Formerly S-1641-57.
8. Formerly S-382-786.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-53-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #RECYCLE 3 (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623]
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623]
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623]
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623]
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623]
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623]
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623]
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]
9. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
10. Formerly S-1130-121-0
11. Formerly S-1641-58.
12. Formerly S-382-787.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-54-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW08 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK SERVED BY A VAPOR RECOVERY SYSTEM (SECTION 8 LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
4. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
5. Tank shall vent vacuum line serving 1C gas plant. [District Rule 2010]
6. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. Formerly S-1130-122-0
9. Formerly S-1641-59.
10. Formerly S-382-788.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-55-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NW10 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
200 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#02GF1, SECTION 10 TANK SETTING, BUENA VISTA HILLS) SERVED BY A PRESSURE-VACUUM VENT VALVE

PERMIT UNIT REQUIREMENTS

1. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623]
2. This tank shall be in a gas-tight condition. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rule 4623]
3. Permittee shall test the True Vapor Pressure (TVP) of organic liquids stored at actual storage temperature at least once every 24 months during summer (July - September) and/or whenever there is a change in the source or type of organic liquid stored. Permittee may use the TVP test results from a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 are met. Permittee shall submit the records of TVP and/or API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. [District Rule 4623]
4. TVP of liquids stored shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM 323-94, then converting the RVP to TVP at the maximum storage temperature using the equation in Rule 4623, Appendix B. As an alternative to ASTM D 323-94, the TVP of crude oil with an API gravity range greater than 20 degrees but less than or equal to 30 degrees may be determined by other equivalent test methods approved by APCO, ARB, and EPA. [District Rule 4623]
5. If the tank stores crude oil or petroleum distillates, the permittee shall also conduct API gravity testing. [District Rule 4623]
6. The API gravity of crude oil or petroleum distillate shall be determined by ASTM Method D 287-92 (2000) e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057-95 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products". [District Rule 4623]
7. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623]
8. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]
9. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Formerly S-1130-123-0
11. Formerly S-1641-60.
12. Formerly S-382-789.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-56-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE14 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (#5GF14, SECTION 14, BUENA VISTA HILLS) SERVED BY A PRESSURE-VACUUM VENT VALVE

PERMIT UNIT REQUIREMENTS

1. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623]
2. This tank shall be in a gas-tight condition. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rule 4623]
3. True vapor pressure of any organic liquid introduced to the tank shall be less than 1.5 psia at liquid temperature. [District Rule 4623]
4. Permittee shall test the True Vapor Pressure (TVP) of organic liquids stored at actual storage temperature at least once every 24 months during summer (July - September) and/or whenever there is a change in the source or type of organic liquid stored. Permittee may use the TVP test results from a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 are met. Permittee shall submit the records of TVP and/or API gravity testing to the APCO within 45 days after the date of testing. The record shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. [District Rule 4623]
5. TVP of liquids stored shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM 323-94, then converting the RVP to TVP at the maximum storage temperature using the equation in Rule 4623, Appendix B. As an alternative to ASTM D 323-94, the TVP of crude oil with an API gravity range greater than 20 degrees but less than or equal to 30 degrees may be determined by other equivalent test methods approved by APCO, ARB, and EPA. [District Rule 4623]
6. If the tank stores crude oil or petroleum distillates, the permittee shall also conduct API gravity testing. [District Rule 4623]
7. The API gravity of crude oil or petroleum distillate shall be determined by ASTM Method D 287-92 (2000) e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057-95 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products". [District Rule 4623]
8. Permittee shall keep an accurate record of each organic liquid stored, including its storage temperature, TVP, and API gravity. [District Rule 4623]
9. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
11. Formerly S-1130-124-0
12. Formerly S-1641-61.
13. Formerly S-382-790.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-57-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #1GF34 (SECTION 16A LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623]
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623]
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080]
5. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
6. Formerly S-1130-125-0
7. Formerly S-1641-62.
8. Formerly S-382-791.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-58-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE16 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #1GF35 (SECTION 16A LEASE)

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of liquids stored shall not exceed 1.5 psia. [District Rule 4623]
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623. [District Rule 4623]
3. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
4. All liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080]
5. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
6. Formerly S-1130-127-0
7. Formerly S-1641-63.
8. Formerly S-382-792.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-59-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-48 (SECTION 26 BUENA VISTA LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
4. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. API gravity of liquid stored shall not exceed 30 as determined by ASTM D-1298-85 or tanks shall be subject to the requirements of District Rule 4403. [District Rules 2201 and 4403]
8. Average daily throughput of oil (on annual basis) shall not exceed 420 bbl per day. [District Rule 2201]
9. Permittee shall maintain records of API gravity and average daily throughput, records shall be retained for a minimum of 2 years, and shall be made available for District inspection upon request. [District Rule 2201]
10. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
11. Formerly S-1130-133-0
12. Formerly S-1641-64.
13. Formerly S-382-793.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-60-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL STORAGE TANK SERVED BY A VAPOR CONTROL SYSTEM WITH A 25 HP COMPRESSOR SHARED WITH S-1216-61 AND '-62 (B.V. HILLS OILFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
5. True vapor pressure shall not exceed 4.7 psia. [District Rule 2201]
6. The permittee shall maintain accurate records of true vapor pressure, storage temperature and types of liquids stored. Such records shall be retained for a period of at least two years, and shall be made readily available for District inspection upon request. [District Rule 1070]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. Formerly S-1130-134-3
9. Formerly S-1641-65.
10. Formerly S-382-794.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-61-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-60 (B.V. HILLS OILFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
5. True vapor pressure shall not exceed 4.7 psia. [District Rule 2201]
6. The permittee shall maintain accurate records of true vapor pressure, storage temperature and types of liquids stored. Such records shall be retained for a period of at least two years, and shall be made readily available for District inspection upon request. [District Rule 1070]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. Formerly S-1130-135-2
9. Formerly S-1641-66.
10. Formerly S-382-795.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-62-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF CRUDE OIL WASH TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-60 (B.V. HILLS OILFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
5. True vapor pressure shall not exceed 4.7 psia. [District Rule 2201]
6. The permittee shall maintain accurate records of true vapor pressure, storage temperature and types of liquids stored. Such records shall be retained for a period of at least two years, and shall be made readily available for District inspection upon request. [District Rule 1070]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. Formerly S-1130-136-2
9. Formerly S-1641-67.
10. Formerly S-382-796.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-63-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
210 BBL FIXED ROOF SHIPPING TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-48 (SEC 26 BUENA VISTA LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
4. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
5. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. True vapor pressure (TVP) of liquid stored in this permit unit shall not exceed 2.71 psia at storage temperature. [District Rule 2201]
8. Average daily throughput of oil (on annual basis) shall not exceed 50 bbl per day. [District Rule 2201]
9. API gravity of liquid stored shall not exceed 30 degrees as determined by ASTM D-1298-85 or liquid handling components shall be subject to the requirements of District Rule 4403. [District Rules 2201 and 4403]
10. Permittee shall maintain records of API gravity, TVP and average daily throughput. Such records shall be retained for a period of at least 2 years, and shall be made readily available for District inspection upon request. [District Rule 2201]
11. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
12. Formerly S-1130-158-0
13. Formerly S-1641-68.
14. Formerly S-382-797.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-64-2 **EXPIRATION DATE:** 08/31/2010

SECTION: NE 23 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
3,000 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR CONTROL SYSTEM SHARED WITH S-1216-66, '-72, '-73, '-74 &'-75

PERMIT UNIT REQUIREMENTS

1. Authority to Construct (ATC) S-1216-64-1 shall be implemented concurrently, or prior to the modification and startup of the equipment authorized by this Authority to Construct. [District Rule 2201]
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
5. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
6. Tank roof appurtenances shall be maintained leak free. [District Rule 4623]
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
9. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]
10. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) eliminate or minimize the leak within 8 hours after detection, (b) if the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices and eliminate the leak within 48 hours after detection. In no event shall the total time to minimize and eliminate the leak exceed 56 hours after detection. [District Rule 4623, 5.7 9 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]
12. Operator shall maintain an inspection log containing the following 1) type of component leaking; 2) date and time of leak detection, and method of detection; 3) date and time of leak repair, and emission level of recheck after leak is repaired; 4) method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 1070]
13. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.4.7]
14. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District Rules 4623 and 2201]
15. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.3 lb/day. [District Rule 2201]
16. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
17. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
18. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
19. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 2201]
20. All records shall be maintained for a period of at least five years and made available for District inspection upon request. [District Rule 1070]
21. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
22. Formerly S-3506-1-0.
23. Formerly S-1641-69.
24. Formerly S-382-798.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-66-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE 23 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
3,000 BBL WELDED, FIXED ROOF PRODUCED WATER TANK SERVED BY VAPOR CONTROL SYSTEM LISTED ON S-1216-64 (ASPHALTO FEE)

PERMIT UNIT REQUIREMENTS

1. VOC emission rate from vapor, light liquid, and light crude oil service components associated with tank, up to the tie-in with the vapor control trunk-line, shall not exceed 0.5 lb/day. [District Rule 2201]
2. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rules 2201 and 4623, 3.9 and 6.4.8]
3. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions using California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2C: Oil and Gas Production Screening Value Ranges (<10,000 ppmv) Emission Factors with 100% VOC content in components. [District Rule 2201]
4. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
5. Except as otherwise provided in this permit, tank roof appurtenances shall be maintained leak free. [District Rules 2201 and 4623]
6. The tank shall be equipped with a vapor control system consisting of a closed vent system that collects all VOCs from the storage tank to vapor control system S-1216-64 capable of reducing VOC emissions by at least 95%. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. [District Rules 2201 & 4623, 5.6.1]
7. If the source can demonstrate compliance with the provisions of Rule 4623 Section 5.7 any deviations that are addressed under the provisions of Table 3 through 6 shall not be in violation of this permit. [District Rule 4623, 5.7]
8. Except as otherwise provided in this permit, all piping, valves, and fittings shall be constructed and maintained in a gas tight condition. [District Rule 4623, 5.6.3]
9. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. [District Rule 4623, 3.9 and 6.4.8]
10. Any tank gauging or sampling device on a tank vented to the vapor control system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2]
11. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
12. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) eliminate or minimize the leak within 8 hours after detection, (b) if the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices and eliminate the leak within 48 hours after detection. In no event shall the total time to minimize and eliminate the leak exceed 56 hours after detection. [District Rule 4623, 5.7 9 (Table 3)]
14. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]
15. Operator shall maintain an inspection log containing the following 1) type of component leaking; 2) date and time of leak detection, and method of detection; 3) date and time of leak repair, and emission level of recheck after leak is repaired; 4) method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 1070]
16. Permittee shall comply with all applicable requirements of Rule 4403. [District Rule 4403]
17. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.4.7]
18. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District Rules 4623 and 2201]
19. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
20. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
21. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
22. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 2201]
23. All records shall be maintained for a period of at least five years and made available for District inspection upon request. [District Rule 1070]
24. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
25. Formerly S-1641-75.
26. Formerly S-382-800.

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

COPY

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-67-2 **ISSUANCE DATE:** 06/10/2008

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS, INC.
MAILING ADDRESS: P.O. BOX 1001
TUPMAN, CA 93276

LOCATION: LIGHT OIL WESTERN

SECTION: NW15 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
225 HP CATERPILLAR MODEL G342NA NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION (NSCR) AND AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR. MODIFICATION TO DESIGNATE AS A NON-COMPLIANT DORMANT EMISSIONS UNIT.

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520]
2. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
3. The fuel supply line shall be physically disconnected from this unit to ensure that this unit is not operated. [District Rule 4702]
4. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4702 and all other applicable District regulations. [District Rule 4702]
5. Approved locations for this IC engine are NW 1/4 Sec 15, T30S, R22E and NW 1/4 Sec 23, T30S, R22E. [District Rule 2201]
6. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070]
7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801)]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 326-6900 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-67-2 : Jun 10 2008 1:08PM -- CHANK : Joint Inspection NOT Required

8. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201]

9. Engine shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District NSR Rule]

10. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 1160]

11. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246. [District Rule 4801]

12. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 4801]

13. The operator of an internal combustion (IC) engine shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4701]

14. Exhaust shall vent through catalytic converter only. [District NSR Rule]

15. Emissions shall not exceed the following: PM10: 9.8E-5 lb/hp-hr, NOx (as NO2): 7.8E-4 lb/hp-hr (25 ppmv at 15% O2), VOC: 3.26E-4 lb/hp-hr (30 ppmv at 15% O2) and CO: 1.52E-2 lb/hp-hr (800 ppmv at 15% O2). [District NSR Rule]

16. NOx, and CO emissions shall be measured at least once every 24 months with source test conducted by an independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 4701]

17. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. [In-stack O2 monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4701]

18. If the NOx or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4701]

19. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4701]

20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance test, and a test plan must be submitted for approval 15 days prior to testing. [District Rule 1081]

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701]

CONDITIONS CONTINUE ON NEXT PAGE

23. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with rule 4701 for a period of five years and shall make such records readily available for District inspection upon request. [District Rule 4701]

24. An operating log record shall be maintained that includes compliance source test results, monitoring data, make and model of exhaust gas analyzer, exhaust gas analyzer calibration records, and catalyst maintenance and cleaning intervals. [District Rules 4701]

25. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100]

26. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100]

27. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rule 2010, 3.0, 4.0, and 2020]

28. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080]

29. Every application for a permit required under Rule 2010 (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040]

30. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2080]

31. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2080]

32. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. [District Rule 1100, 7.0]

33. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit . [District Rule 1080]

34. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2080]

35. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 3010]

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2080]

CONDITIONS CONTINUE ON NEXT PAGE

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2080]

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2080]

39. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2080]

40. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101, by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101]

41. Formerly S-3507-7.

42. Formerly S-382-801.

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-68-3 **ISSUANCE DATE:** 07/19/2011

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: SE14 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:
MODIFICATION OF GLYCOL GAS DEHYDRATION OPERATION INCLUDING GLYCOL REBOILER WITH 0.75 MMBTU/HR AFTERBURNER: ALLOW DESIGNATION AS COMPLIANT DORMANT EMISSIONS UNIT

CONDITIONS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080]
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080]
3. While dormant, normal source testing shall not be required. [District Rule 2080]
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080]
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080]
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
7. Total dehydrated gas by this permit unit shall not exceed 7.5 MMscf of gas in any one day. [District 2201 Rule]
8. All glycol reboiler vent gas shall be burned in afterburner and none shall vent to atmosphere. [District Rule 2201 and 4408]
9. Only glycol shall be used as the dehydration medium. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

COPY

DAVID WARNER, Director of Permit Services
S-1216-68-3 : Jul 20 2011 11:55AM -- SIONGCOJ : Joint Inspection NOT Required

10. Condensate handling shall be conducted in closed systems resulting in fugitive component emissions only and no evaporation of VOCs. [District Rule 2201 and 4408]
11. The afterburner shall operate at all times when dehydration is taking place. [District 2201 Rule]
12. Afterburner shall operate in a smokeless manner. [District Rule 4408]
13. Afterburner shall be equipped with electronically controlled ignition system with a malfunction alarm system if the pilot flame fails. [District Rule 4408]
14. Afterburner shall be equipped with liquid knockout system to condense any condensable vapors. [District Rule 4408]
15. Afterburner shall be equipped with a sight glass port if the flame is not visible. [District Rule 4408]
16. All piping, valves and other fittings shall be constructed and maintained in a gas-tight condition. "Gas-tight" shall be defined as emitting no more than 10,000 ppm of methane measured from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rules 2201 and 4408]
17. Glycol reboiler and afterburner shall be fired on PUC quality natural gas. [District 2201 Rule]
18. Afterburner emissions shall not exceed any of the following: NOx - 1.8 lb/day, VOC - 0.5 lb/day, or CO - 1.5 lb/day. [District 2201 Rule]
19. The VOC destruction efficiency from the glycol dehydration afterburner shall be maintained at or greater than 99.9%. [District 2201 Rule]
20. The owner or operator shall maintain accurate daily records of gas dehydrated for a period of five years and shall make such records available for District inspection upon request. [District Rule 1070]

COPY

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-69-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE24 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:
EMERGENCY GAS PLANT FLARE INCLUDING: AUTOMATIC ELECTRONIC IGNITER AND GAS LIQUID SEPARATOR

PERMIT UNIT REQUIREMENTS

1. Flare shall be equipped with automatic reignition provisions, e.g. electronic spark pilot light. [District Rule 2201]
2. Flare shall operate with visible emissions less than 5% opacity. [District Rule 2201]
3. Flare shall operate only during breakdown conditions pursuant to Rule 1100. [District Rule 2201]
4. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100]
5. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100]
6. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rule 2010, 3.0, 4.0, and 2020]
7. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080]
8. Every application for a permit required under Rule 2010 (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040]
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2080]
10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2080]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. [District Rule 1100, 7.0]
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit . [District Rule 1080]
13. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2080]
14. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 3010]
15. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2080]
16. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2080]
17. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2080]
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2080]
19. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101, by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101]
20. Formerly S-3507-12.
21. Formerly S-1793-2-0.
22. Formerly S-382-803.

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

COPY

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-70-2 **ISSUANCE DATE:** 06/10/2008

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS, INC.
MAILING ADDRESS: P.O. BOX 1001
TUPMAN, CA 93276

LOCATION: LIGHT OIL WESTERN

SECTION: NW15 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
325 HP CATERPILLAR MODEL 3406 TA NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION AND AUTOMATIC AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR. MODIFICATION TO DESIGNATE AS A COMPLIANT DORMANT EMISSIONS UNIT.

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520]
2. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
3. The fuel supply line shall be physically disconnected from this unit to ensure that this unit is not operated. [District Rule 4702]
4. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 2201 and 4702]
5. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rule 2201]
6. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
8. Upon recommencing operation the NOx emission concentration shall not exceed 5 ppmvd @ 15% O2. [District Rules 2201 and 4702]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 326-6900 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-70-2 Jun 10 2008 1:06PM -- CHANK Joint Inspection NOT Required

9. Upon recommencing operation the CO emission concentration shall not exceed 56 ppmvd @ 15% O2. [District Rules 2201 and 4702]

10. Upon recommencing operation the VOC emission concentration shall not exceed 25 ppmvd, as methane, @ 15% O2. [District Rules 2201 and 4702]

11. Upon recommencing operation the PM10 emissions shall not exceed 10.0 lbs/MMscf of natural gas used. [District Rule 2201]

12. Upon recommencing operation the SOx emissions shall not exceed 2.85 lbs/MMscf of natural gas used. [District Rule 2201]

13. The VOC emission rate from fugitive emissions components shall not exceed 0.2 lb/day. [District Rule 2201]

14. There shall be no leaks in excess of 10,000 ppmv measured pursuant to EPA Method 21 from fugitive emissions components associated with this permit. [District Rule 2201]

15. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c , Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) for <10,000 ppmv (no leaks). [District Rule 2201]

16. Engine shall be equipped with nonresettable fuel and hourly meters. [District Rule 4702]

17. The engine shall be equipped with an automatic air to fuel ratio control system. [District Rule 2201]

18. Upon recommencing operation source testing of the NOx, CO and VOC emission concentrations shall be conducted at least once every 12 months. [District Rule 2201 and 4702]

19. Source testing for NOx emissions shall be conducted utilizing CARB 100 or EPA method 7E. [District Rule 4702]

20. Source testing for CO emissions shall be conducted utilizing CARB 100 or EPA method 10. [District Rule 4702]

21. Source testing for VOC emissions shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rule 4702]

22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 4702]

23. The results of each source test must be submitted to the District within 60 days thereafter. [District Rule 1081]

24. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]

25. Upon recommencing operation the permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O2 monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702]

26. Upon recommencing operation if either the NOx or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4702]

CONDITIONS CONTINUE ON NEXT PAGE

27. Upon recommencing operation all alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]

28. Upon recommencing operation the permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702]

29. All records shall be retained for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rule 1070]

30. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100]

31. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100]

32. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rule 2010, 3.0, 4.0, and 2020]

33. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080]

34. Every application for a permit required under Rule 2010 (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040]

35. Upon recommencing operation the operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2080]

36. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2080]

37. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. [District Rule 1100, 7.0]

38. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit . [District Rule 1080]

39. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2080]

CONDITIONS CONTINUE ON NEXT PAGE

40. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 3010]

41. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2080]

42. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2080]

43. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2080]

44. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2080]

45. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101, by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101]

46. Formerly S-3507-16.

47. Formerly S-382-804.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-71-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NW25 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
1478 BHP WAUKESHA MODEL L7042GSI NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION AND AUTOMATIC AIR/FUEL RATIO CONTROLLER POWERING A GAS COMPRESSOR

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
3. The NOx emission concentration shall not exceed 5 ppmvd @ 15% O2. [District Rules 2201, 4701, and 4702]
4. The CO emission concentration shall not exceed 56 ppmvd @ 15% O2. [District Rules 2201, 4701, and 4702]
5. The VOC emission concentration shall not exceed 25 ppmvd, as methane, @ 15% O2. [District Rules 2201, 4701, and 4702]
6. The PM10 emissions shall not exceed 0.02 g/bhp-hr. [District Rule 2201]
7. The SOx emissions shall not exceed 2.85 lbs/MMscf of natural gas used. [District Rule 2201]
8. VOC emission rate from fugitive emissions components shall not exceed 0.2 lb/day. [District Rule 2201]
9. There shall be no leaks in excess of 10,000 ppmv measured pursuant to EPA Method 21 from fugitive emissions components associated with this permit. [District Rule 2201]
10. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c , Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999) for <10,000 ppmv (no leaks). [District Rule 2201]
11. Engine shall be equipped with nonresettable fuel and hourly meters. [District Rule 4702]
12. The engine shall be equipped with an automatic air to fuel ratio control system. [District Rule 2201]
13. Source testing of the NOx, CO and VOC emission concentrations shall be conducted within 60 days of initial startup and at least once every 12 months thereafter. [District Rule 2201, 4701, and 4702]
14. Source testing for NOx emissions shall be conducted utilizing CARB 100 or EPA method 7E. [District Rule 4701]
15. Source testing for CO emissions shall be conducted utilizing CARB 100 or EPA method 10. [District Rule 4701]
16. Source testing for VOC emissions shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rule 4701]
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 4701]
18. The results of each source test must be submitted to the District within 60 days thereafter. [District Rule 1081]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]

20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O2 monitors may be allowed if approved by the APCO.] Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702]

21. If either the NOx or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4701 and 4702]

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702]

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702]

24. All records shall be retained for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rule 1070]

25. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100]

26. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100]

27. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rule 2010, 3.0, 4.0, and 2020]

28. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. Every application for a permit required under Rule 2010 (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040]

30. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2080]

31. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2080]

32. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. [District Rule 1100, 7.0]

33. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit . [District Rule 1080]

34. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2080]

35. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 3010]

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2080]

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2080]

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2080]

39. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2080]

40. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101, by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101]

41. Formerly S-3507-17.

42. Formerly S-382-805.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-72-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
16,000 BBL FIXED ROOF PRODUCTION TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON WITH S-1216-64

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
4. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free. [District Rule 4623]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
8. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]
9. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) eliminate or minimize the leak within 8 hours after detection, (b) if the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices and eliminate the leak within 48 hours after detection. In no event shall the total time to minimize and eliminate the leak exceed 56 hours after detection. [District Rule 4623, 5.7 9 (Table 3)]
10. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Operator shall maintain an inspection log containing the following 1) type of component leaking; 2) date and time of leak detection, and method of detection; 3) date and time of leak repair, and emission level of recheck after leak is repaired; 4) method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 1070]
12. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.4.7]
13. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District Rules 4623 and 2201]
14. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.1 lb/day. [District Rule 2201]
15. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
16. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
17. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
18. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 2201]
19. All records shall be maintained for a period of at least five years and made available for District inspection upon request. [District Rule 1070]
20. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-73-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
1,500 BBL FIXED ROOF PRODUCTION TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
4. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free. [District Rule 4623]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
8. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]
9. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) eliminate or minimize the leak within 8 hours after detection, (b) if the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices and eliminate the leak within 48 hours after detection. In no event shall the total time to minimize and eliminate the leak exceed 56 hours after detection. [District Rule 4623, 5.7 9 (Table 3)]
10. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Operator shall maintain an inspection log containing the following 1) type of component leaking; 2) date and time of leak detection, and method of detection; 3) date and time of leak repair, and emission level of recheck after leak is repaired; 4) method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 1070]
12. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.4.7]
13. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District Rules 4623 and 2201]
14. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.3 lb/day. [District Rule 2201]
15. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
16. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
17. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
18. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 2201]
19. All records shall be maintained for a period of at least five years and made available for District inspection upon request. [District Rule 1070]
20. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-75-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE23 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:
1,500 BBL FIXED ROOF CRUDE OIL TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64 (REVISED 2/4/08)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
4. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free. [District Rule 4623]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
8. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]
9. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) eliminate or minimize the leak within 8 hours after detection, (b) if the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices and eliminate the leak within 48 hours after detection. In no event shall the total time to minimize and eliminate the leak exceed 56 hours after detection. [District Rule 4623, 5.7 9 (Table 3)]
10. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Operator shall maintain an inspection log containing the following 1) type of component leaking; 2) date and time of leak detection, and method of detection; 3) date and time of leak repair, and emission level of recheck after leak is repaired; 4) method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 1070]
12. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.4.7]
13. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District Rules 4623 and 2201]
14. VOC emission rate from vapor, light liquid, and light crude oil components associated with vapor recovery piping shall not exceed 0.3 lb/day. [District Rule 2201]
15. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
16. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
17. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
18. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 2201]
19. All records shall be maintained for a period of at least five years and made available for District inspection upon request. [District Rule 1070]
20. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-78-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF SLOP OIL TANK SERVED BY A VAPOR CONTROL SYSTEM LISTED ON S-1216-64

PERMIT UNIT REQUIREMENTS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. This Authority to Construct (ATC) cancels and supersedes ATC S-1216-74-0. [District Rule 2201]
3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. VOC emission rate associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 0.1 lb/day. [District Rule 2201]
6. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
7. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
9. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
10. Tank roof appurtenances shall be maintained leak free. [District Rule 4623]
11. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
12. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
13. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

14. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) eliminate or minimize the leak within 8 hours after detection, (b) if the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices and eliminate the leak within 48 hours after detection. In no event shall the total time to minimize and eliminate the leak exceed 56 hours after detection. [District Rule 4623, 5.7 9 (Table 3)]
15. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]
16. Operator shall maintain an inspection log containing the following 1) type of component leaking; 2) date and time of leak detection, and method of detection; 3) date and time of leak repair, and emission level of recheck after leak is repaired; 4) method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 1070]
17. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.4.7]
18. Except as otherwise provided in this permit, operator shall ensure that the vapor control system is functional and is operating as designed at all times. [District Rules 4623 and 2201]
19. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
20. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
21. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
22. Permittee shall maintain accurate records of fugitive emissions and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 2201]
23. All records shall be maintained for a period of at least five years and made available for District inspection upon request. [District Rule 1070]

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-85-1 **ISSUANCE DATE:** 09/20/2010

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

EQUIPMENT DESCRIPTION:
MODIFICATION OF 17.5 MMBTU PORTABLE LPG-FIRED STEAM GENERATOR WITH NORTH AMERICAN 4211 GLE BURNER AND FLUE GAS RECIRCULATION: DESIGNATE AS A RULE 4306 COMPLIANT DORMANT EMISSIONS UNIT

CONDITIONS

1. No modification to this unit shall be performed without an Authority to Construct (ATC) for such modifications, except for changes specified in the conditions below. [District Rule 4306]
2. The fuel supply line shall be physically disconnected from this unit [District Rule 4306]
3. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 4306]
4. When designated as a dormant emissions unit, the permittee shall not be required to perform source testing or monitoring requirements otherwise required by this permit. [District Rule 4306]
5. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 4306]
6. This unit may not be operated after the applicable compliance schedule from Rule 4320, unless a valid ATC is implemented that approves the changes allowing this unit to comply with the applicable requirements of Rule 4320. [District Rule 4320]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. The equipment shall not be located within 1,000 feet of any K-12 school. [CH&SC 42301.6]
9. Upon recommencing operation, flue gas recirculation system shall be operational at all times. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-85-1 : Sep 20 2010 10:23AM - TORID : Joint Inspection NOT Required

10. Steam generator shall be fired exclusively on LPG and shall have no provisions for firing on fuel oil. [District NSR Rule] Federally Enforceable Through Title V Permit

11. Emission rates shall not exceed any of the following: PM10: 0.006 lb/MMBtu, SOx (as SO2): 0.001 lb/MMBtu, NOx (as NO2): 14 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu or CO: 25 ppmv @ 3% O2. [District NSR Rule] Federally Enforceable Through Title V Permit

12. Upon recommencing operation, tests for SOx emissions shall be conducted at least once every 12 months by fuel gas sulfur content analysis and higher heating value analysis of fuel source. [District NSR Rule] Federally Enforceable Through Title V Permit

13. Source testing shall be conducted under conditions representative of normal operation. [District Rule 1081] Federally Enforceable Through Title V Permit

14. Source tests for NOx and CO emissions shall be conducted at least once every 12 months. If compliance is demonstrated on two consecutive annual tests, frequency for NOx and CO source tests shall be reduced to at least once every 36 months. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing at least once every 36 months, frequency for NOx and CO source tests shall be increased to at least once every 12 months. [District NSR Rule and District Rule 4305] Federally Enforceable Through Title V Permit

15. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

16. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305,6.3.2] Federally Enforceable Through Title V Permit

17. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

18. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

19. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. Sample collection for source testing shall be District witnessed, or authorized, and be conducted by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305] Federally Enforceable Through Title V Permit

24. Upon recommencing operation the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every month using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the unit unless monitoring has been performed within the last month. [District Rule 4305] Federally Enforceable Through Title V Permit

25. If the NOX and/or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4305] Federally Enforceable Through Title V Permit

26. Upon recommencing operation the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305] Federally Enforceable Through Title V Permit

27. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit

28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

30. On and after July 1, 2012, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320]

31. Formerly S-382-704-1. [District NSR Rule]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-86-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
100 BBL FIXED FIXED ROOF PRODUCTION TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH-1212-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 95% by weight. [40 CFR 60.112a]
2. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2]
3. Collected vapors shall be discharged only to vapor control system listed on S-1216-48. [District Rule 2201]
4. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District NSR Rule]
5. VOC emission rate from the components in gas and light oil service associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 0.1 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, valves and other fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.3.3]
7. A leak free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)]
9. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)]
10. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)]
12. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)]
13. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)]
14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 4623]
15. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4]
16. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b, and analysis of halogenated exempt compounds shall be analyzed by ARB Method 422. [District Rule 4623, 6.2.5]
17. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rules 2201 and 4623]
18. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance but occurs as a routine maintenance activity. [District Rule 2020]
19. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7]
20. Permittee shall comply with all applicable Tank Interior Cleaning Program requirements specified in Table 6 of Rule 4623. [District Rule 4623, 5.7]
21. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201]
22. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4623]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-87-1 **EXPIRATION DATE:** 08/31/2010

SECTION: 29 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
44.58 MMBTU/HR WELL SAFETY FLARE AUTHORIZED TO OPERATE AT VARIOUS UNSPECIFIED LOCATIONS WITHIN THE LIGHT OIL WESTERN STATIONARY SOURCE

PERMIT UNIT REQUIREMENTS

1. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070]
2. The flare shall not operate within 2300 feet of any receptor. [District Rule 4102]
3. Flare shall not be located within 1000 ft of a school. [District Rule CH&SC 42301.6]
4. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)]
5. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)]
6. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0]
7. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020]
8. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031]
9. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040]
10. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1]

12. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4]

13. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3]

14. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F]

15. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B]

16. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8021 and 8011]

17. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8031 and 8011]

18. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8041 and 8011]

19. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8051 and 8011]

20. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8061 and Rule 8011]

21. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8071 and Rule 8011]

22. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M]

23. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

24. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan, and comply with all the requirements of Program 1, 2, or 3 when mandated by the regulation. [40 CFR Part 68]

25. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4409, 5.1.1]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. For valves, threaded connections, flanges, pipes, pumps, compressors, and other components subject to the requirements of Rule 4409, but not specified in this permit; a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 2,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1]

27. For pressure relief devices (PRDs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 200 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 400 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1]

28. For polished rod stuffing boxes (PRSBs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1]

29. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.2]

30. Minor gas leaks from PRSBs detected during any District inspection shall not be counted toward determination of compliance with this rule provided the permittee repairs, replaces, or removes leaking PRSBs from VOC service as soon as practicable but not later than seven calendar days. [District Rule 4409, 5.1.3.1.2]

31. Leaks detected during quarterly operator inspections shall not be counted towards determination of compliance with the provisions of Rule 4409 provided the leaking components are repaired as soon as practicable but not later than the time frame specified in this permit. Leaks detected during quarterly operator inspections that are not repaired, replaced, or removed from operation as soon as practicable but not later than the time frame specified in this rule shall be counted toward determination of compliance with the provisions of Rule 4409. [District Rule 4409, 5.1.3.2.1 and 5.1.3.2.2]

32. Leaking components at this facility detected during annual operator inspections, as required by Rule 4409 for a specific component type, that exceed the leak standards specified in this permit, shall constitute a violation of this rule. This violation is regardless of whether or not the leaking components are repaired, replaced, or removed from operation within the allowable repair time frame specified in this permit. [District Rule 4409, 5.1.3.2.3]

33. An open-ended line, or a valve located at the end of the line, that is not sealed with either a blind flange, a plug, a cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended line is a leak. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.4.1]

34. A leak from a component is when there is a major liquid leak from the component. A major liquid leak from a component is when a visible mist or a continuous flow of liquid, that is not seal lubricant, leaks from the component. [District Rule 4409, 5.1.4.2]

35. A leak from a component is when gas emissions greater than 50,000 ppmv, as methane, leaks from the component. [District Rule 4409, 5.1.4.3]

36. A minor liquid leak from a component is when more than three drops of liquid per minute, that is not seal lubricant and is not a major liquid leak, leaks from the component. [District Rule 4409, 5.1.4.4]

37. When 200 or fewer valves are inspected, a leak from a valve is when more than one valve has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 valves are inspected, a leak from a valve is when more than 0.5 % (rounded up to the nearest whole number) of the valves have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

38. When 200 or fewer threaded connections are inspected, a leak from a threaded connection is when more than one threaded connection has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 threaded connections are inspected, a leak from a threaded connection is when more than 0.5 % (rounded up to the nearest whole number) of the threaded connections have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

39. When 200 or fewer flanges are inspected, a leak from a flange is when more than one flange has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 flanges are inspected, a leak from a flange is when more than 0.5 % (rounded up to the nearest whole number) of the flanges have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

40. When 200 or fewer pumps are inspected, a leak from a pump is when more than two pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. When greater than 200 pumps are inspected, a leak from a pump is when more than 1.0 % (rounded up to the nearest whole number) of the pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

41. When compressors, PRDs, or other components not specified in this permit are inspected, a leak from these components is when more than one component has a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

42. When 200 or fewer PRSBs are inspected, a leak is when more than four have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 PRSBs are inspected, a leak is when more than 2.0 % (rounded up to the nearest whole number) of the PRSBs have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

43. When 200 or fewer wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than two or more pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than 1.0 % (rounded up to the nearest whole number) of the pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

44. When pipes at natural gas processing facilities are inspected, a leak from a pipe is when more than two have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4]

45. For manned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once every 24 hours except when operators do not report to the facility during a 24 hour period. [District Rule 4409, 5.2.1]

46. For unmanned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once per calendar week. [District Rule 4409, 5.2.2]

47. All accessible operating pumps, compressors, and PRDs, in service, that are found to be leaking by audio-visual inspection shall be attempted to be repaired immediately. The leaking component shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.3]

48. Except for inaccessible components, unsafe-to-monitor components, or pipes, all components, in service, shall be tested for leaks at least once every calendar quarter. [District Rule 4409, 5.2.4]

49. All new, replaced, or repaired fittings, flanges, and threaded connections shall be tested for leaks immediately after being placed into service. [District Rule 4409, 5.2.5]

50. All inaccessible components shall be tested for leaks at least once every 12 months. [District Rule 4409, 5.2.6]

51. All unsafe-to-monitor components shall be tested for leaks during each turnaround. [District Rule 4409, 5.2.7]

52. All pipes shall be visually inspected for leaks at least once every 12 months. [District Rule 4409, 5.2.8]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

53. All pipes, in service, that are found to be leaking by visual inspection shall be attempted to be repaired immediately. The leaking pipe shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.8.1]

54. The annual pipe inspection required by either the Department of Oil, Gas, and Geothermal Resources (DOGGR) pursuant to California Code of Regulation Title 14, Division 2, Subchapter 2, Section 1774 (Oilfield Facilities and Equipment Maintenance), or by the Spill Prevention Control and Countermeasure Plan (SPCC) pursuant to 40 Code of Federal Regulation Part 112 (Oil Prevention and Response: Non- Transportation-Related Onshore and Offshore Facilities) can be used as the annual pipe inspection required by District Rule 4409. [District Rule 4409, 5.2.8.2]

55. Except for pumps, compressors, and PRDs, the permittee may apply for written approval from the District to change the inspection frequency of accessible components from quarterly to annually for a specific component type provided the following two qualifying requirements are met. During the previous five consecutive quarterly inspections, for the specific component type, there shall be no more leaks than as allowed by this permit. The permittee also shall not have received a Notice of Violation (NOV) from the District during the previous 12 months for violating any provisions of District Rule 4409 for the specific component type. If these two qualifying requirements have not been met, then the inspection frequency shall revert back to quarterly. The written request shall include pertinent documentation to demonstrate that the operator has successfully met the two qualifying requirements. [District Rule 4409, 5.2.9 and 5.2.10]

56. The permittee shall notify the District in writing within five calendar days after changing the inspection frequency for a specific component type. The written notification shall include the reason(s) and date of change to a quarterly inspection frequency. [District Rule 4409, 5.2.11]

57. A PRD that releases to the atmosphere shall be inspected by the permittee for leaks as soon as practicable but not later than 24 hours after the time of the release. The permittee shall reinspect the PRD for leaks not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the date of the initial release. If the PRD is found by the permittee to be leaking during either inspection, the PRD leak shall be treated as if the leak was found during the required quarterly operator inspections. [District Rule 4409, 5.2.12]

58. Except for PRDs, a component shall be inspected for leaks not later than 15 calendar days after repairing the leak or replacing the component. [District Rule 4409, 5.2.13]

59. District inspections shall not be counted as an operator inspection required by District Rule 4409. Any attempt by an operator to count such District inspections as part of the operator's mandatory inspections is considered a willful circumvention of the rule and is a violation of this rule. [District Rule 4409, 5.2.14]

60. The operator, upon detection of a leaking component, shall affix to that component a weatherproof, readily visible tag, bearing the date and time when the leak was detected and the date and time of the leak measurement. For gaseous leaks, the tag shall indicate the leak concentration in ppmv. For liquid leaks, the tag shall indicate whether it is a major liquid leak or a minor liquid leak. The tag shall indicate, when applicable, whether the component is an essential component, an unsafe-to-monitor component, or a critical component. The tag shall remain in place until the leaking component is repaired or replaced and reinspected and found to be in compliance with the requirements of this rule. [District Rule 4409, 5.3.1]

61. The operator shall minimize all component leaks immediately, to the extent possible, but not later than one hour after detection of the leak in order to stop or reduce leakage to the atmosphere. If the leak has been minimized but the leak still exceeds the applicable leak standards specified in this permit, the operator shall do one of the following within the timeframes specified within this permit: 1) repair or replace the leaking component; 2) vent the leaking component to a closed vent system; 3) or remove the leaking component from operation. A closed vent system is a District approved system that is not open to the atmosphere. It is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to a District approved control device that has a overall VOC collection and destruction or removal efficiency of at least 95%, or that transports gases or vapors back to a process system. [District Rule 4409, 5.3.4 and 5.3.5]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

62. The operator shall repair minor gas leaks within seven days. The operator shall repair major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, within three days. The operator shall repair major gas leaks, which are > 50,000 ppmv, within two days. The operator shall repair minor liquid leaks within three days. The operator shall repair major liquid leaks within two days. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period. The start of the repair period shall be the time of the initial leak detection. [District Rule 4409, 5.3.4 and 5.3.5]

63. For each calendar quarter, the operator may extend the repair period for a total number of leaking components, not to exceed 0.05 % of the number of components inspected, by type, rounded upward to the nearest whole number. The repair period for minor gas leaks can be extended by seven additional days. The repair period for major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, can be extended by two additional days. [District Rule 4409, 5.3.5]

64. If a leaking component is an essential component or a critical component and which cannot be shut down immediately for repairs, the operator shall do the following: 1) minimize the leak within one hour after detection of the leak; 2) and if the leak has been minimized, but the leak still exceeds the applicable leak standards of Rule 4409 as specified in this permit, the essential component or critical component shall be repaired or replaced to eliminate the leak during the next process unit turnaround. The repair shall occur no later than one year from the date of the original leak detection. [District Rule 4409, 5.3.6]

65. For any component that has incurred five repair actions for major gas leaks or major liquid leaks, or a combination of major gas leaks and major liquid leaks within a continuous 12-month period, the operator shall do one of the following four options. Options 1a through 1f require written notification to the District, option 2 requires written notification to the District and written District approval, options 3 and 4 do not require written notification to the District: 1a) For compressors replace the existing seal with either a dual mechanical seal, an oil film seal, a gas seal, or a face-type seal; 1b) for pumps replace the pump with a seal-less pump or replace the seal with a dual mechanical seal; 1c) for PRDs replace the PRD and install a rupture disc in the line which precedes the PRD such that the PRD is in series with and follows the rupture disc; 1d) for valves replace the valve with a sealed bellows valve, or for seal rings install graphite or Teflon chevron seal rings in a live-loaded packing gland; 1e) for threaded connections weld the connections or replace threaded connections with flanges; 1f) for sampling connections replace the sampling connection with a closed-loop sampling system; 2) Replace the component with Achieved-in-Practice Best Available Control Technology (BACT) equipment; 3) Vent the component to a District approved closed-vent system; 4) Remove the component from operation. For any component that is accessible, is not unsafe-to-monitor, is not an essential component, or is not a critical component, the operator shall comply with these requirements as soon as practicable but not later than twelve months after the date of detection of the fifth major leak within a continuous 12-month period. For any component that is inaccessible, is unsafe-to-monitor, is essential, or is a critical component, the operator shall comply with these requirements as soon as practicable but not later than the next turnaround or not later than two years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes first. [District Rule 4409, 5.3.7]

66. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and recordkeeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other system approved by the District that enables an operator or the District to locate each individual component. The operator shall replace physical identifications that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4409, 5.4.1]

67. The operator shall keep a copy of the District approved Operator Management Plan (OMP) at the facility and make it available to the District, ARB, and EPA upon request. [District Rule 4409, 6.1.2]

68. By January 30th of each year the operator shall submit to the District for approval, in writing, an annual report indicating any changes to the existing OMP on file at the District. [District Rule 4409, 6.1.4]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

69. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4409, 6.2.1]

70. Records of leaks detected during quarterly or annual operator inspections, and each subsequent repair and re-inspection, shall be submitted to the District, ARB, and EPA upon request. [District Rule 4409, 6.2.2]

71. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4409, 6.2.3]

72. All records required by this permit shall be retained on-site for a minimum of five years and made available for District, ARB, and EPA inspection upon request. [District Rule 4409, 6.2.4]

73. All measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instructions not more than 30 days prior to its use. [District Rule 4409, 6.3.1]

74. The VOC content by weight percent shall be determined using ASTM D-1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 for liquids. [District Rule 4409, 6.3.2]

75. The percent by volume liquid evaporated at 302 øF (150 øC) shall be determined using ASTM D-86. [District Rule 4409, 6.3.3]

76. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D-323, and converting the RVP to TVP at the maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures specified in Appendix A of District Rule 4409. [District Rule 4409, 6.3.4]

77. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM D-287 or ASTM 1298. Sampling for API gravity shall be performed in accordance with ASTM D-4057. [District Rule 4409, 6.3.5]

78. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4409, 6.3.6]

79. Halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422. [District Rule 4409, 6.3.7]

80. Formerly S-382-409-4. [District NSR Rule]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-88-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 29 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
44.58 MMBTU/HR EMERGENCY WELL SAFETY FLARE

PERMIT UNIT REQUIREMENTS

1. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. The operator shall test the sulfur content of the gases being flared and demonstrate the sulfur content does not exceed 3.3% by weight. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
2. To show compliance with sulfur emission limits, the gas being flared shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for the flared gas, then the compliance testing frequency shall be semi-annually. If a semi-annual sulfur content test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The sulfur content of the gas being flared shall be determined using ASTM D 1072-80,D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. The fuel higher heating value for the gases being flared shall be certified by third party fuel supplier or determined by ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The permittee shall maintain accurate records of gas volume flared. These records and all records of required monitoring data and support information shall be maintained and retained for a period of 5 years and made available for inspection at any time. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. If this flare requires a pilot flame, then the flare shall be operated with a flame present at all times, and kept in operation when emissions may be vented to it. The presence of a flare pilot flame shall be monitored using a thermocouple or any other equivalent device to detect the presence of a flame. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. This flare shall not be used as a leak control device as described in Rule 4403, 5.3.1, nor as a control device for any permit unit subject to NSPS, without modification of permit requirements to address 40 CFR 60.18. [District Rule 2520, 9.4.3] Federally Enforceable Through Title V Permit
8. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

10. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

11. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

12. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

13. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

14. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

15. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

16. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

17. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

19. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

20. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

22. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

23. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

24. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

25. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

26. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

29. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

30. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

31. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

32. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

33. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

34. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

36. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

37. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

38. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

39. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

40. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

41. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

42. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

43. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

44. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

45. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

46. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (9/17/2004); 8031 (9/17/2004); 8041 (9/17/2004); 8051 (9/17/2004); 8061 (9/17/2004); and 8071 (9/17/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

48. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

49. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan, and comply with all the requirements of Program 1, 2, or 3 when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit

50. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

51. For valves, threaded connections, flanges, pipes, pumps, compressors, and other components subject to the requirements of Rule 4409, but not specified in this permit; a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 2,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

52. For pressure relief devices (PRDs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 200 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 400 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

53. For polished rod stuffing boxes (PRSBs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

54. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.2] Federally Enforceable Through Title V Permit

55. Minor gas leaks from PRSBs detected during any District inspection shall not be counted toward determination of compliance with this rule provided the permittee repairs, replaces, or removes leaking PRSBs from VOC service as soon as practicable but not later than seven calendar days. [District Rule 4409, 5.1.3.1.2] Federally Enforceable Through Title V Permit

56. Leaks detected during quarterly operator inspections shall not be counted towards determination of compliance with the provisions of Rule 4409 provided the leaking components are repaired as soon as practicable but not later than the time frame specified in this permit. Leaks detected during quarterly operator inspections that are not repaired, replaced, or removed from operation as soon as practicable but not later than the time frame specified in this rule shall be counted toward determination of compliance with the provisions of Rule 4409. [District Rule 4409, 5.1.3.2.1 and 5.1.3.2.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

57. Leaking components at this facility detected during annual operator inspections, as required by Rule 4409 for a specific component type, that exceed the leak standards specified in this permit, shall constitute a violation of this rule. This violation is regardless of whether or not the leaking components are repaired, replaced, or removed from operation within the allowable repair time frame specified in this permit. [District Rule 4409, 5.1.3.2.3] Federally Enforceable Through Title V Permit

58. An open-ended line, or a valve located at the end of the line, that is not sealed with either a blind flange, a plug, a cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended line is a leak. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.4.1] Federally Enforceable Through Title V Permit

59. A leak from a component is when there is a major liquid leak from the component. A major liquid leak from a component is when a visible mist or a continuous flow of liquid, that is not seal lubricant, leaks from the component. [District Rule 4409, 5.1.4.2] Federally Enforceable Through Title V Permit

60. A leak from a component is when gas emissions greater than 50,000 ppmv, as methane, leaks from the component. [District Rule 4409, 5.1.4.3] Federally Enforceable Through Title V Permit

61. A minor liquid leak from a component is when more than three drops of liquid per minute, that is not seal lubricant and is not a major liquid leak, leaks from the component. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

62. When 200 or fewer valves are inspected, a leak from a valve is when more than one valve has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 valves are inspected, a leak from a valve is when more than 0.5 % (rounded up to the nearest whole number) of the valves have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

63. When 200 or fewer threaded connections are inspected, a leak from a threaded connection is when more than one threaded connection has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 threaded connections are inspected, a leak from a threaded connection is when more than 0.5 % (rounded up to the nearest whole number) of the threaded connections have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

64. When 200 or fewer flanges are inspected, a leak from a flange is when more than one flange has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 flanges are inspected, a leak from a flange is when more than 0.5 % (rounded up to the nearest whole number) of the flanges have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

65. When 200 or fewer pumps are inspected, a leak from a pump is when more than two pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. When greater than 200 pumps are inspected, a leak from a pump is when more than 1.0 % (rounded up to the nearest whole number) of the pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

66. When compressors, PRDs, or other components not specified in this permit are inspected, a leak from these components is when more than one component has a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

67. When 200 or fewer PRSBs are inspected, a leak is when more than four have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 PRSBs are inspected, a leak is when more than 2.0 % (rounded up to the nearest whole number) of the PRSBs have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

68. When 200 or fewer wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than two or more pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than 1.0 % (rounded up to the nearest whole number) of the pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

69. When pipes at natural gas processing facilities are inspected, a leak from a pipe is when more than two have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

70. For manned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once every 24 hours except when operators do not report to the facility during a 24 hour period. [District Rule 4409, 5.2.1] Federally Enforceable Through Title V Permit

71. For unmanned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once per calendar week. [District Rule 4409, 5.2.2] Federally Enforceable Through Title V Permit

72. All accessible operating pumps, compressors, and PRDs, in service, that are found to be leaking by audio-visual inspection shall be attempted to be repaired immediately. The leaking component shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.3] Federally Enforceable Through Title V Permit

73. Except for inaccessible components, unsafe-to-monitor components, or pipes, all components, in service, shall be tested for leaks at least once every calendar quarter. [District Rule 4409, 5.2.4] Federally Enforceable Through Title V Permit

74. All new, replaced, or repaired fittings, flanges, and threaded connections shall be tested for leaks immediately after being placed into service. [District Rule 4409, 5.2.5] Federally Enforceable Through Title V Permit

75. All inaccessible components shall be tested for leaks at least once every 12 months. [District Rule 4409, 5.2.6] Federally Enforceable Through Title V Permit

76. All unsafe-to-monitor components shall be tested for leaks during each turnaround. [District Rule 4409, 5.2.7] Federally Enforceable Through Title V Permit

77. All pipes shall be visually inspected for leaks at least once every 12 months. [District Rule 4409, 5.2.8] Federally Enforceable Through Title V Permit

78. All pipes, in service, that are found to be leaking by visual inspection shall be attempted to be repaired immediately. The leaking pipe shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.8.1] Federally Enforceable Through Title V Permit

79. The annual pipe inspection required by either the Department of Oil, Gas, and Geothermal Resources (DOGGR) pursuant to California Code of Regulation Title 14, Division 2, Subchapter 2, Section 1774 (Oilfield Facilities and Equipment Maintenance), or by the Spill Prevention Control and Countermeasure Plan (SPCC) pursuant to 40 Code of Federal Regulation Part 112 (Oil Prevention and Response: Non- Transportation-Related Onshore and Offshore Facilities) can be used as the annual pipe inspection required by District Rule 4409. [District Rule 4409, 5.2.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

80. Except for pumps, compressors, and PRDs, the permittee may apply for written approval from the District to change the inspection frequency of accessible components from quarterly to annually for a specific component type provided the following two qualifying requirements are met. During the previous five consecutive quarterly inspections, for the specific component type, there shall be no more leaks than as allowed by this permit. The permittee also shall not have received a Notice of Violation (NOV) from the District during the previous 12 months for violating any provisions of District Rule 4409 for the specific component type. If these two qualifying requirements have not been met, then the inspection frequency shall revert back to quarterly. The written request shall include pertinent documentation to demonstrate that the operator has successfully met the two qualifying requirements. [District Rule 4409, 5.2.9 and 5.2.10] Federally Enforceable Through Title V Permit

81. The permittee shall notify the District in writing within five calendar days after changing the inspection frequency for a specific component type. The written notification shall include the reason(s) and date of change to a quarterly inspection frequency. [District Rule 4409, 5.2.11] Federally Enforceable Through Title V Permit

82. A PRD that releases to the atmosphere shall be inspected by the permittee for leaks as soon as practicable but not later than 24 hours after the time of the release. The permittee shall reinspect the PRD for leaks not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the date of the initial release. If the PRD is found by the permittee to be leaking during either inspection, the PRD leak shall be treated as if the leak was found during the required quarterly operator inspections. [District Rule 4409, 5.2.12] Federally Enforceable Through Title V Permit

83. Except for PRDs, a component shall be inspected for leaks not later than 15 calendar days after repairing the leak or replacing the component. [District Rule 4409, 5.2.13] Federally Enforceable Through Title V Permit

84. District inspections shall not be counted as an operator inspection required by District Rule 4409. Any attempt by an operator to count such District inspections as part of the operator's mandatory inspections is considered a willful circumvention of the rule and is a violation of this rule. [District Rule 4409, 5.2.14] Federally Enforceable Through Title V Permit

85. The operator, upon detection of a leaking component, shall affix to that component a weatherproof, readily visible tag, bearing the date and time when the leak was detected and the date and time of the leak measurement. For gaseous leaks, the tag shall indicate the leak concentration in ppmv. For liquid leaks, the tag shall indicate whether it is a major liquid leak or a minor liquid leak. The tag shall indicate, when applicable, whether the component is an essential component, an unsafe-to-monitor component, or a critical component. The tag shall remain in place until the leaking component is repaired or replaced and reinspected and found to be in compliance with the requirements of this rule. [District Rule 4409, 5.3.1] Federally Enforceable Through Title V Permit

86. The operator shall minimize all component leaks immediately, to the extent possible, but not later than one hour after detection of the leak in order to stop or reduce leakage to the atmosphere. If the leak has been minimized but the leak still exceeds the applicable leak standards specified in this permit, the operator shall do one of the following within the timeframes specified within this permit: 1) repair or replace the leaking component; 2) vent the leaking component to a closed vent system; 3) or remove the leaking component from operation. A closed vent system is a District approved system that is not open to the atmosphere. It is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to a District approved control device that has a overall VOC collection and destruction or removal efficiency of at least 95%, or that transports gases or vapors back to a process system. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

87. The operator shall repair minor gas leaks within seven days. The operator shall repair major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, within three days. The operator shall repair major gas leaks, which are > 50,000 ppmv, within two days. The operator shall repair minor liquid leaks within three days. The operator shall repair major liquid leaks within two days. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period. The start of the repair period shall be the time of the initial leak detection. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

88. For each calendar quarter, the operator may extend the repair period for a total number of leaking components, not to exceed 0.05 % of the number of components inspected, by type, rounded upward to the nearest whole number. The repair period for minor gas leaks can be extended by seven additional days. The repair period for major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, can be extended by two additional days. [District Rule 4409, 5.3.5] Federally Enforceable Through Title V Permit

89. If a leaking component is an essential component or a critical component and which cannot be shut down immediately for repairs, the operator shall do the following: 1) minimize the leak within one hour after detection of the leak; 2) and if the leak has been minimized, but the leak still exceeds the applicable leak standards of Rule 4409 as specified in this permit, the essential component or critical component shall be repaired or replaced to eliminate the leak during the next process unit turnaround. The repair shall occur no later than one year from the date of the original leak detection. [District Rule 4409, 5.3.6] Federally Enforceable Through Title V Permit

90. For any component that has incurred five repair actions for major gas leaks or major liquid leaks, or a combination of major gas leaks and major liquid leaks within a continuous 12-month period, the operator shall do one of the following four options. Options 1a through 1f require written notification to the District, option 2 requires written notification to the District and written District approval, options 3 and 4 do not require written notification to the District: 1a) For compressors replace the existing seal with either a dual mechanical seal, an oil film seal, a gas seal, or a face-type seal; 1b) for pumps replace the pump with a seal-less pump or replace the seal with a dual mechanical seal; 1c) for PRDs replace the PRD and install a rupture disc in the line which precedes the PRD such that the PRD is in series with and follows the rupture disc; 1d) for valves replace the valve with a sealed bellows valve, or for seal rings install graphite or Teflon chevron seal rings in a live-loaded packing gland; 1e) for threaded connections weld the connections or replace threaded connections with flanges; 1f) for sampling connections replace the sampling connection with a closed-loop sampling system; 2) Replace the component with Achieved-in-Practice Best Available Control Technology (BACT) equipment; 3) Vent the component to a District approved closed-vent system; 4) Remove the component from operation. For any component that is accessible, is not unsafe-to-monitor, is not an essential component, or is not a critical component, the operator shall comply with these requirements as soon as practicable but not later than twelve months after the date of detection of the fifth major leak within a continuous 12-month period. For any component that is inaccessible, is unsafe-to-monitor, is essential, or is a critical component, the operator shall comply with these requirements as soon as practicable but not later than the next turnaround or not later than two years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes first. [District Rule 4409, 5.3.7] Federally Enforceable Through Title V Permit

91. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and recordkeeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other system approved by the District that enables an operator or the District to locate each individual component. The operator shall replace physical identifications that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4409, 5.4.1] Federally Enforceable Through Title V Permit

92. The operator shall keep a copy of the District approved Operator Management Plan (OMP) at the facility and make it available to the District, ARB, and EPA upon request. [District Rule 4409, 6.1.2] Federally Enforceable Through Title V Permit

93. By January 30th of each year the operator shall submit to the District for approval, in writing, an annual report indicating any changes to the existing OMP on file at the District. [District Rule 4409, 6.1.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

94. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4409, 6.2.1] Federally Enforceable Through Title V Permit

95. Records of leaks detected during quarterly or annual operator inspections, and each subsequent repair and re-inspection, shall be submitted to the District, ARB, and EPA upon request. [District Rule 4409, 6.2.2] Federally Enforceable Through Title V Permit

96. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4409, 6.2.3] Federally Enforceable Through Title V Permit

97. All records required by this permit shall be retained on-site for a minimum of five years and made available for District, ARB, and EPA inspection upon request. [District Rule 4409, 6.2.4] Federally Enforceable Through Title V Permit

98. All measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instructions not more than 30 days prior to its use. [District Rule 4409, 6.3.1] Federally Enforceable Through Title V Permit

99. The VOC content by weight percent shall be determined using ASTM D-1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 for liquids. [District Rule 4409, 6.3.2] Federally Enforceable Through Title V Permit

100. The percent by volume liquid evaporated at 302 øF (150 øC) shall be determined using ASTM D-86. [District Rule 4409, 6.3.3] Federally Enforceable Through Title V Permit

101. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D-323, and converting the RVP to TVP at the maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures specified in Appendix A of District Rule 4409. [District Rule 4409, 6.3.4] Federally Enforceable Through Title V Permit

102. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM D-287 or ASTM 1298. Sampling for API gravity shall be performed in accordance with ASTM D-4057. [District Rule 4409, 6.3.5] Federally Enforceable Through Title V Permit

103. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4409, 6.3.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

104. Halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422. [District Rule 4409, 6.3.7] Federally Enforceable Through Title V Permit

105. For vapor recovery systems connected to tanks with pressure relief valves, operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

106. For tanks equipped with pressure relief valves, operator shall inspect pressure relief valves for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

107. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon June 1 of each year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days of the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

108. Formerly S-382-410-3. [District NSR Rule]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-89-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 29 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
0.028 MMBTU/HR TANK VAPOR RECOVERY SYSTEM FLARE

PERMIT UNIT REQUIREMENTS

1. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. The operator shall test the sulfur content of the gases being flared and demonstrate the sulfur content does not exceed 3.3% by weight. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
2. To show compliance with sulfur emission limits, the gas being flared shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for the flared gas, then the compliance testing frequency shall be semi-annually. If a semi-annual sulfur content test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The sulfur content of the gas being flared shall be determined using ASTM D 1072-80,D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. The fuel higher heating value for the gases being flared shall be certified by third party fuel supplier or determined by ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The permittee shall maintain accurate records of gas volume flared. These records and all records of required monitoring data and support information shall be maintained and retained for a period of 5 years and made available for inspection at any time. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. If this flare requires a pilot flame, then the flare shall be operated with a flame present at all times, and kept in operation when emissions may be vented to it. The presence of a flare pilot flame shall be monitored using a thermocouple or any other equivalent device to detect the presence of a flame. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. This flare shall not be used as a leak control device as described in Rule 4403, 5.3.1, nor as a control device for any permit unit subject to NSPS, without modification of permit requirements to address 40 CFR 60.18. [District Rule 2520, 9.4.3] Federally Enforceable Through Title V Permit
8. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

10. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

11. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

12. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

13. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

14. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

15. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

16. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

17. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

19. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

20. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

22. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

23. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

24. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

25. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

26. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

29. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

30. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

31. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

32. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

33. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

34. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

36. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

37. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

38. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

39. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

40. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

41. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/17/2004) or Rule 8011 (9/17/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

42. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

43. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

44. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

45. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

46. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (9/17/2004); 8031 (9/17/2004); 8041 (9/17/2004); 8051 (9/17/2004); 8061 (9/17/2004); and 8071 (9/17/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

48. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

49. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan, and comply with all the requirements of Program 1, 2, or 3 when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit

50. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

51. For valves, threaded connections, flanges, pipes, pumps, compressors, and other components subject to the requirements of Rule 4409, but not specified in this permit; a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 2,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

52. For pressure relief devices (PRDs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 200 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 400 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

53. For polished rod stuffing boxes (PRSBs); a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

54. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.2] Federally Enforceable Through Title V Permit

55. Minor gas leaks from PRSBs detected during any District inspection shall not be counted toward determination of compliance with this rule provided the permittee repairs, replaces, or removes leaking PRSBs from VOC service as soon as practicable but not later than seven calendar days. [District Rule 4409, 5.1.3.1.2] Federally Enforceable Through Title V Permit

56. Leaks detected during quarterly operator inspections shall not be counted towards determination of compliance with the provisions of Rule 4409 provided the leaking components are repaired as soon as practicable but not later than the time frame specified in this permit. Leaks detected during quarterly operator inspections that are not repaired, replaced, or removed from operation as soon as practicable but not later than the time frame specified in this rule shall be counted toward determination of compliance with the provisions of Rule 4409. [District Rule 4409, 5.1.3.2.1 and 5.1.3.2.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

57. Leaking components at this facility detected during annual operator inspections, as required by Rule 4409 for a specific component type, that exceed the leak standards specified in this permit, shall constitute a violation of this rule. This violation is regardless of whether or not the leaking components are repaired, replaced, or removed from operation within the allowable repair time frame specified in this permit. [District Rule 4409, 5.1.3.2.3] Federally Enforceable Through Title V Permit

58. An open-ended line, or a valve located at the end of the line, that is not sealed with either a blind flange, a plug, a cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended line is a leak. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.4.1] Federally Enforceable Through Title V Permit

59. A leak from a component is when there is a major liquid leak from the component. A major liquid leak from a component is when a visible mist or a continuous flow of liquid, that is not seal lubricant, leaks from the component. [District Rule 4409, 5.1.4.2] Federally Enforceable Through Title V Permit

60. A leak from a component is when gas emissions greater than 50,000 ppmv, as methane, leaks from the component. [District Rule 4409, 5.1.4.3] Federally Enforceable Through Title V Permit

61. A minor liquid leak from a component is when more than three drops of liquid per minute, that is not seal lubricant and is not a major liquid leak, leaks from the component. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

62. When 200 or fewer valves are inspected, a leak from a valve is when more than one valve has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 valves are inspected, a leak from a valve is when more than 0.5 % (rounded up to the nearest whole number) of the valves have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

63. When 200 or fewer threaded connections are inspected, a leak from a threaded connection is when more than one threaded connection has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 threaded connections are inspected, a leak from a threaded connection is when more than 0.5 % (rounded up to the nearest whole number) of the threaded connections have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

64. When 200 or fewer flanges are inspected, a leak from a flange is when more than one flange has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 flanges are inspected, a leak from a flange is when more than 0.5 % (rounded up to the nearest whole number) of the flanges have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

65. When 200 or fewer pumps are inspected, a leak from a pump is when more than two pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. When greater than 200 pumps are inspected, a leak from a pump is when more than 1.0 % (rounded up to the nearest whole number) of the pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

66. When compressors, PRDs, or other components not specified in this permit are inspected, a leak from these components is when more than one component has a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

67. When 200 or fewer PRSBs are inspected, a leak is when more than four have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 PRSBs are inspected, a leak is when more than 2.0 % (rounded up to the nearest whole number) of the PRSBs have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

68. When 200 or fewer wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than two or more pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 wells at light crude oil or gas production facilities are inspected, a leak from a pipe is when more than 1.0 % (rounded up to the nearest whole number) of the pipes have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

69. When pipes at natural gas processing facilities are inspected, a leak from a pipe is when more than two have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

70. For manned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once every 24 hours except when operators do not report to the facility during a 24 hour period. [District Rule 4409, 5.2.1] Federally Enforceable Through Title V Permit

71. For unmanned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once per calendar week. [District Rule 4409, 5.2.2] Federally Enforceable Through Title V Permit

72. All accessible operating pumps, compressors, and PRDs, in service, that are found to be leaking by audio-visual inspection shall be attempted to be repaired immediately. The leaking component shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.3] Federally Enforceable Through Title V Permit

73. Except for inaccessible components, unsafe-to-monitor components, or pipes, all components, in service, shall be tested for leaks at least once every calendar quarter. [District Rule 4409, 5.2.4] Federally Enforceable Through Title V Permit

74. All new, replaced, or repaired fittings, flanges, and threaded connections shall be tested for leaks immediately after being placed into service. [District Rule 4409, 5.2.5] Federally Enforceable Through Title V Permit

75. All inaccessible components shall be tested for leaks at least once every 12 months. [District Rule 4409, 5.2.6] Federally Enforceable Through Title V Permit

76. All unsafe-to-monitor components shall be tested for leaks during each turnaround. [District Rule 4409, 5.2.7] Federally Enforceable Through Title V Permit

77. All pipes shall be visually inspected for leaks at least once every 12 months. [District Rule 4409, 5.2.8] Federally Enforceable Through Title V Permit

78. All pipes, in service, that are found to be leaking by visual inspection shall be attempted to be repaired immediately. The leaking pipe shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.8.1] Federally Enforceable Through Title V Permit

79. The annual pipe inspection required by either the Department of Oil, Gas, and Geothermal Resources (DOGGR) pursuant to California Code of Regulation Title 14, Division 2, Subchapter 2, Section 1774 (Oilfield Facilities and Equipment Maintenance), or by the Spill Prevention Control and Countermeasure Plan (SPCC) pursuant to 40 Code of Federal Regulation Part 112 (Oil Prevention and Response: Non- Transportation-Related Onshore and Offshore Facilities) can be used as the annual pipe inspection required by District Rule 4409. [District Rule 4409, 5.2.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

80. Except for pumps, compressors, and PRDs, the permittee may apply for written approval from the District to change the inspection frequency of accessible components from quarterly to annually for a specific component type provided the following two qualifying requirements are met. During the previous five consecutive quarterly inspections, for the specific component type, there shall be no more leaks than as allowed by this permit. The permittee also shall not have received a Notice of Violation (NOV) from the District during the previous 12 months for violating any provisions of District Rule 4409 for the specific component type. If these two qualifying requirements have not been met, then the inspection frequency shall revert back to quarterly. The written request shall include pertinent documentation to demonstrate that the operator has successfully met the two qualifying requirements. [District Rule 4409, 5.2.9 and 5.2.10] Federally Enforceable Through Title V Permit

81. The permittee shall notify the District in writing within five calendar days after changing the inspection frequency for a specific component type. The written notification shall include the reason(s) and date of change to a quarterly inspection frequency. [District Rule 4409, 5.2.11] Federally Enforceable Through Title V Permit

82. A PRD that releases to the atmosphere shall be inspected by the permittee for leaks as soon as practicable but not later than 24 hours after the time of the release. The permittee shall reinspect the PRD for leaks not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the date of the initial release. If the PRD is found by the permittee to be leaking during either inspection, the PRD leak shall be treated as if the leak was found during the required quarterly operator inspections. [District Rule 4409, 5.2.12] Federally Enforceable Through Title V Permit

83. Except for PRDs, a component shall be inspected for leaks not later than 15 calendar days after repairing the leak or replacing the component. [District Rule 4409, 5.2.13] Federally Enforceable Through Title V Permit

84. District inspections shall not be counted as an operator inspection required by District Rule 4409. Any attempt by an operator to count such District inspections as part of the operator's mandatory inspections is considered a willful circumvention of the rule and is a violation of this rule. [District Rule 4409, 5.2.14] Federally Enforceable Through Title V Permit

85. The operator, upon detection of a leaking component, shall affix to that component a weatherproof, readily visible tag, bearing the date and time when the leak was detected and the date and time of the leak measurement. For gaseous leaks, the tag shall indicate the leak concentration in ppmv. For liquid leaks, the tag shall indicate whether it is a major liquid leak or a minor liquid leak. The tag shall indicate, when applicable, whether the component is an essential component, an unsafe-to-monitor component, or a critical component. The tag shall remain in place until the leaking component is repaired or replaced and reinspected and found to be in compliance with the requirements of this rule. [District Rule 4409, 5.3.1] Federally Enforceable Through Title V Permit

86. The operator shall minimize all component leaks immediately, to the extent possible, but not later than one hour after detection of the leak in order to stop or reduce leakage to the atmosphere. If the leak has been minimized but the leak still exceeds the applicable leak standards specified in this permit, the operator shall do one of the following within the timeframes specified within this permit: 1) repair or replace the leaking component; 2) vent the leaking component to a closed vent system; 3) or remove the leaking component from operation. A closed vent system is a District approved system that is not open to the atmosphere. It is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to a District approved control device that has a overall VOC collection and destruction or removal efficiency of at least 95%, or that transports gases or vapors back to a process system. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

87. The operator shall repair minor gas leaks within seven days. The operator shall repair major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, within three days. The operator shall repair major gas leaks, which are > 50,000 ppmv, within two days. The operator shall repair minor liquid leaks within three days. The operator shall repair major liquid leaks within two days. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period. The start of the repair period shall be the time of the initial leak detection. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

88. For each calendar quarter, the operator may extend the repair period for a total number of leaking components, not to exceed 0.05 % of the number of components inspected, by type, rounded upward to the nearest whole number. The repair period for minor gas leaks can be extended by seven additional days. The repair period for major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, can be extended by two additional days. [District Rule 4409, 5.3.5] Federally Enforceable Through Title V Permit

89. If a leaking component is an essential component or a critical component and which cannot be shut down immediately for repairs, the operator shall do the following: 1) minimize the leak within one hour after detection of the leak; 2) and if the leak has been minimized, but the leak still exceeds the applicable leak standards of Rule 4409 as specified in this permit, the essential component or critical component shall be repaired or replaced to eliminate the leak during the next process unit turnaround. The repair shall occur no later than one year from the date of the original leak detection. [District Rule 4409, 5.3.6] Federally Enforceable Through Title V Permit

90. For any component that has incurred five repair actions for major gas leaks or major liquid leaks, or a combination of major gas leaks and major liquid leaks within a continuous 12-month period, the operator shall do one of the following four options. Options 1a through 1f require written notification to the District, option 2 requires written notification to the District and written District approval, options 3 and 4 do not require written notification to the District: 1a) For compressors replace the existing seal with either a dual mechanical seal, an oil film seal, a gas seal, or a face-type seal; 1b) for pumps replace the pump with a seal-less pump or replace the seal with a dual mechanical seal; 1c) for PRDs replace the PRD and install a rupture disc in the line which precedes the PRD such that the PRD is in series with and follows the rupture disc; 1d) for valves replace the valve with a sealed bellows valve, or for seal rings install graphite or Teflon chevron seal rings in a live-loaded packing gland; 1e) for threaded connections weld the connections or replace threaded connections with flanges; 1f) for sampling connections replace the sampling connection with a closed-loop sampling system; 2) Replace the component with Achieved-in-Practice Best Available Control Technology (BACT) equipment; 3) Vent the component to a District approved closed-vent system; 4) Remove the component from operation. For any component that is accessible, is not unsafe-to-monitor, is not an essential component, or is not a critical component, the operator shall comply with these requirements as soon as practicable but not later than twelve months after the date of detection of the fifth major leak within a continuous 12-month period. For any component that is inaccessible, is unsafe-to-monitor, is essential, or is a critical component, the operator shall comply with these requirements as soon as practicable but not later than the next turnaround or not later than two years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes first. [District Rule 4409, 5.3.7] Federally Enforceable Through Title V Permit

91. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and recordkeeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other system approved by the District that enables an operator or the District to locate each individual component. The operator shall replace physical identifications that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4409, 5.4.1] Federally Enforceable Through Title V Permit

92. The operator shall keep a copy of the District approved Operator Management Plan (OMP) at the facility and make it available to the District, ARB, and EPA upon request. [District Rule 4409, 6.1.2] Federally Enforceable Through Title V Permit

93. By January 30th of each year the operator shall submit to the District for approval, in writing, an annual report indicating any changes to the existing OMP on file at the District. [District Rule 4409, 6.1.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

94. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4409, 6.2.1] Federally Enforceable Through Title V Permit

95. Records of leaks detected during quarterly or annual operator inspections, and each subsequent repair and re-inspection, shall be submitted to the District, ARB, and EPA upon request. [District Rule 4409, 6.2.2] Federally Enforceable Through Title V Permit

96. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4409, 6.2.3] Federally Enforceable Through Title V Permit

97. All records required by this permit shall be retained on-site for a minimum of five years and made available for District, ARB, and EPA inspection upon request. [District Rule 4409, 6.2.4] Federally Enforceable Through Title V Permit

98. All measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instructions not more than 30 days prior to its use. [District Rule 4409, 6.3.1] Federally Enforceable Through Title V Permit

99. The VOC content by weight percent shall be determined using ASTM D-1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 for liquids. [District Rule 4409, 6.3.2] Federally Enforceable Through Title V Permit

100. The percent by volume liquid evaporated at 302 øF (150 øC) shall be determined using ASTM D-86. [District Rule 4409, 6.3.3] Federally Enforceable Through Title V Permit

101. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D-323, and converting the RVP to TVP at the maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures specified in Appendix A of District Rule 4409. [District Rule 4409, 6.3.4] Federally Enforceable Through Title V Permit

102. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM D-287 or ASTM 1298. Sampling for API gravity shall be performed in accordance with ASTM D-4057. [District Rule 4409, 6.3.5] Federally Enforceable Through Title V Permit

103. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4409, 6.3.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

104. Halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422. [District Rule 4409, 6.3.7] Federally Enforceable Through Title V Permit

105. For vapor recovery systems connected to tanks with pressure relief valves, operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

106. For tanks equipped with pressure relief valves, operator shall inspect pressure relief valves for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

107. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon June 1 of each year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days of the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

108. Formerly S-382-411-3. [District NSR Rule]

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-93-1 **ISSUANCE DATE:** 09/07/2010

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 42,000 GALLON FIXED ROOF WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-94 AND CONNECTED TO S-48 FIELD GAS COLLECTION HEADER): CONNECT VAPOR RECOVERY SYSTEM TO TANKS S-1216-108, -109 AND -110; AND DELETE REFERENCE TO CONNECTION TO S-48 FIELD GAS COLLECTION HEADER

CONDITIONS

1. This permit unit was formerly number S-2010-2-0. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rules 2201 and 4623]
5. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1216-93-1 : Sep 7 2010 4:45PM – TOMS : Join Inspection NOT Required

6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rules 2201 and 4623]

7. VOC fugitive emissions from the components in gas service on tank and tank vapor collection system shall not exceed 0.16 lb/day. [District Rule 2201]

8. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District Rule 2201]

9. Except as otherwise provided in this permit, the operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2201]

10. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rules 2201 and 4623]

11. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rules 2201 and 4623]

12. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rules 2201 and 4623]

13. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 1070]

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

18. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

19. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations; and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

21. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

22. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

23. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

24. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

25. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

26. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

27. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

28. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

29. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

30. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

31. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

32. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

37. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

38. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

39. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

40. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

41. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

42. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

43. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

44. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

45. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

46. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

47. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

48. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

49. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

50. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

51. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

52. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

53. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

56. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

57. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

58. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District Rule 2201]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-94-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
3,300 BBL FIXED ROOF WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-7-0. [District NSR Rule]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
5. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

17. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

18. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

19. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

20. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

21. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

22. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

25. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

26. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

27. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

28. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

29. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

30. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

35. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

37. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

38. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

39. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

40. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

41. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

42. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

43. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

44. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

45. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

46. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

50. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

51. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

55. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

56. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-95-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
WATERFLOOD PLANT/WATER CLEANING AND INJECTION OPERATION INCLUDING ONE 5,000 BBL WASH TANK (T1) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-17-0. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Crude oil throughput of gauging/cleaning plant shall not exceed 1,800 bbl/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operation shall include up to 6 liquid transfer pumps. [District Rule 2010] Federally Enforceable Through Title V Permit
4. The operation shall include vapor piping from tanks T1 (S-1216-95), T2 (S-1216-135), T3 (S-1216-96), T4 (S-1216-98), T5 (S-1216-97), T6 (S-1216-133), T7 (S-1216-134), T8 (S-1216-136) and Wemco (S-1216-132) to 1 C gas plant (S-48) collection system. [District Rule 2010] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
6. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
7. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
8. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
10. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.063 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
11. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

15. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

16. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

17. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

18. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

21. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

22. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

24. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

26. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

27. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

28. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

29. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

30. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

31. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

32. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

33. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

34. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

35. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

36. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

37. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

38. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

39. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

40. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

41. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

42. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

43. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

44. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

45. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

46. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

47. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

48. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

49. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

50. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

51. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

52. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

53. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

54. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

55. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

56. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

57. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

58. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

59. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

60. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

61. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

62. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

63. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

64. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

65. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

66. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

67. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

68. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-96-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED ROOF STORAGE/SHIPPING TANK (#3) SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-18-0. [District NSR Rule]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
5. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

17. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

18. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

19. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

20. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

21. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

23. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

25. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

26. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

27. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

28. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

29. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

30. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

36. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

37. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

38. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

39. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

40. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

41. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

42. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

43. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

44. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

45. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

46. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

49. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

50. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

51. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

55. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

56. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-97-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,000 BBL FIXED ROOF FILTER FEED TANK (T5) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-19-0. [District NSR Rule]
2. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
3. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
4. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201]
5. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201]
6. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.026 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
8. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
10. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

17. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

18. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

19. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

21. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit

22. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

23. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

25. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

26. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

27. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

28. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

29. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

30. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

31. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

32. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

33. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

34. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

35. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

37. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

38. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

39. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

40. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

41. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

42. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

43. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

44. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

45. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

46. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

47. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

48. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

49. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

50. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

51. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

52. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

53. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

54. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

55. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

56. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

57. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

58. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

59. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

60. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

61. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

62. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

63. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

64. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

65. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-98-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2,000 BBL FIXED CRUDE OIL PRODUCTION TANK (T4) SERVED BY A VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-21-0. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
3. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
4. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201]
5. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201]
6. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.026 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
8. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
10. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

17. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

18. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

19. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

21. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit

22. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

23. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

25. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

26. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

27. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

28. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

29. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

30. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

31. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

32. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

33. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

34. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

35. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

37. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

38. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

39. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

40. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

41. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

42. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

43. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

44. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

45. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

46. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

47. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

48. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

49. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

50. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

51. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

52. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

53. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

54. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

55. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

56. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

57. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

58. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

59. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

60. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

61. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

62. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

63. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

64. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

65. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-100-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH TANKS S-1216-101, '-102, '-103, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-65-1. [District NSR Rule]
2. Tank shall be equipped with temperature indicator. [District Rule 4623, 6.2.1.1.5, 6.2.1.2, 6.3.1, 6.4.5] Federally Enforceable Through Title V Permit
3. Tank vapors shall vent only through collection system and discharge only to gas gathering line. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Tank vapor control system shall include interconnecting piping between tanks, liquid knock out vessel, pressure control valve, emergency relief valves, piping connecting to gas gathering system. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Pressure relief valves setting shall be higher than that required to activate vapor compressor. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit
6. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
7. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
8. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
9. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
10. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

13. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

15. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

17. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

18. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

19. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

20. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

21. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

23. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

24. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

25. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

26. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

27. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

28. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

29. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

30. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

31. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

32. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

33. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

38. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

39. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

40. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

41. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

42. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

43. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

44. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

45. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

46. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

47. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

48. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

50. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

51. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

52. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

53. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

54. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

55. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

56. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

57. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

58. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

59. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-101-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-3079-19 SHARED WITH S-1216-100, '-102, '-103, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-66-1. [District NSR Rule]
2. Tank shall be equipped with temperature indicator. [District Rule 4623, 6.2.1.1.5, 6.2.1.2, 6.3.1, 6.4.5] Federally Enforceable Through Title V Permit
3. Tank vapors shall vent to control system on permit S-1216-100. [District Rule 4623, 5.1.2 and 5.6.1] Federally Enforceable Through Title V Permit
4. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
6. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

13. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

18. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

19. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

20. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

21. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

22. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

24. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

25. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

26. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

27. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

28. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

29. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

30. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

31. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

37. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

38. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

39. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

40. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

41. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

42. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

43. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

44. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

45. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

46. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

47. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

50. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

51. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

52. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

56. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

57. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-102-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
532 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM AT S-1216-100 SHARED WITH S-1216-100, '-101, '-103, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-67-1. [District NSR Rule]
2. Tank shall be equipped with temperature indicator. [District Rule 4623, 6.2.1.1.5, 6.2.1.2, 6.3.1, 6.4.5] Federally Enforceable Through Title V Permit
3. Tank vapors shall vent to control system on permit S-1216-100. [District Rule 4623, 5.1.2 and 5.6.1] Federally Enforceable Through Title V Permit
4. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
6. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

13. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

18. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

19. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

20. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

21. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

22. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

24. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

25. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

26. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

27. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

28. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

29. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

30. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

31. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

37. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

38. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

39. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

40. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

41. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

42. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

43. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

44. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

45. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

46. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

47. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

50. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

51. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

52. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

56. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

57. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-103-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-100, -101, '-102, '-104, AND '-105

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-68-1. [District NSR Rule]
2. Tank shall be equipped with temperature indicator. [District Rule 4623, 6.2.1.1.5, 6.2.1.2, 6.3.1, 6.4.5] Federally Enforceable Through Title V Permit
3. Tank vapors shall vent to control system on permit S-1216-100. [District Rule 4623, 5.1.2 and 5.6.1] Federally Enforceable Through Title V Permit
4. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
6. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

13. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

18. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

19. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

20. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

21. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

22. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

24. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

25. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

26. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

27. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

28. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

29. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

30. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

31. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

37. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

38. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

39. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

40. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

41. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

42. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

43. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

44. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

45. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

46. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

47. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

50. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

51. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

52. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

56. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

57. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-104-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-100, '-101, '-102, '-103, AND '-105

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-69-1. [District NSR Rule]
2. Tank shall be equipped with temperature indicator. [District Rule 4623, 6.2.1.1.5, 6.2.1.2, 6.3.1, 6.4.5] Federally Enforceable Through Title V Permit
3. Tank vapors shall vent to control system on permit S-1216-100. [District Rule 4623, 5.2.1 and 5.6.1] Federally Enforceable Through Title V Permit
4. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
6. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

13. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

18. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

19. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

20. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

21. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

22. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

24. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

25. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

26. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

27. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

28. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

29. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

30. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

31. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

37. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

38. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

39. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

40. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

41. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

42. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

43. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

44. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

45. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

46. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

47. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

50. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

51. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

52. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

56. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

57. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-105-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1,968 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR CONTROL SYSTEM SHARED WITH S-1216-100, '-101, '-102, '-103, AND '-104

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-70-1. [District NSR Rule]
2. Tank shall be equipped with temperature indicator. [District Rule 4623, 6.2.1.1.5, 6.2.1.2, 6.3.1, 6.4.5] Federally Enforceable Through Title V Permit
3. Tank vapors shall vent to control system on permit S-1216-100. [District Rule 4623, 5.2.1 and 5.6.1] Federally Enforceable Through Title V Permit
4. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
6. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

13. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

18. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

19. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

20. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

21. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

22. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

24. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

25. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

26. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

27. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

28. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

29. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

30. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

31. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

37. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

38. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

39. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

40. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

41. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

42. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

43. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

44. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

45. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

46. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

47. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

50. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

51. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

52. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

56. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

57. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-106-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
191 BBL FIXED ROOF PETROLEUM STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-72-0. [District NSR Rule]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
4. This unit is a tank of a small producer with a throughput of 50 barrels of crude oil per day or less and is exempt from District Rule 4623. Operator shall maintain a record of average daily crude oil throughput to determine compliance with section 3.25, and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. The monthly crude oil production records required by the California Division of Oil, Gas, and Geothermal Resources may be used to comply with the above requirement. Operator shall also maintain monthly records of the average daily crude oil throughput of this tank to demonstrate compliance with Section 4.4 and/or 5.1.2 [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. This tank shall be subject to the requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.3] Federally Enforceable Through Title V Permit
6. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2 and 4623, 6.3] Federally Enforceable Through Title V Permit
7. The requirements of District Rule 4623 (amended December 20, 2001) do not apply to this source since this tank is exempt under section 4.0 as a small producer tank. A permit shield is granted from this requirement except for sections 6.3.4 and 7.3 for small producer tanks. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

11. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

12. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

13. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

14. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

15. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

16. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

17. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

18. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

19. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

20. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

21. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

23. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

24. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

25. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

26. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

29. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

30. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

31. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

32. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

33. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

34. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

35. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

37. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

38. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

39. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

40. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

41. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

42. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

43. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

44. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

45. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

46. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

49. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

50. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

51. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-107-1 **ISSUANCE DATE:** 01/11/2011

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: SW26 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 1,042 BBL FIXED ROOF CRUDE OIL STORAGE TANK: DESIGNATE AS DORMANT EMISSIONS UNIT, DELETE SMALL PRODUCER EXEMPTIONS, AND ADD TVP LIMIT OF 0.5 PSIA FOR RULE 4623 COMPLIANCE

CONDITIONS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2201]
2. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit (DEU), at which time this permit will be administratively modified to remove DEU references. [District Rule 2080]
3. When this tank is not operated (dormant for Rule 4623), all liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 4623]
4. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623]
5. Results of TVP test on material introduced to this tank upon reactivation shall be submitted to the District within 60 days of recommencing operation of this tank. [District Rule 2080]
6. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623]
7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-107-1 : Jan 11 2011 9:37AM -- BUSSM Joint Inspection NOT Required

8. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

9. Upon recommencing operation, permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623, 6.2.2]

10. In lieu of testing each uncontrolled fixed roof tank, an operator may conduct a TVP testing of a representative tank provided the following requirements are met. The selection of representative, uncontrolled fixed roof tanks is submitted in writing to the APCO, and written approval is granted by the APCO prior to conducting the test. One uncontrolled fixed roof tank represents some or all of the tanks in a tank battery. For crude oil production facilities, the representative uncontrolled fixed roof tank shall be the first line tank (or tanks) in a tank battery that is first receiving the produced fluids (mixture of oil, water, and gases) from the crude oil production wells. The stored organic liquid in each of the represented tanks is the same and came from the same source. The TVP and storage temperature of the stored organic liquid of the representative tank to be tested are the same or higher than those of the tanks it is to represent. [District Rule 4623, 6.2.2]

11. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. If the tank stores crude oil or petroleum distillates, the operator shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2]

12. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2]

13. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4]

14. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623]

15. This tank shall be subject to the control requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.2]

16. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623]

17. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

18. Formerly S-2010-74

19. Formerly S-3079-26

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-108-2 **ISSUANCE DATE:** 01/11/2011

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 532 BBL FIXED ROOF CRUDE OIL STORAGE TANK: DESIGNATE AS A DORMANT EMISSIONS UNIT AND DELETE SMALL PRODUCER CONDITIONS

CONDITIONS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010]
2. All liquids shall be removed from this dormant emissions unit and the produced crude oil inlet line shall be physically disconnected. [District Rule 4623]
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued and implemented for all necessary retrofits to comply with the applicable requirements of District Rule 4623. [District Rule 4623]
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
6. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4623, 6.3]
7. Formerly S-2010-82
8. Formerly S-3079-28

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-108-2 : Jan 11 2011 9:37AM -- BUSSM : Joint Inspection NOT Required

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-109-1 **ISSUANCE DATE:** 09/07/2010

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
MODIFICATION OF ONE 22,344 GALLON FIXED ROOF PETROLEUM STORAGE TANK: CONNECT TO THE VAPOR CONTROL SYSTEM LISTED ON TANK S-1216-93.

CONDITIONS

1. This permit unit was formerly number S-2010-83-0. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rules 2201 and 4623]
5. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-109-1 : Sep 7 2010 4:45PM -- TOMB : Joint Inspection NOT Required

6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rules 2201 and 4623]

7. VOC fugitive emissions from the components in gas service on tank shall not exceed 0.1 lb/day. [District Rule 2201]

8. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District Rule 2201]

9. Except as otherwise provided in this permit, the operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2201]

10. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rules 2201 and 4623]

11. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rules 2201 and 4623]

12. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rules 2201 and 4623]

13. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 1070]

14. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

15. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

18. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

19. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

20. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

21. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

22. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

23. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

24. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

25. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

26. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

27. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

28. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

29. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

30. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

31. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

32. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

37. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

38. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

39. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

40. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

41. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

42. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

43. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

44. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

45. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

46. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

47. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

48. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

49. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

50. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

51. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

52. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

53. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

56. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

57. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

58. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District Rule 2201]

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-110-1 **ISSUANCE DATE:** 09/07/2010

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
MODIFICATION OF ONE 22,344 GALLON FIXED ROOF PETROLEUM STORAGE TANK: CONNECT TO THE VAPOR CONTROL SYSTEM LISTED ON S-1216-93

CONDITIONS

1. This permit unit was formerly number S-2010-84-0. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
4. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District Rules 2201 and 4623]
5. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-110-1 Sep 7 2010 4:45PM -- TOWE Joint Inspection NOT Required

6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rules 2201 and 4623]

7. VOC fugitive emissions from the components in gas service on tank shall not exceed 0.08 lb/day. [District Rule 2201]

8. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed. [District Rule 2201]

9. Except as otherwise provided in this permit, the operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2201]

10. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rules 2201 and 4623]

11. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rules 2201 and 4623]

12. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rules 2201 and 4623]

13. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 1070]

14. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

15. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

18. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

19. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

20. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

21. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

22. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

23. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

24. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

25. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

26. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

27. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

28. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

29. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

30. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

31. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

32. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

37. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

38. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

39. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

40. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

41. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

42. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

43. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

44. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

45. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

46. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

47. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

48. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

49. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

50. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

51. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

52. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

53. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

56. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

57. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

58. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District Rule 2201]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-111-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE12 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
1571 BBL FIXED ROOF PETROLEUM STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1216-122

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-87-4. [District NSR Rule]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
4. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
5. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
7. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

11. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

12. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

14. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

16. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

17. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

18. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

19. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

20. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

21. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

22. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

24. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

25. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

26. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

27. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

28. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

29. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

30. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

34. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

35. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

37. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

38. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

39. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

40. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

41. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

42. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

43. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

44. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

45. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

46. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

48. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

50. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

51. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

54. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

55. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-122-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE12 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
ONE 42,000 GALLON CRUDE OIL STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48 SHARED WITH S-1216-111

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-184-0. [District NSR Rule]
2. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
4. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
5. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
6. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
7. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

11. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

12. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

14. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

16. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

17. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

18. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

19. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

20. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

21. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

23. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

24. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

25. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

26. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

27. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

28. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

29. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

30. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

34. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

36. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

37. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

38. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

39. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

40. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

41. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

42. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

43. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

44. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

45. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

46. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

49. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

50. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

51. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

54. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

55. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-123-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 420,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM SHARED WITH TANKS S-1216-125 AND '-126 AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-185-0. [District NSR Rule]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
5. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. This unit has a storage capacity of 420,000 gallons but is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

17. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

18. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

19. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

20. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

21. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

23. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

25. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

26. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

27. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

28. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

29. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

30. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

36. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

37. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

38. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

39. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

40. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

41. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

42. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

43. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

44. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

45. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

46. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

49. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

50. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

51. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

55. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

56. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-124-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 429,282 GALLON FIXED ROOF STORAGE TANK SERVED BY A VAPOR RECOVERY SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-187-0. [District NSR Rule]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. This unit is a tank of a small producer with a throughput of 50 barrels of crude oil per day or less, it is exempt from District Rule 4623. Operator shall maintain a record of average daily crude oil throughput to determine compliance with section 3.25, and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. The monthly crude oil production records required by the California Division of Oil, Gas, and Geothermal Resources may be used to comply with the above requirement. Operator shall also maintain monthly records of the average daily crude oil throughput of this tank to demonstrate compliance with Section 4.4 and/or 5.1.2 [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
4. This tank shall be subject to the requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.3] Federally Enforceable Through Title V Permit
5. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. The requirements of District Rule 4623 (amended December 20, 2001) do not apply to this source since this tank is exempt under section 4.0 as emergency standby, temporary, or a small producer tank. A permit shield is granted from this requirement except for sections 6.3.4 and 7.3 for small producer tanks. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. This unit is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
9. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

11. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

12. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

13. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

14. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

15. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

16. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

17. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

19. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

20. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

21. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

22. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

24. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

25. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

26. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

29. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

30. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

31. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

32. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

33. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

34. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

35. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

37. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

38. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

39. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

40. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

41. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

42. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

43. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

44. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

45. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

46. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

48. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

49. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

50. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-125-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 429,282 GALLON FIXED ROOF STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-123 AND '-126) AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-188-0. [District NSR Rule]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
5. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. This unit is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

17. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

18. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

19. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

20. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

21. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

23. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

25. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

26. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

27. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

28. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

29. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

30. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

36. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

37. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

38. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

39. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

40. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

41. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

42. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

43. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

44. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

45. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

46. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

49. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

50. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

51. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

55. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

56. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-126-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 429,282 GALLON FIXED ROOF STORAGE TANK SERVED BY VAPOR RECOVERY SYSTEM (SHARED WITH S-1216-123 AND '-125) AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-189-0. [District NSR Rule]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
4. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
5. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, 4623. 6.3] Federally Enforceable Through Title V Permit

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

13. This unit is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

15. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

17. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

18. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

19. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

20. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

21. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

23. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

25. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

26. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

27. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

28. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

29. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

30. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

31. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

36. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

37. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

38. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

39. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

40. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

41. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

42. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

43. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

44. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

45. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

46. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

47. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

49. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

50. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

51. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

52. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

55. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

56. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: S-1216-127-1 **ISSUANCE DATE:** 01/11/2011

LEGAL OWNER OR OPERATOR: OCCIDENTAL OF ELK HILLS INC
MAILING ADDRESS: 10800 STOCKDALE HIGHWAY
BAKERSFIELD, CA 93311

LOCATION: LIGHT OIL WESTERN

SECTION: SW27 **TOWNSHIP:** 31S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
MODIFICATION OF 250 BBL FIXED ROOF CRUDE OIL DRAIN TANK SERVED BY A P/V RELIEF VALVE: DELETE SMALL PRODUCER EXEMPTIONS AND ADD RULE 4623 CONDITIONS

CONDITIONS

1. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
4. Crude oil throughput shall be less than 50 bbl/day. [District Rule 2080]
5. TVP of material stored in tank shall not exceed 11 psia. [District Rule 4623 5.1.1]
6. Permittee shall conduct True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623, 6.2.2]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1216-127-1 : Jan 11 2011 9:37AM -- BUSSM : Joint Inspection NOT Required

7. In lieu of testing each uncontrolled fixed roof tank, an operator may conduct a TVP testing of a representative tank provided the following requirements are met. The selection of representative, uncontrolled fixed roof tanks is submitted in writing to the APCO, and written approval is granted by the APCO prior to conducting the test. One uncontrolled fixed roof tank represents some or all of the tanks in a tank battery. For crude oil production facilities, the representative uncontrolled fixed roof tank shall be the first line tank (or tanks) in a tank battery that is first receiving the produced fluids (mixture of oil, water, and gases) from the crude oil production wells. The stored organic liquid in each of the represented tanks is the same and came from the same source. The TVP and storage temperature of the stored organic liquid of the representative tank to be tested are the same or higher than those of the tanks it is to represent. [District Rule 4623, 6.2.2]

8. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. If the tank stores crude oil or petroleum distillates, the operator shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2]

9. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2]

10. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4]

11. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623]

12. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. Permittee shall also maintain monthly records of average daily throughput. [District Rules 4623and 2080]

13. This unit is a tank of a small producer with a throughput of 50 barrels of crude oil per day or less and is exempt from District Rule 4623. Operator shall maintain a record of average daily crude oil throughput to determine compliance with section 3.25, and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. The monthly crude oil production records required by the California Division of Oil, Gas, and Geothermal Resources may be used to comply with the above requirement. Operator shall also maintain monthly records of the average daily crude oil throughput of this tank to demonstrate compliance with Section 4.4 and/or 5.1.2 [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit

14. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623]

15. Formerly S-3079-48-0.

16. Formerly S-2010-190-0

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-128-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW21 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 84,000 GALLON FIXED ROOF WASH TANK SERVED BY A VAPOR CONTROL SYSTEM INCLUDING PIPING TO CHEVRON 1-C GAS PLANT (S-48)

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-193-0. [District NSR Rule]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
4. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. Collected vapors shall be directed to approved control devices having a destruction efficiency of at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623, 5.6.1] Federally Enforceable Through Title V Permit
6. All piping valves and fittings shall be constructed and maintained in a gas tight condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
7. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.9 and 6.4.8] Federally Enforceable Through Title V Permit
8. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2, and 4623. 6.3] Federally Enforceable Through Title V Permit

13. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended December 20, 2001). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

14. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

15. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

16. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

17. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

18. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

19. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

20. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

21. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

22. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

24. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

25. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

26. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

27. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

28. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

29. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

30. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

31. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

32. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

33. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

34. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

37. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

38. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

39. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

40. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

41. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

42. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

43. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

44. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

45. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

46. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

47. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

48. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

50. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

51. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

52. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

53. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

54. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

55. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

56. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

57. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-129-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW21 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 5,880 GALLON FIXED ROOF STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. This permit unit was formerly number S-2010-194-0. [District NSR Rule]
2. Crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
4. This unit is a tank of a small producer with a throughput of 50 barrels of crude oil per day or less and is exempt from District Rule 4623. Operator shall maintain a record of average daily crude oil throughput to determine compliance with section 3.25, and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. The monthly crude oil production records required by the California Division of Oil, Gas, and Geothermal Resources may be used to comply with the above requirement. Operator shall also maintain monthly records of the average daily crude oil throughput of this tank to demonstrate compliance with Section 4.4 and/or 5.1.2 [District Rule 4623, 6.3.4] Federally Enforceable Through Title V Permit
5. This tank shall be subject to the requirements of Rule 4623 if the tank loses its exemption under section 4.0 on the date the exemption status is lost. [Rule 4623, 7.3] Federally Enforceable Through Title V Permit
6. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2 and 4623, 6.3] Federally Enforceable Through Title V Permit
7. The requirements of District Rule 4623 (amended December 20, 2001) do not apply to this source since this tank is exempt under section 4.0 as a small producer tank. A permit shield is granted from this requirement except for sections 6.3.4 and 7.3 for small producer tanks. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

11. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

12. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

13. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

14. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

15. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

16. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

17. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

18. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

19. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

20. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

21. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

23. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

24. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

25. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

26. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

29. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

30. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

31. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

32. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

33. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

34. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

35. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

37. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

38. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

39. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

40. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

41. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

42. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

43. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

44. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

45. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

46. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

49. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

50. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

51. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-130-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 100,800 GALLON FIXED-ROOF PETROLEUM WASH TANK SERVED BY A VAPOR RECOVERY SYSTEM (BUENA VISTA)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free (less than 10,000 ppmv). [District NSR Rule]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. Tank shall vent exclusively to vapor recovery system. [District NSR Rule]
8. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
9. Formerly S-1641-43-0
10. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
11. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

13. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

14. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

15. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

16. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

17. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

18. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

19. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

20. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

21. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

22. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

23. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

24. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

26. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

29. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

30. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

31. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

32. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

33. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

34. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

35. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

36. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

37. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

38. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

39. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

40. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

41. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

42. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

43. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

44. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

45. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

46. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

47. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

48. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

50. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

51. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

52. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-131-0 **EXPIRATION DATE:** 08/31/2010

SECTION: 06 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:
ONE 42,000 GALLON FIXED-ROOF PETROLEUM WASH TANK (#IGF52) SERVED BY A VAPOR RECOVERY SYSTEM (LITTLE SIX LEASE)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in gas-tight condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623]
2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
3. All piping, valves, and fittings shall be constructed and maintained in a gas-tight condition. [District Rule 4623]
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623]
5. Tank roof appurtenances shall be maintained leak free (less than 10,000 ppmv). [District NSR Rule]
6. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623]
7. Operation shall include make-up gas line with Varec Fig. 181 valve regulator and piping through Varec Fig. 180 valve regulator to gas gathering line shared between permit units S-1641-42 and S-1641-45. [District NSR Rule]
8. Tank shall vent exclusively to vapor recovery system shared between permit units S-1641-42 and S-1641-45. [District NSR Rule]
9. Tank S-1641-42 shall be operated at constant fluid level. [District NSR Rule]
10. Tank vapor recovery system shall comply with all applicable Rule 4403 requirements. [District Rule 4403]
11. Varec Fig. 181 gas regulator shall activate when tank pressure falls below 2 in. H2O allowing make-up gas to enter tank. [District NSR Rule]
12. Varec Fig. 180 gas regulator shall activate when tank pressure rises above 2 in-H20 allowing vapor to be drawn into gas gathering line. [District NSR Rule]
13. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District Rule 4623]
14. Total combined volatile organic compound (VOC) emissions from tanks S-1641-42 and S-1641-45 shall not exceed 0.24 lb per day. [District NSR Rule]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

15. The operator shall keep accurate records of types, storage temperature and true vapor pressure of liquids stored. [District Rule 1070]

16. Formerly S-1130-23-0

17. Formerly S-1641-45-0

18. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

19. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

20. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

21. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

22. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

23. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

24. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

25. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

26. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

27. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

28. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

29. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

30. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

31. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

32. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

33. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

34. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

39. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

40. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

41. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

42. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

43. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

44. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

45. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

46. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

47. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

48. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

49. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

50. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

51. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

52. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

53. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

54. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

55. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

56. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

57. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

58. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

59. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

60. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-132-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
WEMCO MODEL 84 OIL/WATER SEPARATOR RATED AT 40,000 BBL/DAY AND SERVED BY GAS PLANT VAPOR RECOVERY SYSTEM AT FACILITY S-48

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. All piping, valves, and fittings shall be constructed and maintained in a leak-tight condition. [District NSR Rule] Federally Enforceable Through Title V Permit
4. A leak-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. Fugitive VOC emissions rate for the WEMCO oil/water separator shall be calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components in gas/light liquid service, shall not exceed 0.3 lb-VOC/day or 110 lb-VOC/yr. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Components subject to District Rule 4409 shall be identified and categorized according to District Rule 4409 component types. [District NSR Rule] Federally Enforceable Through Title V Permit
10. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. For valves, threaded connections, flanges, pipes, pumps, compressors, and other components subject to the requirements of Rule 4409, but not specified in this permit; a major gas leak is a detection of > 10,000 ppmv as methane; a minor gas leak is a detection of 1,000 to 10,000 ppmv as methane when the component is in liquid service; a minor gas leak is a detection of 2,000 to 10,000 ppmv as methane when the component is in gas/vapor service. [District Rule 4409, 5.1.1] Federally Enforceable Through Title V Permit

12. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.2] Federally Enforceable Through Title V Permit

13. Leaks detected during quarterly operator inspections shall not be counted towards determination of compliance with the provisions of Rule 4409 provided the leaking components are repaired as soon as practicable but not later than the time frame specified in this permit. Leaks detected during quarterly operator inspections that are not repaired, replaced, or removed from operation as soon as practicable but not later than the time frame specified in this rule shall be counted toward determination of compliance with the provisions of Rule 4409. [District Rule 4409, 5.1.3.2.1 and 5.1.3.2.2] Federally Enforceable Through Title V Permit

14. Leaking components at this facility detected during annual operator inspections, as required by Rule 4409 for a specific component type, that exceed the leak standards specified in this permit, shall constitute a violation of this rule. This violation is regardless of whether or not the leaking components are repaired, replaced, or removed from operation within the allowable repair time frame specified in this permit. [District Rule 4409, 5.1.3.2.3] Federally Enforceable Through Title V Permit

15. An open-ended line, or a valve located at the end of the line, that is not sealed with either a blind flange, a plug, a cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended line is a leak. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4409, 5.1.4.1] Federally Enforceable Through Title V Permit

16. A leak from a component is when there is a major liquid leak from the component. A major liquid leak from a component is when a visible mist or a continuous flow of liquid, that is not seal lubricant, leaks from the component. [District Rule 4409, 5.1.4.2] Federally Enforceable Through Title V Permit

17. A leak from a component is when gas emissions greater than 50,000 ppmv, as methane, leaks from the component. [District Rule 4409, 5.1.4.3] Federally Enforceable Through Title V Permit

18. A minor liquid leak from a component is when more than three drops of liquid per minute, that is not seal lubricant and is not a major liquid leak, leaks from the component. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

19. When 200 or fewer valves are inspected, a leak from a valve is when more than one valve has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 valves are inspected, a leak from a valve is when more than 0.5 % (rounded up to the nearest whole number) of the valves have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

20. When 200 or fewer threaded connections are inspected, a leak from a threaded connection is when more than one threaded connection has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 threaded connections are inspected, a leak from a threaded connection is when more than 0.5 % (rounded up to the nearest whole number) of the threaded connections have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. When 200 or fewer flanges are inspected, a leak from a flange is when more than one flange has a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. When greater than 200 flanges are inspected, a leak from a flange is when more than 0.5 % (rounded up to the nearest whole number) of the flanges have a minor liquid leak, a minor gas leak, or a gas leak > 10,000 ppmv and < or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

22. When 200 or fewer pumps are inspected, a leak from a pump is when more than two pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. When greater than 200 pumps are inspected, a leak from a pump is when more than 1.0 % (rounded up to the nearest whole number) of the pumps have a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

23. When compressors, PRDs, or other components not specified in this permit are inspected, a leak from these components is when more than one component has a minor liquid leak, a minor gas leak, or a gas leak greater than 10,000 ppmv and less than or equal to 50,000 ppmv. [District Rule 4409, 5.1.4.4] Federally Enforceable Through Title V Permit

24. For unmanned facilities all accessible operating pumps, compressors, and PRDs, in service, shall be audio-visually inspected for leaks at least once per calendar week. [District Rule 4409, 5.2.2] Federally Enforceable Through Title V Permit

25. All accessible operating pumps, compressors, and PRDs, in service, that are found to be leaking by audio-visual inspection shall be attempted to be repaired immediately. The leaking component shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.3] Federally Enforceable Through Title V Permit

26. Except for inaccessible components, unsafe-to-monitor components, or pipes, all components, in service, shall be tested for leaks at least once every calendar quarter. [District Rule 4409, 5.2.4] Federally Enforceable Through Title V Permit

27. All new, replaced, or repaired fittings, flanges, and threaded connections shall be tested for leaks immediately after being placed into service. [District Rule 4409, 5.2.5] Federally Enforceable Through Title V Permit

28. All inaccessible components shall be tested for leaks at least once every 12 months. [District Rule 4409, 5.2.6] Federally Enforceable Through Title V Permit

29. All unsafe-to-monitor components shall be tested for leaks during each turnaround. [District Rule 4409, 5.2.7] Federally Enforceable Through Title V Permit

30. All pipes shall be visually inspected for leaks at least once every 12 months. [District Rule 4409, 5.2.8] Federally Enforceable Through Title V Permit

31. All pipes, in service, that are found to be leaking by visual inspection shall be attempted to be repaired immediately. The leaking pipe shall then be tested within 24 hours and, if found leaking again, shall be repaired as soon as practicable but not later than the timeframe specified in this permit. [District Rule 4409, 5.2.8.1] Federally Enforceable Through Title V Permit

32. The annual pipe inspection required by either the Department of Oil, Gas, and Geothermal Resources (DOGGR) pursuant to California Code of Regulation Title 14, Division 2, Subchapter 2, Section 1774 (Oilfield Facilities and Equipment Maintenance), or by the Spill Prevention Control and Countermeasure Plan (SPCC) pursuant to 40 Code of Federal Regulation Part 112 (Oil Prevention and Response: Non- Transportation-Related Onshore and Offshore Facilities) can be used as the annual pipe inspection required by District Rule 4409. [District Rule 4409, 5.2.8.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. Except for pumps, compressors, and PRDs, the permittee may apply for written approval from the District to change the inspection frequency of accessible components from quarterly to annually for a specific component type provided the following two qualifying requirements are met. During the previous five consecutive quarterly inspections, for the specific component type, there shall be no more leaks than as allowed by this permit. The permittee also shall not have received a Notice of Violation (NOV) from the District during the previous 12 months for violating any provisions of District Rule 4409 for the specific component type. If these two qualifying requirements have not been met, then the inspection frequency shall revert back to quarterly. The written request shall include pertinent documentation to demonstrate that the operator has successfully met the two qualifying requirements. [District Rule 4409, 5.2.9 and 5.2.10] Federally Enforceable Through Title V Permit

34. The permittee shall notify the District in writing within five calendar days after changing the inspection frequency for a specific component type. The written notification shall include the reason(s) and date of change to a quarterly inspection frequency. [District Rule 4409, 5.2.11] Federally Enforceable Through Title V Permit

35. Except for PRDs, a component shall be inspected for leaks not later than 15 calendar days after repairing the leak or replacing the component. [District Rule 4409, 5.2.13] Federally Enforceable Through Title V Permit

36. District inspections shall not be counted as an operator inspection required by District Rule 4409. Any attempt by an operator to count such District inspections as part of the operator's mandatory inspections is considered a willful circumvention of the rule and is a violation of this rule. [District Rule 4409, 5.2.14] Federally Enforceable Through Title V Permit

37. The operator, upon detection of a leaking component, shall affix to that component a weatherproof, readily visible tag, bearing the date and time when the leak was detected and the date and time of the leak measurement. For gaseous leaks, the tag shall indicate the leak concentration in ppmv. For liquid leaks, the tag shall indicate whether it is a major liquid leak or a minor liquid leak. The tag shall indicate, when applicable, whether the component is an essential component, an unsafe-to-monitor component, or a critical component. The tag shall remain in place until the leaking component is repaired or replaced and reinspected and found to be in compliance with the requirements of this rule. [District Rule 4409, 5.3.1] Federally Enforceable Through Title V Permit

38. The operator shall minimize all component leaks immediately, to the extent possible, but not later than one hour after detection of the leak in order to stop or reduce leakage to the atmosphere. If the leak has been minimized but the leak still exceeds the applicable leak standards specified in this permit, the operator shall do one of the following within the timeframes specified within this permit: 1) repair or replace the leaking component; 2) vent the leaking component to a closed vent system; 3) or remove the leaking component from operation. A closed vent system is a District approved system that is not open to the atmosphere. It is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to a District approved control device that has a overall VOC collection and destruction or removal efficiency of at least 95%, or that transports gases or vapors back to a process system. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

39. The operator shall repair minor gas leaks within seven days. The operator shall repair major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, within three days. The operator shall repair major gas leaks, which are > 50,000 ppmv, within two days. The operator shall repair minor liquid leaks within three days. The operator shall repair major liquid leaks within two days. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period. The start of the repair period shall be the time of the initial leak detection. [District Rule 4409, 5.3.4 and 5.3.5] Federally Enforceable Through Title V Permit

40. For each calendar quarter, the operator may extend the repair period for a total number of leaking components, not to exceed 0.05 % of the number of components inspected, by type, rounded upward to the nearest whole number. The repair period for minor gas leaks can be extended by seven additional days. The repair period for major gas leaks, which are > 10,000 ppmv but < or equal to 50,000 ppmv, can be extended by two additional days. [District Rule 4409, 5.3.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

41. If a leaking component is an essential component or a critical component and which cannot be shut down immediately for repairs, the operator shall do the following: 1) minimize the leak within one hour after detection of the leak; 2) and if the leak has been minimized, but the leak still exceeds the applicable leak standards of Rule 4409 as specified in this permit, the essential component or critical component shall be repaired or replaced to eliminate the leak during the next process unit turnaround. The repair shall occur no later than one year from the date of the original leak detection. [District Rule 4409, 5.3.6] Federally Enforceable Through Title V Permit

42. For any component that has incurred five repair actions for major gas leaks or major liquid leaks, or a combination of major gas leaks and major liquid leaks within a continuous 12-month period, the operator shall do one of the following four options. Options 1a through 1f require written notification to the District, option 2 requires written notification to the District and written District approval, options 3 and 4 do not require written notification to the District: 1a) For compressors replace the existing seal with either a dual mechanical seal, an oil film seal, a gas seal, or a face-type seal; 1b) for pumps replace the pump with a seal-less pump or replace the seal with a dual mechanical seal; 1c) for PRDs replace the PRD and install a rupture disc in the line which precedes the PRD such that the PRD is in series with and follows the rupture disc; 1d) for valves replace the valve with a sealed bellows valve, or for seal rings install graphite or Teflon chevron seal rings in a live-loaded packing gland; 1e) for threaded connections weld the connections or replace threaded connections with flanges; 1f) for sampling connections replace the sampling connection with a closed-loop sampling system; 2) Replace the component with Achieved-in-Practice Best Available Control Technology (BACT) equipment; 3) Vent the component to a District approved closed-vent system; 4) Remove the component from operation. For any component that is accessible, is not unsafe-to-monitor, is not an essential component, or is not a critical component, the operator shall comply with these requirements as soon as practicable but not later than twelve months after the date of detection of the fifth major leak within a continuous 12-month period. For any component that is inaccessible, is unsafe-to-monitor, is essential, or is a critical component, the operator shall comply with these requirements as soon as practicable but not later than the next turnaround or not later than two years after the date of detection of the fifth major leak within a continuous 12-month period, whichever comes first. [District Rule 4409, 5.3.7] Federally Enforceable Through Title V Permit

43. All major components and critical components shall be physically identified clearly and visibly for inspection, repair, and recordkeeping purposes. The physical identification shall consist of labels, tags, manufacturer's nameplate identifier, serial number, or model number, or other system approved by the District that enables an operator or the District to locate each individual component. The operator shall replace physical identifications that become missing or unreadable as soon as practicable but not later than 24 hours after discovery. [District Rule 4409, 5.4.1] Federally Enforceable Through Title V Permit

44. The operator shall keep a copy of the District approved Operator Management Plan (OMP) at the facility and make it available to the District, ARB, and EPA upon request. [District Rule 4409, 6.1.2] Federally Enforceable Through Title V Permit

45. By January 30th of each year the operator shall submit to the District for approval, in writing, an annual report indicating any changes to the existing OMP on file at the District. [District Rule 4409, 6.1.4] Federally Enforceable Through Title V Permit

46. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4409, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

47. Records of leaks detected during quarterly or annual operator inspections, and each subsequent repair and re-inspection, shall be submitted to the District, ARB, and EPA upon request. [District Rule 4409, 6.2.2] Federally Enforceable Through Title V Permit

48. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4409, 6.2.3] Federally Enforceable Through Title V Permit

49. All records required by this permit shall be retained on-site for a minimum of five years and made available for District, ARB, and EPA inspection upon request. [District Rule 4409, 6.2.4] Federally Enforceable Through Title V Permit

50. All measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instructions not more than 30 days prior to its use. [District Rule 4409, 6.3.1] Federally Enforceable Through Title V Permit

51. The VOC content by weight percent shall be determined using ASTM D-1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 for liquids. [District Rule 4409, 6.3.2] Federally Enforceable Through Title V Permit

52. The percent by volume liquid evaporated at 302 øF (150 øC) shall be determined using ASTM D-86. [District Rule 4409, 6.3.3] Federally Enforceable Through Title V Permit

53. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D-323, and converting the RVP to TVP at the maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures specified in Appendix A of District Rule 4409. [District Rule 4409, 6.3.4] Federally Enforceable Through Title V Permit

54. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM D-287 or ASTM 1298. Sampling for API gravity shall be performed in accordance with ASTM D-4057. [District Rule 4409, 6.3.5] Federally Enforceable Through Title V Permit

55. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4409, 6.3.6] Federally Enforceable Through Title V Permit

56. Halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422. [District Rule 4409, 6.3.7] Federally Enforceable Through Title V Permit

57. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

58. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

59. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

60. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

61. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

62. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

63. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

64. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

65. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

66. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

67. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

68. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

69. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

70. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

71. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

72. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

73. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

74. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

75. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

76. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

77. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

78. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

79. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

80. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

81. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

82. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

83. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

84. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

85. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

86. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

87. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

88. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

89. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

90. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

91. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

92. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

93. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

94. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

95. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

96. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

97. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

98. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

99. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-133-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T6) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
3. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
4. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201]
5. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201]
6. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
7. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
8. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit
9. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
10. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

17. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

18. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

19. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

21. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

22. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

24. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

25. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

26. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

27. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

28. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

29. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

30. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

31. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

32. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

33. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

34. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

35. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

37. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

39. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

40. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

41. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

42. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

43. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

44. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

45. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

46. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

47. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

48. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

50. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

51. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

52. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

53. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

54. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

55. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

56. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

57. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

58. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

59. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

60. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

61. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

62. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

63. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-134-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T7) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
2. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201]
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201]
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
9. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

11. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

16. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

17. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

18. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

20. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

21. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

23. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

24. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

25. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

26. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

27. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

28. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

29. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

30. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

31. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

32. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

33. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

34. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

36. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

39. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

40. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

41. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

42. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

43. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

44. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

45. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

46. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

47. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

49. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

50. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

51. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

52. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

53. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

54. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

55. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

56. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

57. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

58. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

59. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

60. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

61. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

62. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-135-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
10,000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T2) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
2. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201]
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201]
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
9. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

11. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

16. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

17. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

18. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

20. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

21. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

23. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

24. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

25. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

26. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

27. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

28. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

29. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

30. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

31. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

32. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

33. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

34. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

36. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

39. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

40. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

41. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

42. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

43. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

44. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

45. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

46. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

47. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

49. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

50. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

51. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

52. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

53. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

54. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

55. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

56. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

57. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

58. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

59. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

60. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

61. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

62. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-136-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
2000 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK (T8) SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
2. All tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
3. VOC content of hydrocarbons in gas shall not exceed 37% by weight. Permittee shall sample and record the VOC content of hydrocarbons at least once every 12 months. [District Rules 1070 and 2201]
4. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201]
5. Fugitive VOC emissions rate shall be, calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC fugitive emissions from the components in gas service on the tank shall not exceed 0.008 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
9. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

11. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. If a component type for a given tank is found to leak during an annual inspection, then conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

13. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule NSR] Federally Enforceable Through Title V Permit

16. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

17. Interior tank cleaning shall be performed in accordance with provisions specified in Table 6 of Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

18. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

20. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

21. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

23. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

24. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

25. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

26. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

27. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

28. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

29. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

30. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

31. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

32. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

33. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

34. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

36. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

39. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

40. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

41. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

42. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

43. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

44. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

45. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

46. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

47. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

49. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

50. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

51. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

52. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

53. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

54. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

55. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

56. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

57. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

58. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

59. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

60. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

61. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

62. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-137-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE36 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL STORAGE TANK T9 SERVED BY VAPOR CONTROL SYSTEM AT GAS PLANT S-48

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor loss prevention system capable of collecting all VOC emissions and preventing their emissions to the atmosphere at an efficiency of at least 99% by weight. [District Rules 2201 and 4623, 5.3.1] Federally Enforceable Through Title V Permit
2. All tank gauging or sampling devices on a tank vented to the vapor recovery system shall be equipped with a gas tight cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.3.2] Federally Enforceable Through Title V Permit
3. Fugitive VOC emissions rate shall be calculated using CAPCOA California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities Table IV-2c, Oil and Gas Production Screening Value Ranges Emission Factors (Feb 1999), from the total number of components from this tank. [District Rule 2201] Federally Enforceable Through Title V Permit
4. VOC fugitive emissions from the components in gas and light oil service shall not exceed 0.1 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. A leak-free condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and shall be reported as a deviation. [District Rules 2201 and 4623] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
7. If any of the tank components are found to be leaking, operator shall immediately affix a tag and maintain records of gas leak detection readings, date/time leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of any leaking components (having a gas leak >10,000 ppmv, measured in accordance with EPA Method 21 by a portable hydrocarbon detection instrument that is calibrated with methane) operator shall: (a) Eliminate or minimize the leak within 8 hours after detection. (b) If the leak can not be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices; and eliminate the leak within 48 hours after detection. (c) In no event that the total time to minimize and eliminate the leak shall exceed 56 hours after detection. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Leaking tank components affixed to the tank or within five feet of the tank that have been discovered by the operator and that have been immediately tagged and repaired within the specified deadlines, shall not constitute a violation of the District Rule 4623. However, leaking components discovered during inspections by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within specified deadlines, shall constitute a violation of the District Rule 4623. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

10. If a component type for a given tank is found to leak during an annual inspection, then operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If a component type is found to have no leak after four consecutive quarterly inspections, then operator shall revert to annual inspections. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

11. Any component found to be leaking on two consecutive annual inspections is in violation of District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623, 5.7 (Table 3)] Federally Enforceable Through Title V Permit

12. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

13. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit

14. This permit authorizes tank cleaning that is not the result of breakdowns or poor maintenance as a routine maintenance activity. [District Rule 2020] Federally Enforceable Through Title V Permit

15. Interior tank cleaning shall be performed in accordance with provisions specified in Rule 4623. [District Rules 2201 & 4623] Federally Enforceable Through Title V Permit

16. Permittee shall keep in their facility at all times a copy of the letter sent to the APCO requesting participation in the Rule 4623 Fixed Roof Tank Preventive Inspection and Maintenance Program, and Tank Interior Cleaning Program, and maintain the records of annual tank inspections, maintenance, and cleaning to document the participation in the program. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

17. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

18. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

19. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit

20. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

21. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

23. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

24. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

25. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

26. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

27. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

28. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

29. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

30. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

31. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

32. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

33. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

34. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

36. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

37. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

38. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

39. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

40. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

41. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

42. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

43. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

44. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

45. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

46. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

47. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

48. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

49. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

50. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

51. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

52. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

53. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

54. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

55. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

56. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

57. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

58. On January 31, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

59. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

60. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rules 3020, 4623, 3.25 and 4.4] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-139-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NW 20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
195 BHP WAUKESHA MODEL F-1197 SERIAL #265448 FIELD GAS/PROPANE -FIRED RICH BURN CYCLICALLY LOADED I.C. ENGINE WITH NON SELECTIVE CATALYTIC REDUCTION (NSCR) EMISSIONS CONTROL

PERMIT UNIT REQUIREMENTS

1. Unit shall not be located within 1000 feet of any K-12 school. [CH&SC 42301.6]
2. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Permittee shall notify the District Compliance Division of each location at which the unit is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
6. When unit is dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
7. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
10. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. This unit shall be fired only on propane or gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
12. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

14. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

15. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit

16. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

17. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

22. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

28. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

29. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits for propane combustion shall be conducted at startup. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

30. NOx, CO, and VOC emissions shall be measured (source tested) not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

31. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

32. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

33. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

35. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

36. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-140-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW 20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
135 BHP WAUKESHA MODEL F-817 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
2. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
4. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
5. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
6. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
7. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

23. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-141-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NW 29 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
195 BHP WAUKESHA MODEL F-1197 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED I.C. ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule 2201 and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

23. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-142-1 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
84,588 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM INCLUDING COMPRESSOR(S) CONNECTED WITH TANKS S-1216-143 THROUGH '-145 AND '-152 THROUGH '-156 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
2. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
3. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Vapor recovery system shall vent to gas plant (permit S-39-1) only. [District NSR Rule] Federally Enforceable Through Title V Permit

11. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

12. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

13. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

14. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

15. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

16. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

17. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

18. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

20. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-143-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
105,000 GALLON (2500 BBL) FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
2. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. The tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Tank throughput shall not exceed 1,500 bbl/day. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

12. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

13. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

14. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

15. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

16. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

17. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

18. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

20. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Operator shall maintain records of daily tank throughput. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-144-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
84,588 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
2. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. The tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

11. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

12. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

13. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

14. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

15. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

16. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

17. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

18. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

19. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-145-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
84,588 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. All piping valves and fittings shall be constructed and maintained in a leak-free condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
2. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. The tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Tank shall not be used to store or process liquids if the vapor control system is inoperable. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

11. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

12. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

13. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

14. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

15. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

16. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

17. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

18. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

19. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-146-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
8,400 GALLON FIXED ROOF PETROLEUM TEST TANK (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 11 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

15. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

16. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-147-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
8,400 GALLON FIXED ROOF PETROLEUM TEST TANK (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 11 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

15. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

16. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-148-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-149-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701, 6.3.1 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-150-0 **EXPIRATION DATE:** 08/31/2010

SECTION: NE20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
147 HP MINNEAPOLIS MOLINE MODEL HD800-6A FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 50 ppmv-NOx @ 15% O2, 2,000 ppmv-CO @ 15% O2 and 250 ppmv-VOC @ 15% O2. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on natural gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
12. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Upon recommencing operation, permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

14. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall update the I & M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I & M plan and must submit an updated I & M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I & M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I & M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

16. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

17. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

18. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701and 4702] Federally Enforceable Through Title V Permit

20. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

21. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

23. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

27. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rule 4701, 6.3.1 and 4702] Federally Enforceable Through Title V Permit

29. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit

30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

33. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rules 4701 and 4702. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-151-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
135 BHP WAUKESHA MODEL 817 FIELD GAS-FIRED RICH-BURN CYCLICALLY LOADED IC ENGINE WITH NSCR

PERMIT UNIT REQUIREMENTS

1. When dormant, the fuel supply line shall be physically disconnected from this unit, or an alternate method approved by the APCO shall be instituted to ensure this unit is not operated. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
2. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
3. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Unit shall only be operated within Occidental of Elk Hills Inc/Vintage Production California, LLC. light oil western stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Unit shall not be located within 1000 feet of any K-12 school. [District Rule CH&SC 42301.6]
6. Engine shall be maintained according to engine manufacturer's specifications. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
8. Emissions from the engine shall not exceed any of the following limits: 50 ppmv NOx @ 15% O2 (equivalent to 0.7 g/bhp-hr), 2,000 ppmv CO @ 15% O2 (equivalent to 17.0 g/bhp-hr), 250 ppmv VOC @ 15% O2 (equivalent to 1.2 g/bhp-hr), and 0.063 g-PM10/bhp-hr. [District NSR Rule and 4702] Federally Enforceable Through Title V Permit
9. This unit shall be fired only on natural gas with a sulfur content not exceeding 5 grains/100 dscf. [District NSR Rule and Kern County Rule 407] Federally Enforceable Through Title V Permit
10. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOX (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If the NOX or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. [District Rule 4702] Federally Enforceable Through Title V Permit

12. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOX and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records using Protocol 1 gases, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit

13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit

14. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit

15. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

17. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

18. The requirements of SJVAPCD District Rule 1080 (Amended December 17, 1992), do not apply to this source because this unit is subject to alternate monitoring in lieu of any continuous emission monitoring requirements. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Catalyst shall be periodically inspected and cleaned according to manufacturer's recommendations. [District NSR Rule] Federally Enforceable Through Title V Permit

21. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

22. Upon recommencing operation, source testing to demonstrate compliance with NOX, CO, and VOC emission limits shall be conducted not less than once every 24 months. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, VOC (ppmv) - EPA Method 25 or 25B, or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit

26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

27. Upon recommencing operation, an operating log record shall be maintained that includes, on a monthly basis, the total hours of operation, the type and quantity of fuel used, maintenance or modifications performed, compliance source test results, monitoring data, and any other information necessary to demonstrate compliance with Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit

28. Permittee shall maintain records of source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with District Rules for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1081 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-152-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SE20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
84,000 GALLON PRODUCED WATER TANK WITH VAPOR CONTROL (STEVENS LEASE)

PERMIT UNIT REQUIREMENTS

1. The fixed-roof storage tank shall be vented to vapor control system described in PTO S-1738-251. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
4. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
5. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
6. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to relieve pressure at a pressure level higher than that required to actuate compressor. The P/V valve shall be permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District NSR Rule and Rule 4623] Federally Enforceable Through Title V Permit
7. The water level in the water seal hatch shall be kept in accordance with the manufacturer's specifications, maintaining a leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall inspect and replenish the water level in the water seal hatch on a daily basis. Records of the water level shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
9. If the unit is a pressure vessel maintaining working pressures sufficient at all times to prevent organic liquid loss or VOC loss to the atmosphere, then no monitoring or recordkeeping shall be required. [District Rule 2520, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623]

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

17. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

18. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-153-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
84,000 GALLON PRODUCED WATER TANK WITH VAPOR CONTROL (STEVENS LEASE)

PERMIT UNIT REQUIREMENTS

1. The fixed-roof storage tank shall be vented to vapor control system described in PTO S-1738-251. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.7. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping valves and fittings shall be constructed and maintained in a leak-free condition [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
4. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
5. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
6. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to relieve pressure at a pressure level higher than that required to actuate compressor. The P/V valve shall be permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District NSR Rule and Rule 4623] Federally Enforceable Through Title V Permit
7. The water level in the water seal hatch shall be kept in accordance with the manufacturer's specifications, maintaining a leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall inspect and replenish the water level in the water seal hatch on a daily basis. Records of the water level shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
9. If the unit is a pressure vessel maintaining working pressures sufficient at all times to prevent organic liquid loss or VOC loss to the atmosphere, then no monitoring or recordkeeping shall be required. [District Rule 2520, 4.1] Federally Enforceable Through Title V Permit
10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623]

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

17. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

18. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-154-0 **EXPIRATION DATE:** 08/31/2010

EQUIPMENT DESCRIPTION:
42,000 GALLON PRODUCED WATER TANK #508 WITH VAPOR CONTROL (STEVENS LEASE)

PERMIT UNIT REQUIREMENTS

1. The fixed-roof storage tank shall be vented to vapor control system described in PTO# S-1738-7. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The tank shall be equipped with a vapor recovery system consisting of a closed vent system that collects all VOCs from the storage tank, and a VOC control device. The vapor recovery system shall be APCO-approved and maintained in leak-free condition. The VOC control device shall be either of the following: a vapor return or condensation system that connects to a gas pipeline distribution system, or an approved VOC destruction device the reduces the inlet VOC emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6. [District Rule 4623] Federally Enforceable Through Title V Permit
3. All piping valves and fittings shall be constructed and maintained in a leak-free condition. [District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
4. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11, 3.17, 3.18, and 6.4.8] Federally Enforceable Through Title V Permit
5. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
6. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to relieve pressure at a pressure level higher than that required to actuate compressor. The P/V valve shall be permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District NSR Rule and Rule 4623] Federally Enforceable Through Title V Permit
7. The water level in the water seal hatch shall be kept in accordance with the manufacturer's specifications, maintaining a leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall inspect and replenish the water level in the water seal hatch on a daily basis. Records of the water level shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
9. If the unit is a pressure vessel maintaining working pressures sufficient at all times to prevent organic liquid loss or VOC loss to the atmosphere, then no monitoring or recordkeeping shall be required. [District Rule 2520, 4.1] Federally Enforceable Through Title V Permit
10. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Permittee shall record and maintain monthly records of average daily crude oil throughput and shall make such records readily available for District inspection upon request for a period of five years. [District Rule 4623] Federally Enforceable Through Title V Permit

12. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired upon detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired. Leaks over 10,000 ppmv shall be reported as a deviation. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

15. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (Amended May 19, 2005). A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Therefore, the requirements of 40CFR 60 Subpart K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

17. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit

18. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-155-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
420,000 GALLON (10,000 BBL) FIXED ROOF PETROLEUM PRODUCTION TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. Tank shall be connected to the VOC vapor control system listed on S-1216-142. VOC vapors from tank shall vent only to the vapor control system. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
2. Storage tank pressure-vacuum cap(s) shall be set to relieve pressure at a pressure level higher than that required to actuate compressor. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
3. Storage tank pressure-vacuum cap(s) shall be leak-free (except for inbreathing) during normal operation. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
4. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR and District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 parts per million by volume (ppmv), as methane, above background on a portable hydrocarbon detection instrument that is calibrated with methane in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. [District NSR Rule and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR and District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. VOC fugitive emissions from the components in both gas and liquid service on this tank shall not exceed 0.2 lb-VOC/day [District NSR Rule] Federally Enforceable Through Title V Permit
9. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed [District NSR Rule] Federally Enforceable Through Title V Permit
10. Except as otherwise provided in this permit, the operator shall ensure that the VOC vapor control system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Any component found to be leaking is in violation of the District's NSR Rule, even if it is under the voluntary inspection and maintenance program. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

13. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

14. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

15. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

16. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

17. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

18. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

22. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

23. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid is placed, held, or stored in this tank. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

24. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

25. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

26. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

27. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

28. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 4623, 5.7] Federally Enforceable Through Title V Permit

29. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4623, 6.3] Federally Enforceable Through Title V Permit

30. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; Kern County Rule 111] Federally Enforceable Through Title V Permit

31. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; Kern County Rule 111] Federally Enforceable Through Title V Permit

32. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

33. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

35. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

36. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

37. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

38. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

39. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

40. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

41. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

42. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

43. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

44. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

45. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

46. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

47. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

48. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

49. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

50. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

51. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

52. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

53. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

54. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

55. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

56. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

57. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

58. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

59. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

60. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

61. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

62. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

63. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

64. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

65. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

66. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

67. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

68. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

69. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (12/17/09); 8021 (8/19/04); 8031 (8/19/04); 8041 (8/19/04); 8051 (8/19/04); 8061 (8/19/04); and 8071 (9/16/04). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

70. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1216-156-0 **EXPIRATION DATE:** 08/31/2010

SECTION: SW20 **TOWNSHIP:** 31S **RANGE:** 23E

EQUIPMENT DESCRIPTION:
21,000 GALLON (500 BBL) FIXED ROOF PETROLEUM PRODUCTION TANK WITH PIPING TO VAPOR RECOVERY SYSTEM UNDER PERMIT S-1216-142 (555 STEVENS ZONE UNIT)

PERMIT UNIT REQUIREMENTS

1. Tank shall be connected to the VOC vapor control system listed on S-1216-142. VOC vapors from tank shall vent only to the vapor control system. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
2. Storage tank pressure-vacuum cap(s) shall be set to relieve pressure at a pressure level higher than that required to actuate compressor. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
3. Storage tank pressure-vacuum cap(s) shall be leak-free (except for inbreathing) during normal operation. [District NSR and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
4. Operator shall inspect pressure relief valve for fugitive leaks annually in accordance with EPA Method 21, with the instrument calibrated with methane. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. All piping, valves, and fittings shall be constructed and maintained in a leak-free condition. [District NSR and District Rule 4623, 5.6.3] Federally Enforceable Through Title V Permit
6. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 parts per million by volume (ppmv), as methane, above background on a portable hydrocarbon detection instrument that is calibrated with methane in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. [District NSR Rule and District Rule 4623, 5.1] Federally Enforceable Through Title V Permit
7. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a leak-free cover which shall be closed at all times except during gauging or sampling. [District NSR and District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
8. VOC fugitive emissions from the components in both gas and liquid service on this tank shall not exceed 0.2 lb-VOC/day [District NSR Rule] Federally Enforceable Through Title V Permit
9. Permittee shall maintain accurate component count for tank according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Value Range emission factors < 10,000 ppmv. Permittee shall update such records when new components are approved and installed [District NSR Rule] Federally Enforceable Through Title V Permit
10. Except as otherwise provided in this permit, the operator shall ensure that the VOC vapor control system is functional and is operating as designed at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Any component found to be leaking is in violation of the District's NSR Rule, even if it is under the voluntary inspection and maintenance program. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

13. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

14. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

15. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

16. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623, Table 3] Federally Enforceable Through Title V Permit

17. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

18. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

19. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

20. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

22. This tank shall be in compliance with the applicable requirements of District Rule 4623 at all times during draining, degassing, and refilling the tank with an organic liquid. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

23. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid is placed, held, or stored in this tank. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

24. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

25. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

26. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

27. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 4623, 5.7] Federally Enforceable Through Title V Permit

28. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 4623, 5.7] Federally Enforceable Through Title V Permit

29. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4623, 6.3] Federally Enforceable Through Title V Permit

30. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; Kern County Rule 111] Federally Enforceable Through Title V Permit

31. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; Kern County Rule 111] Federally Enforceable Through Title V Permit

32. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit

33. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit

35. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit

36. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit

37. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

38. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

39. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

40. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

41. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

42. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

43. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

44. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

45. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

46. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

47. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

48. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

49. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

50. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

51. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

52. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

53. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

54. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

55. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

56. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

57. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit

58. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit

59. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit

60. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

61. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit

62. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

63. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit

64. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

65. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

66. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

67. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

68. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), and Rule 111 (Kern, Tulare, Kings). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

69. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (12/17/09); 8021 (8/19/04); 8031 (8/19/04); 8041 (8/19/04); 8051 (8/19/04); 8061 (8/19/04); and 8071 (9/16/04). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

70. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

Attachment D

Stringency Analysis of District Rule 4311

Comparison of the latest amended version (amended June 18, 2009) of District Rule 4311 and the current SIP approved version, adopted June 20, 2002

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
APPLICABILITY		
This rule is applicable to operations involving the use of flares.	X	X
DEFINITIONS		
Air-Assisted Flare: a combustion device where forced air is injected to promote turbulence for mixing and to provide combustion air.	X	X
Air Pollution Control Officer (APCO): as defined in Rule 1020 (Definitions).		X
Air Resources Board (ARB): as defined in Rule 1020 (Definitions).		X
British Thermal Unit (Btu): the amount of heat required to raise the temperature of one pound of water from 59 ^{o}F to 60 ^{o}F at one atmosphere.		X
Calendar Day: any day starting at twelve o'clock AM and ending at 11:59 PM.		X
Coanda Effect Flare: A flare in which the high pressure flare gas flows along a curved surface nspiriting air into the gas to promote combustion.		X
Emergency: any situation or a condition arising from a sudden and reasonably unforeseeable event beyond the control of the operator. An emergency situation requires immediate corrective action to restore safe operation. A planned flaring event shall not be considered as an emergency.	X	
Emergency: any situation or a condition arising from a sudden and reasonably unforeseeable and unpreventable event beyond the control of the operator. Examples include, but are not limited to, not preventable equipment failure, natural disaster, act of war or terrorism, or external power curtailment, excluding a power curtailment due to an interruptible power service agreement from a utility. A flaring event due to improperly designed equipment, lack of preventative maintenance, careless or improper operation, operator error or willful misconduct does not quality as an emergency. An emergency situation requires immediate corrective action to restore safe operation. A planned flaring event shall not be considered as an emergency.		X
Enclosed Flare: a flare composed of multiple gas burners that are grouped in an enclosure, and are staged to operate at a	X	X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
wide range of flow rates.		
EPA: United States Environmental Protection Agency.		X
Feasible: Capable of being accomplished in a successful manner within a reasonable period of time, taking into account economic, environmental, legal, social, and technological factors.		X
Flare: a direct combustion device in which air and all combustible gases react at the burner with the objective of complete and instantaneous oxidation of the combustible gases. Flares are used either continuously or intermittently and are not equipped with devices for fuel-air mix control or for temperature control.	X	X
Flare Event: any intentional or unintentional combustion of vent gas in a flare. The flare event ends when the flow velocity drops below 0.12 feet per second or when the operator can demonstrate that no more vent gas was combusted based upon the monitoring records of the flare water seal level and/or other parameters as approved by the APCO in the Flare Monitoring and Recording Plan. For a flare event that continues for more than one calendar day, each calendar day or venting of gases shall constitute a separate flare event.		X
Flare Gas: gas burned in a flare.	X	X
Flare Minimization Plan (FMP): a document intended to meet the requirements of Section 6.5 of this Rule.		X
Flare Monitoring System: all flare monitoring and recording equipment used for the determination of flare operating parameters. Flare monitoring and recording equipment includes, but is not limited to, sample systems, transducers, transmitters, data acquisition equipment, data recording equipment, and video monitoring equipment and video recording equipment.		X
Flexigas: a low BTU fuel gas produced by gasifying coke produced in a fluid-bed Coker. Due to the air used in the gasifying process, Flexigas is approximately 50% nitrogen.		X
Gaseous Fuel: any gases used as combustion fuel which include, but are not limited to, any natural, process, synthetic, landfill, sewage digester, or waste gases. Gaseous fuels include produced gas, pilot gas and, when burned, purge gas.	X	X
Major Source: as defined in Rule 2201 (New and Modified Stationary Source Review Rule).	X	
MMBtu: million British thermal units.		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
Non-Assisted Flare: a combustion device without any auxiliary provision for enhancing the mixing of air into its flame. This definition does not include those flares, that by design, provide excess air at the flare tip.	X	X
Nox: any nitrogen oxide compounds	X	X
Open Flare: a vertically or horizontally oriented open pipe flare from which gases are released into the air before combustion is commenced.	X	X
Operator: includes, but not limited to, any person who owns, leases, supervises, or operates a facility.		X
Petroleum Refinery: a facility that processes petroleum, as defined in the Standard Industrial Classification Manual as Industry No. 2911, Petroleum Refining. For the purpose of this rule, all portions of the petroleum refining operation, including those at non-contiguous locations operating flares, shall be considered as one petroleum refinery.		X
Pilot: an auxiliary burner used to ignite the vent gas routed to a flare.		X
Pilot Gas: the gas used to maintain the presence of a flame for ignition of vent gases.		X
Planned Flaring: a flaring operation that constitutes a designed and planned process at a source, and which would have been reasonably foreseen ahead of its actual occurrence, or is scheduled to occur. The operation of a flare for the purpose of performing equipment maintenance provided it does not exceed 200 hours per calendar year, or during compliance source testing or visible emission inspections is not considered planned flaring. Planned flaring includes, but is not limited to, the following flaring activities: Oil or gas well tests, well related work, tests ordered by a regulatory agency. Equipment depressurization for maintenance purposes. Equipment start-up or shutdown. Flaring of gas at production sources where no gas handling, gas injection or gas transmission facilities exists. Flaring of off-specification gas (i.e. non PUC quality gas), unless the operator can demonstrate that the gas must be flared for engineering or safety reasons, e.g., under emergency.	X	
Planned Flaring: a flaring operation that constitutes a		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
designed and planned process at a source, and which would have been reasonably foreseen ahead of its actual occurrence, or is scheduled to occur. Planned flaring includes, but is not limited to, the following flaring activities: Oil or gas well tests, well related work, tests ordered by a regulatory agency. Equipment depressurization for maintenance purposes. Equipment start-up or shutdown. Flaring of gas at production sources where no gas handling, gas injection or gas transmission facilities exists. Flaring of off-specification gas (i.e. non-PUC quality gas), unless the operator can demonstrate that the gas must be flared for engineering or safety reasons, e.g., under emergency. The operation of a flare for the purpose of performing equipment maintenance.		
Prevention Measure: a component, system, procedure, or program that will minimize or eliminate flaring.		X
Public Utilities Commission (PUC) Quality Gas: any gaseous fuel, gas containing fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet and no more than five grains of total sulfur per one hundred (100) standard cubic feet. PUC quality gas shall also mean high methane (at least 80 % by volume) gas as specified in PUC's General Order 58-A.	X	X
Purge Gas: Nitrogen, carbon dioxide, liquefied petroleum gas, or natural gas, any of which can be used to maintain a non-explosive mixture of gases in the flare header or provide sufficient exit velocity to prevent any regressive flame travel back into the flare header.	X	X
Refinery Fuel Gas: a combustible gas, which is a by-product of the refinery process.		X
Reportable Flaring Event: any flaring where more than 500,000 standard cubic feet of vent gas is flared per calendar day, or where sulfur oxide emissions are greater than 500 pounds per calendar day. A reportable flaring event ends when it can be demonstrated by monitoring required in Section 6.8 that the integrity of the water seal has been maintained sufficiently to prevent vent gas to the flare tip. For flares without water seals or water seal monitors as required by Section 6.8, a reportable flaring event ends when the rate of flow of vent gas falls below 0.12 feet per second.		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
Representative Sample: a sample of vent gas collected from the location as approved for flare monitoring and analyzed utilizing test methods specified in Section 6.3.4.		X
Shutdown: the procedure by which the operation of a process unit or piece of equipment is stopped due to the end of a production run, or for the purpose of performing maintenance, repair and replacement of equipment. Stoppage caused by frequent breakdown due to poor maintenance or operator error shall not be deemed a shutdown.		X
Startup: the procedure by which a process unit or piece of equipment achieves normal operational status, as indicated by such parameters as temperature, pressure, feed rate and product quality.		X
Steam-Assisted Flare: a combustion device where steam is injected into the combustion zone to promote turbulence for the mixing of the combustion air before it is introduced to the flame.		X
Thermal oxidizer: an enclosed or partially enclosed combustion device, other than a flare, that is used to oxidize combustible gases.		X
Total Organic Gases (TOG): all hydrocarbon compounds containing hydrogen and carbon with or without other chemical elements.	X	X
Turnaround: a planned activity involving shutdown and startup of one or several process units for the purpose of performing periodic maintenance, repair, replacement of equipment or installation of new equipment.		X
Vent Gas: any gas directed into a flare, excluding assisting air or steam, flare pilot gas, and any continuous purge gases.		X
Volatile Organic Compound (VOC): as defined in Rule 1020 (Definitions).	X	X
Water Seal: a liquid barrier, or seal, to prevent the passage of gas. Water seals provide a positive means of flash-back prevention in addition to enabling the upstream flare system header to operate at a slight positive pressure at all times.		X
EXEMPTIONS		
Flares operated in municipal solid waste landfills subject to the requirements of Rule 4642 (Solid Waste Disposal Sites) are exempt from this rule. Flares that are subject to the requirements of 40 CFR 60 Subpart WWW (Standards of Performance for Municipal	X	X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
Waste Landfills), or Subpart Cc (Emission Guidelines and Compliance Times for Municipal Solid Waste Landfills) are exempt from this rule.		
Except for the recordkeeping requirements in Section 6.1.4 the requirements of this rule shall not apply to any stationary source that has the potential to emit, for all processes, less than ten (10.0) tons per year of VOC and less than ten (10.0) tons per year of Nox.		X
REQUIREMENTS		
The operator of any source subject to this rule shall comply with the following requirements: Flares that are permitted to operate only during an emergency are not subject to the requirements of Sections 5.6 and 5.7. The flame shall be present at all times when combustible gases are vented through the flare. The outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares.	X	X
Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, <u>or an equivalent device</u>, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated.	X	
Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, <u>or an alternative equivalent device</u>, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated.		X
Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging.	X	X
Open flares (air-assisted, steam-assisted, or non-assisted) in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18.	X	
Open flares (air-assisted, steam-assisted, or non-assisted) in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
provisions of 40 CFR 60.18. The requirements of this section shall not apply to Coanda effect flares.		
Ground-level enclosed flares shall meet the following emission standards: Flares without Steam Assist Heat Release Rate: <10 MMBtu VOC limit = 0.0051 (lb/MMBtu) Nox limit = 0.0952 (lb/MMBtu) Heat Release Rate: 10-100 MMBtu VOC limit = 0.0027 (lb/MMBtu) Nox limit = 0.1330 (lb/MMBtu) Heat Release Rate: >100 MMBtu VOC limit = 0.0013 (lb/MMBtu) Nox limit = 0.5240 (lb/MMBtu) Flares with Steam Assist All Heat Release Rates VOC limit = 0.0014 (lb/MMBtu) as TOG Nox limit = 0.068 (lb/MMBtu)	X	X
Flare Minimization Plan Effective on and after July 1, 2011, flaring is prohibited unless it is consistent with an approved flare minimization plan (FMP), pursuant to Section 6.5, and all commitments listed in that plan have been met. This standard shall not apply if the APCO determines that the flaring is caused by an emergency as defined by Section 3.7 and is necessary to prevent an accident, hazard or release of vent gas directly to the atmosphere.		X
Petroleum Refinery SO_2 Performance Targets Effective on and after January 1, 2011, the operator of a petroleum refinery shall minimize sulfur dioxide flare emissions to less than 1.50 tons per million barrels of crude processing capacity, calculated as an average over one calendar year. Effective on and after January 1, 2017, the operator of a petroleum refinery shall minimize sulfur dioxide flare emissions to less than 0.50 tons per million barrels of crude processing capacity, calculated as an average over one calendar year.		X
Effective on and after July 1, 2011, the operator of a flare subject to flare minimization requirements pursuant to Section 5.8 shall monitor the vent gas flow to the flare with a flow measuring device or other parameters as specified in the Permit to Operate. The operator shall maintain records		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
pursuant to Section 6.1.7. Flares that the operator can verify, based on permit conditions, are not capable of producing reportable flare events pursuant to Section 6.2.2 shall not be required to monitor vent gas flow to the flare.		
Effective on and after July 1, 2011, the operator of a petroleum refinery or a flare with a flaring capacity equal to or greater than 50 MMBtu/hr shall monitor the flare pursuant to Sections 6.6, 6.7, 6.8, 6.9, and 6.10.		X
ADMINISTRATIVE REQUIREMENTS		
Compliance Determination Upon request the operator of flares that are subject to Section 5.6 shall make_available to the APCO the compliance determination records that demonstrate compliance with the provisions of 40 CFR 60.18, (c)(3) through (c)(5). The operator of ground-level enclosed flares shall conduct source testing at least once every 12 months to demonstrate compliance with Section 5.7. The operator shall submit a copy of the testing protocol to the APCO at least 30 days in advance of the scheduled testing. The operator shall submit the source test results not later than 45 days after completion of the source testing. For flares used during an emergency, record of the duration of flare operation, amount of gas burned, and the nature of the emergency situation.	X	X
Operators claiming an exemption pursuant to Section 4.3 shall record annual throughput, material usage, or other information necessary to demonstrate an exemption under that section. Effective on and after July 1, 2011, a copy of the approved flare minimization plan pursuant to Section 6.5. Effective on and after July 1, 2012, where applicable, a copy of annual reports submitted to the APCO pursuant to Section 6.2. Effective on and after July 1, 2011, where applicable, monitoring data collected pursuant to Sections 5.10, 6.6, 6.7, 6.8, 6.9, and 6.10.		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
Flare Reporting Unplanned Flaring Event Effective on and after July 1, 2011, the operator of a flare subject to flare minimization plans pursuant to Section 5.8 of this rule shall notify the APCO of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, which ever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. Reportable Flaring Event Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare minimization plans pursuant to Section 5.8 shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. The report shall include, but is not limited to all of the following: The results of an investigation to determine the primary cause and contributing factors of the flaring event; Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and The date, time, and duration of the flaring event.		X
Annual Monitoring Report Effective on and after July 1, 2012, and annually thereafter, the operator of a flare subject to flare monitoring requirements pursuant to Sections 5.10, 6.6, 6.7, 6.8, 6.9, and 6.10, as appropriate, shall submit an annual report to the APCO within 30 days following the end of each 12 month period. The report shall include the following: The total volumetric flow of vent gas in standard cubic feet for each day. Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
Section 6.6. If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month. If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month. For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow. Flare monitoring system downtime periods, including dates and times. For each day and for each month provide calculated sulfur dioxide emissions. A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5.		
<u>Test Methods</u> The test methods listed below shall be used to demonstrate compliance with this rule. Alternate equivalent test methods may be used provided the test methods have been approved by the APCO and EPA. VOC, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case Method 25a may be used, and analysis of halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422 "Determination of Volatile organic Compounds in Emission from Stationary Sources". The VOC concentration in ppmv shall be converted to pounds per million Btu (lb/MMBtu) by using the following equation: VOC in lb/MMBtu = $\frac{(ppmv\ dry)\ x\ (F, dscf / MMBtu)}{(1.135 x 10^6)\ x\ (20.9 - \%O_2)}$ Where: F = As determined by EPA Method 19 NOx emissions in pounds per million BTU shall be determined by using EPA Method 19. NOx and O_2 concentrations shall be determined by using EPA Method 3A, EPA Method 7E, or ARB 100.	X	X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
Testing and Sampling Methods for Flare Monitoring Effective on and after July 1, 2011 operators subject to vent gas composition monitoring requirements pursuant to Section 6.6 shall use the following test methods as appropriate, or by an alternative method approved by the APCO, ARB and EPA: Total hydrocarbon content and methane content of vent gas shall be determined using ASTM Method D 1945-96, ASTM Method UOP 539-97, EPA Method 18, or EPA Method 25A or 25B, Hydrogen sulfide content of vent gas shall be determined using ASTM Method D 1945-96, ASTM Method UOP 539-97, ASTM Method D 4084-94, or ASTM Method D 4810-88. If vent gas composition is monitored with a continuous analyzer employing gas chromatography the minimum sampling frequency shall be one sample every 30 minutes. If vent gas composition is monitored using continuous analyzers not employing gas chromatography, the total reduced sulfur content of vent gas shall be determined by using EPA Method D4468-85.		X
Flow Verification Test Methods For purposes of the flow verification report required by Section 6.2.3.8, vent gas flow shall be determined using one or more of the following methods, or by any alternative method approved by the APCO, ARB, and EPA: EPA Methods 1 and 2; A verification method recommended by the manufacturer of the flow monitoring equipment installed pursuant to Section 5.10. Tracer gas dilution or velocity. Other flow monitors or process monitors that can provide comparison data on a vent stream that is being directed past the ultrasonic flow meter.		X
<u>Flare Minimization Plan</u> By July 1, 2010, the operator of a petroleum refinery flare or any flare that has a flaring capacity of greater than or equal to 5.0 MMBtu per hour shall submit a flare minimization plan (FMP) to the APCO for approval. The FMP shall include, but not be limited to:		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
A description and technical specifications for each flare and associated knock-out pots, surge drums, water seals and flare gas recovery systems.		
Detailed process flow diagrams of all upstream equipment and process units venting to each flare, identifying the type and location of all control equipment.		
A description of equipment, processes, or procedures the operator plans to install or implement to eliminate or minimize flaring and planned date of installation or implementation.		
An evaluation of prevention measures to reduce flaring that has occurred or may be expected to occur during planned major maintenance activities, including startup and shutdown.		
An evaluation of preventative measures to reduce flaring that may be expected to occur due to issues of gas quantity and quality. The evaluation shall include an audit of the vent gas recovery capacity of each flare system, the storage capacity available for excess vent gases, and the scrubbing capacity available for vent gases including any limitations associated with scrubbing vent gases for use as a fuel; and shall determine the feasibility of reducing flaring though the recovery, treatment and use of the gas or other means.		
An evaluation of preventative measures to reduce flaring caused by the recurrent failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. The evaluation shall determine the adequacy of existing maintenance schedules and protocols for such equipment. For purposes of this section, a failure is recurrent if it occurs more than twice during any five year period as a result of the same cause as identified in accordance with Section 6.2.2.		
Any other information requested by the APCO as necessary for determination of compliance with applicable provisions of this rule.		
Every five years after the initial FMP submittal, the operator shall submit an updated FMP for each flare to the APCO for approval. The current FMP shall remain in effect until the updated FMP is approved by the APCO. If the operator fails to submit an updated FMP as required by this section, the existing FMP shall no longer be considered an approved plan.		
An updated FMP shall be submitted by the operator pursuant to Section 6.5 addressing new or modified equipment, prior to installing the equipment. Updated		

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
FMP submittals are only required if: The equipment change would require an authority to construct (ATC) and would impact the emissions from the flare, and The ATC is deemed complete after June 18, 2009, and The modification is not solely the removal or decommissioning of equipment that is listed in the FMP, and has no associated increase in flare emissions. When submitting the initial FMP, or updated FMP, the operator shall designate as confidential any information claimed to be exempt from public disclosure under the California Public Records Act, Government Code Section 6250 et seq. If a document is submitted that contains information designated confidential, the operator shall provide a justification for this designation and shall submit a separate copy of the document with the information designated confidential redacted.		
<u>Vent Gas Composition Monitoring</u> Effective on and after July 1, 2011, the operator of a petroleum refinery flare or any flare that has a flaring capacity equal to or greater than 50 MMBtu per hour shall monitor vent gas composition using one of the five methods pursuant to Section 6.6.1 through Section 6.6.5 as appropriate. Sampling that meets the following requirements: If the flow rate of vent gas flared in any consecutive 15-minute period continuously exceeds 330 standard cubic feet per minute (SCFM), a sample shall be taken within 15 minutes. The sampling frequency thereafter shall be one sample every three hours and shall continue until the flow rate of vent gas flared in any consecutive 15-minute period is continuously 330 SCFM or less. In no case shall a sample be required more frequently than once every 3 hours. Samples shall be analyzed pursuant to Section 6.3.4. Integrated sampling that meets the following requirements: If the flow rate of vent gas flared in any consecutive 15 minute period continuously exceeds 330 SCFM, integrated sampling shall begin within 15 minutes and shall continue until the flow rate of vent gas flared in any consecutive 15 minute period is continuously 330 SCFM or less. Integrated sampling shall consist of a minimum of one aliquot for each 15-minute period until the sample		X

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
container is full. If sampling is still required pursuant to Section 6.6.2.1, a new sample container shall be placed in service within one hour after the previous sample was filled. A sample container shall not be used for a sampling period that exceeds 24 hours. Samples shall be analyzed pursuant to Section 6.3.4. Continuous analyzers that meet the following requirements: The analyzers shall continuously monitor for total hydrocarbon methane, and depending upon the analytical method used pursuant to Section 6.3.4, hydrogen sulfide or total reduced sulfur. The hydrocarbon analyzer shall have a full-scale range of 100% total hydrocarbon. Each analyzer shall be maintained to be accurate to within 20% when compared to any field accuracy tests or to within 5% of full scale. Continuous analyzers employing gas chromatography that meet the following requirements: The gas chromatography system shall monitor for total hydrocarbon, methane, and hydrogen sulfide. The gas chromatography system shall be maintained to be accurate within 5% of full scale. Monitor sulfur content using a colorimetric tube system on a daily basis, and monitor vent gas hydrocarbon on a weekly basis by collecting samples and having them tested pursuant to a method in Section 6.3.4. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Section 5.11. <u>Pilot and Purge Gas Monitoring</u> Effective on and after July 1, 2011, the operator of a petroleum refinery flare or any flare that has a flaring capacity equal to or greater than 50 MMBtu per hour shall monitor the volumetric flows of purge and pilot gases with flow measuring devices or other parameters as specified on the Permit to Operate so that volumetric flows of pilot and purge gas may be calculated based on pilot design and the parameters monitored. <u>Water Seal Monitoring</u> Effective on and after July 1, 2011, the operator of a		

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
petroleum refinery flare or any flare that has a flaring capacity equal to or greater than 50 MMBtu per hour with a water seal shall monitor and record the water level and pressure of the water seal that services each flare daily or as specified on the Permit to Operate. <u>General Monitoring</u> Effective on and after July 1, 2011, the operator of a petroleum refinery flare or any flare that has a flaring capacity equal to or greater than 50 MMBtu per hour shall comply with the following, as applicable: Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. Maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. <u>Video Monitoring</u> Effective on and after July 1, 2011, the operator of a petroleum refinery flare shall install and maintain equipment that records a real-time digital image of the flare and flame at a frame rate of no less than one frame per minute. The recorded image of the flare shall be of sufficient size, contrast,		

District Rule 4311 Requirements	Adopted June 20, 2002	Amended June 18, 2009
and resolution to be readily apparent in the overall image or frame. The image shall include an embedded date and time stamp. The equipment shall archive the images for each 24-hour period. In lieu of video monitoring the operator may use an alternative monitoring method that provides data to verify date, time, vent gas flow, and duration of flaring events.		