



**FACILITY PERMIT TO OPERATE
CONOCOPHILLIPS COMPANY**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 13 : STORAGE TANKS					P13.1, P13.2
System 8 : DOME COVERED EXTERNAL FLOATING ROOF TANKS					S13.8
STORAGE TANK, DOMED EXTERNAL FLOATING ROOF, NO. 349, RECOVERED OIL, 20000 BBL, DIAMETER: 60 FT, HEIGHT: 40 FT 6 IN WITH A/N : 499914 DOME COVER, GEODESIC FLOATING ROOF, PONTOON, WELDED SHELL PRIMARY SEAL, CATEGORY A, MECHANICAL SHOE SECONDARY SEAL, CATEGORY B OR BETTER, WIPER TYPE GUIDEPOLE, GASKETED SLIDING COVER, WITH WIPER, UNSLOTTED	D610			BENZENE: (10) [40CFR 61 SUBPART FF_01, 12-4-2003]; HAP: (10) [40CFR 63 SUBPART CC, #3A, 6-23-2003]	B22.xx, C1.xx, H23.9, K67.11, K171.x

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limits (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE CONOCOPHILLIPS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

F14.1 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

This condition shall become effective on or after June 1, 2004.

[RULE 431.2, 5-4-1990; RULE 431.2, 9-15-2000]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive Officer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).

b). The operator shall submit any additional relevant information requested by the Executive Officer or designated agency.

[40CFR 68 – Accidental Release Prevention, 5-24-1996]



FACILITY PERMIT TO OPERATE CONOCOPHILLIPS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- F25.1 The permit holder of this facility shall not install, alter, or operate a refinery process unit or other non-Rule 219 exempt equipment without a valid RECLAIM/TitleV permit issued by the AQMD pursuant to Rule 201 - Permit to Construct, Rule 203 - Permit to Operate, Rule 2004 - Requirements, and Rule 3002 - Requirements, as applicable.

Notwithstanding the above, the provisions of Rules 201, 203, 2004, and 3002 shall not apply to installations or alterations that involve only the equipment listed in Table 1 below, nor shall they apply to the operation of equipment listed in Table 1, when directly associated with permitted process units or other permitted equipment.

Notwithstanding the above, all new equipment listed in Table 1, including associated fugitive components installed with such equipment, shall have Best Available Control Technology installed in conformance with the Best Available Control Technology Guidelines in effect at the time of the installation.

TABLE 1

- (a) Heat Exchanger (including air-cooler, reboiler, cooler, condenser, and shell and tube exchanger)
- (b) In-line Mixer
- (c) Pump
- (d) Knockout Pot - Compressor inlet (immediate inlet) and interstage
- (e) Knockout Pot - Fuel Gas System (downstream of fuel gas mix drums)

This condition applies only to the facility that processes petroleum as defined in the Standard Industrial Classification Manual as Industry No. 2911 - Petroleum Refining, as well as its directly associated sulfur recovery plant which may be located outside of the facility.

[RULE 2004, 5-11-2001; RULE 2004, 4-6-2007]

- F34.2 The operator shall not sell refinery gas containing sulfur compounds in excess of 40 ppmv, calculated as hydrogen sulfide, averaged over 4-hour period.

[RULE 431.1, 6-12-1998]

**FACILITY PERMIT TO OPERATE
CONOCOPHILLIPS COMPANY**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

F52.1 This facility is subject to the applicable requirements of the following rules or regulation(s):

40CFR79
40CFR80
California Code of Regulations, Title 13, Division 3, Chapter 5

[40CFR 79, 7-1-1999; 40CFR 80, 7-1-1999; CCR Title 13, 9-24-1999]

F52.2 This facility is subject to the applicable requirements of the following rules or regulation(s):

CONSENT DECREE CIVIL NO. H-05-0258. The facility shall send the District a copy of the semiannual updates sent to the EPA of the specific requirement of emission standards and limitations from the Consent Decree as well as dates of compliance for the requirement not yet fulfilled.

[CONSENT DECREE CIVIL NO. H-05-0258, 8-11-2008]

F52.3 This facility is subject to the applicable requirements of the following rules or regulation(s):

40 CFR 60 SubpartA
40 CFR 61 SubpartA
40 CFR 63 SubpartA

[40CFR 60 Subpart A, 5-16-2007; 40CFR 61 Subpart A, 5-16-2007; 40CFR 63 Subpart A, 5-16-2007]

F60.1 The emission limits identified in Section D and H of the permit shall be defined as emissions discharged to the atmosphere from the originating equipment.



**FACILITY PERMIT TO OPERATE
CONOCOPHILLIPS COMPANY**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

PROCESS CONDITIONS

P13.1 All devices under this process are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	463

[Rule 463, 5-6-2005]

[Processes subject to this condition : 13]

P13.2 All devices under this process are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
HAPs	40CFR61, SUBPART	FF

[40CFR 61 Subpart FF, 12-4-2003]

[Processes subject to this condition : 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 18]

FACILITY PERMIT TO OPERATE CONOCOPHILLIPS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

SYSTEM CONDITIONS

S13.8 All devices under this system are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	463
VOC	District Rule	1178
VOC	District Rule	1149

For Rule 463 applicability, only subdivision (d) in the March 11, 1994 amendment, or equivalent requirements in the future amendments, shall apply to domed external floating roof tanks. This does not preclude any requirements specified in Rule 1178.

[RULE 1149, 7-14-1995; RULE 1149, 5-2-2008; RULE 1178, 4-7-2006; RULE 463, 5-6-2005]

[Systems subject to this condition : Process 13, System 3, 8]

DEVICE CONDITIONS

B. Material/FuelType Limits

B22.xx The operator shall not use this equipment with materials having a(n) true vapor pressure of 8.82 psia or greater under actual operating conditions.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D610]



FACILITY PERMIT TO OPERATE CONOCOPHILLIPS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C. Throughput or Operating Parameter Limits

C1.xx The operator shall limit the throughput to no more than 30,000 barrel(s) in any one calendar month.

The operator shall comply with the following throughput measurement practices.

The operator shall calculate the throughput, in barrels, by the following equation: $0.14 \times D \times D \times L$, where D is the diameter of the tank in feet based on the tank strapping chart and L is the total vertical one-way roof travel in feet per month.

The operator shall install and maintain an automatic tank level gauge (ATLG) and recorder to continuously record the vertical movement of the roof. For the purpose of this condition, continuous recording is defined as once per hour.

The operator shall calculate the total one-way roof movement, in feet, on a daily and monthly basis.

The ATLG installed shall be verified once per quarter by comparing against a manual tank level measurement. If the ATLG differs from the manual tank level measurement by more than 1.0 inch or 0.8 %, whichever is greater, the ATLG shall be repaired and put back into service within 10 days. While the ATLG is being repaired, the throughput shall be determined by the hourly tank level data averaged from the previous 30 days prior to the discovery of the discrepancy.

In the event of a failure or routine maintenance of the ATLG, the ATLG shall be repaired (if necessary) and put back into service within 10 days of the time that the ATLG failed or was removed from service for maintenance. While the ATLG is being repaired or maintained, the throughput shall be determined by the hourly tank level data averaged from the previous 30 days prior to time that the ATLG went out of service.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D610]



FACILITY PERMIT TO OPERATE CONOCOPHILLIPS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H. Applicable Rules

H23.9 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	40CFR60, SUBPART	Kb
Benzene	40CFR61, SUBPART	FF

[40CFR 60 Subpart Kb, 10-15-2003; 40CFR 61 Subpart FF, 12-4-2003]

[Devices subject to this condition : D546, D549, D555, D556, D602, D610, D612, D630, D633]

K. Recordkeeping/Reporting

K67.11 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Tank throughput in barrels

Commodity stored and its time period.

True vapor pressure, in psia at actual storage temperature, of each commodity stored.

Hydrocarbon concentration measurements of the vapor space above the floating roof of the tank.

Other records that are required to comply with the applicable requirements of Rule 463(d), 1149, 1178, and 40CFR63 Subpart CC.

[RULE 1149, 7-14-1995; RULE 1149, 5-2-2008; RULE 1178, 4-7-2006; RULE 1301, 12-7-1995; RULE, 463, 5-6-2005; 40CFR 63 Subpart CC, 6-23-2003]

[Devices subject to this condition : D549, D555, D610]



**FACILITY PERMIT TO OPERATE
CONOCOPHILLIPS COMPANY**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K171.x The operator shall provide to the District, the following item(s):

Final drawings and/or specifications of the geodesic dome cover, slotted/unslotted guidepole, wiper and other tank appurtenances upgrades to be installed/constructed shall be submitted to the district within 60 days after construction.

[RULE 1178, 4-7-2006]

[Devices subject to this condition : D549, D555, D610]