

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Title V Permit Summary

AQMD Facility ID:	139010	Company Name:	RIPON COGENERATION LLC
Equipment Location:	1507 Mount Vernon Ave., Pomona, Ca 91768		SIC Code: 4911
Permit Revision #:	Revision Date:	Facility Permit Section(s) Affected: ALL	
Application #(s):	436152	Application Submittal Date(s):	10/26/2004
AQMD Contact Person:	Tracy Nguyen	Phone #:	(909) 396-2427
		E-Mail Address:	tnguyen1@aqmd.gov
Project Description: This is an existing facility, applying for a renewal to their Title V permit. This facility is in the business of providing electricity and steam to other facility. This facility is operating a cogeneration system and other supporting equipment. The NOx and CO emissions from the cogeneration system are controlled by a selective catalytic reduction (SCR) system.			
Permit Type: <input type="checkbox"/> Initial Title V Permit <input type="checkbox"/> Significant Revision <input checked="" type="checkbox"/> Permit Renewal			
Permit Features: <input type="checkbox"/> Federally Enforceable Emission Cap For Exemption From Certain NESHAP Requirements <input type="checkbox"/> Permit Shield Applies <input type="checkbox"/> Permit Contains Conditions Allowing Emission Trading <input type="checkbox"/> Alternative Operating Scenario <input type="checkbox"/> Permit Streamlines Overlapping or Outdated Requirements <input type="checkbox"/> Other: _____ <input type="checkbox"/> Source Out of Compliance With Applicable Requirements and/or Operating Under a Variance			
Toxic Air Contaminant Emissions (TAC) - Annual Reported Emissions for Reporting Year: 2006-2007		<input type="checkbox"/> No TACs Reported <input checked="" type="checkbox"/> The Following TACs Were Reported:	
		1,3-BUTADIENE AMMONIA BENZENE FORMALDEHYDE NAPHTALENE PAHS	Emissions (lbs/yr): 0.018 4466.578 0.509 30.234 0.055 0.038
Health Risk From Toxic Air Contaminants: <input type="checkbox"/> Health Risk Assessment Required for this Permit Action (AQMD Rule 1401) <input type="checkbox"/> Health Risk Reduction Plan Approved (AQMD Rule 1402) (Year): _____ <input checked="" type="checkbox"/> Facility is Subject to Review by the Air Toxics Information and Assessment Act (AB2588) <input type="checkbox"/> Facility Determined to be Exempt from AB2588 Requirements <input checked="" type="checkbox"/> AQMD is Tracking Status of Facility under AB2588 <input type="checkbox"/> Health Risk Assessment Submittal Pending <input type="checkbox"/> Health Risk Assessment Submitted to AQMD and Is Being Reviewed <input type="checkbox"/> Final Facility Health Risk Approved (date) _____ Cancer Risk = <u>in one million</u> Acute Hazard Index = _____ Chronic Hazard Index = _____			
Criteria Pollutant Emissions Annual Reported Emissions (tons/year) for Reporting Year: 2006-2007		<input checked="" type="checkbox"/> NOx <u>17.5</u> <input checked="" type="checkbox"/> PM <u><0.001</u> <input checked="" type="checkbox"/> CO <u>45.047</u> <input checked="" type="checkbox"/> SOx <u>0.544</u> <input checked="" type="checkbox"/> VOC <u>10.015</u> <input type="checkbox"/> Other: _____	
Compliance History: <input checked="" type="checkbox"/> Citizen Complaints Filed in Last Two Calendar Years (# 0) <input checked="" type="checkbox"/> Notices to Comply Issued in Last Two Calendar Years (# 0) <input checked="" type="checkbox"/> Notices of Violation Issued in Last Two Calendar Years (# 0)			
Comments:			