

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT ENGINEERING AND COMPLIANCE DIVISION PERMIT APPLICATION EVALUATION AND CALCULATIONS	PAGES 1	PAGE 1
	APPL NO 503281	DATE 1/29/2010
	PROCESSED BY GCR	CHECKED BY

TITLE V PERMIT (REV 02) EVALUATION (Significant Rev.)

Applicant's Name: OC WASTE & RECYCLING (OCWR), PRIMA DESHECHA

Mailing Address: 300 N. Flower Street, Suite 400
Santa Ana, CA 92703-5000

Equipment Location: 32250 La Pata Avenue (Prima Deshecha Landfill)
San Juan Capistrano, CA 92675

Facility ID NO.: 52753

Background:

This application 503281 was submitted for Title V permit revision (No. 2) on 10/27/2009.
Title V permit revision (No. 1) was issued 10/28/2008 (A/N 456597).

This proposed revision includes the following equipment and their respective evaluations are included here.

PERMITS TO CONSTRUCT AND PERMITS TO OPERATE:

<u>Appl. No.</u>	<u>Description</u>
497358	Fuel storage & dispensing gasoline equipment
503282	Installation of an emergency IC engine for power generation.

PERMITS TO CONSTRUCT:

<u>Appl. No.</u>	<u>Description</u>
492235	Alteration/Modification to the LFG collection system, F38717 (A/N 384568)
499317	Alteration/Modification to the Landfill Condensate and LCRS Collection and Storage System, F38427 (A/N 456274)

This revision is considered a Significant Permit Revision as installation of new emergency IC engine is subject to NSPS pursuant to 40 CFR Part 60, subpart IIII and subject to 40 CFR Part 63 subpart ZZZZ (NESHAP). Emissions increase from emergency IC engine is below daily maximum threshold (lb/day), under Title V. Public notice is required for significant permit revision and is also subject to EPA 45-day review and comment period. For further information, please refer to the emergency ICE evaluation included in folder.

Rules Evaluation:

Compliance with applicable rules and Reg. XXX -Title V permits is expected.

Conclusions & Recommendations:

Issue the revised Title V permit (Revision 02) upon completion of public notice issuance and 45-day EPA review and commenting period.