



OCT 28 2009

Mr. John Gruber
Chevron USA, Inc
PO Box 1392
Bakersfield, CA 93302

**Re: Notice of Preliminary Decision - ATC / Certificate of Conformity
Facility # S-1128
Project # S-1093660**

Dear Mr. Gruber:

Enclosed for your review and comment is the District's analysis of an application for Authorities to Construct for Chevron USA, Inc within the Cymric Oilfield, CA. Chevron proposes to modify the steam generators by replacing fuel/air train components, limiting fuel sulfur content, or designating the units as dormant for Rule 4320 compliance

After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the Authorities to Construct will be issued to the facility with Certificates of Conformity. Prior to operating with modifications authorized by the Authorities to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

The public notice will be published approximately three days from the date of this letter. Please submit your written comments within the 30-day public comment period which begins on the date of publication of the public notice.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,

David Warner
Director of Permit Services

DW:KR/ls

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



OCT 28 2009

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St.
San Francisco, CA 94105

**Re: Notice of Preliminary Decision - ATC / Certificate of Conformity
Facility # S-1128
Project # S-1093660**

Dear Mr. Rios:

Enclosed for your review is the District's engineering evaluation of an application for Authorities to Construct for Chevron USA, Inc within the Cymric Oilfield, CA, which has been issued a Title V permit. Chevron USA, Inc is requesting that Certificates of Conformity, with the procedural requirements of 40 CFR Part 70, be issued with this project. Chevron proposes to modify the steam generators by replacing fuel/air train components, limiting fuel sulfur content, or designating the units as dormant for Rule 4320 compliance

Enclosed is the engineering evaluation of this application, along with the current Title V permit, and proposed Authorities to Construct # ATC S-1128-3-36, '-4-30, '-4-31, '-4-32, '-5-31, '-5-32, '-5-33, '-21-34, '-21-35, '-21-36, '-24-35, '-25-40, '-25-41, '-25-42, '-27-28, '-27-29, '-27-30, '-28-27, '-28-28, '-28-29, '-35-34, '-35-35, '-35-36, '-38-28, '-38-29, '-38-30, '-64-18, '-65-17, '-66-24, '-66-25, '-66-26, '-68-16, '-68-17, '-68-18, '-75-21, '-75-22, '-75-23, '-76-20, '-76-21, '-76-22, '-77-20, '-77-21, '-77-22, '-79-16, '-79-17, '-79-18, '-80-18, '-80-19, '-80-20, '-84-18, '-111-18, '-111-19, '-111-20, '-112-19, '-112-20, '-112-21, '-113-19, '-113-20, '-113-21, '-154-27, '-154-28, '-154-29, '-159-19, '-159-20, '-159-21, '-396-10, '-941-6, '-941-7, '-941-8 with Certificates of Conformity. After demonstrating compliance with the Authority to Construct, the conditions will be incorporated into the facility's Title V permit through an administrative amendment.

Please submit your written comments on this project within the 45-day comment period that begins on the date you receive this letter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Mr. Gerardo C. Rios
Page 2

Thank you for your cooperation in this matter.

Sincerely,

A handwritten signature in black ink, appearing to read 'David Warner', with a long horizontal flourish extending to the right.

David Warner
Director of Permit Services

DW:KR/ls

Enclosures



OCT 28 2009

Mike Tollstrup, Chief
Project Assessment Branch
Air Resources Board
P O Box 2815
Sacramento, CA 95812-2815

Re: **Notice of Preliminary Decision - ATC / Certificate of Conformity**
Facility # S-1128
Project # S-1093660

Dear Mr. Tollstrup:

Enclosed for your review and comment is the District's analysis of an application for Authorities to Construct for Chevron USA, Inc within the Cymric Oilfield, CA. Chevron proposes to modify the steam generators by replacing fuel/air train components, limiting fuel sulfur content, or designating the units as dormant for Rule 4320 compliance

The public notice will be published approximately three days from the date of this letter. Please submit your written comments within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,



David Warner
Director of Permit Services

DW:KR/ls

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Bakersfield Californian

**NOTICE OF PRELIMINARY DECISION
FOR THE PROPOSED ISSUANCE OF
AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed issuance of Authority To Construct to Chevron USA, Inc for its Heavy Oil Western Stationary Source within the Cymric Oilfield, California. Chevron proposes to modify the steam generators by replacing fuel/air train components, limiting fuel sulfur content, or designating the units as dormant for Rule 4320 compliance

The analysis of the regulatory basis for these proposed actions, Project #S-1093660, is available for public inspection at the District office at the address below. Written comments on the proposed initial permit must be submitted within 30 days of the publication date of this notice to **DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CA 93726-0244.**

San Joaquin Valley Air Pollution Control District Authority to Construct

Modify Gas-Fired Steam Generators for Rule 4320 Compliance

Facility Name: Chevron USA, Inc. Date: August 31, 2009
Mailing Address: P.O. Box 1392 Engineer: Kris Rickards
Bakersfield, CA 93302 Lead Engineer: Allan Phillips *AP SUPR AOE*
Contact Person: John Gruber OCT 26 2009
Telephone: 661-654-7038
Fax: 661-654-7606

Application #(s): S-1128-3-36, '-4-30, '-4-31, '-4-32, '-5-31, '-5-32, '-5-33, '-21-34, '-21-35, '-21-36, '-24-35, '-25-40, '-25-41, '-25-42, '-27-28, '-27-29, '-27-30, '-28-27, '-28-28, '-28-29, '-35-34, '-35-35, '-35-36, '-38-28, '-38-29, '-38-30, '-64-18, '-65-17, '-66-24, '-66-25, '-66-26, '-68-16, '-68-17, '-68-18, '-75-21, '-75-22, '-75-23, '-76-20, '-76-21, '-76-22, '-77-20, '-77-21, '-77-22, '-79-16, '-79-17, '-79-18, '-80-18, '-80-19, '-80-20, '-84-18, '-111-18, '-111-19, '-111-20, '-112-19, '-112-20, '-112-21, '-113-19, '-113-20, '-113-21, '-154-27, '-154-28, '-154-29, '-159-19, '-159-20, '-159-21, '-396-10, '-941-6, '-941-7, '-941-8

Project #: S-1093660

Deemed Complete: August 19, 2009

I. PROPOSAL

Chevron USA, Inc. (CUSA) is requesting Authorities to Construct (ATCs) for the modification of 27 natural-gas-fired steam generators located within the heavy oil western stationary source. In order to comply with District Rule 4320 requirements, the applicant proposes the following scenarios for the steam generators:

- Reduce the NO_x limit to 7 or 9 ppmv (regular or staged schedule) for units firing on >50% PUC gas (Table 1.C.2 options a and b)
- Reduce the NO_x limit to 12 ppmv for units firing on <50% PUC gas (Table 1.C.3)
- Limit SO_x to either PUC-quality or 5 gr-S/100 dscf (Section 5.4.1.1 or 5.4.1.2)
- Designate the units non-compliant dormant

CUSA has also requested modifications to allow for the replacement of several air and fuel train components to meet the lower NO_x limits (FGR piping and control valve, blower, intake control valve, orifice plate, etc.) required by Rule 4320.

Additionally CUSA intends to comply with the NO_x requirements of Rule 4320 by paying annual emission fees as allowed in Rule 4320 section 5.1.2. The proposed ATCs are solely an optional form of compliance.

There will not be an increase in potential emissions of any pollutant as a result of this project. Modification of the NO_x emission limits, limiting the sulfur, and replacing or modifying the air fuel train components are proposed solely to comply with District Rule 4320 requirements. Since there is a change to the method of operation of the steam generators these changes are modifications pursuant to District Rule 2201, *New and Modified Stationary Source Review Rule*.

In addition, the facility currently follows Alternate Monitoring Scheme "A" using a portable analyzer, according to District Policy SSP-1105, and is requesting to maintain the current monitoring arrangement.

Chevron USA, Inc. received their Title V Permit on April 3, 2001. This modification can be classified as a Title V minor modification pursuant to Rule 2520, Section 3.20, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. Chevron USA, Inc. must apply to administratively amend their Title V Operating Permit to include the requirements of the ATC(s) issued with this project.

There are no unimplemented ATCs for any units in this project (the two ATCs used as base documents have been implemented).

II. APPLICABLE RULES

- Rule 2201 New and Modified Stationary Source Review Rule (9/21/06)
- Rule 2520 Federally Mandated Operating Permits (6/21/01)
- Rule 4001 New Source Performance Standards (4/14/99)
- Rule 4101 Visible Emissions (2/17/05)
- Rule 4102 Nuisance (12/17/92)
- Rule 4201 Particulate Matter Concentration (12/17/92)
- Rule 4301 Fuel Burning Equipment (12/17/92)
- Rule 4304 Equipment Tuning Procedure for Boilers, Steam Generators and Process Heaters (10/19/95)
- Rule 4305 Boilers, Steam Generators and Process Heaters – Phase II (8/21/03)
- Rule 4306 Boilers, Steam Generators and Process Heaters – Phase III (10/16/08)
- Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr (10/16/08)
- Rule 4405 Oxides Of Nitrogen Emissions From Existing Steam Generators Used In Thermally Enhanced Oil Recovery -Central And Western Kern County Fields (12/17/92)
- Rule 4406 Sulfur Compounds From Oil-Field Steam Generators – Kern County (12/17/92)
- Rule 4801 Sulfur Compounds (12/17/92)
- CH&SC 41700 Health Risk Assessment
- CH&SC 42301.6 School Notice
- Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)
- California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines

III. PROJECT LOCATION

These steam generators are located at the Cymric Oilfield within CUSA's Heavy Oil Western Source. The equipment will not be located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. PROCESS DESCRIPTION

Chevron operates permitted equipment within their Heavy Oil Western stationary source, utilized for the thermally enhanced production of crude oil and natural gas. In thermally enhanced oil recovery (TEOR), natural gas is combusted in steam generators to produce steam for injection into heavy crude oil bearing strata via injection wells to reduce viscosity of the crude oil, thereby facilitating thermally enhanced oil production.

V. EQUIPMENT LISTING

Pre-Project Equipment Description:

See Appendix A.

Proposed Modification:

For steam generators firing exclusively on PUC quality natural gas:

Unit	Proposed modification
S-1128-4-30, '5-31, '21-34, '27-28, '28-27, '35-34, '66-24, '68-16, '75-21, '76-20, '77-20, '79-16, '80-18, '111-18, '112-19, '113-19, '154-27, '159-19, '941-6	LOWER NOX LIMIT TO 7 PPMV FOR RULE 4320 COMPLIANCE, UPGRADE/REPLACE FGR PIPING AND CONTROL VALVE, REPLACE/RETAIN BLOWER, ADD/RETAIN AIR INTAKE CONTROL VALVE OR ORIFICE PLATE RESTRICTOR, AND UPGRADE/REPLACE FUEL TRAIN COMPONENTS AS NECESSARY.
S-1128-4-31, '5-32, '21-35, '27-29, '28-28, '35-35, '66-25, '68-17, '75-22, '76-21, '77-21, '79-17, '80-19, '111-19, '112-20, '113-20, '154-28, '159-20, '941-7	LOWER NOX LIMIT TO 9 PPMV FOR RULE 4320 COMPLIANCE, UPGRADE/REPLACE FGR PIPING AND CONTROL VALVE, REPLACE/RETAIN BLOWER, ADD/RETAIN AIR INTAKE CONTROL VALVE OR ORIFICE PLATE RESTRICTOR, AND UPGRADE/REPLACE FUEL TRAIN COMPONENTS AS NECESSARY.
S-1128-4-32, '5-33, '21-36, '27-30, '28-29, '35-36, '66-26, '68-18, '75-23, '76-22, '77-22, '79-18, '80-20, '111-20, '112-21, '113-21, '154-29, '159-21, '941-8	LIMIT FUEL GAS SULFUR CONTENT FOR RULE 4320 COMPLIANCE

For steam generators being designated non-compliant dormant:

Unit	Proposed modification
S-1128-3-36, '-24-35, '-64-18, '-65-17, '-84-18, '-396-10	DESIGNATE AS NON-COMPLIANT DORMANT FOR COMPLIANCE WITH RULE 4320.

For steam generators firing on PUC and Non-PUC gas:

Unit	Proposed modification
S-1128-25-40, '-38-28	LOWER NOX LIMIT TO 7 PPMV AT >50% PUC GAS AND 12 PPMV AT <50% PUC GAS FOR STANDARD SCHEDULE AND LIMIT FUEL GAS SULFUR CONTENT TO 5 GR-S/100 SCF FOR RULE 4320 COMPLIANCE, UPGRADE/REPLACE FGR PIPING AND CONTROL VALVE, RELACE/RETAIN BLOWER, ADD/RETAIN AIR INTAKE CONTROL VALVE OR ORIFICE PLATE RESTRICTOR, AND UPGRADE/REPLACE FUEL TRAIN COMPONENTS AS NECESSARY.
S-1128-25-41, '-38-29	LOWER NOX LIMIT TO 9 PPMV AT >50% PUC GAS AND 12 PPMV AT <50% PUC GAS FOR STANDARD SCHEDULE AND LIMIT FUEL GAS SULFUR CONTENT TO 5 GR-S/100 SCF FOR RULE 4320 COMPLIANCE, UPGRADE/REPLACE FGR PIPING AND CONTROL VALVE, RELACE/RETAIN BLOWER, ADD/RETAIN AIR INTAKE CONTROL VALVE OR ORIFICE PLATE RESTRICTOR, AND UPGRADE/REPLACE FUEL TRAIN COMPONENTS AS NECESSARY.
S-1128-25-42, '-38-30	LIMIT FUEL GAS SULFUR CONTENT TO 5 GR-S/100 SCF FOR RULE 4320 COMPLIANCE

Post Project Equipment Description:

PTO S-1128-XX-XX: [DORMANT OR BLANK] [BASE DOCUMENT EQUIPMENT DESCRIPTION]

VI. EMISSION CONTROL TECHNOLOGY EVALUATION

Ultra Low-NO_x burners reduce NO_x formation by producing lower flame temperatures (and longer flames) than conventional burners. Conventional burners thoroughly mix all the fuel and air in a single stage just prior to combustion, whereas low-NO_x burners delay the mixing of fuel and air by introducing the fuel (or sometimes the air) in multiple stages. Generally, in the first combustion stage, the air-fuel mixture is fuel rich. In a fuel rich environment, all the oxygen will be consumed in reactions with the fuel, leaving no excess oxygen available to react with nitrogen to produce thermal NO_x. In the secondary and tertiary stages, the combustion zone is maintained in a fuel-lean environment. The excess air in these stages helps to reduce the flame temperature so that the reaction between the excess oxygen with nitrogen is minimized.

The use of flue gas re-circulation (FGR) can reduce nitrogen oxides (NO_x) emissions by 60% to 70%. In an FGR system, a portion of the flue gas is re-circulated back to the inlet air. As

flue gas is composed mainly of nitrogen and the products of combustion, it is much lower in oxygen than the inlet air and contains virtually no combustible hydrocarbons to burn. Thus, flue gas is practically inert. The addition of an inert mass of gas to the combustion reaction serves to absorb heat without producing heat, thereby lowering the flame temperature. Since thermal NO_x is formed by high flame temperatures, the lower flame temperatures produced by FGR serve to reduce thermal NO_x.

CUSA is proposing to comply with Rule 4320 Table 1, Category C.2 and C.3 for NO_x (several configurations allowed by the rule) and limiting the fuel sulfur content per section 5.4.1.1 and 5.4.1.2 to either PUC quality or 5 gr-S/100 dscf respectively.

VII. GENERAL CALCULATIONS

A. Assumptions

- The maximum operating schedule is 24 hours per day
- The units are fired on natural gas.
- Natural Gas Heating Value: 1,000 Btu/scf (APR-1720)
- F-Factor for Natural Gas: 8,578 dscf/MMBtu corrected to 60°F (40 CFR 60, Appendix B)
- During start-up and shutdown periods the steam generators will have NO_x emissions of no greater than 0.1 lb/MMBtu and CO emissions of no greater than 0.084 lb/MMBtu (previously approved factors for these steam generators)
- Daily NO_x for units proposed to reduce NO_x will be calculated using the currently permitted 15 ppmv as the daily PE2 includes startup and shutdown emissions
- There will be no change in currently permitted, daily nor annual, potential to emit for CO, VOC, or PM10
- Emissions for units permitted to burn <50% PUC gas will be calculated at the higher NO_x emissions factor as allowed by Rule 4320
- There will be no change in any potential to emit for dormant units (and those becoming dormant)
- All non-dormant units in this project are rated at 62.5 MMBtu/hr, and permitted to operate 24 hours/day and 365 days/year

B. Emission Factors

Pre-Project Emission Factors (EF1)

Permit Unit	Pollutant	Pre-Project Emission Factors (EF1)		Source
All units in this project except DEUs	NO _x	0.018 lb/MMBtu	15 ppmvd NO _x (@ 3% O ₂)	Current Permit
Various values	SO _x	See Appendix E	See Appendix E	Current Permit

Post-Project Emission Factors (EF2)

Permit Unit	Pollutant	Post-Project Emission Factors for NO _x (EF2)		Source
All Standard Schedule units in this project except DEUs and units firing on <50% PUC gas	NO _x	0.008 lb/MMBtu	7 ppmvd NO _x (@ 3% O ₂)	Rule 4320 Table 1, Category C.2
All Staged Enhanced Schedule units in this project except DEUs and units firing on <50% PUC gas	NO _x	0.011 lb/MMBtu	9 ppmvd NO _x (@ 3% O ₂)	Rule 4320 Table 1, Category C.2
Units firing on <50% PUC gas	NO _x	0.014 lb/MMBtu	12 ppmvd NO _x (@ 3% O ₂)	Rule 4320 Table 1, Category C.2

The SO_x emission factor is calculated as follows for units fired on non-PUC quality gas and limiting the sulfur concentration in the fuel to 5 gr-S/100 dscf and is converted to lb-SO_x/MMBtu by the following equation:

$$\left(\frac{64 \text{ lb} - \text{SO}_x}{32 \text{ lb} - \text{S}} \right) \frac{5 \text{ gr} - \text{S}}{100 \text{ dscf}} \left(\frac{1 \text{ lb}}{7,000 \text{ gr}} \right) \frac{\text{dscf}}{1,000 \text{ Btu}} \left(\frac{10^6 \text{ Btu}}{\text{MMBtu}} \right) = 0.0143 \frac{\text{lb} - \text{SO}_x}{\text{MMBtu}}$$

The resulting maximum SO_x emission rate is then 0.0143 lb/MMBtu for units proposing particulate controls from Rule 4320 Section 5.4.1.1 and 5.4.1.2. Currently permitted SO_x emission rates below this 5 gr-S/100 dscf limit will not change as a result of this project.

Permit Unit	Pollutant	Post-Project Emission Factors for SO _x (EF2)		Source
All units in this project except DEUs	SO _x	EF1 or 0.0143 lb/MMBtu	PUC Quality Gas and 5 gr-S/100 dscf limit	Rule 4320 Section 5.4.1.1 (definition of PUC gas, Rule 4320 Section 3.7) and 5.4.1.2

C. Calculations

Since there is no change in emission rates and potential to emit for CO, VOC, and PM10 for all units except DEUs and no change of any pollutant for DEUs, emissions for these pollutants are not calculated in this project.

1. Pre-Project Potential to Emit (PE1)

The PE1 for each pollutant is calculated with the following equation (and summarized on the next table):

$$\text{PE1} = \text{EF1 (lb/MMBtu)} \times \text{Heat Input (MMBtu/hr)} \times \text{Op. Sched. (hr/day or hr/year)}$$

Unit	EF _{PE1} NO _x (lb/MMBtu)	EF _{PE1} SO _x (lb/MMBtu)	PE1 _{Daily} NO _x (lb/day) ¹	PE1 _{Annual} NO _x (lb/year)	PE1 _{Daily} SO _x (lb/day)	PE1 _{Annual} SO _x (lb/year)
4-30	0.018	0.007	54.0	9,855	10.5	3,833
4-31	0.018	0.007	54.0	9,855	10.5	3,833
4-32	0.018	0.007	54.0	9,855	10.5	3,833
5-31	0.018	0.007	54.0	9,855	10.5	3,833
5-32	0.018	0.007	54.0	9,855	10.5	3,833
5-33	0.018	0.007	54.0	9,855	10.5	3,833
21-34	0.018	0.00285	54.0	9,855	4.3	1,560
21-35	0.018	0.00285	54.0	9,855	4.3	1,560
21-36	0.018	0.00285	54.0	9,855	4.3	1,560
25-40	0.018	0.324	54.0	9,855	486.0	177,390
25-41	0.018	0.324	54.0	9,855	486.0	177,390
25-42	0.018	0.324	54.0	9,855	486.0	177,390
27-28	0.018	0.007	54.0	9,855	10.5	3,833
27-29	0.018	0.007	54.0	9,855	10.5	3,833
27-30	0.018	0.007	54.0	9,855	10.5	3,833
28-27	0.018	0.007	54.0	9,855	10.5	3,833
28-28	0.018	0.007	54.0	9,855	10.5	3,833
28-29	0.018	0.007	54.0	9,855	10.5	3,833
35-34	0.018	0.00285	54.0	9,855	4.3	1,560
35-35	0.018	0.00285	54.0	9,855	4.3	1,560
35-36	0.018	0.00285	54.0	9,855	4.3	1,560
38-28	0.018	0.324	54.0	9,855	486.0	177,390
38-29	0.018	0.324	54.0	9,855	486.0	177,390
38-30	0.018	0.324	54.0	9,855	486.0	177,390
66-24	0.018	0.00285	54.0	9,855	4.3	1,560
66-25	0.018	0.00285	54.0	9,855	4.3	1,560
66-26	0.018	0.00285	54.0	9,855	4.3	1,560
68-16	0.018	0.00285	54.0	9,855	4.3	1,560
68-17	0.018	0.00285	54.0	9,855	4.3	1,560
68-18	0.018	0.00285	54.0	9,855	4.3	1,560
75-21	0.018	0.00285	54.0	9,855	4.3	1,560
75-22	0.018	0.00285	54.0	9,855	4.3	1,560
75-23	0.018	0.00285	54.0	9,855	4.3	1,560
76-20	0.018	0.00285	54.0	9,855	4.3	1,560
76-21	0.018	0.00285	54.0	9,855	4.3	1,560
76-22	0.018	0.00285	54.0	9,855	4.3	1,560
77-20	0.018	0.00285	54.0	9,855	4.3	1,560
77-21	0.018	0.00285	54.0	9,855	4.3	1,560
77-22	0.018	0.00285	54.0	9,855	4.3	1,560
79-16	0.018	0.00285	54.0	9,855	4.3	1,560
79-17	0.018	0.00285	54.0	9,855	4.3	1,560
79-18	0.018	0.00285	54.0	9,855	4.3	1,560
80-18	0.018	0.00285	54.0	9,855	4.3	1,560
80-19	0.018	0.00285	54.0	9,855	4.3	1,560
80-20	0.018	0.00285	54.0	9,855	4.3	1,560

¹ Taken from the District's PAS database (accounts for start-up and shutdown emissions)

Unit	EF _{PE1} NO _x (lb/MMBtu)	EF _{PE1} SO _x (lb/MMBtu)	PE1 _{Daily} NO _x (lb/day) ²	PE1 _{Annual} NO _x (lb/year)	PE1 _{Daily} SO _x (lb/day)	PE1 _{Annual} SO _x (lb/year)
111-18	0.018	0.00285	54.0	9,855	4.3	1,560
111-19	0.018	0.00285	54.0	9,855	4.3	1,560
111-20	0.018	0.00285	54.0	9,855	4.3	1,560
112-19	0.018	0.00285	54.0	9,855	4.3	1,560
112-20	0.018	0.00285	54.0	9,855	4.3	1,560
112-21	0.018	0.00285	54.0	9,855	4.3	1,560
113-19	0.018	0.00285	54.0	9,855	4.3	1,560
113-20	0.018	0.00285	54.0	9,855	4.3	1,560
113-21	0.018	0.00285	54.0	9,855	4.3	1,560
154-27	0.018	0.0033	54.0	9,855	5.0	1,807
154-28	0.018	0.0033	54.0	9,855	5.0	1,807
154-29	0.018	0.0033	54.0	9,855	5.0	1,807
159-19	0.018	0.00285	54.0	9,855	4.3	1,560
159-20	0.018	0.00285	54.0	9,855	4.3	1,560
159-21	0.018	0.00285	54.0	9,855	4.3	1,560
941-6	0.018	0.00285	54.0	9,855	4.3	1,560
941-7	0.018	0.00285	54.0	9,855	4.3	1,560
941-8	0.018	0.00285	54.0	9,855	4.3	1,560

2. Post-Project Potential to Emit (PE2)

The PE2 for each pollutant is calculated with the following equation (and summarized on the next table):

$$PE2 = EF2 \text{ (lb/MMBtu)} \times \text{Heat Input (MMBtu/hr)} \times \text{Op. Sched. (hr/day or hr/year)}$$

Unit	EF _{PE2} NO _x (lb/MMBtu)	EF _{PE2} SO _x (lb/MMBtu)	PE2 _{Daily} NO _x (lb/day)	PE2 _{Annual} NO _x (lb/year)	PE2 _{Daily} SO _x (lb/day)	PE2 _{Annual} SO _x (lb/year)
4-30	0.008	0.007	27.0	4,380	10.5	3,833
4-31	0.011	0.007	27.0	6,023	10.5	3,833
4-32	0.018	0.007	54.0	9,855	10.5	3,833
5-31	0.008	0.007	27.0	4,380	10.5	3,833
5-32	0.011	0.007	27.0	6,023	10.5	3,833
5-33	0.018	0.007	54.0	9,855	10.5	3,833
21-34	0.008	0.00285	27.0	4,380	4.3	1,560
21-35	0.011	0.00285	27.0	6,023	4.3	1,560
21-36	0.018	0.00285	54.0	9,855	4.3	1,560
25-40	0.014	0.0143	27.0	7,665	21.5	7,829
25-41	0.014	0.0143	27.0	7,665	21.5	7,829
25-42	0.018	0.0143	54.0	9,855	21.5	7,829
27-28	0.008	0.007	27.0	4,380	10.5	3,833
27-29	0.011	0.007	27.0	6,023	10.5	3,833
27-30	0.018	0.007	54.0	9,855	10.5	3,833
28-27	0.008	0.007	27.0	4,380	10.5	3,833
28-28	0.011	0.007	27.0	6,023	10.5	3,833
28-29	0.018	0.007	54.0	9,855	10.5	3,833

² Taken from the District's PAS database (accounts for start-up and shutdown emissions)

Unit	EF _{PE2} NO _x (lb/MMBtu)	EF _{PE2} SO _x (lb/MMBtu)	PE1 & PE2 _{Daily} NO _x (lb/day)	PE2 _{Annual} NO _x (lb/year)	PE2 _{Daily} SO _x (lb/day)	PE2 _{Annual} SO _x (lb/year)
35-34	0.008	0.00285	27.0	4,380	4.3	1,560
35-35	0.011	0.00285	27.0	6,023	4.3	1,560
35-36	0.018	0.00285	54.0	9,855	4.3	1,560
38-28	0.014	0.0143	27.0	7,665	21.5	7,829
38-29	0.014	0.0143	27.0	7,665	21.5	7,829
38-30	0.018	0.0143	54.0	9,855	21.5	7,829
66-24	0.008	0.00285	27.0	4,380	4.3	1,560
66-25	0.011	0.00285	27.0	6,023	4.3	1,560
66-26	0.018	0.00285	54.0	9,855	4.3	1,560
68-16	0.008	0.00285	27.0	4,380	4.3	1,560
68-17	0.011	0.00285	27.0	6,023	4.3	1,560
68-18	0.018	0.00285	54.0	9,855	4.3	1,560
75-21	0.008	0.00285	27.0	4,380	4.3	1,560
75-22	0.011	0.00285	27.0	6,023	4.3	1,560
75-23	0.018	0.00285	54.0	9,855	4.3	1,560
76-20	0.008	0.00285	27.0	4,380	4.3	1,560
76-21	0.011	0.00285	27.0	6,023	4.3	1,560
76-22	0.018	0.00285	54.0	9,855	4.3	1,560
77-20	0.008	0.00285	27.0	4,380	4.3	1,560
77-21	0.011	0.00285	27.0	6,023	4.3	1,560
77-22	0.018	0.00285	54.0	9,855	4.3	1,560
79-16	0.008	0.00285	27.0	4,380	4.3	1,560
79-17	0.011	0.00285	27.0	6,023	4.3	1,560
79-18	0.018	0.00285	54.0	9,855	4.3	1,560
80-18	0.008	0.00285	27.0	4,380	4.3	1,560
80-19	0.011	0.00285	27.0	6,023	4.3	1,560
80-20	0.018	0.00285	54.0	9,855	4.3	1,560
111-18	0.008	0.00285	27.0	4,380	4.3	1,560
111-19	0.011	0.00285	27.0	6,023	4.3	1,560
111-20	0.018	0.00285	54.0	9,855	4.3	1,560
112-19	0.008	0.00285	27.0	4,380	4.3	1,560
112-20	0.011	0.00285	27.0	6,023	4.3	1,560
112-21	0.018	0.00285	54.0	9,855	4.3	1,560
113-19	0.008	0.00285	27.0	4,380	4.3	1,560
113-20	0.011	0.00285	27.0	6,023	4.3	1,560
113-21	0.018	0.00285	54.0	9,855	4.3	1,560
154-27	0.008	0.0033	27.0	4,380	5.0	1,807
154-28	0.011	0.0033	27.0	6,023	5.0	1,807
154-29	0.018	0.0033	54.0	9,855	5.0	1,807
159-19	0.008	0.00285	27.0	4,380	4.3	1,560
159-20	0.011	0.00285	27.0	6,023	4.3	1,560
159-21	0.018	0.00285	54.0	9,855	4.3	1,560
941-6	0.008	0.00285	27.0	4,380	4.3	1,560
941-7	0.011	0.00285	27.0	6,023	4.3	1,560
941-8	0.018	0.00285	54.0	9,855	4.3	1,560

3. Pre-Project Stationary Source Potential to Emit (SSPE1)

SSPE1 calculations are necessary to aid the following determinations:

- If the facility is becoming a new Major Source, or
- An offset threshold will be surpassed, or
- A Stationary Source Increase in Permitted Emissions (SSIPE) public notice is triggered

Pursuant to Section 4.9 of District Rule 2201, the Pre-Project Stationary Source Potential to Emit (SSPE1) is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of emission reduction credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions that have occurred at the source, and which have not been used on-site.

Facility emissions are already above the Offset and Major Source Thresholds for all pollutants. There is no increase in potential emissions for any of the units, for any pollutant in this project; therefore, SSPE1 calculations are not necessary.

4. Post-Project Stationary Source Potential to Emit (SSPE2)

SSPE2 calculations are necessary to aid the following determinations:

- If the facility is becoming a new Major Source,
- An offset threshold will be surpassed, or
- An SSIPE public notice is triggered

Pursuant to Section 4.10 of District Rule 2201, the Post-Project Stationary Source Potential to Emit (SSPE2) is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of emission reduction credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions that have occurred at the source, and which have not been used on-site.

Facility emissions are already above the Offset and Major Source Thresholds for all pollutants. There is no increase in potential emissions for any of the units, for any pollutant in this project. The potential to emit NO_x will decrease in accordance with District Rule 4320. Therefore, SSPE2 calculations are not necessary.

5. Major Source Determination

Pursuant to Section 3.24 of District Rule 2201, a major source is a stationary source a Post-Project Stationary Source Potential to Emit (SSPE2), equal to or exceeding one or more of the Major Source threshold values (excluding ERCs banked onsite that have not been used onsite).

This source is an existing Major Source for all pollutants and will remain so. No change in Major Source status is proposed or expected as a result of this project.

6. Baseline Emissions (BE)

The BE calculation (in lb/year) is performed on a pollutant-by-pollutant basis to determine the amount of offsets required, where necessary, when the SSPE1 is greater than the offset threshold. This project is exempt from offsets pursuant to Rule 2201, Section 4.6.8 as the modification is being made solely to comply with Rule 4320. Therefore, BE calculations are not required.

7. Major Modification

This facility is an existing major source for all air contaminants.

District Rule 2201 references the definition of major modification provided in 40 CFR 51.165 (v)(A) in effect on December 19, 2002, where major modification means any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act.

Significant is defined under Part 51.165(x) as a net emissions increase in the potential of a source to emit any affected pollutant equal to or exceeding any applicable thresholds. For existing major sources in the San Joaquin Valley Air Basin, which is non-attainment for Ozone and PM₁₀, a major modification occurs if the Net Emissions Increases (NEI) is equal to or greater than one or more of the following threshold values when calculated on actual to PE basis:

Major Modification Thresholds (Existing Major Source)			
Pollutant	Project PE (lb/year)	Threshold (lb/year)	Major Modification?
NO _x	>50,000	50,000	Yes ³
SO _x	>80,000	80,000	Yes ³
PM ₁₀	>30,000	30,000	Yes ³
VOC	>50,000	50,000	Yes ³

Therefore, this project is a major modification and public notice is required.

8. Federal Major Modification

Pursuant to Rule 2201 Section 3.17 to determine if a project is a Federal major modification, the calculation procedure in 40 CFR 51.165(a)(2)(ii) shall be used.

This calculation procedure states that if the sum of the differences between the projected actual emissions and the baseline actual emissions (for existing emission units) or the sum of the potentials to emit (for new emission units) is significant, i.e. greater than the values listed in Rule 2201 Table 3-1, the project is a Federal major modification.

³ Due to the large number of affected units proposed by CUSA for facilities S-1128, S-1129, and S-1141 for Rule 4320 compliance this project in conjunction with others (and considering that boilers and steam generators typically have actual emissions below their permitted emission levels) is presumed to cross one or more major modification thresholds.

For existing emission units where there is no increase in design capacity the projected actual emissions (PAE) are equal to the emission rate at which the unit is projected to emit in any one year selected by the operator within 5 years after the unit resumes normal operation (10 years for existing units with an increase in design capacity). This projection is made by the operator and must be based on all relevant information, e.g. expected business activity.

For emission units (other than electric utility steam generating units) the baseline actual emissions (BAE) are calculated based on any 24 month period selected by the operator within the previous 10 year period. These emissions must not include any non-compliant operation

In calculating the emission increase (PAE – BAE), the portion of the emissions after the project that the unit could have actually emitted (during the same period used to determine BAE) that are unrelated to the particular project and emissions due to increased product demand are excluded.

For rule compliance projects, the difference between the PAE and the BAE (excluding emissions that the unit could have emitted during the baseline period) for pollutants targeted by the subject rule will be a negative value.

Additionally, it can reasonably be concluded that the difference between the PAE and the BAE (excluding emissions that the unit could have emitted during the baseline period) for non-targeted pollutants will be zero as any increase in actual emissions (after the project) would be due to increases in business activity and not due to the modification itself. Such emission increases are excluded when calculating the emission increase.

For the reasons stated above, this rule compliance project will not result in a significant emission increase and therefore is not a Federal major modification.

VIII. COMPLIANCE

District Rule 2201 New and Modified Stationary Source Review Rule

A. Best Available Control Technology (BACT)

1. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis for the following*:

- a. Any new emissions unit with a potential to emit exceeding two pounds per day,
- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an AIPE exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in a Major Modification.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

However, BACT shall not be required for the following:

- 4.2.3 For existing facilities, the installation or modification of an emission control technique performed solely for the purpose of compliance with the requirements of District, State or Federal air pollution control laws, regulations, or orders, as approved by the APCO, shall be exempt from Best Available Control Technology for all air pollutants, provided all of the following conditions are met:
 - 4.2.3.1 There shall be no increase in the physical or operational design of the existing facility, except for those changes to the design needed for the installation or modification of the emission control technique itself;
 - 4.2.3.2 There shall be no increase in the permitted rating or permitted operating schedule of the permitted unit;
 - 4.2.3.3 There shall be no increase in emissions from the stationary source that will cause or contribute to any violation of a National Ambient Air Quality Standard, Prevention of Significant Deterioration increment, or Air Quality Related Value in Class I areas; and
 - 4.2.3.4 The project shall not result in an increase in permitted emissions or potential to emit of more than 25 tons per year of NO_x, or 25 tons per year of VOC, or 15 tons per year of SO_x, or 15 tons per year of PM₁₀, or 50 tons per year of CO.

Since each of the above-listed criteria are met, BACT is not required for any pollutant.

B. Offsets

1. Offset Applicability

The proposed modifications are solely for compliance with Rule 4320, and are exempt from offsets if the following criteria are satisfied. Rule 2201, Section 4.6.8 provides the following exemption from offsets.

Emission offsets shall not be required for the following:

- 4.6.8 For existing facilities, the installation or modification of an emission control technique performed solely for the purpose of compliance with the requirements of District, State or Federal air pollution control laws, regulations, or orders, as approved by the APCO, shall be exempt from offset requirements for all air pollutants provided all of the following conditions are met:
 - 4.6.8.1 There shall be no increase in the physical or operational design of the existing facility, except for those changes to the design needed for the installation or modification of the emission control technique itself;
 - 4.6.8.2 There shall be no increase in the permitted rating or permitted operating schedule of the permitted unit;

4.6.8.3 There shall be no increase in emissions from the stationary source that will cause or contribute to any violation of a National Ambient Air Quality Standard, Prevention of Significant Deterioration increment, or Air Quality Related Value in Class I areas; and

4.6.8.4 The project shall not result in an increase in permitted emissions or potential to emit of more than 25 tons per year of NO_x, or 25 tons per year of VOC, or 15 tons per year of SO_x, or 15 tons per year of PM-10, or 50 tons per year of CO.

Since each of the above-listed criteria are met, offsets are not required for any pollutant.

2. Quantity of Offsets Required

As seen above, the project meets the exemption requirements of section 4.6.8 of District Rule 2201; therefore offset calculations are not necessary and offsets are not required for this project.

C. Public Notification

1. Applicability

Public noticing is required for:

- a. Any new Major Source, which is a new facility that is also a Major Source,
- b. Major Modifications,
- c. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- d. Any project which results in the offset thresholds being surpassed, and/or
- e. Any project with an SSIPE of greater than 20,000 lb/year for any pollutant.

a. New Major Source

As demonstrated in section VII.C.5 above, the facility is not becoming a Major Source as a result of this project.

b. Major Modification

As demonstrated in VII.C.7, this project constitutes a Major Modification; therefore, public noticing for Major Modification purposes is required.

c. PE > 100 lb/day

Applications which include a new emissions unit with a PE greater than 100 pounds during any one day for any pollutant will trigger public noticing requirements. There are no new emissions units associated with this project; therefore public noticing is not required for this project for Potential to Emit exceeding the 100 lb/day limit.

d. Offset Threshold

Public notification is required if the Pre-Project Stationary Source Potential to Emit (SSPE1) is increased from a level below the offset threshold to a level exceeding the emissions offset threshold, for any pollutant.

There is no increase in permitted emissions as a result of this project. Therefore, the SSPE is not increasing with this project and an offset threshold cannot be surpassed as a result of this project. A public notice will not be required for offset threshold purposes.

e. SSIPE > 20,000 lb/year

An SSIPE exceeding 20,000 pounds per year for any one pollutant triggers public notice, where $SSIPE = SSPE2 - SSPE1$.

There is no increase in permitted emissions as a result of this project. As a result, SSPE is not increasing with this project. Therefore, the SSIPE is zero for all pollutants and public notice will not be required for SSIPE purposes.

2. Public Notice Action

As discussed above, public notice will be required for this project.

D. Daily Emission Limits (DELs)

Daily Emissions Limitations (DELs) and other enforceable conditions are required by Section 3.15 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. Per Sections 3.15.1 and 3.15.2, the DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

The DELs for the unit is based on the use of natural gas as a fuel and will be stated in the form of emission factors as shown:

For all units except DEUs:

- Emissions from the steam generator shall not exceed any of the following limits: **[EF1 or 0.0143, whichever is lower]** lb-SOx/MMBtu, X.XXX lb-PM10/MMBtu, or X.XXX lb-VOC/MMBtu. [District Rule 2201]
- Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: X ppmvd NOx @ 3% O2 or X.XX lb-NOx/MMBtu or XX ppmvd CO @ 3% O2 or X.XX lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320]
- During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201]
- During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, X.XXX lb-SOx/MMBtu,

X.XXX lb-PM10/MMBtu, XX ppmvd CO @ 3% O₂ or X.XXX lb-CO/MMBtu, or X.XXX lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320]

- Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: XX.X lb-NO_x/day, XXX lb-NO_x/yr, XX.X lb-CO/day, and XXX lb-CO/yr. [District Rules 2201, 4305, 4306, and 4320]

E. Compliance Assurance

1. Source Testing

This unit is subject to District Rule 4305, *Boilers, Steam Generators and Process Heaters, Phase 2*, District Rule 4306, *Boilers, Steam Generators and Process Heaters, Phase 3*, and District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5 MMBtu/hr*. Source testing requirements, in accordance with District Rules 4305, 4306, and 4320 have been included on the ATC.

2. Monitoring

As required by District Rule 4305, *Boilers, Steam Generators and Process Heaters, Phase 2*, District Rule 4306, *Boilers, Steam Generators and Process Heaters, Phase 3*, and District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5 MMBtu/hr*, this unit is subject to monitoring requirements. Monitoring requirements, in accordance with District Rules 4305, 4306, and 4320 have been included on the ATC.

The following condition will be included on the ATC to ensure compliance:

- Permittee shall maintain records of higher heating value (HHV) and annual volume of fuel supplied to the unit. [District Rule 2201]

3. Recordkeeping

As required by District Rule 4305, *Boilers, Steam Generators and Process Heaters, Phase 2*, District Rule 4306, *Boilers, Steam Generators and Process Heaters, Phase 3*, and District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5 MMBtu/hr* this unit is subject to recordkeeping requirements. Recordkeeping requirements, in accordance with District Rules 4305, 4306, and 4320 have been included on the ATC.

For Non PUC units:

- Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR/TVC gas incinerated in this unit. [District Rules 2201 and 4406]
- Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406]
- Permittee shall maintain with the permit a current listing of all TEOR and TVC gas systems providing vapors to this steam generator and shall make such listing readily available for District inspection upon request [District Rule 2201]
- Permittee shall maintain daily records of volume of fuel gas burned, TEOR and TVC gas incinerated, and permit number(s) of systems providing gas for incineration. [District Rule 2201]

4. Reporting

No reporting is required to demonstrate compliance with Rule 2201.

District Rule 2520 Federally Mandated Operating Permits

Chevron USA, Inc. has a Title V permit. The changes authorized by these ATCs constitute a minor modification of their Title V permit. As discussed above, the facility has applied for a Certificate of Conformity (COC); therefore, the facility must apply to modify their Title V permit with an administrative amendment prior to operating with the proposed modifications and permit conditions will be listed as follows:

- {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201]
- {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520]

District Rule 4001 New Source Performance Standards

40 CFR Part 60, Subpart Dc applies to Small Industrial-Commercial-Industrial Steam Generators between 10 MMBtu/hr and 100 MMBtu/hr (post-6/9/89 construction, modification or, reconstruction).

The steam generators listed in this project are subject to this subpart. However, the units are exclusively natural gas-fired and there are no applicable performance standard requirements from this subpart that natural gas-fired steam generators are subject to. The applicable monthly fuel use record keeping requirements of section 60.48c(g) will be satisfied by District Rule 4306 and Rule 4320 requirements.

The applicable 2-year record retention requirement of section 60.48c(i) will be subsumed by the District's 5-year record retention requirement.

40 CFR Part 60, Subpart A, section 14, defines the meaning of modification to which the standards are applicable. §60.14, paragraph (e)(5) states that the following will not be considered as a modification: *"the addition or use of any system or device whose primary function is the reduction of air pollutants, except when an emission control system is removed or replaced by a system which the Administrator determines to be less environmentally beneficial"*.

No newly constructed or reconstructed units are proposed in this project, nor is the unit being modified (as defined above). Since the permittee is retrofitting the unit with an equivalent size, or smaller, burner for compliance with District rules and regulations, the requirements of these sections do not apply to the unit.

District Rule 4101 Visible Emissions

District Rule 4101, Section 5.0, indicates that no air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour, which is dark or darker than Ringlemann 1 or equivalent to 20% opacity.

A permit condition will be listed on the permit as follows:

- {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]

Therefore, compliance with District Rule 4101 requirements is expected.

District Rule 4102 Nuisance

Section 4.0 prohibits discharge of air contaminants, which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

A permit condition will be listed on the permit as follows:

- {98} No air contaminant shall be released into the atmosphere, which causes a public nuisance. [District Rule 4102]

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 - Risk Management Policy for Permitting New and Modified Sources specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

Since the applicant is not proposing an increase in emissions with this project, a health risk assessment is not necessary and no further risk analysis is required.

District Rule 4201 Particulate Matter Concentration

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot. The worst case emissions unit will be used for this calculation (S-1128-25 @ 0.0490 lb-PM₁₀/MMBtu).

F-Factor for NG:	8,578 dscf/MMBtu at 60 °F
PM10 Emission Factor:	0.0490 lb-PM10/MMBtu
Percentage of PM as PM10 in Exhaust:	100%
Exhaust Oxygen (O ₂) Concentration:	3%
Excess Air Correction to F Factor =	$\frac{20.9}{(20.9 - 3)} = 1.17$

$$GL = \left(\frac{0.0490 \text{ lb-PM}}{\text{MMBtu}} \times \frac{7,000 \text{ grain}}{\text{lb-PM}} \right) / \left(\frac{8,578 \text{ ft}^3}{\text{MMBtu}} \times 1.17 \right)$$

$$GL = 0.03 \text{ grain/dscf} < 0.1 \text{ grain/dscf}$$

Therefore, compliance with District Rule 4201 requirements is expected and a permit condition will be listed on the permit as follows:

- {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

District Rule 4301 Fuel Burning Equipment

This rule specifies maximum emission rates in lb/hr for SO₂, NO₂, and combustion contaminants (defined as total PM in Rule 1020). This rule also limits combustion contaminants to ≤ 0.1 gr/scf. According to AP 42 (Table 1.4-2, footnote c), all PM emissions from natural gas combustion are less than 1 μm in diameter.

District Rule 4301 Limits (lb/hr)			
Pollutant	NO ₂	Total PM	SO ₂
Worst case pollutants	1.14 ₁₅ ppm	3.06 _{0.0490} lb/MMBtu	0.84 _{0.0134} lb/MMBtu
Rule Limit (lb/hr)	140	10	200

The above table indicates compliance with the maximum lb/hr emissions in this rule; therefore, continued compliance is expected.

District Rule 4304 - Equipment Tuning Procedure for Boilers, Steam Generators and Process Heaters

Pursuant to District Rules 4305 and 4306, Section 6.3.1, the steam generator is not required to tune since it follows District approved Alternate Monitoring scheme A, where the applicable emission limits are periodically monitored. Therefore, the units are not subject to this rule.

District Rule 4305 Boilers, Steam Generators and Process Heaters – Phase 2

These units are natural gas-fired with a maximum heat input of 62.5 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4305, the units are subject to District Rule 4305, *Boilers, Steam Generators and Process Heaters – Phase 2*.

In addition, these units are also subject to District Rule 4306, *Boilers, Steam Generators and Process Heaters – Phase 3*.

Since the emissions limits of District Rule 4306 and all other requirements are equivalent or more stringent than District Rule 4305 requirements, compliance with District Rule 4306 requirements will satisfy the requirements of District Rule 4305.

District Rule 4306 Boilers, Steam Generators and Process Heaters – Phase 3

These units are natural gas-fired with a maximum heat input of 62.5 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4306, these units are subject to District Rule 4306.

In addition, these units are also subject to *District Rule 4320, Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5 MMBtu/hr*.

The subject units are currently in compliance with the applicable provisions of this rule. Source testing, monitoring and recordkeeping requirements of Rule 4320 are equal to or more stringent than the requirements of this rule; therefore, continued compliance is expected

District Rule 4320 Advance Emission Reduction Options for Boilers, Steam Generators and Process Heaters Greater than 5 MMBtu/hr

This rule limits NO_x, CO, SO₂ and PM₁₀ emissions from boilers, steam generators and process heaters rated greater than 5 MMBtu/hr. This rule also provides a compliance option of payment of fees in proportion to the actual amount of NO_x emitted over the previous year.

The units in this project are all rated at greater than 5 MMBtu/hr heat input. Therefore this rule applies.

Section 5.1 NO_x Emission Limits

Section 5.1 states that an operator of a unit(s) subject to this rule shall comply with all applicable requirements of the rule and one of the following, on a unit-by-unit basis:

- 5.1.1 Operate the unit to comply with the emission limits specified in Sections 5.2 and 5.4; or
- 5.1.2 Pay an annual emissions fee to the District as specified in Section 5.3 and comply with the control requirements specified in Section 5.4; or
- 5.1.3 Comply with the applicable Low-use Unit requirements of Section 5.5.

Section 5.2.1 states that on and after the indicated Compliance Deadline units shall not be operated in a manner which exceeds the applicable NO_x limit specified in Table 1 of this rule.

With a maximum heat input of 62.5 MMBtu/hr for these steam generators the applicable emission limit category Section 5.2, Table 1, Category C.2 (units firing on >50% PUC quality gas) and C.3 (units firing on <50% PUC quality gas), from District Rule 4320 are as follows:

C. Oilfield Steam Generators			
2. Units with a total rated heat input > 20.0 MMBtu/hr	a) Standard Schedule 7 ppmv or 0.008 lb/MMBtu; or	July 1, 2009	July 1, 2010
	b) Staged Enhanced Schedule Initial Limit 9 ppmv or 0.011 lb/MMBtu; and	July 1, 2011	July 1, 2012
	Final Limit 5 ppmv or 0.0062 lb/MMBtu	January 1, 2013	January 1, 2014
3. Units firing on less than 50%, by volume, PUC quality gas.	Staged Enhanced Schedule Initial Limit 12 ppmv or 0.014 lb/MMBtu; and	July 1, 2010	July 1, 2011
	Final Limit 9 ppmv or 0.011 lb/MMBtu	January 1, 2013	January 1, 2014

As shown in the previous table, the 7 and 9 ppmvd @ 3% O₂ NO_x limit proposed for the steam generators, for both standard and staged schedules, in this project are consistent with one of the compliance options allowed by the rule. CUSA has also requested ATCs that address the SO_x emissions limit only in the event that the fee payment option for NO_x control is chosen. The source testing and alternative monitoring requirements of the rule are consistent with those in existing Rule 4306 and will be included on the requested Authority to Construct. Additionally, the emissions factor limits (worst case) of 0.049 lb PM₁₀/MMBtu and 0.0143 lb SO₂/MMBtu are consistent with the particulate matter and SO_x control requirements. Therefore, compliance with this rule is expected.

Daily emission limiting conditions have been included in section VIII.D. Compliance with section 5.2 is expected.

Section 5.4 Particulate Matter Control Requirements

5.4.1 To limit particulate matter emissions, an operator shall comply with one of the following requirements:

- 5.4.1.1 On and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall fire units exclusively on PUC-quality natural gas, commercial propane, butane, or liquefied petroleum gas, or a combination of such gases;
- 5.4.1.2 On and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall limit fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet; or
- 5.4.1.3 On and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall install and properly operate an emission control system that reduces SO₂ emissions by at least 95% by weight; or limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% O₂.
- 5.4.1.4 Notwithstanding the compliance deadlines indicated in Sections 5.4.1.1 through 5.4.1.3, refinery units, which require modification of refinery equipment to reduce sulfur emissions, shall be in compliance with the applicable requirement in Section 5.4.1 no later than July 1, 2013.

CUSA will address the particulate matter in the following manner (conditions previously proposed in the Rule 2201 compliance section VIII.D):

S-1128-4, '-5, '-21, '-27, '-28, '-35, '-66, '-68, '-75, '-76, '-77, '-79, '-80, '-111, '-112, '-113, '-154, '-159, and '-941 (units fired exclusively on PUC-quality gas per Section 5.4.1.1):

- Emissions from the steam generator shall not exceed any of the following limits: [EF1 or 0.0143, whichever is lower] lb-SO_x/MMBtu, X.XXX lb-PM₁₀/MMBtu, or X.XXX lb-VOC/MMBtu. [District Rules 2201 and 4320]

S-1128-28 and '-38 (units with fuel gas limited to 5 Grain-S per Section 5.4.1.2):

- Emissions from the steam generator shall not exceed any of the following limits: 0.0143 lb-SO_x/MMBtu, X.XXX lb-PM₁₀/MMBtu, or X.XXX lb-VOC/MMBtu. [District Rules 2201 and 4320]

Compliance with section 5.4 is expected.

Section 5.6 Startup and Shutdown Provisions

Section 5.6 states that on and after the full compliance deadline specified in Section 5.0, the applicable emission limits of Sections 5.2 Table 1 and 5.5.2 shall not apply during start-up or shutdown provided an operator complies with the requirements specified in Sections 5.6.1 through 5.6.5.

CUSA has proposed to retain existing start-up and shutdown duration limits of 2 hours and 2 hours, respectively. Emissions during start-up and shutdown will not be subject to the emission limits in Sections 5.2 and 5.2.2. The following conditions will be listed on the ATCs:

- Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320]
- Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320]

Shakedown Provision

CUSA is requesting approval of a 60-day "shakedown" period for units to be retrofitted, after installation of the new low-NO_x combustion equipment or the combustion modifications authorized by these ATCs. CUSA requests that the units be allowed to operate at the current NO_x emission limit of 15 ppmv @ 3% O₂ until the shakedown period is completed. The shakedown period will not exceed 60 days nor extend beyond the applicable Rule 4320 compliance deadline. The following condition will be added to ATCs proposing a NO_x reduction:

- During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3, and 4320]

Section 5.7 Monitoring Provisions

Section 5.7.1 requires that permit units subject to District Rule 4320, Section 5.2 shall either install and maintain an operational APCO approved Continuous Emission Monitoring System (CEMS) for NO_x, CO and O₂, or implement an APCO-approved alternate monitoring.

Consistent with current permit requirements, CUSA proposes to continue implementing Alternate Monitoring Scheme A (pursuant to District Policy SSP-1105), which requires that monitoring of NO_x, CO, and O₂ exhaust concentrations shall be conducted at least once per month (in which a source test is not performed) using a portable analyzer. The following

conditions will be incorporated into the ATCs to ensure compliance with the requirements of the proposed alternate monitoring plan:

- {4063} The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Measurement shall be made with the FGR system in the mode of operation (closed or open) in which it was used in the preceding 30 days. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]
- {4064} If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320]
- {4065} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320]
- {4066} The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320]

Section 5.7.6 requires operators complying with Sections 5.4.1.1 or 5.4.1.2 to provide an annual fuel analysis to the District unless a more frequent sampling and reporting period is included in the Permit To Operate. Sulfur analysis shall be performed in accordance with the test methods in Section 6.2.

- Operator shall provide an annual fuel analysis to the District. [District Rule 4320]

Section 5.8 Compliance Determination

Section 5.8.1 requires that the operator of any unit shall have the option of complying with either the applicable heat input (lb/MMBtu), emission limits or the concentration (ppmv) emission limits specified in Section 5.2. The emission limits selected to demonstrate compliance shall be specified in the source test proposal pursuant to Rule 1081 (Source Sampling).

Therefore, the following condition will be listed on the ATCs as follows:

- {2976} The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]

Section 5.8.2 requires that all emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. Therefore, the following permit condition will be listed on the ATCs as follows:

- {2972} All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320]

Section 5.8.4 requires that for emissions monitoring pursuant to Sections 5.7.1 and 6.3.1 using a portable NO_x analyzer as part of an APCO approved Alternate Emissions Monitoring System, emission readings shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15-consecutive-minute period. Therefore, the following previously listed permit condition will be on the ATCs as follows:

- {2937} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320]

Section 5.8.5 requires that for emissions source testing performed pursuant to Section 6.3.1 for the purpose of determining compliance with an applicable standard or numerical limitation of this rule, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. Therefore, the following permit condition will be listed on the permit as follows:

- {2980} For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320]

Section 6.1 Recordkeeping

Section 6.1 requires that the records required by Sections 6.1.1 through 6.1.5 shall be maintained for five calendar years and shall be made available to the APCO and EPA upon request. Failure to maintain records or information contained in the records that demonstrate noncompliance with the applicable requirements of this rule shall constitute a violation of this rule.

A permit condition will be listed on the permit as follows:

- {2983} All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320]

Section 6.2, Test Methods

Section 6.2 identifies the following test methods as District-approved source testing methods for the pollutants listed:

Pollutant	Units	Test Method Required
NO _x	ppmv	EPA Method 7E or ARB Method 100
NO _x	lb/MMBtu	EPA Method 19
CO	ppmv	EPA Method 10 or ARB Method 100
Stack Gas O ₂	%	EPA Method 3 or 3A, or ARB Method 100
Stack Gas Velocities	ft/min	EPA Method 2
Stack Gas Moisture Content	%	EPA Method 4

The following permit conditions will be listed on the permit as follows:

- {109} Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
- The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320]

Section 6.3, Compliance Testing

Section 6.3.1 requires that this unit be tested to determine compliance with the applicable requirements of section 5.1 and 5.2.3 not less than once every 12 months. Upon demonstrating compliance on two consecutive compliance source tests, the following source test may be deferred for up to thirty-six months.

The following permit conditions will be listed on the ATCs:

- Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306, and 4320]
- Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320]
- The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]

In addition, since the applicant has proposed to use pre-approved Alternate Monitoring Scheme "A" using a portable analyzer, the tune-up requirements listed in Section 6.3.1 are

not applicable to these units. Section 6.3.1 also requires that, during the 36-month source testing interval, the owner/operator shall monthly monitor the operational characteristics recommended by the unit manufacturer. Since the pre-approved Alternate Monitoring Scheme "A" using a portable analyzer requires monthly monitoring of NO_x, CO, and O₂ exhaust emissions concentrations, operational characteristics monitoring requirement is satisfied, and no further discussion is required.

The applicant currently uses representative testing for the steam generators involved with this project. Therefore, Section 6.3.2 applies to the units involved with this project. Section 6.3.2 allows that in lieu of compliance with Section 6.3.1, compliance with the applicable emission limits in Sections 5.1 or 5.2.3 shall be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units, provided:

- 1) All units in the group are initially source tested. The emissions from all test runs from units within the group are less than 90% of the permitted value, and the emissions do not vary greater than 25% from the average of all test runs; and
- 2) All units in a group are similar in terms of rated heat input, make and series, operational conditions, fuel used, and control method. No unit with a rated heat input greater than 100 MMBtu shall be considered as part of the group; and
- 3) The group is owned by a single owner and is located at a single stationary source; and
- 4) Selection of the representative unit(s) is approved by the APCO prior to testing; and
- 5) The number of representative units source tested shall be at least 30% of the total number of units in the group. The representative tests shall rotate each year so that within three years all units in the group have been tested at least once.
- 6) All units in the group shall have received the similar maintenance and tune-up procedures as the representative unit(s) as listed in the Permit to Operate. The operator shall submit to the APCO the specific maintenance procedures to be performed on each unit that will be included in the group for representative testing. Such maintenance procedures shall be specified in the Permit to Operate for units that are included in the group for representative testing. Any maintenance work on a unit which has no effect on emissions standards and which is not specified in the maintenance procedures shall be submitted to the APCO for approval before such unit can be included as part of the group for representative testing. Any unit that necessitates any maintenance work which has an effect on emission standards and is beyond the maintenance procedures identified in the Permit to Operate, shall not be included as part of the group for representative testing. The unit shall be source tested in accordance with the provisions of Section 6.3.1; and
- 7) Should any of the representative units exceed the required emission limits, each of the units in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested units being in violation of this rule. After compliance with the requirements of Section 6.3.2.7 has been demonstrated, subsequent source testing shall be performed pursuant to Sections 6.3.1 or 6.3.2.

The following permit conditions will be listed on the ATCs:

- Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 4305, 4306, and 4320]
- The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4320]
- All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4320]
- All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4320]
- The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4320]

Section 6.4, Emission Control Plan (ECP)

Section 6.4 requires the operator of any unit to submit to APCO for approval an Emissions Control Plan no later than January 1, 2010. CUSA has submitted an Emissions Control Plan.

- This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4320]

Section 7.0, Compliance Schedule

Section 7.0 identifies the dates by which the operator shall submit an application for an ATC and the date by which the owner shall demonstrate compliance with this rule.

The units will be in compliance with the emissions limits listed in Table 1, Section 5.2 of this rule, and periodic monitoring and source testing as required by District Rule 4320. Therefore, requirements of the compliance schedule, as listed in Section 7.0 of District Rule 4320, are satisfied. No further discussion is required.

Conclusion

Conditions will be incorporated into the permit in order to ensure compliance with each section of this rule, see attached draft permits in Appendix C. Therefore, compliance with District Rule 4320 requirements is expected.

District Rule 4405 Oxides of Nitrogen Emissions from Existing Steam Generators Used in Thermally Enhanced Oil Recovery – Central and Western Kern County Fields

This rule limits NOx emissions from existing steam generators used in thermally enhanced oil recovery operations prior to August 22, 1986. The steam generators in this project are subject to a NOx limit well below the 0.14 lb/MMBTU limit allowed by this rule for natural gas-fired units. Therefore, continued compliance is expected.

District Rule 4406 Sulfur Compounds from Oil-Field Steam Generators – Kern County

This rule limits SOx emissions from existing steam generators used in oil field operations prior to September 12, 1979. Sulfur compound emissions (as S) from the steam generators in this project are limited to an average rate below the 0.11 lb/MMBTU limit for sulfur (as S) allowed by the rule. Continued compliance is expected.

District Rule 4801 Sulfur Compounds

A person shall not discharge into the atmosphere sulfur compounds, which would exist as a liquid or gas at standard conditions, exceeding in concentration at the point of discharge: 0.2 % by volume calculated as SO₂, on a dry basis averaged over 15 consecutive minutes.

Using the ideal gas equation and the emission factors presented in Section VII, the sulfur compound emissions are calculated as follows:

$$\text{Volume SO}_2 = \frac{n RT}{P}$$

With:

$$\begin{aligned} N &= \text{moles SO}_2 \\ T \text{ (Standard Temperature)} &= 60^\circ\text{F} = 520^\circ\text{R} \\ P \text{ (Standard Pressure)} &= 14.7 \text{ psi} \\ R \text{ (Universal Gas Constant)} &= \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot ^\circ\text{R}} \end{aligned}$$

$$\frac{0.0134 \text{ lb} - \text{SO}_x}{\text{MMBtu}} \times \frac{\text{MMBtu}}{8,578 \text{ dscf}} \times \frac{1 \text{ lb} \cdot \text{mol}}{64 \text{ lb}} \times \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot ^\circ\text{R}} \times \frac{520^\circ\text{R}}{14.7 \text{ psi}} \times \frac{1,000,000 \cdot \text{parts}}{\text{million}} = 9.26 \frac{\text{parts}}{\text{million}}$$

$$\text{Sulfur Concentration} = 9.26 \frac{\text{parts}}{\text{million}} < 2,000 \text{ ppmv (or 0.2\%)}$$

Therefore, compliance with District Rule 4801 requirements is expected.

California Health & Safety Code 42301.6 (School Notice)

This facility is not located within 1,000 feet of a school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

California Environmental Quality Act (CEQA)

The California Environmental Quality Act (CEQA) requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The San Joaquin Valley Unified Air Pollution Control District (District) adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities.
- Identify the ways that environmental damage can be avoided or significantly reduced.
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible.
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

The District performed an Engineering Evaluation (this document) for the proposed project and determined that the activity will occur at an existing facility and the project involves negligible expansion of the existing use. Furthermore, the District determined that the activity will not have a significant effect on the environment. The District finds that the activity is categorically exempt from the provisions of CEQA pursuant to CEQA Guideline § 15031 (Existing Facilities), and finds that the project is exempt per the general rule that CEQA applies only to projects which have the potential for causing a significant effect on the environment (CEQA Guidelines §15061(b)(3)).

IX. RECOMMENDATION

Compliance with all applicable rules and regulations is expected. Issue Authorities to Construct subject to the permit conditions on the attached draft Authorities to Construct in Appendix C.

X. BILLING INFORMATION

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
All Units	3020-02-H	62.5 MMBtu/hr	\$1,030.00

Appendices

- Appendix A: Current Base Documents
- Appendix B: Manufacturer's Guarantee
- Appendix C: Draft ATCs
- Appendix D: TVFORM-009
- Appendix E: SO_x and NO_x Emission Factors

Appendix A
Current Base Documents

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-3-35

EXPIRATION DATE: 02/28/2006

SECTION: 36 TOWNSHIP: 29S RANGE: 21E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 54, DIS# 43010-74) WITH SO2 SCRUBBER - APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. This permit unit shall not be operated unless the owner or operator applies to modify the Title V permit to address the requirements of District Rule 2520, section 9.0 for this permit unit. [District Rule 2520, 9.0] Federally Enforceable Through Title V Permit
5. Emission rates shall not exceed PM10: 0.038 lb/MMBtu, SOx (as SO2): 0.324 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
6. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Approved locations for this equipment: NW/4 and SW/4 of Sec. 36, T29S/R21E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S/R21E; and SE/4 of Sec. 35, T29S/21E. [District Rule 4102] Federally Enforceable Through Title V Permit
8. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Scrubber liquor pH shall be maintained between 6 and 8, and shall be continuously monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Scrubber mist eliminator shall be properly cleaned and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than 8.0 gpm/1000 acfm. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months, except as provided below. [District Rule 4305] Federally Enforceable Through Title V Permit
17. Compliance with NO_x and CO emission limits shall be demonstrated not less than once every 36 months if compliance is demonstrated on two consecutive annual compliance tests. [District Rule 4305] Federally Enforceable Through Title V Permit
18. If permittee fails any compliance demonstration for NO_x and CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305] Federally Enforceable Through Title V Permit
19. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
22. The permittee shall keep daily records of the amount of natural gas and vapor recovery gas combusted, and the date and duration of scrubber operation, for a period of two years, and shall make records available for inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-4-26

EXPIRATION DATE: 02/28/2006

SECTION: NE01 TOWNSHIP: 30S RANGE: 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR #50 DIS# 43009-74 WITH FGR (APPROVED FOR VARIOUS SPECIFIED LOCATIONS)

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Approved locations for this equipment: Section 01 (NE,NW,SE,SW quarters), T30S, R21E; and Section 36 (SW quarter), T29S, R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
18. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Unit shall be fired on PUC quality natural gas only. [District NSR Rule] Federally Enforceable Through Title V Permit
20. Flue gas recirculation shall be utilized, as needed, in conjunction with low NOx burner to maintain ongoing compliance with permitted emission limits [District NSR Rule]
21. Gas fired emission rates shall not exceed PM10: 0.0068 lb/MMBtu, SOx (as SO2): 0.007 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, VOC: 0.011 lb/MMBtu, and CO: 0.023 lb/MMBtu or 31 ppmv @ 3% O2. [District NSR Rule]
22. Fuel gas sulfur content shall not exceed 0.004 lb/MMBtu (as sulfur). [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. Source testing for NO_x and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
24. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
25. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for District inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
30. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
31. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
32. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
33. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
34. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-13] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77- 13] Federally Enforceable Through Title V Permit
36. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-13] Federally Enforceable Through Title V Permit
37. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-13] Federally Enforceable Through Title V Permit
38. Permittee shall continue to operate the vapor recovery system installed on the casing heads of oil wells in Sec 19, T28S, R21E on the Hill Anderson Lease in Lost Hills. Source tests shall be performed on a semi- annual basis to establish the rate of non-methane hydrocarbon recovery. The rate shall be no lower than 427 lbs/day. [PSD SJ 77-13] Federally Enforceable Through Title V Permit
39. Permittee shall undertake a road paving program which will result in the paving of 0.6 miles of currently unpaved road in Sec 35, T30S, R22E (near the project sites). Permittee shall submit quarterly progress reports to the District. [PSD SJ 77-13] Federally Enforceable Through Title V Permit
40. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-13] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-5-30

EXPIRATION DATE: 02/28/2006

SECTION: NE01 TOWNSHIP: 30S RANGE: 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR #51 DIS# 43005-74 WITH NORTH AMERICAN GLE LOW-NOX BURNER, FGR, BLOWER MOTOR AND VARIABLE SPEED DRIVE (APPROVED FOR VARIOUS SPECIFIED LOCATIONS)

PERMIT UNIT REQUIREMENTS

1. Approved locations for this equipment: Section 01 (NE,NW,SE,SW quarters), T30S, R21E; and Section 36 (SW quarter), T29S, R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 [District Rule 1081] Federally Enforceable Through Title V Permit
4. {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. {521} Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 4084, D4468, D6667, D 3246 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. {468} The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. {535} The requirements of SJVUAPCD Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed any of the following: PM10: 0.068 lb/MMBtu, SOx (as SO2): 0.007 lb/MMBtu, or VOC: 0.011 lb/MMBtu. [District Rule NSR Rule]
17. Emission rates, except during startup and shutdown, shall not exceed any of the following: NOx (as NO2): 0.0182 lb/MMBtu or 15 ppmvd @ 3% O2, or CO: 0.023 lb/MMBtu or 31.8 ppmvd @ 3% O2. [District Rules 4305 and 4306]
18. Duration of start-up and shutdown shall not exceed 2 hours each per occurrence. [District Rules 4305 and 4306]
19. During start-up and shutdown periods, emission rates shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201]
20. Emissions shall not exceed either of the following limits: 54.0 lb-NOx/day and 9,965 lb-NOx/year, or 34.5 lb-CO/day and 12,593 lb-CO/year. [District Rule 2201]
21. Source testing for NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
22. Source testing for NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
23. If permittee fails any compliance demonstration for NOx and CO emissions when testing not less than once every 36 months, source testing for NOx and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081]
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081]
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19, and fuel gas sulfur content - ASTM D 1072, D 4084, D4468, D6667, D 3246 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory. [District Rules 1081, 4305, and 4306]
28. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306]
29. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306]
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306]
31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305]
32. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2]
33. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
34. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. As required by PSD permit SJ 77-13 when using fuel oil, the owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-13] Federally Enforceable Through Title V Permit
37. As required by PSD permit SJ 77-13 when using fuel oil, permittee shall undertake a road paving program which will result in the paving of 0.6 miles of currently unpaved road in Sec 35, T30S, R22E (near the project sites). Permittee shall submit quarterly progress reports to the District. [PSD SJ 77-13] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-21-33

EXPIRATION DATE: 02/28/2006

SECTION: SE36 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID# 90, DIS# 43010-80) WITH A NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. Approved locations for this equipment: Section 36 (SE), T32S, 23E; Section 01 (NE,NW,SE,SW quarters), T30S, R21E; and Section 36 (SW quarter), T29S, R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Steam generator may be operated with PCL Industries Inc. diffuser plate (or equivalent District-authorized design). After changing burner diffuser plate, stack concentration of NOx (as NO2), CO, and O2 shall be measured by a District approved portable analyzer. Changes in burner diffuser plates and subsequent emission measurements shall be recorded in a contemporaneous log. [District Rule 2520] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 [District Rule 1081] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 4084, D4468, D6667, D 3246 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Total sulfur content of natural gas combusted shall not exceed 1.0 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed PM₁₀: 0.014 lb/MMBtu, and VOC: 0.003 lb/MMBtu [District Rules 4305 and NSR] Federally Enforceable Through Title V Permit
18. Emission rates, except during startup and shutdown, shall not exceed any of the following: NO_x (as NO₂): 0.0182 lb/MMBtu or 15 ppmvd @ 3% O₂, or CO: 0.021 lb/MMBtu or 29 ppmvd @ 3% O₂. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
19. Duration of start-up and shutdown shall not exceed 2 hours each per occurrence. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
20. During start-up and shutdown periods, emission rates shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Emissions shall not exceed either of the following limits: 54.0 lb-NO_x/day and 9,965 lb-NO_x/year, or 31.5 lb-CO/day and 11,498 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, SOx (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19, and fuel gas sulfur content - ASTM D 1072, D 4084, D4468, D6667, D 3246 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory. [District Rules 1081, 4305, and 4306] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
28. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305] Federally Enforceable Through Title V Permit
31. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NOx and CO. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
32. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
35. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
36. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
37. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
38. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
39. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
40. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
41. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
42. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
43. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-32] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

44. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
45. Permittee shall not discharge into the atmosphere NOx in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
46. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
47. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 38; for NO_x the units designated in condition 40. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
48. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: E-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-32] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-24-34

EXPIRATION DATE: 02/28/2006

SECTION: 31 TOWNSHIP: 29S RANGE: 22E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 61, DIS# 43001-79) WITH SO2 SCRUBBER

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. Permittee shall maintain 0.5 mile of paved asphalt roadway per District "Roadway Maintenance Requirements" guideline. Roadway shall be part of the 4.97 miles of roadway within the Cymric Field, Sections 25, 35 and 36, T29S/R21E, Section 31, T29S/R22E and Section 6, T30S/R22E, designated by Chevron and identified on the map submitted for Project 1000959. [District NSR Rule] Federally Enforceable Through Title V Permit
5. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
6. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
9. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1] Federally Enforceable Through Title V Permit
14. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
15. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
16. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
19. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. This generator is approved to operate at the following locations: Sec. 31, T29S/R22E; SW/4 of Sec. 36, T29S/R21E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S/R21E; and SE/4 of Sec. 35, T29S/21E. [District Rule 4102] Federally Enforceable Through Title V Permit
22. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
23. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule] Federally Enforceable Through Title V Permit
24. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District NSR Rule] Federally Enforceable Through Title V Permit
25. Scrubber liquor pH shall be maintained between 6 and 8, and shall be continuously monitored. [District NSR Rule] Federally Enforceable Through Title V Permit
26. Scrubber mist eliminator shall be properly cleaned and maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
27. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than 8.0 gpm/1000 acfm. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Emission rates shall not exceed PM10: 0.049 lb/MMBtu, SOx (as SO2): 0.324 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu or 29 ppmv @ 3% O2. [District NSR Rule, 4305 and 4306] Federally Enforceable Through Title V Permit
29. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District NSR Rule] Federally Enforceable Through Title V Permit
30. Testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
31. Source testing for NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
32. Source testing for NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
33. If permittee fails any compliance demonstration for NOx and CO emissions when testing not less than once every 36 months, source testing for NOx and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
34. The permittee shall keep daily records of the amount of natural gas and vapor recovery gas combusted, and the date and duration of scrubber operation, for a period of five years, and shall make records available for inspection upon request. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three one-hour test runs for PM10, and the arithmetic mean of three 30-minute test runs for NOx and CO. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
36. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rule 1081] Federally Enforceable Through Title V Permit
37. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rule 1081] Federally Enforceable Through Title V Permit
38. Stack gas oxygen for source test purposes shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

39. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
40. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
41. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
42. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
43. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
44. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
45. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
46. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
47. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
48. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
49. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
50. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-33] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

51. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
52. Permittee shall not discharge into the atmosphere NO_x in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
53. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
54. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 45; for NO_x the units designated in condition 47. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
55. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-33] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-25-35

ISSUANCE DATE: 05/24/2005

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 31 **TOWNSHIP:** 29S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH FGR (CUSA ID# 62, DIS# 43002-79); RETROFIT THE STEAM GENERATOR WITH A NORTH AMERICAN MAGNA-FLAME GLE (OR DISTRICT APPROVED EQUIVALENT) ULTRA-LOW NOX BURNER TO ACHIEVE 15 PPMVD-NOX @ 3% O2 (0.0182 LB-NOX/MMBTU)

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2010] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-25-35 : Aug 25 2009 2:30PM - RICKARDK : Joint Inspection NOT Required

5. Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
6. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
7. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4306 Emission Control Plan. [District Rule 4306, 6.4] Federally Enforceable Through Title V Permit
8. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
9. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
10. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
11. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
12. Permittee shall maintain 0.5 mile of paved asphalt roadway per District "Roadway Maintenance Requirements" guideline. Roadway shall be part of the 4.97 miles of roadway within the Cymric Field, Sections 25, 35 and 36, T29S/R21E, Section 31, T29S/R22E and Section 6, T30S/R22E, designated by Chevron and identified on the map submitted for Project 1000959. [District NSR Rule] Federally Enforceable Through Title V Permit
13. This generator is approved to operate at the following locations: Sec. 31, T29S/R22E; SW/4 of Sec. 36, T29S/R21E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S/R21E; and SE/4 of Sec. 35, T29S/21E. [District NSR Rule] Federally Enforceable Through Title V Permit
14. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
15. Emissions from the steam generator shall not exceed any of the following limits: 0.324 lb-SO_x/MMBtu, 0.049 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 29 ppmvd CO @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
17. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
18. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 30 ppmvd NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.324 lb-SO_x/MMBtu, 0.049 lb-PM₁₀/MMBtu, 29 ppmvd CO @ 3% O₂ or 0.021 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
19. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 30 ppmvd @ 3% O₂ or 0.036 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4306 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
20. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3]

CONDITIONS CONTINUE ON NEXT PAGE

21. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
22. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,965 lb-NOx/yr, 31.5 lb-CO/day, and 11,498 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Source testing to measure NOx and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
24. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. When incinerating vapor recovery gas, testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
31. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
33. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
34. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
35. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
36. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
37. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
38. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
39. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
40. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
41. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
42. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
43. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

44. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
45. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
46. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR/TVC gas incinerated in this unit. [District NSR Rule and 4406] Federally Enforceable Through Title V Permit
47. Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and 4406] Federally Enforceable Through Title V Permit
48. Permittee shall maintain with the permit a current listing of all TEOR and TVC gas systems providing vapors to this steam generator and shall make such listing readily available for District inspection upon request [District NSR Rule] Federally Enforceable Through Title V Permit
49. Permittee shall maintain daily records of volume of fuel gas burned, TEOR and TVC gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
50. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
51. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
52. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
53. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
54. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
55. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
56. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
57. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-33] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

58. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
59. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
60. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
61. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
62. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
63. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
64. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
65. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
66. Permittee shall not discharge into the atmosphere NO_x in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
67. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-33] Federally Enforceable Through Title V Permit
68. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 44; for NO_x the units designated in condition 46. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-33] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

69. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-33] Federally Enforceable Through Title V Permit

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-27-26

EXPIRATION DATE: 02/28/2006

SECTION: 07 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR #53 DIS# 43010-78 WITH NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER AND FGR (APPROVED FOR VARIOUS SPECIFIED LOCATIONS)

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Permittee shall maintain 0.3 mile of paved asphalt roadway per District "Roadway Maintenance Requirements" guideline. Roadway shall be part of the 4.97 miles of roadway within the Cymric Field, Sections 25, 35 and 36, T29S/R21E, Section 31, T29S/R22E and Section 6, T30S/R22E, designated by Chevron and identified on the map submitted for Project 1000959. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Approved locations for this equipment: Sec. 7, T30S/R22E; SW/4 of Sec. 36, T29S/R21E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S/R21E; SE/4 of Sec. 35, T29S/21E; and SE/4 of Sec. 8, T30S/R22E. [District NSR Rule] Federally Enforceable Through Title V Permit
19. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
20. Unit shall be fired on PUC quality natural gas only. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Flue gas recirculation shall be utilized, as needed, in conjunction with low NOx burner to maintain ongoing compliance with permitted emission limits [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. Gas fired emission rates shall not exceed PM10: 0.0068 lb/MMBtu, SOx (as SO2): 0.007 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, VOC: 0.011 lb/MMBtu, and CO: 0.023 lb/MMBtu or 31 ppmv @ 3% O2. [District Rules 4305 and NSR] Federally Enforceable Through Title V Permit
23. Fuel gas sulfur content shall not exceed 0.004 lb/MMBtu (as sulfur). [District NSR Rule] Federally Enforceable Through Title V Permit
24. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
26. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. Source testing for NOx and CO emissions shall be conducted within 60 days of initial startup and not less than once every 12 months thereafter, except as provided below. [District Rules 2520, 9.4.2, 2201, and 4305] Federally Enforceable Through Title V Permit
28. Source testing for NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
29. If permittee fails any compliance demonstration for NOx and CO emissions when testing not less than once every 36 months, source testing for NOx and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
30. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
31. For emissions source-testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
32. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
33. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
34. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-28-26

EXPIRATION DATE: 02/28/2006

SECTION: 07 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 52, DIS# 43014-78) WITH NORTH AMERICAN MAGNA-FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) OPERATING AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. Permittee shall maintain 0.3 mile of paved asphalt roadway per District "Roadway Maintenance Requirements" guideline. Roadway shall be part of the 4.97 miles of roadway within the Cymric Field, Sections 25, 35 and 36, T29S/R21E, Section 31, T29S/R22E and Section 6, T30S/R22E, designated by Chevron and identified on the map submitted for Project 1000959. [District NSR Rule] Federally Enforceable Through Title V Permit
2. This generator is approved to operate at the following locations: Section 7, T30S, R22E; SW/4 of Section 36, T29S, R21E; NE/4, NW/4, SE/4, and SW/4 of Section 1, T30S, R21E; SE/4 of Section 35, T29S, R21E; SW/4 and SE/4 of Section 6, T30S, R22E; SW/4 of Section 31, T29S, R22E; SE/4 and SW/4 of Section 8, T30S, R22E; and all of Sections 19 and 20, T30S, R22E. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
4. {521} Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. {524} When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: CHEVRON USA INC
Location: HEAVY OIL WESTERN STATIONARY SOURCE, KERN COUNTY
S-1128-28-26 : Aug 25 2008 2:25PM - RICKARDK

8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.4.2; 4305, 6.2.1; and 4306, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. {530} Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rule 4301, 5.2.2] Federally Enforceable Through Title V Permit
13. Gas fired emission rates shall not exceed PM₁₀: 0.0068 lb/MMBtu, SO_x (as SO₂): 0.007 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, VOC: 0.011 lb/MMBtu, and CO: 0.023 lb/MMBtu or 31 ppmv @ 3% O₂. [District NSR Rule and District Rules 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
14. Fuel gas sulfur content shall not exceed 0.004 lb/MMBtu (as sulfur). [District NSR Rule] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
16. {518} All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
17. The source plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
19. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
23. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
26. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
27. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
28. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
29. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
30. All records of required monitoring data and support information shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

DRAFT
PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. {533} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
32. {468} The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. {535} The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-35-31

EXPIRATION DATE: 02/28/2006

SECTION: SW36 TOWNSHIP: 29S RANGE: 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (CUSA ID# 89) WITH NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER AND FGR

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed any of the following; PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.002 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 47 ppmv @ 3% O₂. [District NSR Rule and District Rule 4305]
17. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Source testing for NO_x and CO emissions shall be conducted not less than once every 12 months thereafter, except as provided below. [District Rules 2520, 9.4.2, 2201, and 4305]
19. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
20. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
21. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
23. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305 and 4306]
24. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
26. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
30. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
31. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
32. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306]
33. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-32] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
35. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
36. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
37. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
38. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
39. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
40. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
41. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
42. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
43. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-32] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

44. Permittee shall not discharge into the atmosphere NO_x in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
45. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
46. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 38; for NO_x the units designated in condition 40. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-32] Federally Enforceable Through Title V Permit
47. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-32] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-38-23

EXPIRATION DATE: 02/28/2006

SECTION: 25 TOWNSHIP: 31S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER WITH FGR (#94)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
3. This equipment is approved to be operated at the following locations: Sec. 25, T31S/R22E; NE/4, NW/4, SE/4, SW/4 of Sec. 1, T30S/R21E; SW/4 of Sec. 36, T29S/R21E; and the SE/4 of Sec. 35, T29S/R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Only PUC-quality natural gas or a combination of natural gas and vapor recovery gas shall be used as fuel. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The combined PM10 emission rate for steam generators S-1128-38 and -158 shall not exceed 21.0 lb/day whenever steam generator S-1128-38 is at any of the following locations: Sec. 26, T32S/R23E; NE/4, NW/4, SE/4, SW/4 of Sec. 1, T30S/R21E; SW/4 of Sec. 36, T29S/R21E; and the SE/4 of Sec. 35, T29S/R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of fuel type, quantity, and results of monthly vapor recovery gas sulfur analyses, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of the dates, locations, and daily fuel consumption for steam generators S-1128-38 and -158, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Emissions from the steam generator shall not exceed any of the following limits: 0.324 lb-SOx/MMBtu, 0.014 lb-PM10/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.0182 lb-NOx/MMBtu or 29 ppmvd CO @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
11. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
13. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,965 lb-NOx/yr, 31.5 lb-CO/day, and 11,498 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
23. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
25. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
29. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
35. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
36. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR/TVC gas incinerated in this unit. [District NSR Rule and 4406] Federally Enforceable Through Title V Permit
37. Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and 4406] Federally Enforceable Through Title V Permit
38. Permittee shall maintain with the permit a current listing of all TEOR and TVC gas systems providing vapors to this steam generator and shall make such listing readily available for District inspection upon request [District NSR Rule] Federally Enforceable Through Title V Permit
39. Permittee shall maintain daily records of volume of fuel gas burned, TEOR and TVC gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
44. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
45. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
46. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

47. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
48. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
49. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
50. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
51. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
52. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
53. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
54. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
55. Permittee shall not discharge into the atmosphere NO_x in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
56. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

57. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 44; for NO_x the units designated in condition 46. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit
58. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-31, 32, 33, 39] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-64-17

EXPIRATION DATE: 02/28/2006

SECTION: 21 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

DORMANT EMISSIONS UNIT: 62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID# 80, DIS# 26765-77)

PERMIT UNIT REQUIREMENTS

1. This permit unit shall not be operated unless the owner or operator applies to modify the Title V permit to address the requirements of District Rule 2520, section 9.0 for this permit unit. [District Rule 2520, 9.0] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4306. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for that modification(s) except for changes in condition 4. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The fuel supply line shall be locked out with spectacle blind or physically disconnected or prevented from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu @3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District Rules 4305 and 2201] Federally Enforceable Through Title V Permit
7. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-65-16

EXPIRATION DATE: 02/28/2006

SECTION: 21 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

DORMANT EMISSIONS UNIT: 62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID #81, DIS# 26766-77)

PERMIT UNIT REQUIREMENTS

1. This permit unit shall not be operated unless the owner or operator applies to modify the Title V permit to address the requirements of District Rule 2520, section 9.0 for this permit unit. [District Rule 2520, 9.0] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4306. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in condition 4 below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The fuel supply line shall be locked out with spectacle blind or physically disconnected or prevented from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu @3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District Rules 4305 and 2201] Federally Enforceable Through Title V Permit
7. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-66-20

EXPIRATION DATE: 02/28/2006

SECTION: NE01 TOWNSHIP: 30S RANGE: 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (CUSA ID# 82, DIS# 26753-80) WITH FLUE GAS RECIRCULATION, VARIABLE FREQUENCY DRIVE FOR BLOWER MOTOR, AND O2 ANALYZER FOR FGR CONTROL

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Flue gas recirculation shall be utilized, as needed, in conjunction with low NOx burner to maintain ongoing compliance with permitted emission limits [District NSR Rule]
18. Emission rates shall not exceed any of the following; PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.002 lb/MMBtu, NOx (as NO2): 0.018 lb/MMBtu or 15 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 47 ppmv @ 3% O2. [District NSR Rule and District Rule 4305]
19. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
20. Source testing for NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.4.2, 2201, and 4305]
21. Source testing for NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
23. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. If the NO_x or CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed for more than one hour the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
26. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
30. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
32. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
33. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
34. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. These means shall be multiplied by the appropriate factor to determine compliance with the emission limits. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. All equipment, facilities, or systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible. [PSD SJ 76-24] Federally Enforceable Through Title V Permit
36. The regional administrator shall be notified within fifteen (15) days following any sudden and unavoidable failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions, and shall be notified of the estimated resultant emissions in excess of those projected under normal operations; and the methods to be utilized to restore normal operations. [PSD SJ 76-24] Federally Enforceable Through Title V Permit
37. In the event that any National Ambient Air Quality Standard (NAAQS) for sulfur-oxides (3-hour, 24-hour and annual average as provided by 40 CFR 50) is exceeded at any time, at either the CARB or the Westside Operators' SO₂ monitors in the McKittrick area, permittee shall take the control measures specified below, to maintain emissions at the existing levels. The control measure requirements of this permit must be met within twenty-four (24) hours of notification of any exceedance of the NAAQS for sulfur oxides. Also, within twenty-four (24) hours of notification of an exceedance, permittee shall report the exceedance and their control measures to the District and to the EPA's Chief of the Enforcement Section. [PSD SJ 76-24, a.1] Federally Enforceable Through Title V Permit
38. In the event that both the CARB or the Westside Operators' SO₂ monitors in the McKittrick area are removed from their present locations or are shutdown for a period exceeding 6 months, permittee shall reinstall the Chevron McKittrick Oil Field SO₂ monitoring station at its present location. The reinstalled station shall meet the technical specifications of the EPA and the District. Permittee shall then perform continuous ambient air monitoring at the previously approved site location. All monitoring data shall be reported to the District at least monthly or as further specified by the District. [PSD SJ 76-24, a.2] Federally Enforceable Through Title V Permit
39. In the event that there is an exceedance of any NAAQS for SO_x (3-hour, 24-hour and annual average as provided by 40 CFR 50) at the monitoring station described herein after construction and operation of the three proposed steam generators, one heater-treater, and associated equipment, permittee shall take control measures to reduce emissions to the emission levels in the McKittrick Oil Field (The Field) as they existed before the construction of the new equipment. These measures shall consist of: shutting down as many generators and associated equipment in The Field as is necessary to effect a reduction of 669 barrels per day of fuel consumption; or the use of a low sulfur fuel oil in as many generators in The Field to reduce SO₂ emissions by 2.7 tons/day; or such technology as approved by USEPA which would reduce SO₂ emissions by 2.7 tons/day; or any combination of the above. Any emission reductions accomplished for the purpose of avoiding an exceedance of any NAAQS shall be permanent and emissions shall not be increased thereafter. [PSD SJ 76-24] Federally Enforceable Through Title V Permit
40. Permittee shall not use any stacks higher than 50 feet (as measured from ground to top of stack) on any generator in the McKittrick Oil Field. [PSD SJ 76-24] Federally Enforceable Through Title V Permit
41. Permittee shall install and operate a casing-head vapor recovery system on their existing steam flood project as described on P. 15 of their application. [PSD SJ 76-24] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-68-15

EXPIRATION DATE: 02/28/2006

SECTION: 1 TOWNSHIP: 30S RANGE: 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID# 76, DIS# 43016-82) NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER WITH FLUE GAS RECIRCULATION, VARIABLE FREQUENCY DRIVE, AND O2 CONTROLLER - CYMRIC

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; 4306 6.2.1 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed PM₁₀: 0.005 lb/MMBtu and VOC: 0.007 lb/MMBtu. [District Rules 4305 and NSR] Federally Enforceable Through Title V Permit
17. Except during start-up or shutdown periods, emission rates shall not exceed any of the following limits: NO_x (as NO₂) 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, and CO 0.021 lb/MMBtu or 29 ppmv @ 3% O₂. [District Rules 4305, 4306 and NSR] Federally Enforceable Through Title V Permit
18. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation and emissions shall be minimized as technologically possible. The operator shall maintain daily records of the duration of the start-up or shutdown periods. [District Rules 4305 5.5.6 and 4306 5.3] Federally Enforceable Through Title V Permit
19. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operational status. Shutdown is defined as the period of time during which a unit is taken from an operational to non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.22 and 3.25] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
21. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
24. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
26. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the results of the 36-month source test demonstrates that the unit does not meet the applicable emissions limits, the source testing frequency shall revert to at least once every 12 months. [District Rules 4305 5.5.2 and 430 5.5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes, or longer, or within 30 after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 430 5.5.2 and 4306 5.5.2] Federally Enforceable Through Title V Permit
31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
32. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305 and 4306] Federally Enforceable Through Title V Permit
33. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
34. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-75-20

EXPIRATION DATE: 02/28/2006

SECTION: SW6 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID# 91, DIS# 43001-85) WITH NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Approved locations for this equipment: Section 1, T30S, R21E; SW 1/4 of Section 36, T29S, R21E; and SW 1/4 Section 6Z, T30S, R22E. [District NSR Rule and District Rule 4102] Federally Enforceable Through Title V Permit
15. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Emissions from this steam generator shall not exceed any of the following limits: PM₁₀: 0.005 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, VOC: 0.007 lb/MMBtu, and CO: 0.021 lb/MMBtu or 29 ppmv @ 3% O₂. [District NSR Rule and District Rule 4306, 5.1] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
19. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
22. Source testing for NO_x and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.4.2; 4305, 6.3.1; and 4306, 6.3.1] Federally Enforceable Through Title V Permit
23. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2; 4305, 6.3.1; and 4306, 6.3.1] Federally Enforceable Through Title V Permit
24. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2; 4305, 6.3.1; and 4306, 6.3.1] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
27. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
30. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
31. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit
33. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rules 1081; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit
34. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rules 1081; 4305, 6.2; and 4306, 6.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-76-18

ISSUANCE DATE: 03/06/2008

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: SE26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (CUSA ID# 93, DIS# 37425-2) WITH A NORTH AMERICAN GLE MAGNA-FLAME LOW-NOX BURNER, FLUE GAS RECIRCULATION, VARIABLE FREQUENCY DRIVE, AND O2 ANALYZER (PERMITTED FOR VARIOUS SPECIFIED LOCATIONS); UPGRADE THE STEAM/WATER PIPING OF RADIANT AND CONVECTION SECTIONS ONLY, AND ADD THE FOLLOWING SPECIFIED LOCATIONS NE/4, NW/4 AND SW1/4 SECTION 1, T30S, R21E; SW/4 SECTION 6, T30S, R22E; AND ALL OF SECTIONS 19 AND 20, T30S, R22E

CONDITIONS

1. This Authority to Construct (ATC) cancels and supersedes ATC S-1128-76-15. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
3. This generator is permitted to operate at the following locations: NE 1/4 Section 26 and NW 1/4 Section 25, T32S, R23E; all of Section 1, R30S, T21E; NW 1/4 Section 7, R30S, T22E; Section 36, T31S, R23E; SW 1/4 Section 6, R30S, T22E; and all of Section 19 and 20, R30S, T22E. [District Rule 2201 and District Rule 4102] Federally Enforceable Through Title V Permit
4. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST** NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.4.2, 4305, 6.2.1, and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5, and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. Total sulfur content of natural gas combusted shall not exceed 1.0 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Emission rates shall not exceed PM₁₀: 0.005 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, VOC: 0.007 lb/MMBtu, and CO: 0.021 lb/MMBtu or 29 ppmv @ 3% O₂. [District NSR Rule and District Rules 4305, 5.1.1 and 4306, 5.1.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

17. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
18. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
27. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

29. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
30. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
31. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-77-18

EXPIRATION DATE: 02/28/2006

SECTION: SE26 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (CUSA ID# 92, DIS# 37425-1) WITH A NORTH AMERICAN MODEL MAGNA FLAME GLE-4231 LOW NOX BURNER AND A WITH FLUE GAS RECIRCULATION, APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2.1 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Approved locations for this equipment: NE 1/4 Section 26 and NW 1/4 Section 25, T32S, R23E; SE 1/4 Section 1, R30S, T21E; NW 1/4 Section 7, R30S, T22E; Section 36, T31S, R23E; and SW 1/4 Section 6Z, T30S, R22E. [District Rule 4102]
15. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Flue gas recirculation shall be utilized, as needed, in conjunction with low NO_x burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed any of the following limits: 0.005 lb-PM₁₀/MMBtu; 0.018 lb-NO_x/MMBtu or 15 ppmv NO_x @ 3% O₂; 0.007 lb-VOC/MMBtu; and 0.021 lb-CO/MMBtu or 29 ppmv CO @ 3% O₂. [District NSR Rule and District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
20. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
27. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
28. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
29. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
30. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
33. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
36. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
37. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
38. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-79-12

EXPIRATION DATE: 02/28/2006

SECTION: 26 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR #95 (DIS#43007-85) EQUIPPED WITH NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER AND FGR (APPROVED FOR VARIOUS SPECIFIED LOCATIONS)

PERMIT UNIT REQUIREMENTS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
3. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; 4306 6.2.1 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. This equipment is approved to be operated at the following locations: Sec. 26, T32S/R23E; NE/4, NW/4, SE/4, SW/4 of Sec. 1, T30S/R21E; SW/4 of Sec. 36, T29S/R21E; and the SE/4 of Sec. 35, T29S/R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
16. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed: PM₁₀: 0.005 lb/MMBtu and VOC: 0.007 lb/MMBtu. [District Rules 4305 and NSR] Federally Enforceable Through Title V Permit
19. Except during start-up or shutdown periods, emission rates shall not exceed any of the following limits: NO_x (as NO₂) 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, and CO 0.020 lb/MMBtu or 28 ppmv @ 3% O₂. [District Rules 4305, 4306 and NSR]
20. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation and emissions shall be minimized as technologically possible. The operator shall maintain daily records of the duration of the start-up or shutdown periods. [District Rules 4305 5.5.6 and 4306 5.3]
21. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operational status. Shutdown is defined as the period of time during which a unit is taken from an operational to non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.22 and 3.25]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
24. All alternate monitoring parameter emissions readings shall be taken with the unit operating at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced over the 15 consecutive-minute period. [District Rules 4305 5.4 and 4306 5.4]
25. The permitted shall maintain records of: (1) the date and time of NO_x, CO and O₂ measurements; (2) the O₂ concentration in percent and the measured NO_x and CO concentrations, corrected to 3% O₂; (3) the make and model of exhaust gas analyzer; (4) exhaust gas analyzer calibration records and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305 and 4306]
26. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for District inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
27. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the results of the 36-month source test demonstrates that the unit does not meet the applicable emissions limits, the source testing frequency shall revert to at least once every 12 months. [District Rules 4305 5.5.2 and 430 5.5.2] Federally Enforceable Through Title V Permit
33. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes, or longer, or within 30 after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 430 5.5.2 and 4306 5.5.2]
34. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NOx and CO. These means shall be multiplied by the appropriate factor to determine compliance with the emission limits. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
35. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
36. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
37. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-80-12

EXPIRATION DATE: 02/28/2006

SECTION: 26 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH A NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER AND A FLUE GAS RECIRCULATION (FGR) SYSTEM (CUSA ID# 96) - VARIOUS SPECIFIED LOCATIONS IN THE CYMRIC OILFIELD

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993), [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. This equipment is approved to be operated at the following locations: Sec. 26, T32S, R23E; NE/4, NW/4, SE/4, SW/4 of Sec. 1, T30S, R21E; SE/4 and SW/4 of Sec. 36, T29S, R21E; and the SE/4 of Sec. 35, T29S, R21E. [District NSR Rule] Federally Enforceable Through Title V Permit
16. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Only PUC-quality natural gas shall be used as fuel. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed: PM₁₀: 0.005 lb/MMBtu; NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂; VOC: 0.007 lb/MMBtu; and CO: 0.021 lb/MMBtu or 29 ppmv @ 3% O₂. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
20. Source testing for NO_x and CO emissions shall be conducted no less than once every 12 months, except as provided below. [District Rules 2520, 9.4.2, 2201, and 4305] Federally Enforceable Through Title V Permit
21. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
23. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
25. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO_x and CO concentration corrected to 3% O₂, and the O₂ concentration. The records shall include a description of any corrective action taken to maintain the emissions within the acceptable range. These records shall be retained at the facility for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
29. If the NO_x or CO concentration, as measured by the portable analyzer, exceed the allowable emission limits, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission limits, the permittee shall perform compliance source testing within 60 days, utilizing District-approved test methods to demonstrate compliance with the applicable emission limits. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
30. The portable analyzer shall be calibrated as recommended by the manufacturer. All instrument calibration data shall be kept on file including the date of calibration. The calibration date shall not exceed 6 months prior to the date the stack concentrations are measured and recorded. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
31. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
32. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
33. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-84-17

EXPIRATION DATE: 02/28/2006

SECTION: 23 TOWNSHIP: 29S RANGE: 21E

EQUIPMENT DESCRIPTION:

DORMANT EMISSIONS UNIT: 30 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 11, DIS# 27551-77) PERMITTED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. This permit unit shall not be operated unless the owner or operator applies to modify the Title V permit to address the requirements of District Rule 2520, section 9.0 for this permit unit. [District Rule 2520, 9.0] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4306. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in condition 4 below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The fuel supply line shall be locked out with spectacle blind or physically disconnected or prevented from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu @3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This generator is permitted to operate at the following locations: Section 1, Township 30 South, Range 21 East, and Section 23, Township 29 South, Range 21 East. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-111-14

EXPIRATION DATE: 02/28/2006

SECTION: 6 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID# 72) WITH A NORTH AMERICAN MODEL #4231 G-LE MAGNA FLAME LOW-NOX BURNER WITH VARIABLE FREQUENCY DRIVE FOR THE BLOWER MOTOR, AN O2 ANALYZER FOR FGR CONTROL, AND APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. This generator is approved to operate at the following locations: Sec. 6, T30S/R22E; SW/4 of Sec. 36, T29S/R21E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S/R21E; and SE/4 of Sec. 35, T29S/21E. [District NSR Rule] Federally Enforceable Through Title V Permit
16. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed PM₁₀: 0.005 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, VOC: 0.007 lb/MMBtu, and CO: 0.021 lb/MMBtu or 29 ppmv @ 3% O₂. [District Rules 4305 and NSR] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.4.2, 4305, 5.4, and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
21. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.4.2, 4503, 5.4, and 4306, 5.4] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
23. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
26. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. Source testing for NO_x and CO emissions shall be conducted within 60 days of initial startup and not less than once every 12 months thereafter, except as provided below. [District Rules 2520, 9.4.2, 2201, and 4305]
29. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
30. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.4.2 and 4305, 5.5.5] Federally Enforceable Through Title V Permit
32. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
33. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
34. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-112-18

EXPIRATION DATE: 02/28/2006

SECTION: 6 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH A NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER AND FLUE GAS RECIRCULATION (CUSA ID# 73) APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
2. This generator is approved to operate at the following locations: Sec. 6, T30S/R22E; SW/4 of Sec. 36, T29S/R21E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S/R21E; and SE/4 of Sec. 35, T29S/21E. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates shall not exceed PM₁₀: 0.005 lb/MMBtu, NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmv @ 3% O₂, VOC: 0.007 lb/MMBtu, and CO: 0.021 lb/MMBtu or 29 ppmv @ 3% O₂. [District Rules 4305, 4306 and NSR] Federally Enforceable Through Title V Permit
6. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; 4306, 6.2.1 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.4.2, 4305 and 4306] Federally Enforceable Through Title V Permit
14. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
15. Source testing for NO_x and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.4.2, 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
16. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2, 4305, and 4306] Federally Enforceable Through Title V Permit
17. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
18. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
19. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
22. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
23. If permittee fails any compliance demonstration for NOx and CO emissions when testing not less than once every 36 months, source testing for NOx and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2, 4305, and 4306] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
25. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305, and 4306] Federally Enforceable Through Title V Permit
26. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
28. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 2520, 9.4.2, 4305, and 4306] Federally Enforceable Through Title V Permit
30. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
31. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

34. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-113-18

EXPIRATION DATE: 02/28/2006

SECTION: 26 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (CUSA ID# 97) WITH A NORTH AMERICAN MAGNA-FLAME GLE LOW-NOX BURNER AND FGR - VARIOUS SPECIFIED LOCATIONS IN THE CYMRIC OILFIELD

PERMIT UNIT REQUIREMENTS

1. This equipment is approved to be operated at the following locations: Sec. 26, T32S, R23E; NE/4, NW/4, SE/4, and SW/4 of Sec. 1, T30S, R21E; SE/4 and SW/4 of Sec. 36, T29S, R21E; and the SE/4 of Sec. 35, T29S, R21E. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 [District Rule 1081] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 4084, D4468, D6667, D 3246 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Total sulfur content of natural gas combusted shall not exceed 1.0 grain/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Emission rates shall not exceed PM₁₀: 0.005 lb/MMBtu or VOC: 0.007 lb/MMBtu. [District Rules 4305 and 2201]
15. Emission rates, except during startup and shutdown, shall not exceed any of the following: NO_x (as NO₂): 0.0182 lb/MMBtu or 15 ppmvd @ 3% O₂, or CO: 0.021 lb/MMBtu or 29 ppmvd @ 3% O₂. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
16. Duration of start-up and shutdown shall not exceed 2 hours each per occurrence. [District Rules 4305 and 4306, 5.3.1] Federally Enforceable Through Title V Permit
17. During start-up and shutdown periods, emission rates shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Emissions shall not exceed either of the following limits: 54.0 lb-NO_x/day and 9,965 lb-NO_x/year, or 31.5 lb-CO/day and 11,498 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
20. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081]
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4; SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19, and fuel gas sulfur content - ASTM D 1072, D 4084, D4468, D6667, D 3246 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory. [District Rules 1081, 4305, 6.2 and 4306, 6.2]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306]
25. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.3 and 4306, 5.4.3]
26. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
27. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5.4 and 4306, 5.5.4] Federally Enforceable Through Title V Permit
28. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305] Federally Enforceable Through Title V Permit
29. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2]
30. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
31. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
32. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-154-25

EXPIRATION DATE: 02/28/2006

SECTION: 08 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL/PRODUCED GAS FIRED STEAM GENERATOR (CUSA ID #14) WITH NORTH AMERICAN 4231 G-LE MAGNA FLAME LOW NOX BURNER AND FGR (APPROVED FOR VARIOUS SPECIFIED LOCATIONS)

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Permittee shall maintain 0.07 mile of paved asphalt roadway per District "Roadway Maintenance Requirements" guideline. Roadway shall be part of the 4.97 miles of roadway within the Cymric Field, Sections 25, 35 and 36, T29S/R21E, Section 31, T29S/R22E and Section 6, T30S/R22E, designated by Chevron and identified on the map submitted for Project 1000959. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Flue gas recirculation shall be utilized, as needed, in conjunction with low NOx burner to maintain ongoing compliance with permitted emission limits [District NSR Rule] Federally Enforceable Through Title V Permit
19. Emission rates shall not exceed any of the following: PM10 - 0.0076 lb/MMBtu, SOx (as SO2) - 0.0033 lb/MMBtu, NOx (as NO2) - 0.018 lb/MMBtu or 15 ppmv @ 3% O2, VOC - 0.003 lb/MMBtu, or CO - 0.021 lb/MMBtu or 29 ppmv @ 3% O2. [District Rules NSR and 4305] Federally Enforceable Through Title V Permit
20. Steam generator shall be equipped with fuel gas (natural gas) and supplemental gas (produced gas) volumetric flow rate indicators. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Permittee shall measure and record the volume of fuel gas (natural gas) and supplemental gas (produced gas) burned in the steam generator on a daily basis. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. Permittee shall measure and record fuel gas (natural gas) and supplemental gas (produced gas) sulfur contents at least once per month. [District NSR Rule] Federally Enforceable Through Title V Permit
23. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
26. The portable analyzer shall be calibrated as recommended by the manufacturer. All instrument calibration data shall be kept on file including the date of calibration. The calibration date shall not exceed 6 months prior to the date the stack concentrations are measured and recorded. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
27. Source testing for NO_x and CO emissions shall be conducted not less than once every 12 months thereafter, except as provided below. [District Rules 2520, 9.4.2, 2201, and 4305] Federally Enforceable Through Title V Permit
28. Source testing for NO_x and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
29. If permittee fails any compliance demonstration for NO_x and CO emissions when testing not less than once every 36 months, source testing for NO_x and CO emissions shall be conducted not less than once every 12 months. [District Rules 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
30. The following conditions must be met for representative units to be used to test for NO_x and CO emissions for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of heat input, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
31. All units in a group for which representative units are annually source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
32. An operating log shall be maintained for each unit of the group. The log shall include, on a monthly basis, the total hours of operation, type and quantity of fuel used, and preventative and corrective maintenance and modifications performed. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
33. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated such that in three years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. Should any of the representative units exceed the required emission limits of this permit, each of the unit in the group shall conduct emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
35. Permittee shall maintain records of fuel gas and supplemental gas daily flow rates, sulfur contents, and calculated daily SOx emissions. Records shall be kept for 5 years and shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
36. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
37. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
38. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
39. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-159-14

EXPIRATION DATE: 02/28/2006

SECTION: 18 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER WITH FGR (CUSA ID# 18-A)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
2. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
3. This equipment is approved to be operated at the following locations: Sec. 18, T30S, R22E and SE/4 of Sec. 8, T30S, R22E. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.014 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 29 ppmvd CO @ 3% O₂ or 0.021 lb-CO/MMBtu. [District NSR Rule and District Rules 4301, 5.2; 4305, 5.1; and 4306, 5.1] Federally Enforceable Through Title V Permit
7. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3]
9. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
10. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 9,965 lb-NO_x/yr, 31.5 lb-CO/day, and 11,498 lb-CO/yr. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
13. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
17. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2; 4305, 6.3.2; and 4306, 6.3.2] Federally Enforceable Through Title V Permit
27. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2; 4305, 6.3.2; and 4306, 6.3.2] Federally Enforceable Through Title V Permit
28. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2; 4305, 6.3.2; and 4306, 6.3.2] Federally Enforceable Through Title V Permit
29. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2; 4305, 6.3.2; and 4306, 6.3.2] Federally Enforceable Through Title V Permit
30. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 9.3.2; 4305, 6.3.2; and 4306, 6.3.2] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
32. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR/TVC gas incinerated in this unit. [District NSR Rule and District Rule 4406] Federally Enforceable Through Title V Permit
33. Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and District Rule 4406] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

34. Permittee shall maintain with the permit a current listing of all TEOR and TVC gas systems providing vapors to this steam generator and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of volume of fuel gas burned, TEOR and TVC gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
36. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-396-9

EXPIRATION DATE: 02/28/2006

SECTION: NW08 **TOWNSHIP:** 30S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

DORMANT EMISSIONS UNIT: 30 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR DIS# 9157-67

PERMIT UNIT REQUIREMENTS

1. This permit unit shall not be operated unless the owner or operator applies to modify the Title V permit to address the requirements of District Rule 2520, section 9.0 for this permit unit. [District Rule 2520, 9.0] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4306. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
3. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in condition 4 below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The fuel supply line shall be locked out with spectacle blind or physically disconnected or prevented from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Total sulfur content of natural gas combusted shall not exceed 0.75 grain/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emissions rates shall not exceed any of the following: NOx (as NO₂): 30 ppmv @3% O₂; or CO: 400 ppmv @3% O₂. [District Rule 4305] Federally Enforceable Through Title V Permit
7. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1128-941-2

EXPIRATION DATE: 02/28/2006

SECTION: SE 8 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MAGNA-FLAME GLE
ULTRA LOW NOX BURNER WITH FGR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
3. Permittee shall maintain 0.05 mile of paved asphalt roadway per District "Roadway Maintenance Requirements" guideline. Roadway shall be part of the 4.97 miles of roadway within the Cymric Field, Sections 25, 35 and 36, T29S/R21E, Section 31, T29S/R22E and Section 6, T30S/R22E, designated by Chevron and identified on the map submitted for Project 1000959. [Rule 2201] Federally Enforceable Through Title V Permit
4. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 29 ppmvd CO @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 30 ppmvd NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 29 ppmvd CO @ 3% O₂ or 0.021 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
8. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 30 ppmvd @ 3% O₂ or 0.036 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4306 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
9. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
11. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,965 lb-NOx/yr, 31.5 lb-CO/day, and 11,498 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
28. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
29. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
30. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
31. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
33. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR/TVC gas incinerated in this unit. [District NSR Rule and 4406] Federally Enforceable Through Title V Permit
34. Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and 4406] Federally Enforceable Through Title V Permit
35. Permittee shall maintain with the permit a current listing of all TEOR and TVC gas systems providing vapors to this steam generator and shall make such listing readily available for District inspection upon request [District NSR Rule] Federally Enforceable Through Title V Permit
36. Permittee shall maintain daily records of volume of fuel gas burned, TEOR and TVC gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
37. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.