

San Joaquin Valley Air Pollution Control District
Authority to Construct Application Review
Diesel-Fired Emergency Fire Pump

Facility Name:	Bronco Wine Co.	Date:	May 23, 2014
Mailing Address:	PO Box 789 Ceres, CA 95307	Engineer:	Nick Peirce
Contact Person:	Paul Franzia		
Telephone:	(209) 272-3276		
Application No:	N-1665-516-0		
Project No:	N-1141841		
Complete:	May 21, 2014		

I. Proposal:

Bronco Wine Company is proposing to install a 389 bhp diesel-fired emergency standby internal combustion (IC) engines powering an electrical generator.

Bronco Winery Company received their Title V Permit on April 30, 2008. This modification can be classified as a Title V minor modification pursuant to Rule 2520, Section 3.20, and can be processed with a Certificate of Conformity (COC). The facility has requested that this project be processed in that manner. Since the applicant has requested that this project be processed with COC, the 45-day EPA review will be completed prior to the issuance of the ATC permits. The modifications authorized in this project will subsequently be incorporated into the Title V permit through an application for an administrative amendment.

II. Applicable Rules:

Rule 2201 New and Modified Stationary Source Review Rule (4/21/11)
Rule 2410 Prevention of Significant Deterioration (6/16/11)
Rule 2520 Federally Mandated Operating Permits (6/21/01)
Rule 4001 New Source Performance Standards (4/14/99)
Rule 4002 National Emission Standards for Hazardous Air Pollutants (5/20/04)
Rule 4101 Visible Emissions (2/17/05)
Rule 4102 Nuisance (12/17/92)
Rule 4201 Particulate Matter Concentration (12/17/92)
Rule 4701 Stationary Internal Combustion Engines – Phase 1 (8/21/03)
Rule 4702 Stationary Internal Combustion Engines (11/14/13)
Rule 4801 Sulfur Compounds (12/17/92)
CH&SC 41700 Health Risk Assessment
CH&SC 42301.6 School Notice

Title 17 CCR, Section 93115 - Airborne Toxic Control Measure (ATCM) for
Stationary Compression-Ignition (CI) Engines
California Environmental Quality Act (CEQA)
Public Resources Code 21000-21177: California Environmental Quality Act
(CEQA)
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-
15387: CEQA Guidelines

III. Project Location:

The facility is located at 6342 Bystrum Road, Ceres, CA. The District has verified that the equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. Process Description:

The emergency standby engine will power an electrical generator. Other than emergency standby operation, the engine may be operated up to 50 hours per year for maintenance and testing purposes.

V. Equipment Listing:

N-1665-516-0: 389 BHP IVECO MODEL F2CE9685A-E DIESEL-FIRED
EMERGENCY ENGINE (TIER 3 CERTIFIED) POWERING AN
ELECTRICAL GENERATOR.

VI. Emission Control Technology Evaluation:

The applicant has proposed to install a Tier 3 certified diesel-fired IC engine that will be fired on very low-sulfur diesel fuel (0.0015% by weight sulfur maximum).

NO_x, CO, VOC and PM₁₀:

The proposed engine does not meet the latest published Tier Certification requirements; however, compliance with both BACT and CARB's stationary ATCM requirements will be met as described below (see Appendix B for a copy of the emissions data sheet and/or the ARB/EPA executive order).

Although Tier 4i requirements for this category of engine went into effect in 2011, CARB regulations and District policy allows for the availability of Tier 4i units to be accounted for. CARB's Stationary ATCM exemption §93115.3(u) says, "If the Executive Officer or District finds, based on verifiable information from the engine manufacturer, distributor, or dealer, that current model year engines meeting the current emission standards are not available or not available in sufficient numbers

or in a sufficient range of makes, models, and horsepower ratings, then the Executive Officer or the District may allow the sale, purchase, or installation of a new stock engine meeting the emission standards from the previous model year to meet the new stationary diesel-fueled engine emission standards pursuant to title 13 of the California Code of Regulations or 40 CFR part 89.” The District has thoroughly investigated, with each of the common manufacturers’, the availability of Tier 4i units in this size range, and has found them to be currently unavailable. Since Tier 4i units are not available, as described above, the installation of a Tier 3 unit is acceptable, as Tier 3 is the prior published Tier in this engine’s size range.

SO_x:

The use of very low-sulfur diesel fuel (0.0015% by weight sulfur maximum) reduces SO_x emissions by over 99% from standard diesel fuel.

VII. General Calculations:

A. Assumptions:

Operating schedule:	24 hours/day, 50 hours/year
Density of diesel fuel:	7.1 lb/gal
EPA F-factor:	9051 dscf/MMBtu (corrected to 60° F)
PM ₁₀ fraction of diesel exhaust is	96% (Reference - CARB, 1988)
Fuel heating value:	137,000 Btu/gal
BHP to Btu/hr conversion:	2542.5 Btu/hp-hr
Thermal efficiency of engine	commonly ≈ 35%
Fuel rate:	19.1 gal/hr @ 100% load (applicant)

B. Emission Factors:

The applicant supplied the emissions factor for NO_x and VOC emissions as a combined emission factor. Therefore, the District will use data from the EPA document “*Exhaust and Crankcase Emission Factors for Nonroad Engine Modeling – Compressions Ignition*”, dated November 2002, as presented in the following table to estimate NO_x and VOC emissions (District assumption).

Tier 2 and Tier 3 Diesel-Fired IC Engines NO _x and VOC Estimated Emissions						
Horsepower Range (bhp)	Combined Standard, NO _x + VOC (g/bhp-hr)		Estimated NO _x Emissions (g/bhp-hr)		Estimated VOC Emissions (g/bhp-hr)	
	Tier 2	Tier 3	Tier 2	Tier 3	Tier 2	Tier 3
≥ 50 to < 100	5.6	3.5	5.2	3.3	0.4	0.2
≥ 100 to < 175	4.9	3.0	4.5	2.8	0.4	0.2
≥ 175 to < 300	4.9	3.0	4.5	2.8	0.4	0.2
≥ 300 to < 600	4.8	3.0	4.5	2.8	0.3	0.2
≥ 600 to < 750	4.8	3.0	4.5	2.8	0.3	0.2
≥ 750	4.8	N/A	4.5	N/A	0.3	N/A

This 389 bhp engine is a Tier 3 certified IC engine and the applicant supplied the combined NO_x + VOC emissions factor as 2.60 g/bhp-hr. Therefore, the NO_x and VOC emissions factors are calculated as follows:

$$\begin{aligned} \text{NO}_x \text{ (g/bhp-hr)} &= \text{NO}_x + \text{VOC (g/bhp-hr)} \times (2.8 \text{ g/bhp-hr} \div 3.0 \text{ g/bhp-hr}) \\ \text{NO}_x \text{ g/bhp-hr} &= 2.60 \text{ g/bhp-hr} \times (2.8 \text{ g/bhp-hr} \div 3.0 \text{ g/bhp-hr}) \\ \mathbf{NO_x} &= \mathbf{2.43 \text{ g/bhp-hr}} \end{aligned}$$

$$\begin{aligned} \text{VOC (g/bhp-hr)} &= \text{NO}_x + \text{VOC (g/bhp-hr)} \times (0.2 \text{ g/bhp-hr} \div 3.5 \text{ g/bhp-hr}) \\ \text{VOC g/bhp-hr} &= 2.60 \text{ g/bhp-hr} \times (0.2 \text{ g/bhp-hr} \div 3.0 \text{ g/bhp-hr}) \\ \mathbf{VOC} &= \mathbf{0.17 \text{ g/bhp-hr}} \end{aligned}$$

Pollutant	Emission Factor (g/bhp-hr)	Source
NO _x	2.43	Engine manufacturer
CO	0.50	Engine manufacturer
VOC	0.17	Engine manufacturer
PM10	0.13	Engine manufacturer
SO _x	0.005	Calculated below

The emission factor for SO_x may be calculated based on the current CARB standard for diesel sulfur content, which is 15 ppm by weight.

$$\frac{0.000015 \text{ lb - S}}{\text{lb - fuel}} \times \frac{7.1 \text{ lb - fuel}}{\text{gallon}} \times \frac{2 \text{ lb - SO}_2}{1 \text{ lb - S}} \times \frac{1 \text{ gal}}{137,000 \text{ Btu}} \times \frac{1 \text{ bhp input}}{0.35 \text{ bhp out}} \times \frac{2,542.5 \text{ Btu}}{\text{bhp - hr}} \times \frac{453.6 \text{ g}}{\text{lb}} = 0.005 \frac{\text{g - SO}_x}{\text{bhp - hr}}$$

C. Calculations

1. Pre-Project Emissions (PE1)

The unit is new, therefore, PE1 = 0.

2. Post-Project PE (PE2)

The potential to emit emissions from this emergency IC engine is based on the maximum operating capacity of the engine for 24 hours per day. The following calculation for NO_x emissions is representative of emission calculations for all pollutants. Annual emissions are based on 50 hours per year for non-emergency operation.

NO_x: 2.43 g/hp-hr × 389 hp × lb/453.6 g
 NO_x: 2.08 lb/hr, 50.0 lb/day, 104 lb/yr
 CO: 0.43 lb/hr, 10.3 lb/day, 21 lb/yr
 VOC: 0.15 lb/hr, 3.5 lb/day, 7 lb/yr
 PM₁₀: 0.11 lb/hr, 2.7 lb/day, 6 lb/yr
 SO_x: 0.004 lb/hr, 0.1 lb/day, 0.2 lb/yr¹

	NO _x	CO	VOC	PM ₁₀	SO _x
Daily PE	50.0	10.3	3.5	2.7	0.1
Annual PE	104	21	7	6	0

3. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to Section 4.9 of District Rule 2201, the Pre-Project Stationary Source Potential to Emit (SSPE1) is the Potential to Emit (PE) from all units with valid ATCs or PTOs at the Stationary Source and the quantity of Emission Reduction Credits (ERCs) which have been banked since September 19, 1991 for Actual Emissions Reductions that have occurred at the source, and which have not been used on-site. The following is from the Application Review document for project N-1140171, unless otherwise noted.

SSPE1 (lb/yr)					
Permit Nos.	NOx	CO	VOC	SOx	PM10
All Permit Units	3,303	21,494	661,915	708	1,609
ERC	0	0	0	0	0
Total	3,303	21,494	661,915	708	1,609

¹ Per District Policy APR 1105, Use of Significant Figures, annual emissions less than 0.5 lb are set to zero.

4. Post-Project Stationary Source Potential to Emit (SSPE2)

Pursuant to Section 4.10 of District Rule 2201, the Post-Project Stationary Source Potential to Emit (SSPE2) is the Potential to Emit (PE) from all units with valid ATCs or PTOs, except for emissions units proposed to be shut down as part of the Stationary Project, at the Stationary Source and the quantity of Emission Reduction Credits (ERCs) which have been banked since September 19, 1991 for Actual Emissions Reductions that have occurred at the source, and which have not been used on-site.

SSPE2 (lb/yr)					
Permit Nos.	NOx	CO	VOC	SOx	PM10
All Permit Units	3,303	21,494	661,915	708	1,609
ERC	0	0	0	0	0
N-1665-516-0	104	21	7	0	6
Total	3,407	21,515	661,922	708	1,615

5. Major Source Determination

Rule 2201 Major Source Determination:

Pursuant to Section 3.24 of District Rule 2201, a Major Source is a stationary source with post project emissions or a Post Project Stationary Source Potential to Emit (SSPE2), equal to or exceeding one or more of the following threshold values. However, Section 3.24.2 states, “for the purposes of determining major source status, the SSPE2 shall not include the quantity of emission reduction credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions that have occurred at the source, and which have not been used on-site.”

No ERCs for onsite emission reductions have been banked. Therefore, adjustment to SSPE2 is not necessary.

Major Source Determination					
Pollutant	SSPE1 (lb/yr)	SSPE2 (lb/yr)	Major Source Threshold (lb/yr)	Existing Major Source?	Becoming a Major Source?
NO _x	3,303	3,407	20,000	No	No
CO	21,494	21,515	200,000	No	No
VOC	661,915	661,922	20,000	Yes	No
SO _x	708	708	140,000	No	No
PM ₁₀	1,609	1,615	140,000	No	No

As seen in the table above, the facility is an existing Major Source for VOC and it will not become a Major Source for any other pollutants as a result of this project.

Rule 2410 Major Source Determination:

The Major Source thresholds, the current facility potentials to emit and whether or not the facility is currently a PSD Major Source are shown on the following table.

Pollutant	Threshold (tons/yr)	Facility PE (ton/yr)	PSD Major Source
NOx	250	1.7	No
CO	250	10.75	No
VOC	250	331.0	Yes
SOx	250	0.35	No
PM10	250	0.80	No
PM	250	0.80	No
CO ₂ e	100,000	>100,000 ²	Yes

6. Baseline Emissions (BE)

The unit is new, therefore, its Baseline Emissions are zero.

7. SB 288 Major Modification

SB-288 Major Modification:

The purpose of SB-288 Major Modification calculations is to determine the following:

If Best Available Control Technology (BACT) is required for a new or modified emission unit that results in a Major Modification (District Rule 2201, §4.1.3); and

If a public notification is triggered (District Rule 2201, §5.4.1).

The facility is a Major Source only for VOC, therefore, an SB-288 Major Modification determination is required only for VOC. Per section 3.36 of Rule 2201, the SB-288 Major Modification threshold is 50,000 lb/yr. As shown in section VII.C.2 of this document, the potential to emit of VOC is less than this threshold, therefore, this permitting action is not an SB-288 Major Modification.

² From the Application Review document for project N-1140171.

8. Federal Major Modification

As shown in section VII.C.5 of this document, this facility is a Major Source for only VOC. Therefore, a Federal Major Modification determination is required for only VOC. Per section 3.18.1.4 of Rule 2201, the Federal Major Modification Emission Increase (EI) threshold for VOC is 0 lb/yr.

$$EI_{\text{VOC}} = PAE_{\text{VOC}} - BAE_{\text{VOC}}$$

PAE = post-project projected actual emissions

BAE = pre-project baseline actual emissions

PAE (VOC):

The PAE of VOC will be assumed to be the Potential to Emit. As shown in section VII.C.2 of this document, the PAE of VOC is:

$$PAE_{\text{VOC}} = 7 \text{ lb/yr}$$

BAE (VOC):

The unit is new, therefore BAE is zero.

EI (VOC) Calculation:

$$EI (\text{VOC}) = 7 \text{ lb/yr} - 0 \text{ lb/yr} = 7 \text{ lb/yr}$$

Federal Major Modification Determination:

Per the District's draft policy titled "Implementation of Rule 2201 (as amended on 12/18/08 and effective on 6/10/10) for SB288 Major Modifications and Federal Major Modifications", if the average increase in emissions is 0.5 lb/day or less then the project does not trigger a Federal Major Modification.

$$\begin{aligned} \text{Average IPE (to the tenths place of precision as specified in the policy)} \\ = (7 \text{ lb/yr}) / (365 \text{ days/yr}) = 0.02 \text{ lb/day} \end{aligned}$$

The average IPE will not exceed 0.5 lb/day, therefore, this permitting action is not a Federal Major Modification.

9. Quarterly Net Emissions Change (QNEC)

The QNEC is calculated solely to establish emissions that are used to complete the District's PAS emissions profile screen. Detailed QNEC calculations are included in Appendix C.

VIII. Compliance

Rule 2201 New and Modified Stationary Source Review Rule

A. Best Available Control Technology (BACT)

1. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis for the following*:

- a. Any new emissions unit with a potential to emit exceeding two pounds per day,
- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an AIPE exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in an SB288 Major Modification or a Federal Major Modification, as defined by the rule.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

As discussed in Section I, the facility is proposing to install an emergency standby IC engine. Additionally, as determined in Sections VII.C.7 and VII.C.8, this project does not result in an SB288 Major Modification or a Federal Major Modification. Therefore, BACT can only be required if the daily emissions exceed 2.0 lb/day for any pollutant.

The daily emissions from this new engine are compared to the BACT threshold levels in the following table:

New Emissions Unit BACT Applicability				
Pollutant	Daily Emissions for each unit (lb/day)	BACT Threshold (lb/day)	SSPE2 (lb/yr)	BACT Required?
NO _x	50.0	> 2.0	n/a	Yes
SO _x	0.1	> 2.0	n/a	No
PM ₁₀	2.7	> 2.0	n/a	Yes
CO	10.3	> 2.0 and SSPE2 ≥ 200,000 lb/yr	21,515	No
VOC	3.5	> 2.0	n/a	Yes

As shown above, BACT will be required for NO_x, PM₁₀ and VOC emissions.

2. BACT Guideline

BACT Guideline 3.1.1, which appears in Appendix D of this report, covers diesel-fired emergency IC engines.

3. Top-Down BACT Analysis

Per District Policy APR 1305, Section IX, “A top-down BACT analysis shall be performed as a part of the Application Review for each application subject to the BACT requirements pursuant to the District’s NSR Rule for source categories or classes covered in the BACT Clearinghouse, relevant information under each of the following steps may be simply cited from the Clearinghouse without further analysis.” Pursuant to the attached Top-Down BACT Analysis, which appears in Appendix D of this report, BACT is satisfied with:

NO_x, VOC: Tier 3 engine
PM₁₀: 0.15 g/hp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)

The applicant has proposed to install an emergency engine that will comply with these standards. Therefore, BACT will be satisfied.

B. Offsets

Since emergency IC engines are exempt from the offset requirements of Rule 2201, per Section 4.6.2, offsets are not required for this engine and offset calculations are not required.

C. Public Notification

1. Applicability

Public noticing is required for:

- a. New Major Sources, SB288 Major Modifications, Federal Major Modifications

As shown in Sections VII.C.5, VII.C.7, and VII.C.8, this facility is not a new Major Source, not an SB 288 Major Modification and is not a Federal Major Modification.

- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any pollutant

As shown in Section VII.C.2, the daily potential to emit for any pollutant will not exceed 100 pounds. Therefore, a public notice is not required.

- c. Any project that results in the offset thresholds being surpassed
The emission increases associated with this unit will not cause an offset threshold to be surpassed.
- d. Any project with a Stationary Source Project Increase in Permitted Emissions (SSIPE) greater than 20,000 lb/year for any pollutant.

For this project, the proposed engine is the only emission source. Since the proposed engine emissions are below 20,000 lb/year for all pollutants (See Section VII.C.2), the SSIPE for this project will be below the public notice threshold.

2. Public Notice Action

As shown above, this project will not require public noticing.

D. Daily Emissions Limits

Daily Emissions Limitations (DELs) and other enforceable conditions are required by Section 3.16 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. Per Sections 3.16.1 and 3.16.2, the DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. Therefore, the following conditions will be included on the ATC to ensure compliance:

- Emissions from this IC engine shall not exceed any of the following limits: 2.43 g-NOx/bhp-hr, 0.50 g-CO/bhp-hr, or 0.17 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115]
- Emissions from this IC engine shall not exceed 0.13 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 17 CCR 93115]
- Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115]

E. Compliance Assurance

1. Source Testing

Pursuant to District Policy APR 1705, source testing is not required for emergency standby IC engines to demonstrate compliance with Rule 2201.

2. Monitoring

Monitoring is not required to demonstrate compliance with Rule 2201.

3. Recordkeeping

Recordkeeping requirements, in accordance with District Rule 4702, will be discussed in Section VIII, *District Rule 4702*, of this evaluation.

4. Reporting

Reporting is not required to ensure compliance with Rule 2201.

Rule 2410 Prevention of Significant Deterioration

Rule 2410 applies to pollutants for which the District is in attainment or for unclassified, pollutants. The pollutants addressed in the PSD applicability determination are listed as follows:

- NO₂ (as a primary pollutant)
- SO₂ (as a primary pollutant)
- CO
- PM
- PM₁₀
- Greenhouse gases (GHG): CO₂, N₂O, CH₄, HFCs, PFCs, and SF₆

The first step of this PSD evaluation consists of determining whether the facility is an existing PSD Major Source or not. As shown in section VII.C.5, the facility is a major PSD source for VOC and CO₂e.

I. Project Location Relative to Class 1 Area

As demonstrated in the “PSD Major Source Determination” Section above, the facility is an existing major source for PSD. Because the project is not located within 10 km of a Class 1 area – modeling of the emission increase is not required to determine if the project is subject to the requirements of Rule 2410.

II. Significance of Project Emission Increase Determination

Potential to Emit of attainment/unclassified pollutant for New or Modified Emission Units vs PSD Significant Emission Increase Thresholds

As a screening tool, the potential to emit from all new and modified units is compared to the PSD significant emission increase thresholds, and if total potential to emit from all new and modified units is below this threshold, no further analysis will be needed.

PSD Significant Emission Increase Determination: Potential to Emit (tons/year)						
	NO ₂	SO ₂	CO	PM	PM ₁₀	CO _{2e}
Total PE from New and Modified Units	0.052	0	0.011	0.003	0.003	4.0 (shown below)
PSD Significant Emission Increase Thresholds	40	40	100	25	15	75,000
PSD Significant Emission Increase?	No	No	No	No	No	No

EF_{GHG}: 0.000187 metric tons/bhp-hr (CARB greenhouse gas emission factor)
 Rating: 389 bhp
 Schedule: 50 hr/yr

$$PE_{GHG} = (0.000187 \text{ MT/bhp-hr})(389 \text{ bhp})(50 \text{ hr/yr})(2,205 \text{ lb/MT})(\text{ton}/2000 \text{ lb}) = 4.0 \text{ tons/yr}$$

As demonstrated above, because the project has a total potential to emit from all new and modified emission units below the PSD significant emission increase thresholds, this project is not subject to the requirements of Rule 2410 due to a significant emission increase and no further discussion is required.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule and has received their Title V Operating Permit. The proposed modification is a Minor Modification to the Title V Permit pursuant to Section 3.20 of this rule. As discussed previously in the proposal section, the facility has applied for a Certificate of Conformity (COC).

In accordance with Rule 2520, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;

2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

As discussed above, the facility has applied for a Certificate of Conformity (COC). Therefore, the facility must apply to modify their Title V permit with an administrative amendment, prior to operating with the proposed modifications. Continued compliance with this rule is expected. The facility may construct/operate under the ATC upon submittal of the Title V administrative amendment/minor modification application. The following conditions will appear on each ATC permit:

- {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201]
- {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4]

Rule 4001 New Source Performance Standards (NSPS)

40 CFR 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Pursuant to § 60.4200 of Subpart IIII, this engine is subject to this federal regulation. However, the District has not been delegated authorization to enforce the requirements of this regulation. The applicant will be so notified in a permit condition.

Rule 4002 National Emission Standards for Hazardous Air Pollutants

40 CFR 63 Subpart ZZZZ – National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Emissions (RICE)

Pursuant to § 63.6585 of Subpart ZZZZ, this engine is subject to this federal regulation. However, the District has not been delegated authorization to enforce the requirements of 40 CFR 63 Subpart ZZZZ for non-Part 70 sources (Major Sources). The applicant will be so notified in a permit condition.

Rule 4101 Visible Emissions

Rule 4101 states that no air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. Therefore, the following condition will be listed on the ATC to ensure compliance:

- {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]

Rule 4102 Nuisance

Rule 4102 states that no air contaminant shall be released into the atmosphere which causes a public nuisance. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, the following condition will be listed on the ATC to ensure compliance:

- {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 - Risk Management Policy for Permitting New and Modified Sources (dated 3/2/01) specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite. Therefore, a risk management review (RMR) was performed for this project. The RMR results are summarized in the following table, and can be seen in detail in Appendix E.

RMR Summary			
Categories	Emergency Diesel ICE (Unit 516-0)	Project Totals	Facility Totals
Prioritization Score	N/A ¹	N/A ¹	>1
Acute Hazard Index	N/A ²	N/A ²	0.00
Chronic Hazard Index	N/A ²	N/A ²	0.00
Maximum Individual Cancer Risk	3.77E-08	3.77E-08	9.21E-07
T-BACT Required?	No		
Special Permit Conditions?	Yes		

- 1 Prioritization for this unit was not conducted since it has been determined that all diesel-fired IC engines will result in a prioritization score greater than 1.0.
- 2 Acute and Chronic Hazard Indices were not calculated since there is no risk factor, or the risk factor is so low that the risk has been determined to be insignificant for this type of unit.

The following conditions will be listed on the ATC to ensure compliance with the RMR:

Unit # 516-0

1. Modified {1901} The PM10 emissions rate shall not exceed **0.13** g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rule 2201]
2. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. Modified {1344} The engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed **50** hours per year. [District NSR Rule and District Rule 4701]

Rule 4201 Particulate Matter Concentration

Rule 4201 limits particulate matter emissions from any single source operation to 0.1 g/dscf, which, as calculated below, is equivalent to a PM₁₀ emission factor of 0.4 g-PM₁₀/bhp-hr.

$$0.1 \frac{\text{grain-PM}}{\text{dscf}} \times \frac{\text{g}}{15.43 \text{ grain}} \times \frac{1 \text{ Btu}_{in}}{0.35 \text{ Btu}_{out}} \times \frac{9,051 \text{ dscf}}{10^6 \text{ Btu}} \times \frac{2,542.5 \text{ Btu}}{1 \text{ bhp-hr}} \times \frac{0.96 \text{ g-PM}_{10}}{1 \text{ g-PM}} = 0.4 \frac{\text{g-PM}_{10}}{\text{bhp-hr}}$$

The new engine has a PM₁₀ emission factor less than 0.4 g/bhp-hr. Therefore, compliance is expected and the following condition will be listed on the ATC:

- {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

Rule 4701 Internal Combustion Engines – Phase 1

The purpose of this rule is to limit the emissions of nitrogen oxides (NOx), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. Except as provided in Section 4.0, the provisions of this rule apply to any internal combustion engine, rated greater than 50 bhp, which requires a PTO.

The proposed engine(s) are also subject to District Rule 4702, Internal Combustion Engines. Since emissions limits of District Rule 4702 and all other requirements are equivalent or more stringent than District Rule 4701 requirements, compliance with District Rule 4702 requirements will satisfy requirements of District Rule 4701.

Rule 4702 Internal Combustion Engines

The following table demonstrates how the proposed engine(s) will comply with the requirements of District Rule 4702.

District Rule 4702 Requirements Emergency Standby IC Engines	Proposed Method of Compliance with District Rule 4702 Requirements
<p>Operation of emergency standby engines is limited to 100 hours or less per calendar year for non-emergency purposes, verified through the use of a non-resettable elapsed operating time meter.</p>	<p>The Air Toxic Control Measure for Stationary Compression Ignition Engines (Stationary ATCM) limits this engine maintenance and testing to 50 hours/year. Thus, compliance is expected.</p>
<p>Emergency standby engines cannot be used to reduce the demand for electrical power when normal electrical power line service has not failed, or to produce power for the electrical distribution system, or in conjunction with a voluntary utility demand reduction program or interruptible power contract.</p>	<p>The following conditions will be included on the permit:</p> <ul style="list-style-type: none"> • {3807} An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702] • {3808} This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702]
<p>The owner/operator must monitor the operational characteristics of each engine as recommended by the engine manufacturer or emission control system supplier.</p>	<p>The following condition will be included on the permit:</p> <ul style="list-style-type: none"> • {3478} During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system

	<p>supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rules 4701 and 4702]</p>
<p>Records of the total hours of operation of the emergency standby engine, type of fuel used, purpose for operating the engine, all hours of non-emergency and emergency operation, and support documentation must be maintained. All records shall be retained for a period of at least five years, shall be readily available, and be made available to the APCO upon request.</p>	<p>The following conditions will be included on the permit:</p> <ul style="list-style-type: none"> • {3496} The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] • The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] • {3475} All records shall be maintained and retained on-site for a minimum of five years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702 and 17 CCR 93115]

Rule 4801 Sulfur Compounds

Rule 4801 requires that sulfur compound emissions (as SO₂) shall not exceed 0.2% by volume. Using the ideal gas equation, the sulfur compound emissions are calculated as follows:

$$\text{Volume SO}_2 = (n \times R \times T) \div P$$

n = moles SO₂

T (standard temperature) = 60 °F or 520 °R

$$R \text{ (universal gas constant)} = \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot \text{°R}}$$

$$\frac{0.000015 \text{ lb} - \text{S}}{\text{lb} - \text{fuel}} \times \frac{7.1 \text{ lb}}{\text{gal}} \times \frac{64 \text{ lb} - \text{SO}_2}{32 \text{ lb} - \text{S}} \times \frac{1 \text{ MMBtu}}{9,051 \text{ scf}} \times \frac{1 \text{ gal}}{0.137 \text{ MMBtu}} \times \frac{\text{lb} - \text{mol}}{64 \text{ lb} - \text{SO}_2} \times \frac{10.73 \text{ psi} - \text{ft}^3}{\text{lb} - \text{mol} - \text{°R}} \times \frac{520 \text{°R}}{14.7 \text{ psi}} \times 1,000,000 = 1.0 \text{ ppmv}$$

Since 1.0 ppmv is ≤ 2,000 ppmv, this engine is expected to comply with Rule 4801. Therefore, the following condition will be listed on the ATC to ensure compliance:

- Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115]

California Health & Safety Code 42301.6 (School Notice)

The District has verified that the engine will not be located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

Title 17 California Code of Regulations (CCR), Section 93115 - Airborne Toxic Control Measure (ATCM) for Stationary Compression-Ignition (CI) Engines

The following table demonstrates how the proposed engine(s) will comply with the requirements of Title 17 CCR Section 93115.

Title 17 CCR Section 93115 Requirements for New Emergency IC Engines Powering Electrical Generators	Proposed Method of Compliance with Title 17 CCR Section 93115 Requirements
Emergency engines must be fired on CARB diesel fuel, or an approved alternative diesel fuel.	The applicant has proposed the use of CARB certified diesel fuel. The proposed permit condition, requiring the use of CARB certified diesel fuel, was included earlier in this evaluation.
Engines must emit diesel PM at a rate less than or equal to 0.15 g/bhp-hr or must meet the diesel PM standard, as specified in the off-road compression ignition standards for off-road engines with the same maximum rated power (17 CCR 93115)	The applicant has proposed the use of an engine that is certified to the applicable EPA Tier Certification level for the applicable horsepower range, guaranteeing compliance with the emission standards of Subpart IIII. Additionally, the proposed diesel PM emissions rate is less than or equal to 0.15 g/bhp-hr.
The engine may not be operated more than 100 hours per year for maintenance and testing purposes.	The following condition will be included on the permit: <ul style="list-style-type: none"> • This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702 & 17 CCR 93115]
Engines, with a PM10 emissions rate greater	The District has verified that this engine is not

<p>than 0.01 g/bhp-hr and located at schools, may not be operated for maintenance and testing whenever there is a school sponsored activity on the grounds. Additionally, engines located within 500 feet of school grounds may not be operated for maintenance and testing between 7:30 AM and 3:30 PM</p>	<p>located within 500' of a school.</p>
<p>An owner or operator shall maintain monthly records of the following: emergency use hours of operation; maintenance and testing hours of operation; hours of operation for emission testing; initial start-up testing hours; hours of operation for all other uses; and the type of fuel used. All records shall be retained for a minimum of 36 months.</p>	<p>Permit conditions enforcing these requirements were shown earlier in the evaluation.</p>

California Environmental Quality Act (CEQA)

The California Environmental Quality Act (CEQA) requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The San Joaquin Valley Unified Air Pollution Control District (District) adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities.
- Identify the ways that environmental damage can be avoided or significantly reduced.
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible.
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

The District performed an Engineering Evaluation (this document) for the proposed project and determined that the project qualifies for ministerial approval under the District's Guideline for Expedited Application Review (GEAR). Section 21080 of the Public Resources Code exempts from the application of CEQA those projects over which a public agency exercises only ministerial approval. Therefore, the District finds that this project is exempt from the provisions of CEQA.

IX. Recommendation:

Issue Authority to Construct N-1665-516-0 subject to the permit conditions on the attached Authority to Construct in Appendix A.

X. Billing Information:

Billing Schedule			
Permit Number	Fee Schedule	Fee Description	Fee Amount
N-1665-516-0	3020-10-C	389 bhp IC engine	\$240

Appendices

- A. Authority to Construct permit N-1665-516-0
- B. Emissions Data Sheet
- C. BACT Guideline and BACT Analysis
- D. QNEC Calculations
- E. Health Risk Assessment Summary

Appendix A

ATC N-1665-516-0

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: N-1665-516-0

LEGAL OWNER OR OPERATOR: BRONCO WINE COMPANY
MAILING ADDRESS: P O BOX 789
CERES, CA 95307

LOCATION: 6342 BYSTRUM RD
CERES, CA 95307

EQUIPMENT DESCRIPTION:

389 BHP IVECO MODEL F2CE9685A-E DIESEL-FIRED EMERGENCY ENGINE (TIER 3 CERTIFIED) POWERING AN ELECTRICAL GENERATOR.

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
7. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjolle, Director of Permit Services

N-1665-516-0 : May 23 2014 12:49PM - CRUZF - Joint Inspection NOT Required

9. Emissions from this IC engine shall not exceed any of the following limits: 2.43 g-NOx/bhp-hr, 0.50 g-CO/bhp-hr, or 0.17 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.13 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
13. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
14. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
17. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
19. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002] Federally Enforceable Through Title V Permit

DRAFT

Appendix B

Emissions Data Sheet

**EXHAUST EMISSIONS
DATA**

**STATEMENT OF EXHAUST EMISSIONS
2014 FPT DIESEL FUELED GENERATOR**

The measured emissions values provided here are proprietary to Generac and its authorized dealers. This information may only be disseminated upon request, to regulatory governmental bodies for emissions permitting purposes or to specifying organizations as submittal data when expressly required by project specifications, and shall remain confidential and not open to public viewing. This information is not intended for compilation or sales purposes and may not be used as such, nor may it be reproduced without the expressed written permission of Generac Power Systems, Inc. The data provided shall not be meant to include information made public by Generac.

Generator Model:	SD230	EPA Certificate Number:	FFPXL08.7TR3-005
kW _e Rating:	230	CARB Certificate Number:	Not Applicable
Engine Family:	FFPXL08.7TR3	SCAQMD CEP Number:	511712
Engine Model:	F2CE9685A-E	Emission Standard Category:	Tier 3
Rated Engine Power (BHP)*:	389	Certification Type:	Stationary Emergency CI (40 CFR Part 60 Subpart IIII)
Fuel Consumption (gal/hr)*:	19.1		
Aspiration:	Turbo/Aftercooled		
Rated RPM:	1800		

*Engine Power and Fuel Consumption are declared by the Engine Manufacturer of Record and the U.S. EPA.

Emissions based on engine power of specific Engine Model.			
(These values are actual composite weighted exhaust emissions results over the EPA 5-mode test cycle.)			
CO	NOx + NMHC	PM	
0.5	3.5	0.13	Grams/kW-hr
0.4	2.6	0.10	Grams/bhp-hr

- The stated values are actual exhaust emission test measurements obtained from an engine representative of the type described above.
- Values based on 5-mode testing are official data of record as submitted to regulatory agencies for certification purposes. Testing was conducted in accordance with prevailing EPA protocol, which is typically accepted by SCAQMD and other regional authorities.
- No emissions values provided above are to be construed as guarantees of emission levels for any given Generac generator unit.
- Generac Power Systems, Inc. reserves the right to revise this information without prior notice.
- Consult state and local regulatory agencies for specific permitting requirements.
- The emission performance data supplied by the equipment manufacturer is only one element required toward completion of the permitting and installation process. State and local regulations may vary on a case-by-case basis and local agencies must be consulted by the permit application/equipment owner prior to equipment purchase or installation. The data supplied herein by Generac Power Systems cannot be construed as a guarantee of installability of the generating set.

Appendix C

QNEC Calculations

Quarterly Net Emissions Change (QNEC)

The Quarterly Net Emissions Change is used to complete the emission profile screen for the District's PAS database. The QNEC shall be calculated as follows:

QNEC = PE2 - PE1, where:

- QNEC = Quarterly Net Emissions Change for each emissions unit, lb/qtr
- PE2 = Post-Project Potential to Emit for each emissions unit, lb/qtr
- PE1 = Pre-Project Potential to Emit for each emissions unit, lb/qtr

Using the emission calculations in this evaluation, $PE2_{quarterly}$ and $BE_{quarterly}$ can be calculated as follows:

This calculation is required for application emission profile purposes. It is assumed that the unit's annual emissions are evenly distributed throughout the year as follows: $\Delta PE \text{ (lb/qtr)} = PE \text{ (lb/yr)} \div 4 \text{ qtr/yr}$.

N-1665-516-0:

ΔPE_{NOx}	= 104 lb-NOx/year – 0 lb-NOx/year	= 104 lb/year
ΔPE_{CO}	= 21 lb-CO/year – 0 lb-CO/year	= 21 lb/year
ΔPE_{VOC}	= 7 lb-VOC/year – 0 lb-VOC/year	= 7 lb/year
ΔPE_{PM10}	= 6 lb-PM10/year – 0 lb-PM10/year	= 6 lb/year
ΔPE_{SOx}	= 0 lb-SOx/year – 0 lb-SOx/year	= 0 lb/year

	Quarter 1	Quarter 2	Quarter 3	Quarter 4
NOx	26	26	26	26
CO	5	5	5	6
VOC	1	2	2	2
PM₁₀	1	1	2	2
SOx	0	0	0	0

Appendix D

BACT Guideline and BACT Analysis

San Joaquin Valley Unified Air Pollution Control District

Best Available Control Technology (BACT) Guideline 3.1.1
Last Update: 9/10/2013
Emergency Diesel IC Engine

Pollutant	Achieved in Practice or in the SIP	Technologically Feasible	Alternate Basic Equipment
CO	Latest EPA Tier Certification level for applicable horsepower range		
NOX	Latest EPA Tier Certification level for applicable horsepower range		
PM10	0.15 g/hp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)		
SOX	Very low sulfur diesel fuel (15 ppmw sulfur or less)		
VOC	Latest EPA Tier Certification level for applicable horsepower range		

*Note: for emergency engines 50 ≤ bhp < 75, Tier 4 Interim certification is the requirement; for emergency engines 75 ≤ bhp < 750 bhp, Tier 3 certification is the requirement; for emergency engines ≥ 750 bhp, Tier 2 certification is the requirement.

BACT is the most stringent control technique for the emissions unit and class of source. Control techniques that are not achieved in practice or contained in a state implementation plan must be cost effective as well as feasible. Economic analysis to demonstrate cost effectiveness is required for all determinations that are not achieved in practice or contained in an EPA approved State Implementation Plan.

Top Down BACT Analysis for NO_x and VOC emissions:

BACT Guideline 3.1.1 (July 10, 2009) applies to emergency diesel IC engines. In accordance with the District BACT policy, information from that guideline will be utilized without further analysis.

1. BACT analysis for NO_x and VOC emissions:

a. Step 1 - Identify all control technologies

BACT Guideline 3.1.1 identifies only the following option:

- *Latest EPA Tier Certification level for applicable horsepower range*

To determine the latest applicable Tier level, the following EPA and state regulations were consulted:

- 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
- 40 CFR Part 89 – Control of Emissions from New and In-Use Nonroad Compression – Ignition Engines
- 40 CFR Part 1039 – Control of Emissions from New and In-Use Nonroad Compression-Ignition Engines
- Title 17 CCR, Section 93115 - Airborne Toxic Control Measure (ATCM) for Stationary Compression-Ignition (CI) Engines

40 CFR Parts 89 and 1039, which apply only to nonroad engines, do not directly apply because the proposed emergency engine does not meet the definition of a nonroad engine. Therefore, only Title 17 CCR, Section 93115 and 40 CFR Part 60 Subpart IIII apply directly to the proposed emergency engine.

Title 17 CCR, Section 93115.6(a)(3)(A) (CARB stationary diesel engine ATCM) applies to emergency standby diesel-fired engines and requires that such engines be certified to the emission levels in Table 1 (below). Please note that these levels are at least as stringent or more stringent than the emission levels in 40 CFR Subpart IIII.

Maximum Engine Power	Tier	Model Year(s)	PM	NMHC+NOx	CO
50 ≤ HP < 75 (37 ≤ kW < 56)	2	2007	0.15 (0.20)	5.6 (7.5) 3.5 (4.7)	3.7 (5.0)
	4i	2008+			
75 ≤ HP < 100 (56 ≤ kW < 75)	2	2007	0.15 (0.20)	5.6 (7.5) 3.5 (4.7)	3.7 (5.0)
	3	2008+			
100 ≤ HP < 175 (75 ≤ kW < 130)	3	2007	0.15 (0.20)	3.0 (4.0)	3.7 (5.0)
		2008+			
175 ≤ HP < 300 (130 ≤ kW < 225)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)
		2008+			
300 ≤ HP < 600 (225 ≤ kW < 450)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)
		2008+			
600 ≤ HP < 750 (450 ≤ kW ≤ 560)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)
		2008+			
HP > 750 (kW > 560)	2	2007	0.15 (0.20)	4.8 (6.4)	2.6 (3.5)
		2008+			

Additionally, 40 CFR Subpart IIII establishes emission standards for emergency diesel IC engines. These emission standards are the same as those specified in the CARB ATCM, except for engines rated greater than or equal to 50 and less than 75 hp. For such IC engines, the CARB ATCM is more stringent.

Therefore, the most stringent applicable emission standards are those listed in the CARB ATCM (Table 1). For IC engines rated greater than or equal to 100 hp and less than 175 hp the highest Tier required is Tier 3.

Also, please note that neither the state ATCM nor the Code of Federal Regulations require the installation of IC engines meeting a higher Tier standard than those listed above for emergency applications, due to concerns regarding the effectiveness of the exhaust emissions controls during periods of short-term operation (such as testing operational readiness of an emergency engine).

The proposed engine is rated at 110 bhp. Therefore, the applicable control technology option is EPA Tier 3 certification.

b. Step 2 - Eliminate technologically infeasible options

The control option listed in Step 1 is not technologically infeasible.

c. Step 3 - Rank remaining options by control effectiveness

Ranking is not necessary since there is only one control option listed in Step 1.

d. Step 4 - Cost Effectiveness Analysis

The applicant has proposed the only control option remaining under consideration. Therefore, a cost effectiveness analysis is not required.

e. Step 5 - Select BACT

The applicant is proposing to use a Tier 4i engine. Therefore, BACT will be satisfied for NOx and VOC emissions control.

2. BACT Analysis for PM₁₀ Emissions:

a. Step 1 - Identify all control technologies

BACT Guideline 3.1.1 identifies only the following option:

- *0.15 g/bhp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)*

The latest EPA Tier Certification level for an engine of the proposed model year and horsepower rating is Tier 2/3. Refer to the Top-Down BACT analysis for NOx for a discussion regarding the determination of the EPA Tier level to be considered.

Please note Tier 2 or 3 IC engines do not have a PM emission standard that is more stringent than 0.15 g/hp-hr. Additionally, the ATCM requires a PM emission standard of 0.15 g/hp-hr for all new emergency diesel IC engines.

Therefore, a PM/PM₁₀ emission standard of 0.15 g/hp-hr is required as BACT.

b. Step 2 - Eliminate technologically infeasible options

The control option listed in Step 1 is not technologically infeasible.

c. Step 3 - Rank remaining options by control effectiveness

Ranking is not necessary since there is only one control option listed in Step 1.

d. Step 4 - Cost Effectiveness Analysis

The applicant has proposed the only control option remaining under consideration. Therefore, a cost effectiveness analysis is not required.

e. Step 5 - Select BACT

BACT for PM₁₀ is emissions of 0.15 g/hp-hr or less. The applicant is proposing an engine that meets this requirement. Therefore, BACT will be satisfied.

Appendix E

Health Risk Assessment Summary

San Joaquin Valley Air Pollution Control District Risk Management Review

To: Fred Cruz – Permit Services
 From: Kyle Melching - Technical Services
 Date: May 21, 2014
 Facility Name: Bronco Winery Company
 Location: 6342 Bystrum Rd., Ceres
 Application #(s): N-1665-516-0
 Project #: N-1141841

A. RMR SUMMARY

RMR Summary			
Categories	Emergency Diesel ICE (Unit 516-0)	Project Totals	Facility Totals
Prioritization Score	N/A ¹	N/A ¹	>1
Acute Hazard Index	N/A ²	N/A ²	0.00
Chronic Hazard Index	N/A ²	N/A ²	0.00
Maximum Individual Cancer Risk	3.77E-08	3.77E-08	9.21E-07
T-BACT Required?	No		
Special Permit Conditions?	Yes		

- 1 Prioritization for this unit was not conducted since it has been determined that all diesel-fired IC engines will result in a prioritization score greater than 1.0.
- 2 Acute and Chronic Hazard Indices were not calculated since there is no risk factor, or the risk factor is so low that the risk has been determined to be insignificant for this type of unit.

Proposed Permit Conditions

To ensure that human health risks will not exceed District allowable levels; the following permit conditions must be included for:

Unit # 516-0

1. Modified {1901} The PM10 emissions rate shall not exceed **0.13** g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rule 2201]
2. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] N
3. Modified {1344} The engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed **50** hours per year. [District NSR Rule and District Rule 4701]N

B. RMR REPORT

I. Project Description

Technical Services received a request on May 21, 2014, to perform a Risk Management Review for a 389 bhp emergency diesel IC engine powering an electrical generator.

II. Analysis

Technical Services performed a screening level health risk assessment using the District's Diesel Exhaust Risk Screening spreadsheet.

The following parameters were used for the review:

Analysis Parameters						
Unit #s	bhp-hr	PM ₁₀ g/hp-hr	Receptor (m)	Quad	Hours/Year	Load%
516-0	389	0.13	305	1	50	100
Location Type			Rural	Receptor Type		Resident

III. Conclusion

The individual cancer risk associated with the operation of the proposed emergency diesel IC engine is **3.77E-08**; which is less than the 1 in a million threshold. In accordance with the District's Risk Management Policy, the project is approved as proposed **without** Toxic Best Available Control Technology (T-BACT).

To ensure that human health risks will not exceed District allowable levels; the permit conditions listed on Page 1 of this report must be included for the proposed unit.

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

IV. Attachments

- A. RMR request from the project engineer
- B. Additional information from the applicant/project engineer
- C. DICE Screening Risk Tool
- D. Facility Summary