



## Muscoy Team Conference Call Notes

2 October 2006 (2:00 P.M.)

### Conference Call Members Present for Call:

- |  |   |
|--|---|
| <input type="checkbox"/> Dwayne Deutscher/URS            | <input checked="" type="checkbox"/> Kim Hoang/EPA         |
| <input type="checkbox"/> Dennis Bane/URS                 | <input type="checkbox"/> Stacey Aldstadt/SBMWD            |
| <input checked="" type="checkbox"/> Adam Harvey/URS      | <input checked="" type="checkbox"/> Robin Ohama/SBMWD     |
| <input type="checkbox"/> Kit Veldman/URS                 | <input checked="" type="checkbox"/> Matt Litchfield/SBMWD |
| <input checked="" type="checkbox"/> Roger Nommensen/URS  | <input type="checkbox"/> John Perry/SBMWD                 |
| <input checked="" type="checkbox"/> Connie Biedel/URS    | <input type="checkbox"/> Dave Solomona/SBMWD              |
| <input type="checkbox"/> Mark Eisen/Secor                | <input type="checkbox"/> Terry Tonn/SBMWD                 |
| <input checked="" type="checkbox"/> Tom Perina/CH2M Hill | <input checked="" type="checkbox"/> Mike Lowe/SBMWD       |
| <input type="checkbox"/> Bob Kemmerle/E2                 | <input checked="" type="checkbox"/> Lana Kennerly/SBMWD   |

### Construction/Validation/Performance (Adam Harvey)

- El-Co and David's Electric replaced the instrument cables at 19<sup>th</sup> Street, and also replaced the cable at Encanto Park. Dave Solomona is satisfied with the replacements that were done. Mike will ask Dave to write a memo stating they concur with the changes that were made. Mike stated that a separate inspection is not required.
- The City found a couple of errors in the ATSI control panel drawings. URS will work with ATSI and get the drawings corrected and reissued.
- John Wiles (El-Co) is still awaiting word on the differential pressure transducer (suppose to be in Houston).
- Last week, the passive diffusion bags were set in the Muscoy and Source wells. This week, the sampling of the non-PDB source wells is taking place.
- Next week is the sampling of the Muscoy and Source passive diffusion bags and the Treatment Plant.
- URS has final data for samples through August and electronic validation reports through June 2006.
- Adam will note in next week's report which of the samples are being duplicated with the city.
- URS is finalizing the draft six-month semi-annual data evaluation report, and should go out today or tomorrow.
- URS is working on the draft RA report and should go out by end of week.
- URS distributed the pre-draft cost and performance report to the EPA and CH2M Hill on 26 September. Kim will try to respond to URS by 13 October.
- The City is still working on the well site report. Matt will have a draft report within 2-3 weeks (by the end of October).
- A meeting was held regarding EW109. Mike will ask Matt to get a construction order to lower the pump. Transducer cables were ordered and the transducers (B and C) are scheduled to be lowered this week.

### General Discussion

- The EPA will be meeting with the City on 5 October.

### Next Conference Call

Monday, 9 October 2006, 2:00 PM Call in #: 415-947-8520, Access Code 2332#

*The minutes of this meeting represent the writer's understanding of the events as discussed. Should an attendee's understanding differ, please contact Dwayne Deutscher at 916-679-2051, or [dwayne\\_deutscher@urscorp.com](mailto:dwayne_deutscher@urscorp.com). The minutes contained herein will stand if not corrected within ten (10) days of this writing.*