



Newmark/Muscoy Conference Call Notes

18 July 2005 (1:30 P.M.)

Conference Call Members Present for Call:

- | | |
|----------------------------------------------------------|-----------------------------------------------------------|
| <input checked="" type="checkbox"/> Dwayne Deutscher/URS | <input checked="" type="checkbox"/> Kim Hoang/EPA |
| <input checked="" type="checkbox"/> Dennis Bane/URS | <input type="checkbox"/> Jackie Lane/EPA |
| <input checked="" type="checkbox"/> Matt Dwyer/URS | <input type="checkbox"/> Francisco Arcaute/EPA |
| <input checked="" type="checkbox"/> Adam Harvey/URS | |
| <input checked="" type="checkbox"/> Connie Biedel/URS | <input checked="" type="checkbox"/> Stacey Aldstadt/SBMWD |
| <input checked="" type="checkbox"/> Kit Veldman/URS | <input type="checkbox"/> Bill Bryden/SBMWD |
| | <input checked="" type="checkbox"/> Mark Eisen/SBMWD |
| | <input checked="" type="checkbox"/> Terry Tonn/SBMWD |
| <input checked="" type="checkbox"/> Tom Perina/CH2M Hill | <input checked="" type="checkbox"/> Mike Lowe/SBMWD |
| <input checked="" type="checkbox"/> Bob Kemmerle/E2 | <input checked="" type="checkbox"/> Lana Kennerly/SBMWD |

Contract Issues

- URS will review the SBMWD O&M Plan for consistency with URS O&M Manual.

Construction

- Nick worked with Adam to identify issues with the air accumulation in carbon vessels.
- Waiting on the cable for Encanto Park to complete installation of probes.
- Mike Lowe was concerned about the possibility of some problems with air locking, so he tapped one of the vessels on the influent line and also two effluent lines. They could not locate trapped air. He would like to continue to monitor the system and evaluate the situation when steady state conditions are reached (when all extraction wells are on line for a period of time). He stated that the vessels are currently operating at 32 to 33 psi and does not want to increase operation pressure at this time.

Well Construction

- Dennis said the flows have dropped off on EW 110. Mike stated this is due to water table level dropping. An option will be to wait until the system is up and running fully, then bring off line for a few days, and then bring it back on line.

General

- The inspection team (Dennis, Matt, Adam, Nick, Bob, Terry, Mike Garland) is scheduled to meet at the trailer at 10:00 A.M. on 27 July, and the classroom meeting at 8:30 A.M. on 28 July. Mike stated that Terry, Mike Garland would work with Nick on the checklists beginning on Monday, 25 July. Bob will join the inspection team on Tuesday, 26 July.
- Adam will resend to everyone the 19th Street Treatment Plant, Encanto Park, monitoring wells, and extraction wells checklists.

Community

- It has been pointed out to Terry by one of the residents on Virginia Street that the driveways do not drain correctly because the overlay is higher than the approaches on the driveways. Terry will look into getting a price from a few contractors to grind it down.

Next Conference Call

Monday, 1 August 2005, 2:00 P.M.; Call in #: 202-275-0170; Participant Code: 7860 (#).

The minutes of this meeting represent the writer's understanding of the events as discussed. Should an attendee's understanding differ, please contact Dwayne Deutscher at 916-679-2051, or dwayne_deutscher@urscorp.com. The minutes contained herein will stand if not corrected within ten (10)

days of this writing.